



نگهداشت و افزایش تولید میدان نفتی بینک  
سطح الارض



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

DATA SHEETS FOR MV INDUCTION MOTORS

پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	GCS	PEDCO	120	EL	DT	0009	D02

شماره صفحه: ۱ از ۷

طرح نگهداشت و افزایش تولید ۲۷ مخزن

## DATA SHEETS FOR MV INDUCTION MOTORS

نگهداشت و افزایش تولید میدان نفتی بینک

Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
D02	May. 2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D01	FEB. 2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D00	SEP. 2021	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	

Class: CLIENT Doc. Number: F0Z-709026

Status:

IDC: Inter-Discipline Check  
IFC: Issued For Comment  
IFA: Issued For Approval  
AFD: Approved For Design  
AFC: Approved For Construction  
AFP: Approved For Purchase  
AFQ: Approved For Quotation  
IFI: Issued For Information  
AB-R: As-Built for CLIENT Review  
AB-A: As-Built -Approved



نگهداشت و افزایش تولید میدان نفتی بینک  
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

DATA SHEETS FOR MV INDUCTION MOTORS



نسخه	سریال	نوع مدارک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
D02	0009	DT	EL	120	PEDCO	GCS	BK

شماره صفحه: ۲ از ۷


REVISION RECORD SHEET



PAGE	D00	D01	D02	D03	D04
1	X	X	X		
2	X	X	X		
3	X	X	X		
4	X	X			
5	X	X			
6	X	X	X		
7		X	X		
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					



	<b>نگهداشت و افزایش تولید میدان نفتی بینک</b> <b>سطح الارض</b> <b>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</b>								
	<b>DATA SHEETS FOR MV INDUCTION MOTORS</b>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	پروژه BK	بسته کاری GCS	صادر کننده PEDCO	تسهیلات 120	رشته EL	نوع مدرک DT	سریال 0009	نسخه D02	شماره صفحه: ۳ از ۷

**Data Sheets for MV Induction Motors**



Item	Category	Required Specification	Vendor Data
1	Driven Machine	Electrical Motor	
2	Driven Machine Tag No.	-	
3	Manufacturer	By Vendor	
4	Manufacturer's Number / Type	By Vendor	
5	Manufacturing Standard	IEC 60034 & IPS-M-EL-132(2)	
6	Location	[X] Outdoor (Under Shelter) [ ] Indoor	
7	Area Classification	Acc. to requisition data	
8	Ambient Temperature	5 to +55°C	
9	Relative Humidity	100 %	
10	Dust	[X] Yes [ ] No	
11	Corrosion	[X] Yes [ ] No	
12	Elevation	12.5m Above Sea Level	
13	Quantity	Acc. To Load List (BK-GCS-PEDCO-120-EL-LI-0001)	
14	Tag Number	Acc. To Load List (BK-GCS-PEDCO-120-EL-LI-0001)	
15	Motor Type	Asynchronous, Squirrel Cage	
16	Mounting	[ ] Horizontal [ ] Vertical	
17	Rotor Construction	<input checked="" type="checkbox"/> Brazed Copper Bars <input type="checkbox"/> Aluminum Die Cast	
18	Stator Case Material	Cast Iron	
19	Frame Material	Steel Sheet or Cast Iron	
20	Cooling Method	According to IPS-M-EL-131(2)	
21	Ingress Protection Degree for Motor	IP 54	
22	Ingress Protection Degree for Terminal Box	IP 55	
23	Explosion Protection of Motor	N/A for Safe Area Zone 2, IIB, T3	
24	Explosion Protection of Terminal Box	N/A for Safe Area Zone 2, IIB, T3	
25	Ex. Certificate Authority/Certificate No.	By Vendor	
26	Driven Machine Shaft Power Requirement (P <sub>mp</sub> )	As Per Related Mechanical Data sheet (to be Specified by Vendor)	
27	API Design Margin (Km)	1.10	
28	Motor output shaft power requirement @ site condition (=Pmp/Km)	As Per Related Mechanical Data sheet (to be Specified by Vendor)	
29	De-rating factor due to Ambient	0.85 (MFR Shall Advise The Value)	

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>DATA SHEETS FOR MV INDUCTION MOTORS</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>EL</td> <td>DT</td> <td>0009</td> <td>D02</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	EL	DT	0009	D02	<p>شماره صفحه: ۴ از ۷</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	EL	DT	0009	D02											



Data Sheets for MV Induction Motors			
Item	Category	Required Specification	Vendor Data
	Temperature (Kt)		
30	De-rating factor due to Altitude (Ka)	1 (MFR Shall Advise The Value)	
31	Motor Power (Defined for IEC condition i.e. 40°C)	As Per Related Mechanical Data sheet (to be Specified by Vendor)	
32	Standard Rated Motor Output $=K_m \times P_{mp} / (K_a K_t)$	By Vendor	
33	Frame Size	By Vendor	
34	Rated Voltage	11KV $\pm 10\%$ or 3.3KV $\pm 10\%$	
35	Rated Frequency	50 Hz $\pm 5\%$	
36	Voltage During Motor Start	80% $U_n$	
37	Synchronous Speed	By Vendor	
38	Full Load Speed [RPM]	By Vendor	
39	Number of Poles	By Vendor	
40	Starting Method	Direct on Line	
41	Direction of Rotation (Viewed from coupling end)	Shall be Proposed by MFR Based on Driven Load Rotation of Direction	<input type="checkbox"/> CW <input type="checkbox"/> CCW <input type="checkbox"/> Unidirectional <input type="checkbox"/> Bidirectional
42	Stator Winding Connection	Star	
43	Location of Terminal Box (Viewed from DE)	<input type="checkbox"/> Right <input type="checkbox"/> Left	
44	Insulation Class	Class F	
45	Class of Temperature Rise	Class B	
46	Max. Permissible Starting Time [s]	By Vendor	
47	Accelerating Time DOL starting, at 100% $U_n$ [s]	By Vendor	
48	Accelerating Time DOL starting, at 80% $U_n$ [s]	By Vendor	
49	Starting Torque at 100% $U_n$ [N.m]	By Vendor	
50	Starting Torque at 80% $U_n$ [N.m]	By Vendor	
51	Maximum Torque [N.m]	By Vendor	
52	Rated Torque [N.m]	By Vendor	
53	Rated Current [A]	By Vendor	
54	No Load Current [A]	By Vendor	
55	Locked Rotor Current [A]	$< 7I_n$	
56	Torque-Speed Class	Shall be Selected Based on Driven Load Torque Requirement	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D
57	Permit to Start Times	3C2H	

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>DATA SHEETS FOR MV INDUCTION MOTORS</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدارک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>EL</td> <td>DT</td> <td>0009</td> <td>D02</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدارک	سریال	نسخه	BK	GCS	PEDCO	120	EL	DT	0009	D02	<p>شماره صفحه: ۵ از ۷</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدارک	سریال	نسخه											
BK	GCS	PEDCO	120	EL	DT	0009	D02											

Data Sheets for MV Induction Motors			
Item	Category	Required Specification	Vendor Data
58	Reacceleration	Capable for connection to 100% main voltage with 30%, 180° out of phase residual voltage.	
59	Heating time Constant [minute]	By Vendor	
60	Cooling Time Constant [minute]	By Vendor	
61	Duty Cycle	S1	
62	Rotor Moment of Inertia [kgm <sup>2</sup> ]	By Vendor	
63	Driven Machine Moment of Inertia [kgm <sup>2</sup> ]	By Vendor	
64	Max. Allowable Load Moment of Inertia [kgm <sup>2</sup> ]	By Vendor	
65	Power Factor at ½ Rated Load	By Vendor	
66	Power Factor at ¾ Rated load	By Vendor	
67	Power factor at Rated Load	By Vendor	
68	Efficiency at ½ Rated Load	By Vendor	
69	Efficiency at ¾ Rated Load	By Vendor	
70	Efficiency at Rated Load	By Vendor	
71	Bearing (DE)		
	Type (Detail Description by Vendor)	<input type="checkbox"/> Antifriction (Ball Bearing) <input type="checkbox"/> Antifriction (Roller Bearing) <input checked="" type="checkbox"/> Sleeve (Spherical Self Aligned)	
	Manufacturer	By Vendor	
	Minimum Life Without Load	Minimum 100,000 Hours	
	Minimum Life With Load	By Vendor	
	Lubrication	Oil (oil specification shall be specified by manufacturer)	
	Lubrication system (To be advised by manufacturer considering ambient temperature)	<input type="checkbox"/> Grease (anti friction bearings) <input checked="" type="checkbox"/> Air cooled oil reservoir with Lubricating ring <input type="checkbox"/> Forced Oil Lubrication with air cooled radiator	
	Oil Capacity [Liter]	By Vendor	
	Permissible Trust Force [N]	By Vendor	
	Max. Normal Operating Temperature	By Vendor	
72	Bearing (NDE)		
	Type (Detail Description by Vendor)	<input type="checkbox"/> Anti friction (Ball Bearing) <input type="checkbox"/> Antifriction (Roller Bearing) <input checked="" type="checkbox"/> Sleeve (Spherical self aligned)	
	Manufacturer	By Vendor	

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>DATA SHEETS FOR MV INDUCTION MOTORS</p> <table border="1"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>EL</td> <td>DT</td> <td>0009</td> <td>D02</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	EL	DT	0009	D02	<p>شماره صفحه : ۶ از ۷</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	EL	DT	0009	D02											

Data Sheets for MV Induction Motors			
Item	Category	Required Specification	Vendor Data
	Minimum Life Without Load	Minimum 100,000 Hours	
	Minimum Life With Load	By Vendor	
	Lubrication	Oil (Specification must be specified by manufacturer)	
	Oil Capacity [Liter]	By Vendor	
	Permissible Trust Force [N]	Shall meet coupled machine trust	
	Max. Normal Operating Temperature	By Vendor	
73	DE Bearing Temperature Sensor / Meter	<input type="checkbox"/> Not Required <input type="checkbox"/> PTC <input checked="" type="checkbox"/> RTD <input checked="" type="checkbox"/> Thermometer (Dial) <input type="checkbox"/> Temperature Switch	
74	NDE Bearing Temperature Sensor	<input type="checkbox"/> Not Required <input type="checkbox"/> PTC <input checked="" type="checkbox"/> RTD <input checked="" type="checkbox"/> Thermometer (Dial) <input type="checkbox"/> Temperature Switch	
75	Winding Temperature Sensor	<input type="checkbox"/> Not Required <input type="checkbox"/> PTC <input checked="" type="checkbox"/> RTD (9 RTD's 3 per phase)	
76	Space Heater	Required	
	Space Heater Voltage [V]	230VAC, 50Hz, 1Ph	
	Space Heater Power [W]	By Vendor	
77	Terminal Boxes	<input checked="" type="checkbox"/> MV main Terminal Box <input checked="" type="checkbox"/> Space heater / RTD's / Switches Terminal Box	
78	Main Power Cable Specification & Size & Orientation	According to BK-GCS-PEDCO-120-EL-CN-0003	
79	Method of Cable Entry	<input checked="" type="checkbox"/> Cable Gland <input type="checkbox"/> Sealing Gasket	
80	Short Circuit Capability of Terminal Box	25 kA for 0.2 S	
81	Power terminal box connection method	Motor & Supply wires with cable shoe to be fixes on suitable post insulators	
82	Sound Level at 1 distance (m) From Motor	Max. 85 dB(A)	
83	Finish Color	Manufacturer Standard	
84	Test & Inspection Routine tests including: a) Insulation resistance test on windings, heaters, temperature detectors and bearing insulations b) Measurement of winding resistance (cold) c) Measurement of winding resistance	For P<=500kW Witness on test of all motors[X] Report of test of all motors[X]  For P>500kW Witness on test of all motors[X] Report of test of all motors[X]	

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>DATA SHEETS FOR MV INDUCTION MOTORS</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>EL</td> <td>DT</td> <td>0009</td> <td>D02</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	EL	DT	0009	D02	<p>شماره صفحه: ۷ از ۷</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	EL	DT	0009	D02											

Data Sheets for MV Induction Motors			
Item	Category	Required Specification	Vendor Data
	(hot) d) Bearing temperature rise e) No load current f) Current unbalance at full load g) Locked rotor current (at full or reduced voltage) h) Locked rotor torque (at full or reduced voltage) i) Torque speed curve j) No load losses k) Direction of rotation l) Slip and nominal speed and full load m) Vibration severity n) Noise test o) bearings inspection  Type test: p) Heat run test	<p style="text-align: center;">For P&lt;=1000kW Report of test of one identical motor[X]</p> <p style="text-align: center;">For P&gt;1000kW Witness on test of One project motor[X] Report of test of above mentioned test[X]</p>	

DE: Drive End  
 NDE: Non Drive End  
 CW: Clockwise  
 CCW: Counter Clockwise

Note 1: IPS design margin is defined in accordance with standard output power rating of motor:

	Standard Output Power Rating	Design margin
1	Up to 22kW	1.25
2	from 22kW to 55kW	1.15
3	Above 55kW	1.10

Note 2: **Conventional** Differential protection (**not self-balancing**) is required for motors with rated power 1000kW and above. CTs shall be provided by vendor and installed in the motor terminal box. And special care shall be considered on CT window size and motor cables overall diameter to be coordinate with each other.