



NISOC

افزایش تولید میدان نفتی بینک
سطح الارض
احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



CABLE SCHEDULE FOR PABX

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

پروژه

BK

بسته کاری

GCS

صادر کننده

PEDCO

تسهیلات

120

رشته

TE

نوع مدرک

LI

سریال

0003

نسخه

D00

شماره صفحه: ۱ از ۳

طرح نگهداشت و افزایش تولید ۲۷ مخزن

CABLE SCHEDULE FOR PABX

نگهداشت و افزایش تولید میدان نفتی بینک

D00	June .2022	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 2

CLIENT Doc. Number: F0Z-709093

status:

IDC: Inter-Discipline Check

IFC: Issued For Comment

IFA: Issued For Approval

AFD: Approved For Design

AFC: Approved For Construction

AFP: Approved For Purchase

AFQ: Approved For Quotation

IFI: Issued For Information

AB-R: As-Built for CLIENT Review

AB-A: As-Built -Approved



NISOC

افزایش تولید میدان نفتی بینک
سطح الارض
احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



CABLE SCHEDULE FOR PABX

شماره پیمان:	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	شماره صفحه: ۳ از ۲
۰۵۳ - ۰۷۳ - ۹۱۸۴	D00	0003	LI	TE	120	PEDCO	GCS	BK	

REVISION RECORD SHEET

Page	D00	D01	D02	D03	D04	Page	D00	D01	D02	D03	D04
1	X					51					
2	X					52					
3	X					53					
4						54					
5						55					
6						56					
7						57					
8						58					
9						59					
10						60					
11						61					
12						62					
13						63					
14						64					
15						65					
16						66					
17						67					
18						68					
19						69					
20						70					
21						71					
22						72					
23						73					
24						74					
25						75					
26						76					
27						77					
28						78					
29						79					
30						80					
31						81					
32						82					
33						83					
34						84					
35						85					
36						86					
37						87					
38						88					
39						89					
40						90					
41						91					
42						92					
43						93					
44						94					
45						95					
46						96					
47						97					
48						98					
49						99					
50						100					

 NISOC			افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک												
			CABLE SCHEDULE FOR PABX												
			نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده						بسته کاری	پروژه
			D00	3	LI	TE	120	PEDCO						GCS	BK
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴			FROM			TO			SIGNAL	CABLE DETAIL					
Item	Rev.	Cable Tag No.	EQUIPMENT TAG No.	LOCATION	EQUIPMENT DESCRIPTION	EQUIPMENT DESCRIPTION	LOCATION	CABLE CONNECTOR/ GLAND SIZE		SIZE	DESCRIPTION	ESTIMATED LENGTH (m)	DRUM		
Telephone Multipair Cable Between New Control Building and Exist Telephone MDF at exist TELECOM ROOM															
1	D00	MDF-01-T-01	MDF-01	GCS Control Building(new)	NEW TELEPHONE MDF	MDF-02	EXISTTELECOM MDF AT Exist CCB	M20	Analoue Telephone	50X2X0.6 mm	CU/PVC/(SC)/SWA/ (OUTDOOR)	60			
Telephon Cable Between New Control Building and Field Area															
2	D00	GCS-TJB-TC-01	MDF-01	GCS Control Building(new)	TELEPHONE SET	CGS-TJB-01	GCS Field Area	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	500			
3	D00	GCS-TJB-TC-02	MDF-01	GCS Control Building(new)	TELEPHONE SET	CGS-TJB-02	GCS Field Area	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	250			
4	D00	GCS-TJB-TC-03	MDF-01	GCS Control Building(new)	TELEPHONE SET	CGS-TJB-03	GCS Field Area	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	600			
5	D00	GCS-TJB-TC-04	MDF-01	GCS Control Building(new)	TELEPHONE SET	CGS-TJB-04	GCS Field Area	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	650			
POWER Cable Between UPS Distribution Panel AND Field Area(For Flasher of Analoue Telephone)															
6	D00	GCS-PJB-PC-01	UPS	GCS Control Building(new)	UPS Panel	CGS-PJB-01	Telephone PowerJB	M20	Power Cable	3 Core 2.5 mm2	CU/PVC/SWA/PVC	500			
7	D00	GCS-PJB-PC-02	UPS	GCS Control Building(new)	UPS Panel	CGS-PJB-02	Telephone PowerJB	M20	Power Cable	3 Core 2.5 mm2	CU/PVC/SWA/PVC	250			
8	D00	GCS-PJB-PC-03	UPS	GCS Control Building(new)	UPS Panel	CGS-PJB-03	Telephone PowerJB	M20	Power Cable	3 Core 2.5 mm2	CU/PVC/SWA/PVC	600			
9	D00	GCS-PJB-PC-04	UPS	GCS Control Building(new)	UPS Panel	CGS-PJB-04	Telephone PowerJB	M20	Power Cable	3 Core 2.5 mm2	CU/PVC/SWA/PVC	650			
Telephon Cable Between New Control Building and Hotline Telephone															
10	D00	GCS-HJB-TC-01	MDF-01	GCS Control Building(new)	TELEPHONE MDF	GCS-HJB-01	Hotline Telephone JB	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	500			
11	D00	GCS-HJB-TC-02	MDF-01	GCS Control Building(new)	TELEPHONE MDF	GCS-HJB-02	Hotline Telephone JB	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	700			
12	D00	GCS-HJB-TC-03	MDF-01	GCS Control Building(new)	TELEPHONE MDF	GCS-HJB-03	Hotline Telephone JB	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	600			
Telephon Cable Between New Control Building and Electrical Building															
13	D00	GCS-TJB-TC-01	MDF-01	GCS Control Building(new)	TELEPHONE MDF	CGS-TJB-01	GCS Field Area	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	60			
14	D00	GCS-PJB-PC-01	UPS	GCS Control Building(new)	UPS Panel	CGS-PJB-01	Telephone PowerJB	M20	Power Cable	3 Core 2.5 mm2	CU/PVC/SWA/PVC	60			
15	D00	GCS-TJB-TC-05	MDF-01	GCS Control Building(new)	TELEPHONE MDF	TSO-01	Telephone Socket	M20	Analoue Telephone	2X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	100			