



NISOC

افزایش تولید میدان نفتی بینک
سطح الارض
احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



CABLE SCHEDULE FOR PAGA

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

پروژه

BK

بسته کاری

GCS

صادر کننده

PEDCO

تسهیلات

120

رشته

TE

نوع مدرک

LI

سریال

0004

نسخه

D00

شماره صفحه: ۱ از ۴

طرح نگهداشت و افزایش تولید ۲۷ مخزن

CABLE SCHEDULE FOR PAGA

نگهداشت و افزایش تولید میدان نفتی بینک

D00	June .2022	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 2

CLIENT Doc. Number: F0Z-709094

status:

IDC: Inter-Discipline Check

IFC: Issued For Comment

IFA: Issued For Approval

AFD: Approved For Design

AFC: Approved For Construction

AFP: Approved For Purchase

AFQ: Approved For Quotation

IFI: Issued For Information

AB-R: As-Built for CLIENT Review

AB-A: As-Built -Approved



NISOC

افزایش تولید میدان نفتی بینک
سطح الارض
احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

CABLE SCHEDULE FOR PAGA



شماره صفحه: ۴ از ۲

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
D00	0004	LI	TE	120	PEDCO	GCS	BK

REVISION RECORD SHEET

Page	D00	D01	D02	D03	D04	Page	D00	D01	D02	D03	D04
1	X					51					
2	X					52					
3	X					53					
4	X					54					
5						55					
6						56					
7						57					
8						58					
9						59					
10						60					
11						61					
12						62					
13						63					
14						64					
15						65					
16						66					
17						67					
18						68					
19						69					
20						70					
21						71					
22						72					
23						73					
24						74					
25						75					
26						76					
27						77					
28						78					
29						79					
30						80					
31						81					
32						82					
33						83					
34						84					
35						85					
36						86					
37						87					
38						88					
39						89					
40						90					
41						91					
42						92					
43						93					
44						94					
45						95					
46						96					
47						97					
48						98					
49						99					
50						100					

 NISOC			افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک												
															CABLE SCHEDULE FOR PAGA
			شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴			پروژه	بسته کاری	صادرکننده	تسهیلات						رشته
			BK	GCS	PEDCO	120	TE	LI	4	D00					
			FROM			TO				SIGNAL	CABLE DETAIL				
Item	Rev.	Cable Tag No.	EQUIPMENT TAG No.	LOCATION	EQUIPMENT DESCRIPTION	EQUIPMENT DESCRIPTION		LOCATION	CABLE CONNECTOR/ GLAND SIZE		SIZE	DESCRIPTION	ESTIMATE D LENGTH (m)	DRUM	
PAGA Power Cable Between NEW CONTROL BUILDING AND FIELD AEA															
1	D00	BD-05-PA-RA-01	PAGA-MDF-01	NEW CONTROL BUILDING (Rack Room)	PAGA MDF	PA-ST-01		Field Area	M25	PAGA	3 Core 4 mm2	CU/PVC/XLPE/SWA	250		
2	D00	BD-05-PA-RA-01	PAGA-MDF-01	NEW CONTROL BUILDING (Rack Room)	PAGA MDF	PA-ST-02		Field Area	M25	PAGA	3 Core 4 mm2	CU/PVC/XLPE/SWA	550		
3	D00	BD-05-PA-RA-01	PAGA-MDF-01	NEW CONTROL BUILDING (Rack Room)	PAGA MDF	PA-ST-03		Field Area	M25	PAGA	3 Core 4 mm2	CU/PVC/XLPE/SWA	350		
	PAGA Power Cable Between Junction Box To Loudspeaker														
4	D00		PA-ST-01	Field Area	JUNCTION BOX	*-PA-SP-01		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
5	D00		PA-ST-01	Field Area	JUNCTION BOX	*-PA-SP-02		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
6	D00		PA-ST-01	Field Area	JUNCTION BOX	*-PA-SP-03		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
7	D00		PA-ST-01	Field Area	JUNCTION BOX	*-PA-SP-04		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
8	D00		PA-ST-02	Field Area	JUNCTION BOX	*-PA-SP-05		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
9	D00		PA-ST-02	Field Area	JUNCTION BOX	*-PA-SP-06		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
10	D00		PA-ST-02	Field Area	JUNCTION BOX	*-PA-SP-07		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
11	D00		PA-ST-02	Field Area	JUNCTION BOX	*-PA-SP-08		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
12	D00		PA-ST-03	Field Area	JUNCTION BOX	*-PA-SP-09		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
13	D00		PA-ST-03	Field Area	JUNCTION BOX	*-PA-SP-10		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
14	D00		PA-ST-03	Field Area	JUNCTION BOX	*-PA-SP-11		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		
15	D00		PA-ST-03	Field Area	JUNCTION BOX	*-PA-SP-12		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE	6		

 NISOC			افزایش تولید میدان نفتی بینک سطح الارض					 							
			CABLE SCHEDULE FOR PAGA												
			نسخه	سریال	نوع مدرک	رشته	تسهيلات						صادرکننده	بسته کاری	پروژه
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴			D00	4	LI	TE	120	PEDCO	GCS	BK					
			TO					FROM							
POWER Cable Between UPS Distribution Panel AND Field Area(For Flasher of Loudspeaker)															
16	D00		UPS	GCS Control Building(new)	ELEC PDP	*-PA-ST-01		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE/SWA	400		
17	D00		UPS	GCS Control Building(new)	ELEC PDP	*-PA-ST-02		Field Area	M20	PAGA	3 Core 2.5 mm2	CU/PVC/XLPE/SWA	600		
Intercom Cable(Between New CCR & intercom set at field area)															
18	D00	BD-05-PA-RA-01	PAGA-MDF-01	GCS Control Building(new)	INTERCOM MDF	*-PA-IC-01		INTERCOM SET	M20	SIGNAL	4X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	500		
19	D00	BD-05-PA-RA-02	PAGA-MDF-02	GCS Control Building(new)	INTERCOM MDF	*-PA-IC-02		INTERCOM SET	M20	SIGNAL	4X2X0.6 mm	CU/PVC/(SC)/SWA/PVC (OUTDOOR)	700		
POWER Cable Between UPS Distribution Panel AND Field Area(For Flasher of INTERCOM SET)															
20	D00	1XL2	UPS	GCS Control Building(new)	UPS Panel	INTERCOM FLASHER FOR INTERCM *-PA-IC-01		INTERCOM FLASER	M20	Power Cable	3 Core 2.5 mm2	CU/PVC/SWA/PVC/SWA	500		
21	D00	1XL2	UPS	GCS Control Building(new)	UPS Panel	INTERCOM FLASHER FOR INTERCM 2 *-PA-IC-02		INTERCOM FLASER	M20	Power Cable	3 Core 2.5 mm2	CU/PVC/SWA/PVC/SWA	300		