

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک						 		
	ELECTRICAL LOAD LIST								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	پروژه BK	بسته کاری GNRAL	صادر کننده PEDCO	تسهیلات 220	رشته EL	نوع مدرک LI	سریال 0001	نسخه D01	شماره صفحه: ۴ از ۴

طرح نگهداشت و افزایش تولید ۲۷ مخزن

ELECTRICAL LOAD LIST

نگهداشت و افزایش تولید میدان نفتی بینک

D01	Jul.2022	AFC	H.Shakiba	M.Fakharian	M.Mehrshad	
D00	May.2022	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 2	CLIENT Doc. Number: F0Z-707104
----------	--------------------------------

status:

IDC: Inter-Discipline Check
 IFC: Issued For Comment
 IFA: Issued For Approval
 AFD: Approved For Design
 AFC: Approved For Construction
 AFP: Approved For Purchase
 AFQ: Approved For Quotation
 IFI: Issued For Information
 AB-R: As-Built for CLIENT Review
 AB-A: As-Built –Approved



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

عمومی و مشترک

ELECTRICAL LOAD LIST



شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
D01	0001	LI	EL	220	PEDCO	GNRAL	BK

شماره صفحه: ۲ از ۴

REVISION RECORD SHEET

Page	D00	D01	D02	D03	D04	Page	D00	D01	D02	D03	D04
1	X	X				51					
2	X	X				52					
3	X	X				53					
4	X	X				54					
5						55					
6						56					
7						57					
8						58					
9						59					
10						60					
11						61					
12						62					
13						63					
14						64					
15						65					
16						66					
17						67					
18						68					
19						69					
20						70					
21						71					
22						72					
23						73					
24						74					
25						75					
26						76					
27						77					
28						78					
29						79					
30						80					
31						81					
32						82					
33						83					
34						84					
35						85					
36						86					
37						87					
38						88					
39						89					
40						90					
41						91					
42						92					
43						93					
44						94					
45						95					
46						96					
47						97					
48						98					
49						99					
50						100					



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

عمومی و مشترک

ELECTRICAL LOAD LIST



شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

پروژه

BK

بسته کاری

GNRAL

صادر کننده

PEDCO

تسهیلات

220

رشته

EL

نوع مدرک

LI

سریال

0001

نسخه

D01

شماره صفحه: ۳ از ۴

Service Type:

N : Normal Load

E : Emergency Load

Load Duty:

C : Continuous Load

I : Intermitant Load

S : Stand By Load

LR/FL: Loacked Rotor / Full Load Current

Load Type:

M: Motor

F: Non-Motor

Definition of API Factor

1.25 for Motor Power < 22kW,

1.15 for Motor Power between, 22kW and 55kW

1.1 for Motor Power > 55kW

Height derating factor can be determined as follows if no manufacturer data is available:

Height Above Sea Level	Height Factor
< 1000 m	1
1000 < Height < 1500 m	0.97
1500 m >	0.94

Coolant (Cooling) Factor is 0.88 according to basic document for motor feeder type.

LV Feeder Type:

F1: Simple 4-Pole MCCB Feeder with Thermal/Magnetic Trips, for $I < 63A$ Feeders

F2: Simple 4-Pole MCCB Feeder with Thermal/Magnetic Trips, for $63A = I < 100A$ Feeders

F3: Simple 4-Pole MCCB Feeder with Thermal/Magnetic Trips, for $100A = I$ Feeders

F4: Simple 3-Pole MCCB Feeder with Thermal/Magnetic Trips, for $I < 63A$ Feeders

F5: Simple 3-Pole MCCB Feeder with Thermal/Magnetic Trips, for $63A = I < 100A$ Feeders

F6: Simple 3-Pole MCCB Feeder with Thermal/Magnetic Trips, for $100A = I$ Feeders

F7: Simple 2-Pole MCCB Feeder for Feeding Single Phase Loads (Ph+N or 2-Ph)

M1: Direct on Line Motor Starter Feeders for $0.4 \leq P < 4kW$ (Switch Fuse + Contactor + Bimetal + R/L Signaling)

M2: Direct on Line Motor Starter Feeders for $4kW \leq P < 18.5kW$ (Switch Fuse + Contactor + Bimetal + R/L Signaling + R/L Ammeter)

M3: Direct on Line Motor Starter Feeders for $18.5kW \leq P < 30$ (Switch Fuse + Contactor + Bimetal + R/L Signaling + R/L Ammeter (49, 50G, Phase Control))

M4: Direct on Line Motor Starter Feeders for $30kW \leq P$ (Switch Fuse + Contactor + Overload CT + R/L Signaling + R/L Ammeter (49, 50G, Phase Control))

MV Feeder Type:

C1: 11 KV Incoming Feeder

C2: Outgoing Transformer 2000 KVA

C3: Outgoing Motor Starter <1000 KW

C4: Bus Coupler 11 KV

 NISOC				تنگداشت و افزایش تولید میدان نفتی بینک							 		
				سطح الارض و ابنیه تحت الارض									
				عمومی و مشترک									
				ELECTRICAL LOAD LIST									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴				پرژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۴ از ۴	
				BK	GNRAL	PEDCO	220	EL	LI	0001	D01		
Item NO	Rev	Bus	Equipment Number	Load Description	Service Type	No Phases	Rated Voltage (V)	Load Type	Rated Power (Kw)	Eff. (%)	Power Factor	Current Normal Operation (A)	
1	D01	A	NISOC Office Building Panel	NO-DP	N	3	400	F	118.76	100	0.9	190.46	
2	D01	A	NISOC Residential Building Panel	NR-DP	N	3	400	F	115.28	100	0.9	184.88	
3	D01	A	Petro Office Building Panel	PO-DP	N	3	400	F	80.28	100	0.9	128.75	
4	D01	A	Petro Residential Building Panel	PR-DP	N	3	400	F	77.28	100	0.9	123.94	
5	D01	A	Restaurant Building Panel	RES-DP	N	3	400	F	71.28	100	0.9	114.32	
6	D00	A	Driver Building Panel	DR-DV	N	3	400	F	23.28	100	0.9	37.34	
7	D00	A	Warehouse Panel	WH-DP	N	3	400	F	7	100	0.9	11.23	
8	D01	A	Workshop Panel	WSH-DP	N	3	400	F	38.75	100	0.9	62.15	
9	D00	A	Gatehouse Panel	GH-DP	N	3	400	F	5	100	0.9	8.02	
10	D01	A	Outdoor Area Panel	CMP-DP	N	3	400	F	4.25	100	0.9	6.82	

Building Numbering Procedure

NO: NISOC Office
NR: NISOC Residential
PO: PETRO Office
PR: PETRO Residential
RES: Restaurant
DVR: Driver
WH: WareHouse
WS: WorkShop
GH: Gate House
CMP: Camp

To calculate power demand, below assumptions have been considered:
- Since staffs will present in one building at the same time, therefore the power consumption of NO-DP or NR-DP (each one is bigger), will be considered. This note is valid for PO-DP & PR-DP.
- The power demand of other panels will be considered completely.
- At the end, diversity factor "0.5" will be considered for active power.

Active Power (Kw)
345.12
Active Demand (Kw)
172.56
Reactive Demand (kvar)
75.22

Apparent Power (Kva)
188.24

According to above calculation, one transformer 250 KVA is sufficient to supply power demand in camp area