

عمومی و مشترک



شماره پیمان:

· 27 - · 77 - 9114

CALCULATION NOTE	FOR LV CAPACITOR	BANK OF WELL PADS

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
BK	SSGRL	PEDCO	110	EL	CN	0010	D01

شماره صفحه : ۱ از ۷

طرح نگهداشت و افزایش تولید ۲۷ مخزن

CALCULATION NOTE FOR LV CAPACITOR BANK OF WELL PADS

نگهداشت و افزایش تولید میدان نفتی بینک

Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
D00	Jan. 2022	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	·
D01	Jul. 2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	·

Class:2 CLIENT Doc. Number: F0Z-707386

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for CLIENT Review

AB-A: As-Built -Approved



عمومی و مشترک



شماره پیمان:

CALCULATION NOTE FOR LV CAPACITOR BANK OF WELL PADS

· 24 - · 74 - 9114

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه
BK	SSGRL	PEDCO	110	EL	CN	0010	D01

شماره صفحه: ۲ از ۷

REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	Х	Χ			
2	Х	Х			
3	Х				
4	Х				
5	Х				
6	Х	Х			
7	Х	Х			
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40	1				
41					
42	-				
43					
44					
45					
46					
47					
48	1				
49 50	1				

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90			ļ		
91					
92			ļ		
93					
94					
95					
96			ļ		
97					
98					
99					
100			<u> </u>		
· <u></u>					



عمومي و مشترك



شماره پیمان:

· 27 - · 77 - 9114

CALCULATION NOTE FOR LV CAPACITOR BANK OF WELL PADS

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 SSGRL
 PEDCO
 110
 EL
 CN
 0010
 D01

شماره صفحه: ۳ از ۷

CONTENTS

1.0	INTRODUCTION					
2.0	SCOPE					
-	NORMATIVE REFERENCES					
3.1	LOCAL CODES AND STANDARDS	5				
3.2	The Project Documents.					
3.3	ENVIRONMENTAL DATA	5				
3.4	Order of Precedence	5				
4.0	CALCULATION	6				
4.1	CALCULATION FOR LV CAPACITOR BANK	6				



عمومی و مشترک



شماره پیمان:

· ۵۳ - · ۷۳ - 9114

CALCULATION NOTE FOR LV CAPACITOR BANK OF WELL PADS							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	EL	CN	0010	D01

شماره صفحه: ۴ از ۷

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, construction of well location, access roads, wellhead facilities for 6 new wells (with electric power supply for 2 of them) and required modifications on 4 workover wells (with electric power supply) shall be done. In addition, construction of 6 new flowlines from new wells to Binak B/C unit (with extension of relevant manifold) are in the Project scope of work.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development – Construction of New Well

Locations, Modifications on Workover Wells, Wellhead Facilities, Electrification Facilities, Flowlines and

Extension of Binak B/C Manifold

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy – Design & Inspection

(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by



عمومی و مشترک



شماره صفحه: ۵ از ۷

پیمان:	شماره
--------	-------

· ۵۳ - · ۷۳ - 9 1 1 4

CALCULATION NOTE FOR LV CAPACITOR BANK OF WELL PADS							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	EL	CN	0010	D01

CLIENT rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.

2.0 SCOPE

This document covers minimum necessary requirements for the design, selection, manufacture, inspection, testing and delivery of Capacitor bank.

It shall be used in conjunction with data/requisition sheets for present document subject.

3.0 NORMATIVE REFERENCES

3.1 LOCAL CODES AND STANDARDS

• IPS-E-EL-100 (1) Engineering Standard for Electrical System Design

• IPS-M-EL-181 (2) Material & Equipment Standard for Power Factor Improvement Capacitor

3.2 THE PROJECT DOCUMENTS

3.3 ENVIRONMENTAL DATA

Refer to "Process Basis of Design; Doc. No. BK-GNRAL-PEDCO-000-PR-DB-0001"

3.4 ORDER OF PRECEDENCE

In case of conflict between requirements specified herein & the requirements of any other referenced document, the most approved stringent requirements of below listed items shall be considered based on the approval given by the owner's representative:

- Purchase order
- Material Requisition
- MTO & Data Sheet
- This Specification
- Drawing & Other Specification
- Reference Project Specification
- Iranian Petroleum Standard (IPS)
- Reference international Code & Standards



عمومي و مشترك



ىمان:	شماره پ
-------	---------

· ۵۳ - · ۷۳ - 9 1 1 8	۰۵۳	_	٠	٧٣	_	٩	١	٨	۴
-----------------------	-----	---	---	----	---	---	---	---	---

CALCULATION NOTE FOR LY CAPACITOR BANK OF WELL PADS									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	SSGRL	PEDCO	110	EL	CN	0010	D01		

شماره صفحه: ۶ از ۷

When the term "Authorized", Authorization", "Approval", or "Approved" are used in this specification, it shall mean authorization or Approval from OWNER.


In case of any conflict between the project documents, the most stringent one shall be considered.

4.0 CALCULATION

4.1 Calculation for LV Capacitor Bank

According to Electrical Load List of Well Pads (BK-SSGRL-PEDCO-110-EL-LI-0001-D02):

Total Active Peak Load Power for LV switchgear is 155.413 Kw





Therefore:

Tan
$$(\Psi_1) = \frac{Q}{P} = \frac{93.764}{155.413} = 0.6$$
 while $\cos(\Psi_1) = 0.86$

According to IPS-M-EL-181 power factor shall improve to 0.95

So
$$Cos(\Psi_2) = 0.95$$
 then $Tan(\Psi_2) = 0.33$

$$Q = P \times (Tan(\Psi_1) - Tan(\Psi_2))$$
 Formula (1)

According to formula (1) we calculate:

$$Q_L = 155.413 \times (0.6 - 0.33) = 41.9 \, Kvar$$

Therefore $Q_L \cong 40 \ Kvar$

Note 1: Since there is one LV switchgear which will power both normal & emergency bus & there is not Coupler CB, therefore an interlock will be considered between capacitor bank & generator starting mode to prevent malfunction of diesel generator & capacitor bank.

Note 2: Since there is VFD on LV switchgear, vendor shall consider any technical requirement for capacitors selection.

Note 3: this calculation is valid for each 6 number of well pads.

Also current of capacitor bank will be calculated from following formula:

$$I = Q/(\sqrt{3} \times 0.4)$$
 Formula (3)

According to formula (3):

$$I = \frac{40}{\sqrt{3} \times 0.4} \cong 57.7 A$$



عمومی و مشترک



شماره پیمان:

· 24 - · 74 - 9114

CALCULATION NOTE FOR LV CAPACITOR BANK OF WELL PADS									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	SSGRL	PEDCO	110	EL	CN	0010	D01		

شماره صفحه: ۷ از ۷

We consider upstream breaker bigger than 1.5 I:

$$I_b = 1.5 \times 57.7 = 86$$

Then we select 125A MCCB circuit breaker on LV Switchgear for more reliability.