


 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>PMR FOR FIRE WATER PUMP</p> <table border="1"> <tr> <td>نسخه</td> <td>سریال</td> <td>نوع مدرک</td> <td>رشته</td> <td>تسهیلات</td> <td>صادرکننده</td> <td>بسته کاری</td> <td>پروژه</td> </tr> <tr> <td>D01</td> <td>0011</td> <td>MR</td> <td>ME</td> <td>120</td> <td>PEDCO</td> <td>GCS</td> <td>BK</td> </tr> </table>	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D01	0011	MR	ME	120	PEDCO	GCS	BK	<p>شماره صفحه : ۲ از ۲۷</p>
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه											
D01	0011	MR	ME	120	PEDCO	GCS	BK											

REVISION RECORD SHEET



PAGE	D00	D01	D02	D03	D04
1	X	X			
2	X	X			
3	X				
4	X				
5	X				
6	X				
7	X	X			
8	X	X			
9	X				
10	X				
11	X				
12	X	X			
13	X				
14	X				
15	X	X			
16	X	X			
17	X	X			
18	X				
19	X				
20	X				
21	X				
22	X				
23	X				
24	X	X			
25	X				
26	X				
27		X			
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					

PAGE	D00	D01	D02	D03	D04
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					
129					
130					

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">PMR FOR FIRE WATER PUMP</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D01</td><td>0011</td><td>MR</td><td>ME</td><td>120</td><td>PEDCO</td><td>GCS</td><td>BK</td></tr></table>	PMR FOR FIRE WATER PUMP								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D01	0011	MR	ME	120	PEDCO	GCS	BK	شماره صفحه : ۳ از ۲۷
PMR FOR FIRE WATER PUMP																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D01	0011	MR	ME	120	PEDCO	GCS	BK																			

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	REFERENCE / ATTACHED DOCUMENTS	5
4.0	SUBJECT OF THE SUPPLY	6
5.0	LIMITS OF SUPPLY	6
5.1	SCOPE OF SUPPLY	6
5.2	SCOPE OF WORK	9
5.3	EXCLUSIONS.....	11
5.4	BATTERY LIMITS	11
6.0	INSPECTION AND TESTS.....	12
7.0	VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE	12
8.0	UNIT RESPONSIBILITY	12
9.0	GUARANTEE AND WARRANTY	13
10.0	DEVIATION	13
11.0	PRICE BREAKDOWN	14
	ATTACHMENT 1	15
	ATTACHMENT 2	18
	ATTACHMENT 3.....	26
	ATTACHMENT 4.....	27

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۴ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.



With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – Surface Facilities; New Gas Compressor Station
EPD/EPC CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of : Hirgan Energy – Design & Inspection (D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC CONTRACTOR (GC) and approved by CLIENT (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by CLIENT rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR.
MAY:	Is used where a provision is completely discretionary.

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۵ از ۲۷
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	D01	0011	MR	ME	120	PEDCO	GCS	
	BK							

2.0 GENERAL

- This document presents the item material requisitions for Contractor's use as appropriate.
- This material requisition covers the requirements for the design, manufacturing, testing and supply of fire water pumps package as listed below. All equipment/devices/items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.
- The vendor's supply shall include:

No.	Item	Description	Total QTY.
1	P-2302 A/B	Fire water jockey pumps	2 (1+1)
2	P-2301 A	Fire water pump-electrical motor driven	1
3	P-2301 B	Fire water pumps-diesel engine driven	1



3.0 REFERENCE / ATTACHED DOCUMENTS

- Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- All codes and standards which have been referenced in above mentioned specs shall be considered.
- In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.
- Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه: ۶ از ۲۷
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	ME	MR	0011	D01

If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, the supplier shall be considered to be in full compliance with the relevant document.

The supplier may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY

The supplier shall supply fire water pumps package completely assembled and tested. The scope of supply is detailed at para. 5. The supplier shall include in the supply, all other equipment/devices/items not listed in the following, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.



5.0 LIMITS OF SUPPLY

5.1 SCOPE OF SUPPLY

5.1.1 MAIN DESCRIPTION


❖ The scope of supply is detailed below:

- Complete set of fire water pumps
- Electrical motor:
 - On-skid cabling, tray and fittings
 - Anti-condensation heaters for motor
 - Outdoor MCC for Auxiliaries Electrical Load (if any)
- Diesel Engine:
 - Diesel Fuel System, including Duplex Filter, Pump & Shut-Off Valve



 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۷ از ۲۷
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	ME	MR	0011	D01

- Lubrication Oil System, Including Main Shaft-Driven Pump, Priming Pump, Duplex Filter, Oil Cooler & Heater
- Electric Starting System, Including Electric Motor, Ni-Ca Batteries & Charger
- Fuel Day Tank
- Combustion Air Inlet System Including Filter
- Exhaust System Including Flexible Pipe, Bellows Ductwork, Support, Personnel Protection Insulation, Silencer & Tailpipe
- Closed Circuit Cooling Water System Complying With NFPA 20 Requirements


- Anti-Reverse Rotation Device
- Local Firewater Pump Controller In Accordance With NFPA 20 Requirements (for minimum requirements of electrical /control signals refer to "P&ID for Fire Water Network", Doc. No: BK-GCS-PEDCO-120-SA-PI-0001.



- The Separate Power Panels for Jockey and main pump electric motors and the Separate Power & control Panels for main Pump diesel engine.
- LCP to manage all required monitoring and control signals to be located next to the pumps.
- Automatic Air Release-Vacuum Breaker Valve
- Coupling (dry flexible Spacer with Non sparking guard)
- Anti-vibration Mounts
- Common baseplate for driver and pump
- Foundation bolts (anchor bolt), skid leveling screws, shims, sub-plates
- Overall piping/tubing, valves and fittings within the package for complete operation
- Two earthing bars
- Lifting lugs for four points for each baseplate

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۸ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011	D01	



- Instrumentation (for minimum requirements of instrumentation refer to “P&ID for Fire Water Network”, Doc. No: BK-GCS-PEDCO-120-SA-PI-0001.)
- Instrument wiring within baseplates including junction box
- Mating flange with bolts, nuts and gaskets
- First fill oil
- Special tools for erection and maintenance
- Thermal insulation (if needed)
- Valved casing drain & vent (for horizontal items)
- Any other accessories and auxiliaries specify in data sheet
- Name plates
- Spare Parts for erection, pre-commissioning, commissioning and start up and two years operation.
- Capital spare parts (as option)
- All requirements for safe and easy start up of pumps
- Pressure sensing line, PRV and sight glass
- Any other items not listed above which are necessary for satisfactory design and operation of the pump shall be furnished by vendor



5.1.2 ENGINEERING SERVICES

The supplier shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.
- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۹ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01



- Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:
 - QA/QC Organization Chart and procedures that shall be submitted for approval.
 - Plan for HOLD points in the production process proposed to PURCHASER for witness or approval particular activities.
 - Production schedule indicating main quality manufacturing processes, inspection and tests.
 - Qualification of all personnel performing tests to be reviewed by the inspector
 - Supplier shall also provide the description of the following quality activities:
 - Sub suppliers products quality
 - Quality check and identification of the materials and equipment entering in their manufacturing shop.
- Calibration of test instruments and equipment
- Provide detailed specifications and data sheets.



5.1.3 SPARE PARTS

Following items shall be considered (supplied) and included in the bid documentation:

- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Capital spare parts (as option / if any)

5.1.4 OTHER ITEMS



- Special tools required for installation and maintenance
- Noise acoustic protection and relevant ancillaries in order to match with max. noise level requirements (if necessary)
- Name plate
- Earthing plate
- Painting of all items in accordance with "Painting Specification; Doc. No: BK-GNRAL-PEDCO-000-PI-SP-0006".
- Preparation for shipment

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۱۰ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01

- Packing for sea freight transportation
- Shop inspections and testing as per specifications & data sheets
- Free access to manufacturing plants for the PURCHASER's inspectors
- Certificates or declarations of conformance (as required) of all Ex-equipment.
- Daily rate for erection supervision (separate price)
- Daily rate for commissioning and start-up supervision (separate price)
- Training for customer's personnel (separate price)
- KOM
- Technical/Clarification meeting
- Pre-Inspection Meeting

5.2 SCOPE OF WORK

- Engineering and Documentation
- Manufacturing and assembling
- Mechanical Guarantee
- Performance Guarantee
- Sub-Vendor Coordination
- Mounting of main driver and auxiliary driver on baseplate at shop
- Inspection and testing at shop
- Piping within the Package
- Painting
- Prime Coats at Shop
- Finish Coats at Shop
- Packing Preservation suitable for more than 18 months at outdoor conditions of the site environment
- Packing including suitable protection for both sea transport and road transport on rough tracks
- Rust prevention for long term (over 6 month)
- Shipping and transportation to point of delivery (according to delivery condition)
- Supervision for installation (Per diem rate and/or lump sum - as an option)
- Supervision for erection, commissioning and start up (Per Diem rate and/or lump sum - as an option)

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۱۱ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01

- Preparing of Final Book (Data Book)

5.3 EXCLUSIONS



The following items are excluded by the supplier scope of supply and will be provided by purchaser:

- Concrete foundation (which shall be anyway designed based on supplier's technical data)
- Instrument air supply
- Nitrogen supply (if any)
- Electrical supply
- Interconnecting power cables among each skid mounted terminal boxes and remote switch gear
- Interconnecting cabling, serial link, between the remotely mounted unit control panel and the process control system in the main control room
- Connection to plant earthing system
- Transport from receiving port to site
- Shelter for Pumps
- Site erection
- Lubricants (except first filling)

5.4 BATTERY LIMITS

The battery limits are summarized as follows:

- Process
 - Inlet and outlet flanges on skid
- Lube Oil
 - Lube oil filling point
- Instrumentation and control
 - terminal strips inside junction boxes at skid edges
 - terminal strips inside unit control panel
 - terminal strips inside UCP for integrated safety system (ESD and F&G) connections
 - terminal strips inside UCP for IRP connections
 - MODBUS TCP/IP connections on modules
- Electrical

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۱۲ از ۲۷
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	D01	0011	MR	ME	120	PEDCO	GCS	
	BK							

- Incoming Power Supply of Local MCC
- Incoming Power Supply of AC or DC UPS (if Any)
- Earth Bosses on Skids.
- e) Vents and Drains
 - Drain flanges manifold
 - Outlet vent piping flanges

6.0 INSPECTION AND TESTS





The equipment shall be inspected and tested in accordance with the quality control plan issued by the supplier and approved by the PURCHASER before the award of the order. The QC plan shall at least be according to Doc. No. ICE-EID-MI-SP01- Rev01 (دستورالعمل بازرسی خرید و ساخت کالا) and Doc. No. ICE-EID-MI-SP02-REV-01 (دستورالعمل انتخاب سطح بازرسی کالا و تجهیزات) and data sheets (if any).

The supplier shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE

- Vendor document shall be according to attachment 2 of this document.
- All documents, preliminary or final, are to be stamped and signed by the supplier.
- Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.
- PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.
- All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 **“GENERAL DEFINITION”**

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه: ۱۳ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, testing, final check-out and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.

Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-suppliers.

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.

The guarantee period shall be eighteen (18) months from the date of delivery and/or twelve (12) months from the installation date of each equipment/packages at site.

VENDOR shall guarantee the performance of supplied items (if any).



VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period.

Vendor shall ensure a correct and safe operation of the unit, providing all safety protection Devices.

Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP								شماره صفحه : ۱۴ از ۲۷
	پروژه BK	بسته کاری GCS	صادرکننده PEDCO	تسهیلات 120	رشته ME	نوع مدرک MR	سریال 0011	نسخه D01	

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION



VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.


VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for PURCHASER's approval.

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (END-QC-SP-1)
- 3) 2 years operational spare parts (END-QC-SP-1)
- 4) Packing & transportation
- 5) Other fee (if any)



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">PMR FOR FIRE WATER PUMP</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادر کننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>ME</td><td>MR</td><td>0011</td><td>D01</td></tr></table>	PMR FOR FIRE WATER PUMP								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	ME	MR	0011	D01	شماره صفحه : ۱۵ از ۲۷
PMR FOR FIRE WATER PUMP																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	ME	MR	0011	D01																			





ATTACHMENT 1

LIST OF REFERENCE / APPLICABLE DOCUMENTS



No.	Document No.	Document Title	Rev.
Process			
1	BK-GNRL-PEDCO-000-PR-DB-0001	Process Basis of Design	D06
2	BK-GNRL-PEDCO-000-PR-DC-0001	Process Design Criteria	D02
Mechanical			
3	BK-GNRL-PEDCO-000-ME-DC-0001	Mechanical Design Criteria	D01
4	BK-GCS-PEDCO-120-ME-SP-0005	Specification For Fire Water Pumps	D04
5	BK-GCS-PEDCO-120-ME-DT-0028	Mechanical Data Sheets For Fire Water Jockey Pumps	D02
6	BK-GCS-PEDCO-120-ME-DT-0029	Mechanical Data Sheets For Fire Water Main Pump - Elect. Motor Driven	D02
7	BK-GCS-PEDCO-120-ME-DT-0030	Mechanical Data Sheets For Fire Water Main Pump - Diesel Engine Driven	D02
8	BK-GCS-PEDCO-120-ME-SP-0012	Specification For Diesel Engines	D03
Piping & Material			
9	BK-GCS-PEDCO-120-PI-SP-0001	Piping Material Specification	D01
10	BK-GNRL-PEDCO-000-PI-SP-0005	Specification For Fittings, Flanges, Gaskets and Bolts	D02
11	BK-GNRL-PEDCO-000-PI-SP-0006	Specification For Painting	D04
12	BK-GNRL-PEDCO-000-PI-SP-0019	Specification For Insulation	D02
13	BK-GNRL-PEDCO-000-PI-SP-0009	Specification For Manual Valves	D00
14	BK-GNRL-PEDCO-000-PI-SP-0011	Specification For Welding of Plant Piping System	D00
15	BK-GNRL-PEDCO-000-PI-DC-0001	Piping Design Criteria	D03
16	BK-GCS-PEDCO-120-PI-RT-0001	Piping Corrosion Study & Material Selection Report	D01
17	BK-GNRL-PEDCO-000-PI-SP-0004	Specification For Metallic Pipes	D05
18	BK-GCS-PEDCO-120-PI-PY-0001	Unit Plot Plan Drawing	D02
19	BK-GNRL-PEDCO-000-PI-SP-0003	Specification For the Design of Piping in Mechanical Packages	D00
20	BK-GNRL-PEDCO-000-PI-SP-0007	Specification For Lining (Internal Protection of Equipment by Painting)	D00
21	BK-GNRL-PEDCO-000-PI-	Specification For Piping Cleaning and Flushing	D02


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۱۶ از ۲۷	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01

No.	Document No.	Document Title	Rev.
	SP-0017		
22	BK-GNRAL-PEDCO-000-QC-PR-0041	NDT Plan For steel Structures	D00
23	BK-GNRAL-PEDCO-000-PI-SP-0001	Specification For Color Coding and Marking	D00
24	BK-GNRAL-PEDCO-000-PI-SP-0010	Specification For Plant Piping Systems Pressure Testing	D00
Structure			
25	BK-GNRAL-PEDCO-000-ST-DC-0001	Structural Design Criteria	D00
26	BK-GNRAL-PEDCO-000-ST-DW-0002	Standard Drawing For Anchor Bolts	D02
Control & Instrumentation			
27	BK-GNRAL-PEDCO-000-IN-SP-0001	Specification For Instrumentation	D03
28	BK-GNRAL-PEDCO-000-IN-SP-0004	Specification For Instrument and Control of package Unit System (PU)	D01
29	BK-GNRAL-PEDCO-000-IN-SP-0010	Specification For Instrument/F&G Cables	D01
Electrical			
30	BK-GNRAL-PEDCO-000-EL-DC-0001	Electrical System Design Criteria	D02
31	BK-GNRAL-PEDCO-000-EL-SP-0001	Specification For LV Switchgear & Motor Control Centers	D03
32	Deleted	Deleted	Deleted
33	BK-GNRAL-PEDCO-000-EL-SP-0010	Specification For LV Induction Motors	D03
34	BK-GNRAL-PEDCO-000-EL-SP-0017	Specification For MV Induction Motors	D03
35	BK-GNRAL-PEDCO-000-EL-SP-0011	Specification For Electrical Requirements of Packaged Units	D03
36	Deleted	Deleted	Deleted
37	BK-GCS-PEDCO-120-EL-DT-0008	Data Sheets For LV Induction Motors	D02
Safety & Fire Fighting			
38	BK-GNRAL-PEDCO-000-SA-SP-0002	Specification For Hazardous Area Classification	D03
39	BK-GNRAL-PEDCO-000-SA-SP-0003	Specification For Fire Water System	D02
40	BK-GNRAL-PEDCO-000-SA-SP-0007	Specification For passive Fire protection	D02
41	BK-GCS-PEDCO-120-SA-PY-0002	Hazardous Area Classification Layout	D00
42	BK-GCS-PEDCO-120-SA-PI-0001	P&ID - Fire Water Network	D01
General			

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">PMR FOR FIRE WATER PUMP</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D01</td><td>0011</td><td>MR</td><td>ME</td><td>120</td><td>PEDCO</td><td>GCS</td><td>BK</td></tr></table>	PMR FOR FIRE WATER PUMP								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D01	0011	MR	ME	120	PEDCO	GCS	BK	شماره صفحه : ۱۷ از ۲۷
PMR FOR FIRE WATER PUMP																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D01	0011	MR	ME	120	PEDCO	GCS	BK																			

No.	Document No.	Document Title	Rev.
43	ICE-EID-MI-SP01- Rev01	دستورالعمل بازرسی، خرید و ساخت کالا	D01
44	E&D-QC-SP-1	دستورالعمل تامین قطعات یدکی راه اندازی و راهبری دوسالانه	
45	ICE-EID-MI-SP02-REV-01	دستورالعمل انتخاب سطح بازرسی کالا و تجهیزات	D01
46	BK-GNRAL-PEDCO-000-QC-PR-0022	Specification For Final Data Book (FDB) Requirements	D00
47	BK-GNRAL-PEDCO-000-QC-PR-0045	Packing, Marking, Transportation Procedure	D00



 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۱۸ از ۲۷
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	D01	0011	MR	ME	120	PEDCO	GCS	
	BK							





ATTACHMENT 2

VENDOR DOCUMENTS MIN. REQUIREMENT



Item No.	Document	With Bid	TIME SCHEDULE			
			For Review		Final Issue	
		Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
MANAGEMENT						
001	Vendor Document Index and Schedule	4N	6C+E		6C+E	
002	Organization Brief	3N	6C+E			
003	Schedule Level 1, 2, 3 & 4 showing Engineering, Procurement, Fabrication, Inspection, Testing, and Delivery Plan.	4N	6C+E		6C+E	
004	Physically Progress Report (Every 2 Weeks))		6C+E			
005	Project Organization Chart	3N	6C+E			
006	Reference List	3N				
007	Vendor Catalogue	3N				
QUALITY						
008	Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO)	4N			6C+E	
009	Preliminary Inspection and Test Plan	4N				
010	Inspection and Test Plan		6C+E		6C+E	
HSE						
011	HSE Procedure		6C+E		6C+E	
012	Noise & Vibrations Calculations / Reports (If any)		6C+E		6C+E	
INTERFACE						
013	Electrical & Instrumentation Cable Schedule (for all systems)		6C+E		6C+E	
014	Electrical & Instrumentation Wiring Drawings (for all systems)		6C+E		6C+E	

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۱۹ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01



Item No.	Document	With Bid	TIME SCHEDULE			
			For Review		Final Issue	
		Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
015	Data Sheets	4N	6C+E		6C+E	
016	Reliability, Availability, Maintainability Calculations/Reports	4N	6C+E		6C+E	
017	Performance Curves		6C+E		6C+E	
018	PFD's	4N	6C+E		6C+E	
019	Functional Description		6C+E		6C+E	
020	General Arrangements Drawings	4N	6C+E		6C+E	
021	Mechanical Equipment List	3N	6C+E		6C+E	
022	Electrical Equipment List	3N	6C+E		6C+E	
023	Control, Instrument & Cable List		6C+E		6C+E	
024	Interface Block Diagrams	3N	6C+E		6C+E	
025	Junction Box, Local Panels & Cabinets: wiring diagrams & termination drawings		6C+E		6C+E	
026	Functional Logic Diagram		6C+E		6C+E	
027	P & ID's	3N	6C+E		6C+E	
028	Utility Consumption List	3N	6C+E		6C+E	
029	Power Supply Requirements	3N	6C+E		6C+E	
030	Single Line Diagram	3N	6C+E		6C+E	
031	Earthing Details	3N	6C+E		6C+E	
032	Weight / Centre of Gravity Drawings & Data's		6C+E		6C+E	
033	External Static and Dynamic Forces & Moments (present during test, start-up, normal/maximum operation, shutdown, and other conditions of service)		6C+E		6C+E	
034	Wind and Seismic Loads including shear and moment forces on supports and foundation.		6C+E		6C+E	
035	Anchor Bolt Details Drawings (incl. size, type, locations relative to the equipment center-lines in three planes).		6C+E		6C+E	

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۲۰ از ۲۷
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	D01	0011	MR	ME	120	PEDCO	GCS	
							BK	



Item No.	Document	With Bid	TIME SCHEDULE			
			For Review		Final Issue	
		Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
036	Ladder & Platform Detail Drawing		6C+E		6C+E	
037	Steel Structure Detail Drawing		6C+E		6C+E	
ENGINEERING						
038	Detailed Functional Design Specification		6C+E		6C+E	
039	Detailed Overall Description		6C+E		6C+E	
040	Mechanical Detailed Specifications (one per component)		6C+E		6C+E	
041	Detailed Design / Fabrication Drawings for Equipment & Auxiliary Parts		6C+E		6C+E	
042	Cross Sectional Drawings with Part Lists		6C+E		6C+E	
043	Assembly Drawings		6C+E		6C+E	
044	Design Calculation Notes		6C+E		6C+E	
045	Pressure Parts Calculations		6C+E		6C+E	
046	Piping Detailed Specifications (one per component)		6C+E		6C+E	
047	Piping Routing		6C+E		6C+E	
048	Valves & Instruments Location Drawings (incl. provisions for operational and maintenance access)		6C+E		6C+E	
049	Electrical Detailed Specifications (one per component)		6C+E		6C+E	
050	Electrical Cables Routing (incl. cable trays & junction boxes)		6C+E		6C+E	
051	Electrical Equipment Location Drawings (incl. provisions for operational and maintenance access)		6C+E		6C+E	
052	Protection Device Operating Curves		6C+E		6C+E	
053	Electrical Control Schematics		6C+E		6C+E	
054	Instrument & Control Detailed Specifications (one per component)		6C+E		6C+E	
055	Instrument cables routing (incl. cable trays & junction boxes)		6C+E		6C+E	

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">PMR FOR FIRE WATER PUMP</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D01</td><td>0011</td><td>MR</td><td>ME</td><td>120</td><td>PEDCO</td><td>GCS</td><td>BK</td></tr></table>	PMR FOR FIRE WATER PUMP								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D01	0011	MR	ME	120	PEDCO	GCS	BK	شماره صفحه : ۲۱ از ۲۷
PMR FOR FIRE WATER PUMP																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D01	0011	MR	ME	120	PEDCO	GCS	BK																			



Item No.	Document	With Bid	TIME SCHEDULE			
			For Review		Final Issue	
		Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
056	Instrument Equipment Location Drawings (incl. provisions for operational and maintenance access)		6C+E		6C+E	
057	Hook-Up Diagrams		6C+E		6C+E	
058	Wiring Loops Diagrams		6C+E		6C+E	
059	Instrument Control Schematics		6C+E		6C+E	
060	Instrument Mounting & Housing Instructions		6C+E		6C+E	
061	Power Distribution & Consumption		6C+E		6C+E	
062	Cause & Effect Charts		6C+E		6C+E	
063	Original Software for Control & Monitoring System		6C+E		6C+E	
064	Software System Specifications		6C+E		6C+E	
065	Approximate Weight & Dimension	4N				
066	Shipping Detail Drawing		6C+E		6C+E	
067	Final Data Book		6C+E		6C+E	
068	Pressure Loss Calculations		6C+E		6C+E	
069	Lubrication System Detailed Specifications / Drawings		6C+E		6C+E	
070	Cooling System Detailed Specifications/Drawings		6C+E		6C+E	
071	Shaft Sealing System Detailed Specifications/Drawings	4N	6C+E		6C+E	
072	Completed Equipment Datasheets	4N	6C+E		6C+E	
073	Calculation sheets for safety valves, control valves & orifice plate		6C+E		6C+E	
074	Complex loop & automation descriptions, list of alarms & shutdown with set points		6C+E		6C+E	
075	Electrical Equipment Catalogue	3N	6C+E		6C+E	
076	Electrical Interface Block Diagrams		6C+E		6C+E	
077	Electrical Load List	3N	6C+E		6C+E	
078	Local Control Station of motors wiring		6C+E		6C+E	

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۲۲ از ۲۷	
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری		
	D01	0011	MR	ME	120	PEDCO	GCS		



Item No.	Document	With Bid	TIME SCHEDULE			
			For Review		Final Issue	
		Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
	diagram, termination drawing and general arrangement					
079	Gear System Detailed Specifications / Drawings		6C+E		6C+E	
080	Coupling System Detailed Specifications / Drawings		6C+E		6C+E	
PROCUREMENT						
081	List of Sub-Suppliers (table giving: part of equipment, tag no., sub-supplier reference)(5.1.3)	4N			6C+E	
082	Unpriced copy of sub-orders		6C+E			
MANUFACTURING						
083	Weld and NDT Map		6C+E		6C+E	
084	Surface Preparation and Painting Procedures		6C+E		6C+E	
085	Heat Treatment Procedures		6C+E		6C+E	
086	Welding Procedure Specification (including repair procedures).		6C+E		6C+E	
087	Welder Qualification Procedure		6C+E		6C+E	
088	Fabrication Degree	3N				
TESTING						
089	Hydrostatic / Pneumatic Testing Procedure		6C+E		6C+E	
090	Performance & Functional Test Procedure		6C+E		6C+E	
091	Non-Destructive Testing/Examination Procedures		6C+E		6C+E	
092	Factory Acceptance Test (FAT) Procedure		6C+E		6C+E	
RECORDS, REPORTS & CERTIFICATES						
093	Material Conformity Certificate		6C+E		6C+E	
094	Testing Authority Approval Certificate (if any)		6C+E		6C+E	
095	Hazardous Area Certificates.		6C+E		6C+E	
096	Ingress Protection Certificate		6C+E		6C+E	

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۲۳ از ۲۷
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	D01	0011	MR	ME	120	PEDCO	GCS	
	BK							

Item No.	Document	With Bid	TIME SCHEDULE			
			For Review		Final Issue	
		Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
097	Conformity Certificates (sub-supplier/equipment)		6C+E		6C+E	
098	Material Certificates Identification Diagram. (cross-reference material location ; certificates for critical components)		6C+E		6C+E	
099	Welding Procedure Qualification Record		6C+E		6C+E	
100	Welder Qualification Records.		6C+E		6C+E	
101	NDT Operator Qualifications		6C+E		6C+E	
102	Detailed NDT Reports		6C+E		6C+E	
103	Weld/ NDT Identification Diagram. (Cross-reference weld locations, WPS, welders, NDT reports).		6C+E		6C+E	
104	Dimensional Control Reports		6C+E		6C+E	
105	Hardness Test Reports		6C+E		6C+E	
106	PWHT Charts & Reports, including calibration records of recorders (for each heat treatment)		6C+E		6C+E	
107	Pressure Test Reports / Certificates		6C+E		6C+E	
108	FAT Test Report / Certificates		6C+E		6C+E	
109	Performance Test Report / Certificates		6C+E		6C+E	
110	Noise & Vibration Test Report / Certificates		6C+E		6C+E	
111	Electric Motor Type Test Report (if any)		6C+E		6C+E	
112	Electric Motor Routine Test Report		6C+E		6C+E	
113	Cable Continuity and Resistance Test Reports		6C+E		6C+E	
114	Calibration Curves of Control Equipment		6C+E		6C+E	
115	Calibration Test Certificates		6C+E		6C+E	
116	Surface Preparation & Coating Reports		6C+E		6C+E	
117	Hydrostatic / Pneumatic Testing Certificates		6C+E		6C+E	
118	Welding Consumable Certificate		6C+E		6C+E	
119	Inspection and Test Reports(if any)		6C+E		6C+E	

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۲۴ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01

Item No.	Document	With Bid	TIME SCHEDULE			
			For Review		Final Issue	
			Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1) Calenda r days (3)
120	Rust Prevention Report			6C+E		6C+E
121	Non-Conformities Report			6C+E		6C+E
INSTALLATION						
122	Sub-Assembly Documentation			6C+E		6C+E
123	Sub-Assembly Drawings			6C+E		6C+E
124	Erection/Installation Manual (if required)			6C+E		6C+E
125	Name Plate Documents			6C+E		6C+E
126	Handling, Transportation & Storage Instructions			6C+E		6C+E
127	Unpacking & Inspection Instructions			6C+E		
128	Preliminary Packing List	4N				
129	Packing List			6C+E		6C+E
OPERATION & MAINTENANCE						
130	Operating Instructions			6C+E		6C+E
131	Maintenance Instructions (if required)			6C+E		6C+E
132	Commissioning & Start-up Manual			6C+E		6C+E
133	List of Spare Parts Commissioning & Start-up	4N		6C+E		6C+E
134	List of Spare Parts 2 Years Operation	4N		6C+E		6C+E
135	List of Special Tools	4N		6C+E		6C+E
136	Lube Oil Schedule			6C+E		6C+E
137	Software Manual (incl. Troubleshooting)			6C+E		6C+E
138	Consumables List			6C+E		6C+E
139	Function Test Procedure			6C+E		6C+E
OTHERS						
140	All others documents (if required) will be listed in the order			6C+E		

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۲۵ از ۲۷	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	ME	MR	0011		D01

Item No.	Document	With Bid	TIME SCHEDULE			
			For Review		Final Issue	
		Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)

NOTES:

(1) N= Number of document, C=Copy, E=Electronic Copy

(2) Starting from date of order placement

(3) Starting from reception of documentation without comments

(4) First issue of the document is subjected to the release of payment milestone as per purchase order

(5) Calendar days after reception of drive data



(6) Prior to testing

(7) One copy each bid copy

(8) List of Documents will be Finalized in Vendor Document Index and Schedule

D01



 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۲۶ از ۲۷
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	D01	0011	MR	ME	120	PEDCO	GCS	
							BK	



ATTACHMENT 3
DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION

Requisition No.:

Description:

Equipment No.:

Item No.	Description of Proposed Exception	Recommended Revision to JOB SPECIFICATION	Reason for Proposed Exception	Effect on Base PROPOSAL if CONTRACTOR Rejects Exception

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	PMR FOR FIRE WATER PUMP							شماره صفحه : ۲۷ از ۲۷
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	D01	0011	MR	ME	120	PEDCO	GCS	
							BK	

ATTACHMENT 4
ALTERNATIVES TO JOB SPECIFICATION

Requisition No.:

Description:

Equipment No.:

Item No.	Job Specification No. & Paragraph No.	Requirements of Job Specification	Description of Proposed Alternative	Reason for Proposed Alternative