









# عمومی و مشترک

شماره پیمان:

.04 - .14 - 9114

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه								
BK									

شماره صفحه: 1 از 34

# طرح نگهداشت و افزایش تولید ۲۷ مخزن

### HAZID REPORT FOR WHF & FLOW LINES

نگهداشت و افزایش تولید میدان نفتی بینک

D00 JUL. 2		IFI urpose of Issue/Status	F. Nourai Prepared by:	M.Fakharian Checked by:	M.Mehrshad Approved by:	CLIENT Approval
D00 JUL. 2	2022	IFI	F. Nourai	M.Fakharian	M.Mehrshad	

#### Status:

**IDC: Inter-Discipline Check** IFC: Issued For Comment IFA: Issued For Approval AFD: Approved For Design AFC: Approved For Construction AFP: Approved For Purchase AFQ: Approved For Quotation IFI: Issued For Information AB-R: As-Built for CLIENT Review AB-A: As-Built -Approved











# عمومی و مشترک

شماره پیمان: ۹۱۸۴ – ۰۷۳ – ۵۳۰

HAZID REPORT FOR WHF & FLOW LINES								l
نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه								
BK SSGRL PEDCO 110 GE RT 0003 D00							D00	
								_

شماره صفحه: 2 از 34

### **REVISION RECORD SHEET**

PAGE	D00	D01	D02	D03	D04
1	Х				
2	X				
3	X				
4	X				
5	X X X X X X				
<u>6</u>	\ \ \ \ \				
7	X				
<u>8</u> 9	X				
10	X				
11	X				
12	Χ				
13	X X X				
14	X				
15	X				
16	X				
17	X			-	
18	X			1	
19	\ \ \ \ \ \			-	
20 21	Y Y			<del>                                     </del>	
21	X X X X X X			<b>†</b>	
23	X				
24	X				
25	X X X				
26	Χ				
27	X				
28	X				
29	X				
30	X				
31	X X X				
32	X				
33	X				
34					
35 36					
37					
38					
39					
40					
41					
42	ļ			1	
43	ļ			<b></b>	
44	-			<del>                                     </del>	
<u>45</u>	1			<del>                                     </del>	
46	+			<del>                                     </del>	
47 48	1			<b>†</b>	
48 49					
50					
51					
52					
53					
54					
55					
<u>56</u>				-	
57	-			1	
<u>58</u>	-			<del>                                     </del>	
59	1			-	
60	+			<del>                                     </del>	
61 62					
63					
64					
65				1	

PAGE	D00	D01	D02	D03	D04
66					
67					
68 69					
70					
71					
72					
73					
74					
<u>75</u>					
<u>76</u>					
77 78					
79					
80					
81					
82					
83					
84			-		
85 86			<del>                                     </del>		
87			1		
88			1		
89					
90					
91					
92					
93					
94 95					
96					
97					
98					
99					
100					
101 102					
103					
104					
105					
106					
107					
108			1		
109 110			<u> </u>		
111					
112					
113					
114			ļ		
115	-	-	<del>                                     </del>		
116			1		
117 118			<del>                                     </del>		
119					
120					
121					
122			ļ		
123			-		
124			1		
125 126			<del>                                     </del>		
126			t		
128					
129					
130			l		



 $\textbf{.} \Delta \textbf{r} - \textbf{.} \textbf{V} \textbf{r} - \textbf{9} \textbf{1} \Delta \textbf{f}$ 

### نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های رو زمینی در بسته های کاری تحت الارض





نسخه

D00



# عمومی و مشترک

شماره پیمان:

 HAZID REPORT FOR WHF & FLOW LINES

 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 SSGRL
 PEDCO
 110
 GE
 RT
 0003

شماره صفحه: 3 از 34

### **CONTENTS**

1.0	INTRODUCTION	4
2.0	SCOPE	4
3.0	NORMATIVE REFERENCES	5
3.1 3.2	International Codes and Standards The Project Documents	5
4.0	HAZID STUDY OVERVIEW	5
5.0	ABBREVIATIONS	5
6.0	PROCEDURE	6
6.1 6.2	Study Methodology	7
7.0	HAZID STUDY OUTCOMES	8
8.0	ATTACHMENTS	9
8.1 8.1	Appendix A –Team Members	
8.1	APPENDIX B - HAZARD CATEGORIES (ISO 17776)	10
8.2	ATTACHMENT E – HAZID WORKSHEETS	13









### عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۰۷۳ – ۰۵۳

HAZID REPORT FOR WHF & FLOW LINES								
نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه								
BK SSGRL PEDCO 110 GE RT 0003 D00								

شماره صفحه: 4 از 34

### 1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also, PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, construction of well location, access road, wellhead facilities (with electric power supply) for W007S shall be done. In addition, construction of new flowline from aforementioned well location to Binak B/C unit (with extension of relevant manifold) are in the Project scope of work.

### **GENERAL DEFINITION**

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development - Construction of Well

Location, Wellhead Facilities, Electrification Facilities, Flowlines for W007S and Extension of Binak B/C

Manifold

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of: Hirgan Energy – Design &

Inspection(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.

### 2.0 SCOPE

The scope of HAZID Study covers Extension of Binak B/C Manifold.











### عمومی و مشترک

	پیمان:	شماره
• 54 - • 54 -	- 9114	

HAZID REPORT FOR WHF & FLOW LINES								
نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه								
BK	SSGRL	PEDCO	110	GE	RT	0003	D00	

شماره صفحه: 5 از 34

#### 3.0 NORMATIVE REFERENCES

#### 3.1 INTERNATIONAL CODES AND STANDARDS

ISO 17776 Petroleum and natural gas industries — Offshore

production installations — Major accident hazard

management during the design of new installations

#### 3.2 THE PROJECT DOCUMENTS

BK-GNRAL-HD-000-PR-DB-0001-D05 Process Basis of Design

BK-W007S-PEDCO-110-PI-PY-0001 Plot Plan Drawing – Extension of Binak B/C Manifold

BK-W007S-PEDCO-110-PI-PY-0002 Plot Plan Drawing – W007S

#### 4.0 HAZID STUDY OVERVIEW

Meetings were conducted in two sessions on July 23, 2022 held in Hirgan Energy company office, Tehran.

A team comprising of experts from different disciplines of National Iranian South Oilfields Company (NISOC), Petro Iran Development Company (PEDCO) and Hirgan Energy Company conducted the study with a third-party HAZID Chairman. The list of team members is presented in appendix A.

#### 5.0 **ABBREVIATIONS**

A/C Air-Conditioning

AC/DC Alternating Current/Direct Current

ALARP As Low As Reasonably Practicable

CBA Cost-Benefit Analysis

EMC **Electromagnetic Compatibility** 

ESD **Emergency Shut Down** 

F&G Fire and Gas HC Hydrocarbon HV High Voltage

**ICAO** International Civil Aviation Organization

IΡ **Ingress Protection IRP** Sucker-Rod Pump LBV Line Break Valve

Leak Detection and Repair LDAR









شماره صفحه: 6 از 34



### عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۵۳۰

HAZID REPORT FOR WHF & FLOW LINES										
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه									
BK SSGRL PEDCO 110 GE RT 0003 D00										

LV Low Voltage

MV Medium Voltage

OSBL Outside Battery Limit

PACS Project Applicable Codes and Standards

PPE Personal Protective Equipment

RCD/P Residual Current Device/Protection

ROW Right of Way

SCBA Self-Contained Breathing Apparatus

SIL Safety Integrity Level

SoW Scope of Work

SSSV Sub-Surface Safety Valve

TPD Third-Party Damage

UPS Uninterruptible Power Supply

VOC Volatile Organic Carbon
WHCP Wellhead Control Panel

### 6.0 PROCEDURE

HAZID methodology is in accordance with "HAZID Study Procedure" defined by ISO 17776 checklist.

HAZID study is a tool for hazard identification, used early in a project as soon as process flow diagrams, heat and material balances, and plot layouts are available. Existing site infrastructure, weather, and geotechnical data are also required, these being a source of external hazards. The method is a design-enabling tool, influencing HSE deliverables in the project.

HAZID study is undertaken in order to deliver a good identification of hazard, threat control and recovery measures. This Study helps to ensure that:

- ✓ Major Hazards with potential to affect personnel, environment and assets are revealed and identified at an early stage in the project, before significant costs have been incurred
- ✓ Hazards are recorded so that they can be avoided, mitigated or highlighted during design
- ✓ Design or construction delays and budget over-runs are avoided
- √ Fewer hazards remain un-revealed at commissioning and operation of facilities



# عمومي و مشتر ک



شماره پیمان:

.04 - .74 - 9176

HAZID REPORT FOR WHF & FLOW LINES									
نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه									
BK SSGRL PEDCO 110 GE RT 0003 D00									

شماره صفحه: 7 از 34

### 6.1 STUDY METHODOLOGY

A structured approach to identify hazards will be utilized based on studying the various operational phases of the under-study plant through:

- ✓ Identifying hazards.
- ✓ Describing their failure modes.
- ✓ Suggesting risk reducing measures that can prevent or mitigate each hazard.

The approach to HAZID is using generic guidewords, generic hazard specified for each hazard identified, the causes (threats), consequences and preventative/mitigation measures identified for the event. Recommendations are recorded when the preventative/mitigation measures do not adequately reduce the risk of the hazard.

HAZID formulates a list of hazards and generic hazardous situations by considering the following process characteristics:

- ✓ Impact of the facility to its surroundings
- ✓ Impact of the surroundings to the facility
- ✓ Interference between main units
- ✓ Location / orientation of plant and equipment
- ✓ Location / orientation of plant and equipment
- ✓ Unplanned releases for isolatable sections or units
- ✓ Environmental hazards and natural hazards.

As each hazardous situation is identified, the causes (threats), consequences, and threats control, recovery measures are listed.

For this study, safety analysis will be performed using selected items from the checklist of ISO 17776 standard for hazard categories and guidewords that lead to create a picture of hazardous situations and then to analyze and specify preventative/mitigation measures typical to the facilities under study. The checklist is presented in Appendix B. Brainstorming approach is an integral part of HAZID study, which is to be performed using a team composed of client, contractors, and subcontractors delegates and a HAZID Leader.

### 6.2 HAZID REPORTING FORMAT

Results of the HAZID study will be presented in a worksheet that tabulates the causes (threats), consequences, safeguards (Threat Control & Recovery Measures) and recommendations for each hazard identified. The method used for recording is full recording, i.e., all hazard hierarchy relevant to the context were considered and all operational issues or hazardous consequences were recorded along with any other outcome that may not raise a concern, for the sake of completeness and audit ability.



عمومي و مشترك









### شماره پیمان:

· ۵۳ - · ۷۳ - 9 1 A F

HAZID REPORT FOR WHF & FLOW LINES								
پروژد	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	
BK	SSGRL	PEDCO	110	GE	RT	0003	D00	

شماره صفحه: 8 از 34

Where the existing safeguards are found to be inadequate for the hazard, recommendations will be raised. Therefore, from the worksheets it should be inferred that wherever the hazard has no recommendation, its corresponding safeguards are considered adequate.

### Sample Format for HAZID worksheets

Section:

Hazard Category:

Guideword	Threats (Cause)	Consequences	Threat Control/Recovery Measures	Recommendations

#### 7.0 HAZID STUDY OUTCOMES

A total of 16 recommendations were obtained that are shown in Appendix C. Recommendations are either closed type, i.e., they are final in their description, or open type, which means the final action depends on a study as clearly indicated in the recommendation. One shall note that all recommendations, open or closed, shall be followed up and finalized. Appendix D consists of detailed HAZID Worksheets of the study.



عمومی و مشترک








شماره صفحه: 9 از 34





HAZID REPORT FOR WHF & FLOW LINES									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه								
BK	SSGRL	PEDCO	110	GE	RT	0003	D00		

#### 8.0 **ATTACHMENTS**

### 8.1 APPENDIX A –TEAM MEMBERS

First Name	Last Name	Company	Expertise
Fatemeh	Ghodsi	NISOC	Head of I&C
Sahar	Saba	NISOC	Process
Peyman	Sarvarian	NISOC	Mechanic
Mohammad	Khamisi	NISOC	HSE
Farid	Hedayat Rad	NISOC	Instrument
Hasan	Salari	NISOC	Process
Bahman	Zarei	NISOC	Maintenance
Ghasem	Shahrooei	NISOC	Engineering
Seyed Ali	Mousavi	Gachsaran NISOC	Process
Mohammad	Navid	Gachsaran NISOC	Production Engineer
Mohammad	Fakoor	PEDCO	Process Engineer
Farshid	Amiri	PEDCO	Process
Sepideh	Akbari	PEDCO	I&C Engineer
Sasan	Faramarzpour	PEDCO	Head of Process and Safety Department
Mehdi	Sadeghian	PEDCO	Surface Manager
Fereidoun	Noei	PEDCO	Process
Sadegh	Gharacheh	PEDCO	Process
Mohammad	Fakharian	Hirgan Energy	Project Manager
Masoud	Asgharnejad	Hirgan Energy	Engineering Manager
Mohsen	Aryafar	Hirgan Energy	Process
Parisa	Haji Sadeghi	Hirgan Energy	Head of I&C
Amir Hossein	Saber	Hirgan Energy	Process Safety
Faramarz	Mosayeb Nejad	Hirgan Energy	Piping
Farshad	Nourai	Consultant	HAZID Leader









شماره صفحه: 10 از 34



# عمومی و مشترک

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۵۳۰

	HAZID REPORT FOR WHF & FLOW LINES										
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه				
BK	SSGRL	PEDCO	110	GE	RT	0003	D00				
								_			

### 8.1 APPENDIX B -HAZARD CATEGORIES (ISO 17776)

Hazard Category
1. Hydrocarbons
2. Refined Hydrocarbons
3. Other Flammable Materials
4. Hazards Associated with Difference in Height
5. Environmental Hazards
6. Dynamic Situation Hazards
7. Open Flame
8. Electricity
9. Toxic Gases
10. Entrapment



# عمومی و مشترک







شماره پیمان:

.04 - . 14 - 4114

HAZID REPORT FOR WHF & FLOW LINES										
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	l		
BK	SSGRL	PEDCO	110	GE	RT	0003	D00			
								_		

شماره صفحه: 11 از 34

### 8.1 APPENDIX C – RECOMMENDATIONS LIST

Recommendations	Responsibility	Place(s) Used
Client insists on performing SIL verification on ESD system based on IEC 61511.	N-C	Consequences: 1.1.1.1
Contractor justification for not performing SIL verification will be submitted to Client subsequently.		
<ol><li>Ensure operators (end-user) to be present in the forthcoming 3D model review (90%).</li></ol>	N-C	Consequences: 1.1.3.1, 4.1.1.1
3. Consider LDAR program for operation phase.	N	Consequences: 1.1.4.1
<ol> <li>Verify whether or not automatic fire alarm for transformers in electrical buildings in wellhead areas are provided.</li> </ol>	С	Consequences: 2.2.1.1
<ol> <li>Prepare a cost-benefit analysis (CBA) report for increasing safety of transformers in wellhead area by replacing LVS with MVS and its requirements, acc. to PACS and considering ALARP area requirements.</li> </ol>	С	Consequences: 2.2.2.1
6. Study and report application and costs of providing F&G (H <sub>2</sub> and other detectors) acc. to PACS, regarding ALARP requirements and practical limitations and also referencing relevant SOW.	С	Consequences: 3.1.1.1, 8.2.1.2
<ol> <li>Plan for development of environmental contingency plans incl. communication with local meteorological institute.</li> </ol>	N	Consequences: 5.2.1.2, 8.1.1.2
8. Study application of latest water pollution minimization techniques and tools, including dispersant or anti-static agents and spill collection and containment equipment.	N	Consequences: 5.2.1.2
Provide sunshade for electrical motor of manifold area sump pump exposed to sunlight.	С	Consequences: 5.2.3.2
<ol> <li>Develop a procedure for minimizing site work in times of extreme environmental conditions and provide adequate and appropriate PPE.</li> </ol>	N	Consequences: 5.2.4.4
11. Include fire protection requirements for helipads at wellhead areas in Operating Manual.	С	Consequences: 6.2.1.1
12. In consultation with IRP vendor, consider separate discharge wells for electrical, lightning and instrumentation earthing systems with surge diverters.	С	Consequences: 8.1.1.1
13. Study application of RCPs in wellhead and manifold areas acc. to PACS and relevant SOW.	С	Consequences: 8.2.2.1
14. Ensure that armored LV cables, if any, are armored off and connected to earth system, as	С	Consequences: 8.2.3.1











# عمومی و مشترک

شماره پیمان:

 $\bullet \Delta T - \bullet V T - 91 \Lambda F$ 

HAZID REPORT FOR WHF & FLOW LINES											
پروژه	نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه										
BK SSGRL PEDCO 110 GE RT 0003 D											

شماره صفحه: 12 از 34

Recommendations	Responsibility	Place(s) Used
required by PACS.		
15. Plan for improving process safety culture, and effectiveness of training incl. H₂S awareness, and enforcing appropriate PPE.		Consequences: 9.1.1.1, 9.1.2.1, 9.2.1.1, 10.1.1.1
16. Check and report whether or not electrical and instrument cable covers in the existing Manifold Area Control Building are low-smoke type, subject to availability of documents.	С	Consequences: 10.1.1.2









### عمومي و مشترك

شماره پیمان: .04 - .74 - 9176

	HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه			
BK	SSGRL	PEDCO	110	GE	RT	0003	D00			

شماره صفحه: 13 از 34

#### 8.2 ATTACHMENT E - HAZID WORKSHEETS

Howard	Coupe	Concomuences	Risk Matrix		rix	Safeguards		Sofomundo		Risk Matrix		isk Matrix		Been
Hazard	Causes	Consequences	S	S L RR		Safeguards	S	L	RR	Recommendation	Resp.			
1. Gas and	1. Leakage due to	1.1. Fire and	1	В	Н	1.1.1. Material selection	3	С	M		N-C			
condensate	or rupture due to	explosion with possibility of				1.1.2. Corrosion coupons and probes in manifold area				performing SIL verification on ESD				
	TPD, etc.	injury/fatality				1.1.3. Corrosion allowance				system based on IEC 61511.				
						Minimizing dead points     and pockets in piping     design				Contractor justification for not performing SIL				
						1.1.5. Drain connections at dead points				verification will be submitted to Client				
						1.1.6. Maximum allowable fluid velocity to minimize erosion				subsequently.				
						1.1.7. Stone trap at wellhead area								
						1.1.8. Controlled entry of vehicles in wellhead area (fence) and manifold area								
						1.1.9. Access roads to flowlines have standard clearance to avoid TPD								
						1.1.10. Considerable								



# Déca Monde





# عمومی و مشترک

شماره پیمان:

.04 - .74 - 9176

HAZID REPORT FOR WHF & FLOW LINES									
سخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه									
BK	SSGRL	PEDCO	110	GE	RT	0003	D00		

شماره صفحه: 14 از 34

Hamand	0	0	Ris	k Mat	rix	Cofe monde	Ris	sk Ma	trix	Danaman dation	D
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						thickness of the flow lines acc. to their pressure class in case of physical damage					
						1.1.11. In manifold area, maximum available space is used for clearance					
						1.1.12. Fail safe design of WHCP in case of rupture					
						1.1.13. Fusible plugs on X- mas trees in wellhead area that initiate wellhead shutdown through WHCP					
						1.1.14. Manual shut down through WHCP push buttons					
						1.1.15. Paving is provided instead of gravel to minimize probability of explosion upon gas leakage					
						1.1.16. Slope and open drain connection for					



# Déca Monde





### عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۷۷۰ – ۵۳۰

	HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه							
BK	SSGRL	PEDCO	110	GE	RT	0003	D00							

شماره صفحه: 15 از 34

Harard	Course	C	Ris	k Mat	rix	Cafaguanda	Ris	k Ma	trix	December detion	Daan
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						collection and disposal of liquid leaks in X-mas tree cellar and peripheral area					
						1.1.17. Hazardous area classification					
						1.1.18. Portable and wheeled fire extinguishers and other necessary devices (fire shed for wellheads with IRP)					
						1.1.19. See also Entrapment category					
		1.2. Toxic release with possibility of fatality; see Toxic Gas category									
		1.3. Environmental	2	В	Н	1.3.1. Material selection	3	С	M		
		pollution				1.3.2. Corrosion coupons and probes in manifold area					
						1.3.3. Corrosion allowance					
						Minimizing dead points and pockets in piping design					
						1.3.5. Drain connections at					



# Déca Monde





### عمومي و مشترك

شماره پیمان:

.04 - .74 - 9176

	HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه							
BK	SSGRL	PEDCO	110	GE	RT	0003	D00							

شماره صفحه: 16 از 34

Harard	Causas	Component	Ris	k Mat	rix	Coformando	Ris	sk Ma	ıtrix	December detion	Dage
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						dead points					
						1.3.6. Maximum allowable fluid velocity to minimize erosion					
						1.3.7. Stone trap at wellhead area					
						1.3.8. Controlled entry of vehicles in wellhead area (fence) and manifold area					
						Access roads to     flowlines have standard     clearance to avoid TPD					
						1.3.10. In manifold area, maximum available space is used for clearance					
						1.3.11. Fail safe design of WHCP in case of rupture					
						1.3.12. Manual shut down through WHCP push buttons					
						Slope and open drain connection for collection and disposal					



# Déca Monde





### عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۵۳۰

	HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه							
BK	SSGRL	PEDCO	110	GE	RT	0003	D00							

شماره صفحه: 17 از 34

Harard	Courses	C	Ris	sk Ma	trix	Cafaguanda	Ris	k Ma	trix	December detion	Deen
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						of liquid leaks in X-mas tree cellar and peripheral area					
		1.4. Loss of product,	2	В	Н	1.4.1. Material selection	3	С	M		
		loss of production and damage to				1.4.2. Corrosion coupons and probes in manifold area					
		assets in case of fire/explosion,				1.4.3. Corrosion allowance					
		which also causes loss of reputation				1.4.4. Minimizing dead points and pockets in piping design					
		ropalation				1.4.5. Drain connections at dead points					
						Maximum allowable     fluid velocity to minimize     erosion					
						1.4.7. Stone trap at wellhead area					
						1.4.8. Controlled entry of vehicles in GCS					
						1.4.9. Controlled entry of vehicles in wellhead area (fence) and manifold area					
					· · · · ·	1.4.10. Access roads to flowlines have					



# عمومي و مشترك





شماره صفحه: 18 از 34



شماره پیمان: ۱۸۲۴ – ۱۸۷۳ – ۱۸۳۰

	HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سر يال	نسخه							
BK	SSGRL	PEDCO	110	GE	RT	0003	D00							

Hamand	0	0	Ris	sk Ma	trix	Cofemando	Ris	k Ma	trix	Danaman dation	D
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						standard clearance to avoid TPD  1.4.11. In manifold area, maximum available space is used for clearance  1.4.12. Fail safe design of WHCP in case of rupture  1.4.13. Manual shut down through WHCP push					
	See also     Environmental     Hazards category					buttons					
	Bad Operation or Maintenance due to human error	3.1. Extreme process conditions or overload of equipment, also damage due to impact and similar events, which leads to leakage and fire/explosion or toxic release	2	С	S	3.1.1. Operating manual 3.1.2. Maintenance requirements are foreseen in plant layout 3.1.3. Training for the operation phase 3.1.4. Level of automation to minimize human error	3	D	M	Ensure operators (end- user) to be present in the forthcoming 3D model review (90%).	N-C



# Déca Monde





# عمومی و مشترک

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۵۳۰

	HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه							
BK	SSGRL	PEDCO	110	GE	RT	0003	D00							

شماره صفحه: 19 از 34

Harand	Causas	Component	Ris	sk Ma	trix	Cafamuanda	Ris	k Ma	trix	December detion	Door
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
		3.2. See also HAZOP Report									
	4. VOC	4.1. Personnel exposure may cause chronic health problems and also environmental problem	3	В	S	4.1.1. Operational controls like training and PPE	3	С	M	Consider LDAR program for operation phase.	N
	5. Damage to pipeline due to surge; see HAZOP Report										
	See also Toxic Gas category										
	7. Dispersion of HC vapors upon draining into Open Drain in routine operations										



# Déca Monde





# عمومی و مشترک

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۰۵۳

	HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه							
BK	SSGRL	PEDCO	110	GE	RT	0003	D00							

شماره صفحه: 20 از 34

### **Hazard Category: 2. Refined Hydrocarbons**

11	0	0	Risk Matrix		trix	0-6	Risk Matı		Matrix Bosommondation		D
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
Diesel Fuel for Emergency Generator (only in wellheads with IRP, which	Leakage or spillage due to TPD	1.1. Environmental pollution due to soil contamination in case of spillage	3	В	S	1.1.1. Paved area	4	В	M		
are also manned)		1.2. Small local fire in case of ignition	3	С	M	1.2.1. Portable and wheeled type fire extinguishers are provided	4	С	L		
2. Transformer Oil (only in wellheads with IRP, which are also manned)	Leakage due to corrosion, TPD, maloperation, etc.	Local fire with     possibility of     damage to     transformer	4	С	L	1.1.1. Portable and wheeled fire extinguishers	4	С	L	<ol> <li>Verify whether or not automatic fire alarm for transformers in electrical buildings in wellhead areas are provided.</li> </ol>	С
	Transformer oil     evaporation due to     overcurrent	2.1. Severe damage to transformers	2	D	M	2.1.1. Buchholz relay and relief valve	3	D	M	5. Prepare a cost-benefit analysis (CBA) report for increasing safety of transformers in wellhead area by replacing LVS with MVS and its requirements, acc. to PACS and considering ALARP area requirements.	С
3. Hydraulic oil (WHCP)	Leakage due to TPD	Local fire with     possibility of     damage to	4	С	L	1.1.1. Portable and wheeled fire extinguishers     1.1.2. Fence is provided for	4	D	L		



# عمومي و مشترك









شماره پیمان: · ۵۳ - · ۷۳ - 9114

		HAZID REPO	RT FOR WE	IF & FLO	N LINES		
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D00

شماره صفحه: 21 از 34

### **Hazard Category: 2. Refined Hydrocarbons**

Hamand	0	0	Ris	sk Mat	trix	Coformando	Ris	k Ma	atrix	Danaman dation	Dann
Hazard	Causes	Consequences	S	L	RR	Safeguards	s	L	RR	Recommendation	Resp.
		WHCP				WHCP					
						1.1.3. Tubing is protected by trays					
						1.1.4. Separate reservoir for return oil from SSSV in case of gas mixed with hydraulic oil					

### **Hazard Category: 3. Other Flammable Materials**

Howard	Causas	Concomuences	Risk Ma		trix	Sofoguardo		Risk Matrix		- Decemmendation	Doon
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	لــ	RR	Recommendation	Resp.
Hydrogen in     Battery Room in     switchgear room     in wellheads     with IRP	, ,	1.1. Explosion and damage to Battery Room	2	В	Н	1.1.1. Explosion-proof exhaust fan and other electrical devices for hydrogen service in Battery Room	3	D	M	<ol> <li>Study and report application and costs of providing F&amp;G (H<sub>2</sub> and other detectors) acc. to PACS, regarding ALARP requirements and practical limitations and also referencing relevant SOW.</li> </ol>	С



# عمومی و مشترک





شماره صفحه: 22 از 34



شماره پیمان:

· ۵۳ - · ۷۳ - 9114

	HAZID REPO	ORT FOR WH	IF & FLO\	N LINES		
بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
SSGRL	PEDCO	110	GE	RT	0003	D00

Hazard Category: 4. Hazards Associated with Difference in Height

پروژه

BK

Honord	Courses	C	Ris	Risk Matrix Safeguards		Risk		Risk Matri		Risk Matrix Recommendation		Daan
Hazard	Causes	Consequences	S	L	RR	Sateguards	S	L	RR	Recommendation	Resp.	
. Personnel working at height or depth	1. Trip and fall	1.1. Personnel injury with possibility of fatality	1	С	Н	1.1.1. Platforms for maintenance are provided with adequate floor, access stairway or ladders with appropriate fall protection and handrails	2	D	M	Ensure operators (end- user) to be present in the forthcoming 3D model review (90%).	N-C	
						1.1.2. Monkey ladders for lighting fixtures						
						Access concrete     stairway for wellhead     cellars						
						1.1.4. Cages for monkey ladders on switchgear buildings, guard houses, potable water tank and diesel storage tank						
						1.1.5. Operational controls and PPE						
2. Overhead equipment and objects	1. Fall of load	1.1. Personnel injury with possibility of fatality, and also	1	С	Н	1.1.1. Toe boards are provided on platforms in case of hand tools, etc.	2	D	M			
		damage to equipment				1.1.2. Cross-over bridges on flow lines reduce impact from personnel movements						



# عمومی و مشترک







شماره پیمان:

پروژه

BK

۹۱۸۴ – ۲۷۰ – ۳۵۰

	HAZID REPO	RT FOR WH	IF & FLO	N LINES		
بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
SSGRL	PEDCO	110	GE	RT	0003	D00

شماره صفحه: 23 از 34

	Hanand	0	0	Risk Matrix Safeguards		Ris	k Ma	latrix Recommendation		D		
	Hazard	Causes	Consequences	S	L	RR	Sareguards	S	L	RR	Recommendation	Resp.
1	. Tectonic	1. Natural disasters like	5	1	В	Н	1.1.1. Geotechnical study	3	С	M		
		earthquake or other earth movement	equipment and possible				1.1.2. Seismic design acc. to PACS					
			injury/fatality for personnel				Operational controls like contingency plans, drills, etc.					
							1.1.4. For other safeguards, see Hydrocarbons category					
							1.1.5. For other safeguards, see Entrapment category					
			Possibility of spillage from flow lines or pipelines with subsequent	2	В	Н	1.2.1. For other safeguards, see Hydrocarbons category	3	С	M		
			pollution problems				1.2.2. Operational controls like contingency plans, drills, etc.					
2	. Weather	1. Flood	1.1. Damage to flow lines and	2	С	S	1.1.1. Environmental design data	4	Е	L		
			equipment due to flooding				1.1.2. Ground slope, ditches and trenches lead to open drain for surface					



# Déca Monde





# عمومی و مشترک

شماره پیمان: ۱۸۲۴ – ۱۸۷۳ – ۵۳۰ - ۵۳۰

		HAZID REPO	RT FOR WH	IF & FLO	W LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D00

شماره صفحه: 24 از 34

Harand	0	0	Risk Matr		rix	Coformando	Ris	k Ma	trix	December detion	D
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						run-off  1.1.3. Area topology reduces likelihood of wellhead area flooding	-				
						1.1.4. Diversion channel     1.1.5. Flood control study     based on hydrology     survey results					
						Reinforced flow lines     support for seasonal     rivers in project area					
		Possibility of soil     and water     pollution	2	С	S	1.2.1. Surface run-off leads to Waste Pit OSBL, which accommodates annual rainfall statistics	4	D	L	<ol> <li>Plan for development of environmental contingency plans incl. communication with local meteorological institute.</li> </ol>	N
										8. Study application of latest water pollution minimization techniques and tools, including dispersant or anti-static agents and spill collection and containment equipment.	N
		Soil pollution in burn pit either by	4	E	L	1.3.1. Environmental design data	4	D	L		



# Déca Mond





### عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۷۷۰ – ۵۳۰

		HAZID REPO	ORT FOR WH	IF & FLO\	N LINES		
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D00

شماره صفحه: 25 از 34

Howard	Course	C	Safeguards		Safaguards		k Ma	trix	Dagamman dation	Daam	
Hazard	Causes	Consequences	S	L	RR	Sareguards	S	L	RR	Recommendation	Resp.
		overflow in rain or penetration				1.3.2. Burn pit capacity					
	2. High winds, storm	Possibility of damage to plant	3	С	M	2.1.1. Environmental design data	4	D	L		
		equipment and injury to personnel				2.1.2. Mechanical design for buildings and structures/piping					
	Temperature extremes	3.1. Interference in performance of	2	В	Н	3.1.1. Environmental design data	3	С	M		
		instrumentation				3.1.2. Sunshade for WHCP to avoid impact by sunlight					
						3.1.3. Electrical and control cables are either run in ducts or trays					
		3.2. Damage or performance	3	Α	S	3.2.1. Environmental design data	4	В	M	Provide sunshade for electrical motor of	С
		reduction of sun- exposed electrical equipment				3.2.2. Electrical cables are either run in ducts or trays				manifold area sump pump exposed to sunlight.	
		3.3. Fatigue, injury and increased	3	Α	S	3.3.1. Environmental design data	4	В	M		
		risk of human error in case of maintenance				3.3.2. Operational controls and PPE					
		3.4. Reduced	2	В	Н	3.4.1. Environmental design	4	С	L		



# Déca Monde





# عمومی و مشترک

شماره پیمان: ۹۱۸۴ – ۷۲۰ – ۵۳۰

		HAZID REPO	RT FOR WH	IF & FLO\	N LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D00

شماره صفحه: 26 از 34

Harand	0	0	Risk Matrix		Cofemando	Risk Matrix		trix	D	D	
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
		performance or damage to A/C equipment, which may reduce performance of indoor instrumentation and other equipment				data 3.4.2. Sunshade is provided for A/C equipment					
	4. Dust	4.1. Damage to electrical equipment, instrumentation/telecom equipment	2	В		4.1.1. Environmental design data  4.1.2. IP protection of instrumentation, telecom and electrical enclosures	3	С	M		
		4.2. Reduced performance of Diesel Generators	3	В		<ul> <li>4.2.1. Environmental design data</li> <li>4.2.2. Intake Air Filter for Emergency Diesel Generators</li> <li>4.2.3. Emergency Diesel Generators operation is intermittent</li> </ul>	4	С	L		
		4.3. Reduced quality of conditioned air and damage to	3	С		4.3.1. Environmental design data 4.3.2. Inspection &	3	С	M		



# عمومی و مشترک







شماره پیمان: ۱۸۵۴ – ۷۷۳ – ۵۲۸

	HAZID REPORT FOR WHF & FLOW LINES										
پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه				
BK	SSGRL	PEDCO	110	GE	RT	0003	D00				

شماره صفحه: 27 از 34

### **Hazard Category: 5. Environmental Hazards**

Howard	Courses	Canaaniianaa	Ris	k Mat	trix	Coformando	Ris	k Ma	atrix	Dogger was detice	Resp.
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation R	
		A/C Compressors				maintenance procedures					
		4.4. Personnel injury and health problems and increased possibility of human error	2	В		4.4.1. Environmental design data 4.4.2. Operational controls and PPE	2	С	S	<ol> <li>Develop a procedure for minimizing site work in times of extreme environmental conditions and provide adequate and appropriate PPE.</li> </ol>	N

### **Hazard Category:** 6. Dynamic Situation Hazards









### عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۰۵۳

		HAZID REPO	RT FOR WH	IF & FLO\	N LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D00

شماره صفحه: 28 از 34

### **Hazard Category:** 6. Dynamic Situation Hazards

Howard	Course	Component	Ris	Risk Matrix		Safaanaada		Risk Matrix		Doggmandetien	Daan
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						1.1.5. Safety signs, incl. traffic					
						1.1.6. For other safeguards, see Hydrocarbons category					
Helicopter at wellhead areas	Ground impact,     especially during     landing	1.1. Damage to helicopter and possibility of fire/explosion and personnel injury/fatality	1	D		1.1.1. Area lighting in wellheads with IRP  1.1.2. Helipad design based on Iranian ICAO guidelines	1	E	M	<ol> <li>Include fire protection requirements for helipads at wellhead areas in Operating Manual.</li> </ol>	С

**Hazard Category: 7. Open Flame** 

	Hamand	0	0	Risk Matrix		trix	0-6		Risk Matrix		December detion	D
	Hazard	Causes	Consequences	S	L	RR	Safeguards	S L RR Recommendation		Recommendation	Resp.	
1	. Burn Pit	Exposure of grass in nearby area	1.1. Fire and subsequent pollution and injury to personnel and fauna	4	С	L	1.1.1. Operational controls like regular inspection and removal of excess grass  1.1.2. Burn pit location and clearance acc. to standard drawings and requirements	4	С	L		



# عمومی و مشترک









شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۰۵۳

		HAZID REPO	ORT FOR WE	IF & FLO	N LINES		
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D00

شماره صفحه: 29 از 34

	Hamand	0	0	Ris	k Mat	rix	Cofe weemda	Ris	k Ma	trix	Dogger and detical	Dann
	Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
1	Lightning Discharge	Local atmospheric conditions cause lightning strike	1.1. Damage to electrical equipment and instrumentation	1	В	H	1.1.1. Lightning arrester for wellhead areas with (electrical) IRP	3	D	M	12. In consultation with IRP vendor, consider separate discharge wells for electrical, lightning and instrumentation earthing systems with surge diverters.	С
			Personnel injury     with possibility of     fatality	1	С	Н	Lightning arrester for wellhead areas with (electrical) IRP      Operational controls	3	D	M	7. Plan for development of environmental contingency plans incl. communication with local	N
			1.3. Possibility of fire/explosion	1	В	Н	1.3.1. Lightning arrester for wellhead areas with (electrical) IRP	3	D	M	meteorological institute.	
							1.3.2. For safeguards, see Hydrocarbons category					
2	Electrical	Electrical fire and	1.1. In case of	2	С	S	1.1.1. Protection relays	3	D	M		
	equipment including but not limited to Diesel	explosion (indoors/outdoors)	outdoors, damage to electrical				Electrical and control cables are either run in ducts or trays					
	Generator, electric motor, panels, transformers,		equipment, which can lead to loss of production				Buried cables are less     sensitive to damage by     fire					
	dansionnois,						1.1.4. In manifold area, ESD					



# Déca Monde





### عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۷۷۰ – ۵۳۰

		HAZID REPO	ORT FOR WH	IF & FLO	N LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D00

شماره صفحه: 30 از 34

Howard	Course	Concominance	Risk Matrix Seferiorde Ri		rix	Risk Matrix	Dage
Hazard	Causes	Consequences	S	L	RR	Safeguards S L RR Recommendation	Resp.
AC/DC UPS, lighting towers and cables						cables are fire-resistant  .1.5. Electrical and control cables are flame retardant, except for lighting towers  .1.6. Fire protection in wellhead/manifold area in the form of ABC fire portable and wheeled extinguishers	
		1.2. In case of indoors, damage to electrical equipment; also, personnel injury with possibility of fatality	1	C	Н	extinguishers  2.1. Protection relays  2.2. ESD and F&G cables are fire-resistant in manifold area  2.3. Electrical and control cables are flame retardant in manifold area  2.4. Smoke and Heat-Smoke detectors in Manifold Area Control Room  2.5. Fire protection in Manifold Area Control Room and wellhead area buildings in the	C



# عمومی و مشترک







شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۰۵۳

	HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه			
BK	SSGRL	PEDCO	110	GE	RT	0003	D00			

شماره صفحه: 31 از 34

	Hamand	Course	Camaaa	Ris	sk Mat	rix	Cofoguerdo		Risk Matrix		trix	December detion	Doon				
	Hazard	Causes	Consequences	S	L	RR		Safeguards		L	RR	Recommendation	Resp.				
								form of ABC fire extinguishers									
		2. Electrocution	2.1. Personnel injury	1	С	Н	2.1.1.	Earthing	3	D	M	13. Study application of	С				
			with possibility of fatality					Protection relays				RCPs in wellhead and manifold areas acc. to					
			latality					Cable termination				PACS and relevant					
						2.1.4.	Limited exposure in electrical panels				SOW.						
						2.1.5.	Personnel protection earth relays in electrical										
								racks									
							2.1.6.	Existing plant clinic									
		3. Induction	3.1. Interference in performance of instrumentation	2	С	С	S	3.1.1.	Segregation between instrument and LV electrical cables	3	D	M	<ol> <li>Ensure that armoured LV cables, if any, are armoured off and</li> </ol>	С			
							3.1.2.	Instrument cables screen shields				connected to earth system, as required by					
											3.1.3.	3-core arrangement for electrical cables				PACS.	
								3.1.4.	EMC level of instrumentation								
							3.1.5.	Minimum safe distance between existing and new cables in case of crossings, to minimize EMC influence									



### عمومی و مشترک







Monde Salety

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۵۳۰

,	HAZID REPORT FOR WHF & FLOW LINES											
	پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه				
	BK	SSGRL	PEDCO	110	GE	RT	0003	D00				

شماره صفحه: 32 از 34

Hamand	0	Consequences	Risk Matrix			Safeguards		k Ma	atrix	Decemmendation	Boon
Hazard	Causes	Consequences	S	L	RR	Sareguards	S	L	RR	Recommendation	Resp.
	4. Power failure	4.1. Severe disturbance in production with risk of accidents, and also loss of production	1	A	Н	<ul> <li>4.1.1. Fail safe design of IRP pumps and ESD system at manifold area</li> <li>4.1.2. 100% redundancy in power supply through Emergency Diesel Generators, which supports LV relays, emergency lighting and DC UPS at wellhead areas</li> </ul>	3	D	M		
	5. Existing aerial HV line in case of crane operation; no major concern, as the line only crosses an access road and crane passes through the road in non-operational condition.										



# عمومي و مشترك





شماره صفحه: 33 از 34



شماره پیمان: · ۵۳ - · ۷۳ - 9114

	HAZID REPORT FOR WHF & FLOW LINES           نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D00		

**Hazard Category: 9. Toxic Gases** 

		Consequences	Risk Matrix		trix		Ris	k Ma	trix		Resp.
Hazard	Causes		S	L	RR	Safeguards	S	L	RR	Recommendation R	
1. H <sub>2</sub> S in Process Streams	1. Leakage	1.1. Personnel injury with possibility of	1	С	Η	1.1.1. Operational controls and PPE	2	D	M	<ol> <li>Plan for improving process safety culture,</li> </ol>	N
		fatality				1.1.2. Portable H₂S detector				and effectiveness of	
						1.1.3. For other safeguards, see Hydrocarbons category				training incl. H <sub>2</sub> S awareness, and enforcing appropriate PPE.	
						1.1.4. Safety signs for H <sub>2</sub> S service				11 L.	
	2. Burn pit flame out	2.1. Personnel injury with possibility of fatality	1	С	Н	2.1.1. Operational controls and PPE	2 D	D	M	<ol><li>Plan for improving process safety culture,</li></ol>	N
						2.1.2. Portable H₂S detector				and effectiveness of	
						2.1.3. For other safeguards, see Hydrocarbons category				training incl. H₂S awareness, and enforcing appropriate PPE.	
						2.1.4. Safety signs for H <sub>2</sub> S service				11 L.	
2. SO <sub>2</sub>	1. Burn pit	1.1. Personnel exposure may cause health problems and also environmental problem	3	С	M	1.1.1. Safety signs for toxic service	3	С	M	<ol> <li>Plan for improving process safety culture,</li> </ol>	N
						1.1.2. Operational controls and PPE				and effectiveness of training incl. H <sub>2</sub> S awareness, and enforcing appropriate PPE.	



# Déca Mondo





# عمومي و مشترك

شماره پیمان: ۱۸۲۴ – ۱۸۷۳ – ۵۳۰ - ۵۳۰

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D00		

شماره صفحه: 34 از 34

**Hazard Category: 10. Entrapment** 

		0	Risk Matrix		trix	Cofe weeds	Ris	sk Ma	trix	December detion	Dann			
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.			
1. Emergency	1. Limited access to	1.1. In case of	1	С	Н	1.1.1. Portable H <sub>2</sub> S detector	2	С	S	15. Plan for improving	N			
Case	escape routes	accidents in manifold and			1	1.1.2. Escape routes with safety signs				process safety culture, and effectiveness of				
		wellheads areas, personnel injury				1.1.3. Wind sock				training incl. H <sub>2</sub> S awareness, and				
	with possibility of fatality	with possibility of				1.1.4. Escape mask as regular PPE (not regularly used)				enforcing appropriate PPE.				
					1.1.5. SCBA									
					1.1.6. Photo-luminescent escape route signs in process area									
									1.1.7. For other safeguards, see Hydrocarbons category					
								1.1.8. For other safeguards, see Environment category						
		1.2. In case of accidents inside Manifold Area Control Building,	1	С	Н	1.2.1. Relatively small size of Manifold Area Control Building means quick access to exit door	2 C	С	S	16. Check and report whether or not electrical and instrument cable covers in the existing	С			
		personnel injury with possibility of fatality	f			1.2.2. For other safeguards, see Electricity category				Manifold Area Control Building are low-smoke type, subject to availability of documents.				