
	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
شماره پیمان:	MTO FOR PAGA	شماره صفحه ۱: از ۸																
۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>TE</td><td>MT</td><td>0004</td><td>D01</td></tr></table>	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	TE	MT	0004	D01	
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	TE	MT	0004	D01											

طرح نگهداشت و افزایش تولید ۲۷ مخزن

MTO FOR PAGA

نگهداشت و افزایش تولید میدان نفتی بینک



D01	Sep. 2022	IFI	H.Shakiba	M.Fakharian	M.Mehrshad	
D00	May. 2022	IFI	H.Shakiba	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 2

CLIENT Doc. Number: F8Z-709096

Status:



IDC: Inter-Discipline Check
 IFC: Issued For Comment
 IFA: Issued For Approval
 AFD: Approved For Design
 AFC: Approved For Construction
 AFP: Approved For Purchase
 AFQ: Approved For Quotation
 IFI: Issued For Information
 AB-R: As-Built for CLIENT Review
 AB-A: As-Built –Approved

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان:</p> <p>۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>MTO FOR PAGA</p> <table border="1"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>TE</td> <td>MT</td> <td>0004</td> <td>D01</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	TE	MT	0004	D01	<p>شماره صفحه: ۲ از ۸</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	TE	MT	0004	D01											

REVISION RECORD SHEET





PAGE	D00	D01	D02	D03	D04
1	X	X			
2	X	X			
3	X				
4	X				
5	X				
6	X	X			
7	X	X			
8		X			
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	MTO FOR PAGA							شماره صفحه : ۳ از ۸	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	TE	MT	0004	D01	

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	BILL OF MATERIAL LIST ERROR! BOOKMARK NOT DEFINED.	

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							 شرکت توسعه و پارسا سازی  HIRGAN ENERGY 	
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	MTO FOR PAGA							شماره صفحه : ۴ از ۸	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	TE	MT	0004	D01	

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.



With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields CLIENT (NISOC)
PROJECT:	Binak Oilfield Development – Surface Facilities; New Gas Compressor Station
EPD/EPC CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of : Hirgan Energy – Design & Inspection (D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC CONTRACTOR (GC) and approved by CLIENT (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by CLIENT rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR.
MAY:	Is used where a provision is completely discretionary.




 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	MTO FOR PAGA							شماره صفحه : ۵ از ۸	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	TE	MT	0004	D01	

2.0 GENERAL

- This document presents the item material requisitions for Contractor's use as appropriate.
- This material requisition covers the requirements for the design, manufacturing, testing and supply of **PAGA SYSTEM** as listed below.




The supplier shall supply Telephone System. The supplier shall include in the supply, all other equipment/devices/items not listed in the following, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.



 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							 HIRGAN ENERGY 
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	MTO FOR PAGA							شماره صفحه : ۶ از ۸
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	TE	MT	0004	D01

3.0 BILL OF MATERIAL LIST

Item	Description	Design	Unit	Remark
1	IP-Based PAGA Unit: Centralized Communication System for Intercom, PA and General Alarm Data Transmission through a Standard IP Ethernet-Network according to DIN EN 60849/VDE 0828 installed in 19" rack swing standalone WxHxD:800x2000x800 mm/ 40 HU, With 100mm Base, RAL 7035 Equipped with: - Controller - Power Module - 4x Amplifier Class D 19" 1x250W/100V (Total 1000 W in operation with considering N+1 Configuration) - Tone Generator Module - Zone selection module - 230VAC - 1x SIP link to PABX - Relay Contact with F&G - 1x AM/FM radio / CD / mp3 player 2HU/19" - Customized Software programmed & ready to site connection - SIP Interface to radio System - Service Laptop including software - MDF Terminal	1	Set	
2	Master Call Station: IP21, Desktop mounted including keyboard and Neck swan MIC	1	Set	
3	42 Unit Rack 800x800x2100 mm with full accessories and earth bar (Light, fan, power socket...)	1	Set	
4	LAN Switch Layer 2 , 24x 10/100/1000 Base T +2 SFP Module	1	Set	
5	Ceiling Loudspeaker: Flush Mounted Ceiling Loud speaker 5 watt at 100 V ,with matching transformer 1.5, 3, 5W, Frequency Range 70 Hz to 20 kHz , SPL 90 dB (1watt/1m) and SPL 96 dB (6w/1m)+local Jb	10	Set	CCR

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							 شرکت توسعه ترابریان 
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	MTO FOR PAGA							شماره صفحه: ۷ از ۸
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	TE	MT	0004	D01

Item	Description	Design	Unit	Remark
6	Indoor Horn Loudspeaker: Weather proof pressure chamber Loud speaker 15/25 watt at 100 V, Adjustable Sound level, Frequency Range, Frequency Range 300Hz to 6 kHz, with matching transformer 3,6,12W, SPL 108 dB (1watt/1m) and SPL 118 dB (12w/1m) , Pole mounting with Ushaped , <u>non-rusting stainless steel Bracket, IP54</u>	0	Set	
7	Weather Proof 25 watts: Weather proof pressure Loud speaker 25 watt at 100 V , Adjustable Sound level, Frequency Range 300Hz to 6 kHz, with matching transformer 6,12,25W, SPL 108 dB (1watt/1m) so it can be used in low power case too ,and SPL 121 dB (25w/1m),AL/ABS/fiber glass reinforced plastic enclosure , Pole mounting with <u>U-shaped, non-rusting stainless steel Bracket, IP65</u>	16	Set	Outdoor CGS Area
8	Weather Proof Flash Beacon , Yellow Color,5 Joule	8	Set	For noisy area
9	Weather proof Call Station: IP 65 Digital Explosion proof Call station <u>with Hood-</u> - Break Glass housing for the unit party line /speech key master/ conference cancellation keys, volume control functions, with speech memory <u>Equipped with 2m H.D.G pole</u>	2	Set	
10	HDG Pole seamless industrial Hot dipped Galvanized & base plate including adaptor for 4 speakers Note; The right height for Horn Loud Speakers pole is around 4 m High. More than this height the loss sound power will be high amount.	<div style="border: 1px solid black; padding: 2px; display: inline-block;">D01</div> 4	Set	
11	Outdoor Metal box for Intercom Station, Weather proof, IP65 ,with all required explosion proof cable glands For <u>5Px0.9mm2 cable And required terminal</u> , 2X M20 Gland and Terminal mounting accessories and blind plug	2	Set	
12	Outdoor Metal Type WP PJB for Loud speakers , with all required cable glands, mounting accessories and blind plug 10 xM20 Gland and Terminal	4	Set	

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	MTO FOR PAGA							شماره صفحه: ۸ از ۸	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	TE	MT	0004	D01	

Item	Description	Design	Unit	Remark
13	<p>Indoor AL material PJB for Paging, IP42, with all required cable glands .Capable to install inside the building Minimum 2x M25 Gland Bottom and 5 No.M20 Gland in Top and Terminal</p>	1	Set	