



نگهداشت و افزایش تولید میدان نفتی بینک
 فعالیت های روزمینی در بسته های کاری تحت الارض
 عمومی و مشترک



شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
D00	0007	CN	EL	110	PEDCO	SSGRL	BK

شماره صفحه: ۱ از ۲۱

طرح نگهداشت و افزایش تولید ۲۷ مخزن

CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS

نگهداشت و افزایش تولید میدان نفتی بینک

D01	Oct.2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D00	Apr.2022	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
Class: 2		CLIENT Doc. Number: F0Z-707383				

Status:

- IDC: Inter-Discipline Check
- IFC: Issued For Comment
- IFA: Issued For Approval
- AFD: Approved For Design
- AFC: Approved For Construction
- AFP: Approved For Purchase
- AFQ: Approved For Quotation
- IFI: Issued For Information
- AB-R: As-Built for CLIENT Review
- AB-A: As-Built -Approved



نگهداشت و افزایش تولید میدان نفتی بینک
 فعالیت های روزمینی در بسته های کاری تحت الارض
 عمومی و مشترک



شماره پیمان:

CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS

۰۵۳ - ۰۷۳ - ۹۱۸۴



پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	SSGRL	PEDCO	110	EL	CN	0007	D00

شماره صفحه: ۲ از ۲۱

REVISION RECORD SHEET



PAGE	D00	D01	D02	D03	D04
1	X	X			
2	X	X			
3	X	X			
4	X	X			
5	X	X			
6	X	X			
7	X	X			
8	X	X			
9	X	X			
10	X	X			
11	X	X			
12	X	X			
13	X	X			
14	X	X			
15	X	X			
16	X	X			
17	X	X			
18	X	X			
19	X	X			
20	X	X			
21		X			
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" style="width: 100%; text-align: center;"> <tr> <td>نسخه</td> <td>سریال</td> <td>نوع مدارک</td> <td>رشته</td> <td>تسهیلات</td> <td>صادر کننده</td> <td>بسته کاری</td> <td>پروژه</td> </tr> <tr> <td>D00</td> <td>0007</td> <td>CN</td> <td>EL</td> <td>110</td> <td>PEDCO</td> <td>SSGRL</td> <td>BK</td> </tr> </table>	نسخه	سریال	نوع مدارک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D00	0007	CN	EL	110	PEDCO	SSGRL	BK	<p>شماره صفحه: ۳ از ۲۱</p>
نسخه	سریال	نوع مدارک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه											
D00	0007	CN	EL	110	PEDCO	SSGRL	BK											

CONTENTS

1.0	INTRODUCTION	4
2.0	SCOPE	5
3.0	NORMATIVE REFERENCES.....	5
3.1	LOCAL CODES & STANDARD	5
3.2	THE PROJECT DOCUMENTS.....	5
3.3	ENVIRONMENTAL DATA	6
3.4	ORDER OF PRECEDENCE	6
4.0	DEFINITION.....	6
4.1	EARTH WELL	6
4.2	EARTH ROD.....	6
4.3	EARTH CONDUCTOR.....	6
4.4	MAIN EARTH CONDUCTOR.....	7
4.5	EARTHING SYSTEM.....	7
4.6	EXPOSED CONDUCTIVE PART	7
4.7	EXTRANEOUS CONDUCTIVE PART.....	7
4.8	EQUIPOTENTIAL BONDING.....	7
4.9	NEUTRAL CONDUCTOR	7
4.10	EARTHING VOLTAGE.....	7
4.11	EARTH FAULT CURRENT	7
4.12	REFERENCE EARTH.....	8
5.0	GENERAL CONCEPTION EARTHING	8
5.1	MAIN EARTH CONDUCTOR.....	8
5.2	EARTH WELL	8
5.3	EARTH BAR	8
5.4	EARTH CONDUCTOR.....	8
5.5	EQUIPMENT TO BE EARTHED	8
6.0	SOIL RESISTIVITY	9
7.0	CONDUCTOR SIZING	11
7.1	SELECTION OF AN EARTHING CONDUCTOR FOR TRANSFORMER NEUTRAL POINT	11
7.2	SELECTION OF AN EARTHING CONDUCTOR FOR MAIN EARTHING LOOP AT SITE.....	12
7.3	EARTHING SYSTEM CALCULATION FOR WELL AREA.....	12
7.4	CLEAN EARTH FOR CONTROL ROOM IN MANIFOLD AREA	14
7.5	EQUIPMENT EARTHING CONDUCTOR SIZING	15
8.0	LIGHTNING PROTECTION SYSTEM	16
8.1	CALCULATION METHOD (SIMPLIFIED RISK ASSESSMENT).....	16
8.2	LIGHTNING PROTECTION SYSTEM CALCULATION	21

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" data-bbox="368 387 1198 454"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه: ۴ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.



With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, construction of well location, access roads, wellhead facilities for 6 new wells (with electric power supply for 2 of them) and required modifications on 4 workover wells (with electric power supply) shall be done. In addition, construction of 6 new flowlines from new wells to Binak B/C unit (with extension of relevant manifold) is in the Project scope of work.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – Construction of New Well Locations, Modifications on Workover Wells, Wellhead Facilities, Electrification Facilities, Flowlines and Extension of Binak B/C Manifold
EPD/EPC CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of : Hirgan Energy – Design & Inspection (D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC CONTRACTOR (GC) and approved by CLIENT (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" data-bbox="368 387 1198 454"> <tr> <th>پروژه</th> <th>بسته کاری</th> <th>صادر کننده</th> <th>تسهیلات</th> <th>رشته</th> <th>نوع مدرک</th> <th>سریال</th> <th>نسخه</th> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه : ۵ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by CLIENT rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR.
MAY:	Is used where a provision is completely discretionary.

2.0 SCOPE

This document covers minimum necessary requirements for the design, selection, manufacture, inspection, testing and delivery of Earthing System.

It shall be used in conjunction with data/requisition sheets for present document subject.

3.0 NORMATIVE REFERENCES





9.2.1 LOCAL CODES & STANDARD

- BS 7430:2011+A1:2015 Code of practice for protective earthing of electrical installations
- IEC 60364 Electrical installation of buildings
- IEC 60621 Electrical installation for outdoor sites under heavy conditions
- IEC 60724 Short circuit temperature limits of electric cables
- BS 6651 Protection of structures against lightning
- IPS E-EL-100(1) Engineering standard for electrical system design
- NFPA 780 Standard for installation of lightning protection system

9.2.2 THE PROJECT DOCUMENTS

- BK-W007S-PEDCO-110-GT-RT-0001 Geotechnical Investigation Report - W007S
- BK-BK14-PEDCO-110-GT-RT-0001 Geotechnical Investigation Report - BK14
- BK-BK12-PEDCO-110-GT-RT-0001 Geotechnical Investigation Report - BK12
- BK-BK15-PEDCO-110-GT-RT-0001 Geotechnical Investigation Report - BK15
- BK-W046S-PEDCO-110-GT-RT-0001 Geotechnical Investigation Report - W046S
- BK-BK05-PEDCO-110-GT-RT-0001 Geotechnical Investigation Report - BK05
- BK-SSGRL-PEDCO-110-EL-PY-0010 Earthing & Lightning Layout for Well Pads

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" data-bbox="363 383 1198 448"> <tr> <th>نسخه</th> <th>سریال</th> <th>نوع مدارک</th> <th>رشته</th> <th>تسهیلات</th> <th>صادر کننده</th> <th>بسته کاری</th> <th>پروژه</th> </tr> <tr> <td>D00</td> <td>0007</td> <td>CN</td> <td>EL</td> <td>110</td> <td>PEDCO</td> <td>SSGRL</td> <td>BK</td> </tr> </table>	نسخه	سریال	نوع مدارک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D00	0007	CN	EL	110	PEDCO	SSGRL	BK	<p>شماره صفحه : ۶ از ۲۱</p>
نسخه	سریال	نوع مدارک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه											
D00	0007	CN	EL	110	PEDCO	SSGRL	BK											

9.2.3 ENVIRONMENTAL DATA

- BK-GNRAL-PEDCO-000-PR-DB-0001 Process Basis of Design

9.2.4 ORDER OF PRECEDENCE

In case of conflict between requirements specified herein & the requirements of any other referenced document, the most approved stringent requirements of below listed items shall be considered based on the approval given by the owner's representative:

- Purchase order
- Material Requisition
- MTO & Data Sheet
- This Specification
- Drawing & Other Specification
- Reference Project Specification
- Iranian Petroleum Standard (IPS)
- Reference international Code & Standards

When the term "Authorized", "Authorization", "Approval", or "Approved" are used in this specification, it shall mean authorization or Approval from OWNER.

In case of any conflict between the project documents, the most stringent one shall be considered.

4.0 DEFINITION

9.2.5 EARTH WELL



Earth well shall consist of a 0.7*0.7 square meter copper plate with thickness 3mm which should be set vertically underground to depth where receive wet organics soil.

9.2.6 EARTH ROD

1.5 meter copper rod embedded in ground and electrically connects to it.

9.2.7 EARTH CONDUCTOR

A conductor that connects parts of the installation to main earth conductor and the main earth conductor to the earth well.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" data-bbox="368 383 1193 448"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدارک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدارک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه: ۷ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدارک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

9.2.8 MAIN EARTH CONDUCTOR

A conductor which makes a ring loop in a room or electrical substations or process plants to which several earth conductors are connected.

9.2.9 EARTHING SYSTEM

A locally confined assemblage of earth wells or metal components and earth conductors, electrically connected together.

9.2.10 EXPOSED CONDUCTIVE PART

A conductive part of equipment which can be touched and which is not a live part but may become live under faulty condition.

9.2.11 EXTRANEOUS CONDUCTIVE PART

A conductive part liable to introduce a potential, generally earth potential, and not forming part of the electrical installation.

9.2.12 EQUIPOTENTIAL BONDING

Electrical connection maintaining various exposed conductive parts and extraneous conductive parts at substantially the same potential.

9.2.13 NEUTRAL CONDUCTOR

A conductor connected to the neutral point of a system and capable of contributing to the transmission of electrical energy.



9.2.14 EARTHING VOLTAGE

E_u is the voltage which occurs between an earthing installation and a reference earth.

9.2.15 EARTH FAULT CURRENT

If is the current passing to earth or earthed parts when an earth fault exists at only one point at the site of the fault (earth fault location). This is:

- I) The capacitive earth fault current I_C with networks with isolated neutral.
- II) The earth fault residual current I_{Rest} in networks with earth fault compensation.
- III) The Earth fault current I''_{k1} in networks with low resistance neutral earthing. Also includes networks with isolated neutral point or earth fault compensators in which the neutral point is briefly earthed at the start of the fault.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" data-bbox="368 387 1193 454"> <tr> <th>نسخه</th> <th>سریال</th> <th>نوع مدرک</th> <th>رشته</th> <th>تسهیلات</th> <th>صادر کننده</th> <th>بسته کاری</th> <th>پروژه</th> </tr> <tr> <td>D00</td> <td>0007</td> <td>CN</td> <td>EL</td> <td>110</td> <td>PEDCO</td> <td>SSGRL</td> <td>BK</td> </tr> </table>	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D00	0007	CN	EL	110	PEDCO	SSGRL	BK	<p>شماره صفحه: ۸ از ۲۱</p>
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه											
D00	0007	CN	EL	110	PEDCO	SSGRL	BK											

9.2.16 REFERENCE EARTH

Reference earth or neutral earth, is that part of the earth, particularly surface outside the area of influence of an earth electrode or an earthing system, in which there are no detectable voltages resulting from the earthing current between any two random points.

5.0 GENERAL CONCEPTION EARTHING

9.2.17 MAIN EARTH CONDUCTOR

Insulated stranded copper conductors to be embedded in the soil. This earth conductor will make the main earthing system layout to carry the main earth fault current to earth wells and provide the major safety for operators. This conductor will run among the whole site and will interconnect all earthing wells and sub-systems via a loop.

For achieving more reliability the connection of main earthing conductor to the earthing of a building will be via a ring the buildings. The ring should be installed in a cable gallery.

9.2.18 EARTH WELL

Two earth wells will be installed and connected to main earthing conductor.

9.2.19 EARTH BAR

A 6-way copper earth bar can be installed wherever various earthing conductors should be connected to each other (e.g. Earth well to the main earthing conductor or neutral conductor).



9.2.20 EARTH CONDUCTOR

Above-ground earthing conductor shall be insulated stranded copper conductor. For switchgears, the earthing conductor shall be sized, based on the maximum short circuit current to earthing system i.e. In this project maximum short circuit current is 68 KA. So this fault current should be considered in calculation of earth conductors.

Short circuit analysis will be attached after finalizing in next revision.

9.2.21 EQUIPMENT TO BE EARTHED

- All crane runways shall be earthed on both ends.
- All MV- and LV switchgear should be earthed.
- Steel structures (welded or screwed) should be interconnected to each other (e.g. staircases with railings) and common earth. The minimum size of earth bridges is 50mm² stranded copper conductors.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" data-bbox="363 383 1198 448"> <thead> <tr> <th>نسخه</th> <th>سریال</th> <th>نوع مدرک</th> <th>رشته</th> <th>تسهیلات</th> <th>صادر کننده</th> <th>بسته کاری</th> <th>پروژه</th> </tr> </thead> <tbody> <tr> <td>D00</td> <td>0007</td> <td>CN</td> <td>EL</td> <td>110</td> <td>PEDCO</td> <td>SSGRL</td> <td>BK</td> </tr> </tbody> </table>	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D00	0007	CN	EL	110	PEDCO	SSGRL	BK	<p>شماره صفحه : ۹ از ۲۱</p>
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه											
D00	0007	CN	EL	110	PEDCO	SSGRL	BK											

- Conveyors will be earthed at their entering points to the buildings (inside of building).
- Any mobile electrical equipment (conveyor,...) shall be connected to the earth by earthing tong before operation.
- All LV equipment like MCC panels or distribution boards with metallic covers, doors or walls shall be connected to earth.
- The fixing bolts of the apparatus and structures may not be used for the fixing of earthing wire. If there are no earthing screws, the connection of earthing wire have to be done by means of a hexagonal screw of minimum size M10 welded or screwed to a metallic body of equipment.
- To avoid spark discharges due to either electrostatic charge inside the system or lightning stroke, steel structures and equipment's piping are to be earthed.
- All motor frames and their local control box with metallic covers shall be earthed by earthing conductors separately.
- Vertical beams around structures with height up to 20m shall be earthed at maximum intervals of 20m. For higher structures, maximum interval is 10m.
- The steel structure of all cable trays and ladders installed in the plant should be earthed. The cable ladders shall form a continuous electrically conductive part. Where necessary, the cable ladders must be electrically bridged.
- All cable ladder runs should be earthed with interval connection 20 m.
- All the tanks shall be earthed and bonded earth.

6.0 SOIL RESISTIVITY

D01

Soil resistivity measurement has been done by BARAN Geotechnical Company for several points of the site as below:



نگهداشت و افزایش تولید میدان نفتی بینک
 فعالیت های روزمینی در بسته های کاری تحت الارض
 عمومی و مشترک




شماره پیمان:

CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS


شماره صفحه: ۱۰ از ۲۱

۰۵۳ - ۰۷۳ - ۹۱۸۴

پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	SSGRL	PEDCO	110	EL	CN	0007	D00



There are 6 wells with code number BK-05, BK-12, BK-14, BK-15, W-046S, and W-007S. For each well some points for measurement of earth resistance has been chosen. The average of earth resistance for each well has been shown in Table "1".





The below table has been extracted from ten Geotechnical Investigation Reports:

TABLE "1": ELECTRICAL TEST RESISTIVITY RESULT

WELL NO.	DOCUMENT NO.	AVERAGE P _A (ΩM) IN DEPTH OF 3 METER
BK-05	BK-BK05-PEDCO-110-GT-RT-0001	120.9
BK-12	BK-BK12-PEDCO-110-GT-RT-0001	89.74
BK-14	BK-BK14-PEDCO-110-GT-RT-0001	89.17
BK-15	BK-BK15-PEDCO-110-GT-RT-0001	69.23
W-046S	BK-W046S-PEDCO-110-GT-RT-0001	88.06
W-007	BK-W007S-PEDCO-110-GT-RT-0001	57.37

According to Table "A" for all wells except BK-5, the average resistance in depth of 3 meter approximately is 90 ohm per meter. For well BK-05, the resistance is 120 ohm per meter.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه: ۱۱ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

7.0 CONDUCTOR SIZING

9.2.22 SELECTION OF AN EARTHING CONDUCTOR FOR TRANSFORMER NEUTRAL POINT

The minimum cross-section of earthing conductor for earthing neutral point of transformer and main earthing of around substation is calculated with below formula according to BS 7430:2015.

$$S = I \frac{\sqrt{t}}{K} (\text{mm}^2)$$

Where:

- I: is the average fault current, in A r.m.s.;
- t: is the fault current duration, in s.;
- K: is the current density in amperes per square millimeter r.m.s.;(Table 4:BS 7430)

For other initial and final temperatures the current density K for a 1 s duration may be obtained from the following equation:

$$K = K' \left[\ln \left(\frac{T_2 + \beta}{T_1 + \beta} \right) \right]^{1/2} (\text{A/mm}^2)$$

Where:

- T2: Final temperature in °C
- T1: Initial temperature in °C (max. ambient temp.)
- K' & β: Coefficients as **Error! Not a valid bookmark self-reference.7** of BS 7430

Table 2 – K' Coefficient for different materials (according to BS 7430-Table 7)

Metal	K' A/mm ² (rms)	β
Copper	226	234.5
Aluminum	148	228
Steel	78	202

- T2 = 160 °C for PVC insulation cables (Table 1: IEC 60724)
- T2 = 160 °C for PVC insulation cables (Table 1: IEC 60724)

So, the r.m.s current density (K) for PVC insulation cables will be:

$$K = K' \left[\ln \left(\frac{T_2 + \beta}{T_1 + \beta} \right) \right]^{1/2} = 226 \left[\ln \left(\frac{160 + 234.5}{30 + 234.5} \right) \right]^{1/2} \cong 142.3 (\text{A/mm}^2)$$



So the used values are as below:

Isc= 50 kA (According to ETAP study)

t = 0.5 s

K= 142.3



	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p style="text-align: center;">CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه: ۱۲ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

$$S_{\min} = 50kA \times \frac{\sqrt{0.5}}{142.3} = 248.4 \approx 300 \text{ mm}^2$$

300 mm² PVC insulated copper conductor will be applied for neutral point of transformers earthing.

9.2.23 SELECTION OF AN EARTHING CONDUCTOR FOR MAIN EARTHING LOOP AT SITE

The minimum cross-section of earthing conductor for main earthing loop is calculated with below formula according to BS 7430:2015.

$$S = I \frac{\sqrt{t}}{K} (\text{mm}^2)$$

Where:

- I: is the average fault current, in A r.m.s.;
- t: is the fault current duration, in s.;
- K: is the current density in amperes per square millimeter r.m.s. (Table 4: BS 7430)
- So the used values are as below:
- I_{sc} = 16 kA (According ETAP result)
- t = 0.5 s
- K = 159

$$S_{\min} = 16kA \times \frac{\sqrt{0.5}}{159} = 71 \approx 70 \text{ mm}^2$$



Therefore, 70 mm² **bare copper conductor** will be applied for earthing system around site.

EARTHING SYSTEM CALCULATION



9.2.24 EARTHING SYSTEM CALCULATION FOR WELL AREA

Refer to section 9.5.5 of BS 7430, the approximate resistance to earth of a round conductor can be calculated from the following:

$$R_t = \frac{\rho}{2\pi L} \ln \left(\frac{L^2}{khd} \right)$$

Where:

- ρ: is the resistivity of the soil in Ω.m
- L: is the length of the strip or conductor, in metres (m)
- h: is the depth of the buried, in metres (m)

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS	شماره صفحه: ۱۳ از ۲۱																
	<table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

- d: is the width of the strip or the diameter of the round conductor, in metres (m);
- k: has the value 1.36 for strip or 1.83 for round conductor.
- R_t is the resistance of a single strip of length L, calculated from the preceding R_t equation, in ohms (Ω).

When two or more straight lengths, each of length L in metres (m) and a separation distance s metres (m) are laid parallel to each other and connected together at one end only the combined resistance may be calculated from the following equation:

$$R_n = FR_t$$

Where:


- R_n is the resistance of n conductors in parallel, in ohms (Ω)

F has the following value:

$$\text{For two lengths, } F = 0.5 + 0.078 \times \left(\frac{s}{L}\right)^{-0.307}$$

$$\text{For three lengths, } F = 0.33 + 0.071 \times \left(\frac{s}{L}\right)^{-0.408}$$



$$\text{For four lengths, } F = 0.25 + 0.067 \times \left(\frac{s}{L}\right)^{-0.451}$$



Based on explanation on table "A", soil resistance of all wells is 90 $\Omega \cdot m$ except 120 $\Omega \cdot m$

Calculation of Earth in Different Wells

Item	Well BK-12, BK-14, BK-15, W-046S & W-007S	Well BK-05
ρ	90 $\Omega \cdot m$	90 $\Omega \cdot m$
L	130 m	130 m
W	40	40
h	0.6 m	0.6 m
d	$\sqrt{\frac{70 \times 4}{\pi}} = 9.44 \text{ mm}$	$\sqrt{\frac{70 \times 4}{\pi}} = 9.44 \text{ mm}$
K	1.83	1.83
R_t	$\frac{90}{2 * 3.14 * 130} \ln\left(\frac{130^2}{1.83 * 0.6 * 0.00944}\right) = 1.58 \Omega$	$\frac{120}{2 * 3.14 * 130} \ln\left(\frac{130^2}{1.83 * 0.6 * 0.00944}\right) = 2.1 \Omega$
F_2	$0.5 + 0.078 \times \left(\frac{40}{130}\right)^{-0.307} = 0.612$	$0.25 + 0.067 \times \left(\frac{40}{130}\right)^{-0.451} = 0.364$
$R_t = FR_n$	$1.58 \times 0.612 = 0.965$	$2.1 \times 0.364 = 0.765$

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه: ۱۴ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

9.2.25 CLEAN EARTH FOR CONTROL ROOM IN MANIFOLD AREA

Around existing control room, clean earth is required for instrument system, the earthing resistance shall be below 0.5Ω. Regarding to achieve this resistance using rod electrode with 1 meter length and 19 mm² diameter rod based on BS 7430 section 9.5.8.5 around control room is done as below: The average of soil resistance in depth of 1 meter is almost 6.7 based on document No." BK-GCS-PEDCO-120-EL-CN-0006-D01", so it should be considered for calculating clean earth system as well.

$$R_{rod} = \frac{\rho}{2\pi L} \times \left[\ln\left(\frac{8L}{d}\right) - 1 \right]$$

Where:

L: is the length of electrode in (m)

d: is the diameter of the electrode in (m)

ρ: The resistivity of the soil (Ω.m)

$$R_{rod} = \frac{6.7}{2 \times \pi \times 1} \times \left[\ln\left(\frac{8 \times 1}{0.019}\right) - 1 \right] = 5.37 \Omega$$

The combine resistance of 'N' rod electrodes in parallel can be obtained from the following equation (BS 7430-2011-table2):

Table 2 Factors for vertical electrodes arranged in a hollow square

Number of electrodes (n) along the side of the square	Factor λ	Number of electrodes (n) along the side of the square	Factor λ
2	2.71	9	7.65
3	4.51	10	7.90
4	5.46	12	8.22
5	6.14	14	8.67
6	6.63	16	8.95
7	7.03	18	9.22
8	7.30	20	9.40

NOTE The number of electrodes around the square is 4(n - 1).

$$R_n = R \left[\frac{1 + \lambda a}{N} \right]$$

In Which



$$a = \frac{\rho}{2\pi R_s}$$

R_n: is the resistance of 'n' rods in Hollow Square in 'Ω'

R: is the resistance of one rod in 'Ω'

s : is the spacing of rods, in meters (m);=10



	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه: ۱۵ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

λ : is a factor given in above table

N: is the number of rods used as electrodes ($N=4*(n-1)$) $n=4$ and $N=12$

$$a = \frac{6.7}{2 \times \pi \times 5.37 \times 10} = 0.02$$

Therefore:

$$R_n = 5.37 \left[\frac{1.75 \cdot 46 \times 0.02}{12} \right] = 0.496 \Omega \text{ (Calculated value } R_n \text{ is lower than criterion, } 0.5 \Omega \text{)}$$



So all instrument facilities should be connected to clean earth system.

9.2.26 EQUIPMENT EARTHING CONDUCTOR SIZING

According to IPS-D-EL-417, all steel structures in site shall be earthed with Green-Yellow PVC insulated stranded copper wire. Earthing conductor which is applied to the exposed conductive part shall be selected from following table:

Number of Metallic Earthing Connection

Equipment	Remark	No. of Grounding Points	Grounding Conductor Size (sq.mm.)
Tank or Storage	≤ 10 m in diameter	2	35
	>10 m in diameter	One connection at maximum 30 m interval along the perimeter of the tank	35
Tower	<20 m in height	1	35
	≥20 m in height	2	35
Drum		1	35
Heat Exchanger		1	16
Steel Structure		2	70 or 35
Pipe Rack		Every 30 m (Min. 2)	70
Pipe		In Accordance with Layout	16
Ladder & Stairways		In Accordance with Layout	35

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>نسخه</td> <td>سریال</td> <td>نوع مدرک</td> <td>رشته</td> <td>تسهیلات</td> <td>صادر کننده</td> <td>بسته کاری</td> <td>پروژه</td> </tr> <tr> <td>D00</td> <td>0007</td> <td>CN</td> <td>EL</td> <td>110</td> <td>PEDCO</td> <td>SSGRL</td> <td>BK</td> </tr> </table>	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D00	0007	CN	EL	110	PEDCO	SSGRL	BK	شماره صفحه: ۱۶ از ۲۱
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه											
D00	0007	CN	EL	110	PEDCO	SSGRL	BK											

Number of Electrical Earthing Connection

Electrical Equipment	Remark	No. of Grounding Points	Grounding Conductor Size (sq.mm.)
Transformer	Body	1	70 (min.)
Medium Voltage & High Voltage Switchgear	Switchgear	2	120 (min.)
	Lightning Arrestor	1	70
Low Voltage Switchgear, MCC or Panels	-	In Accordance with Layout	185 (min.)
Local Control Station	-	1	16
Local lighting/Small Power Distribution Boards	-	1	35
Motor	Up to 22kW	1	16
	23kW to 55kW	1	35
	More than 56kW	1	70
Welding Outlet	-	1	35
Main Loop	-	In Accordance with Layout	70
Substation Loop	-	In Accordance with Layout	300

8.0 LIGHTNING PROTECTION SYSTEM



9.2.27 CALCULATION METHOD (SIMPLIFIED RISK ASSESSMENT)

Regarding to BS 6651 standard, at first we have to calculate the risk assessment of lightning which may be occur. If the risk is high according to NFPA780 standard, lightning protection system shall be considered.

9.2.28 AVERAGE LIGHTNING FLASH DENSITY

According to below map, approximately 15 thunderstorm days per year is expected for site location.

Average lightning flash density (N_g) will be estimated from following equation according to BS EN 62305-2-2012



$$N_g = 0.1(T_d)$$

Where:

T_d : Thunderstorm days per year

So:

$$N_g = 0.1 \times (15) = 1.5$$

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روز زمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدارک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدارک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه: ۱۷ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدارک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											




Figure A: Lightning isochrones map of Iran

9.2.29 ANNUAL THREAT OF OCCURRENCE

The yearly annual threat of occurrence (lightning strike frequency) (N_d) to a structure is determined by the following equation:

$$N_d = N_g \times A_e \times C_1 \times 10^{-6}$$

Where:

N_d = yearly lightning strike frequency to the structure or object



N_g = lightning ground flash density in flashes/km²/year

A_e = the equivalent collection area of the structure (m²)

C_1 = environmental coefficient


9.2.30 EQUIVALENT COLLECTION AREA

It is an area adjusted for the structure that includes the effect of the height and location of the structure.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	شماره صفحه: ۱۸ از ۲۱
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

The equivalent collection area of a rectangular structure with length L, width W, and height H is as follows:

$$A_e = (L \times W) + 6 \times H \times (L + W) + \pi \times 9 \times H^2$$



Where:

A_e = equivalent collection area of the building in m²

L = length of the building in meter



W = Width of the building in meter

H = Height of the building in meter.

9.2.31 ENVIRONMENTAL COEFFICIENT (C1)

The location factor accounts for the topography of the site of the structure and any objects located within the distance 3H from the structure that can affect the collection area.

Location factors are given in below Table:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک																	
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS	شماره صفحه: ۱۹ از ۲۱																
	<table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

Relative Structure Location	C_1
Structure surrounded by taller structures or trees within a distance of $3H$	0.25
Structure surrounded by structures of equal or lesser height within a distance of $3H$	0.5
Isolated structure, with no other structures located within a distance of $3H$	1
Isolated structure on hilltop	2

NFPA 780 - Table L.4.2- Location Factor, C_1

9.2.32 SIMPLIFIED RISK ASSESSMENT

Simplified risk assessment calculates the tolerable lightning frequency (N_c) and compares it to the annual threat of occurrence (N_d). The tolerable lightning frequency (N_c) is a measure of the risk of damage to the structure, including factors affecting risks to the structure, to the contents, and of environmental loss. It is calculated by dividing the acceptable frequency of property losses by various coefficients relating to the structure, the contents, and the consequence of damage.

The tolerable lightning frequency is expressed by the following formula:

$$N_c = \frac{1.5 \times 10^{-3}}{C}$$



Where:

$$C = C_2 \times C_3 \times C_4 \times C_5$$

9.2.33 CONSTRUCTION COEFFICIENT (C_2)

Construction Coefficient— C_2			
Structure	Metal Roof	Nonmetallic Roof	Combustible Roof
Metal	0.5	1.0	2.0
Nonmetallic	1.0	1.0	2.5
Combustible	2.0	2.5	3.0

NFPA 780 - Table L.5.1.2 (a) - Determination of Construction Coefficient, C_2

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS</p> <table border="1" data-bbox="368 383 1198 448"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	<p>شماره صفحه : ۲۰ از ۲۱</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

9.2.34 STRUCTURE CONTENTS COEFFICIENT (C3)

Structure Contents	C_3
Low value and noncombustible	0.5
Standard value and noncombustible	1.0
High value, moderate combustibility	2.0
Exceptional value, flammable liquids, computer or electronics	3.0
Exceptional value, irreplaceable cultural items	4.0

NFPA 780 - Table L.5.1.2 (b) - Determination of Structure Contents Coefficient, C_3

9.2.35 STRUCTURE OCCUPANCY COEFFICIENT (C4)



Structure Occupancy	C_4
Unoccupied	0.5
Normally occupied	1.0
Difficult to evacuate or risk of panic	3.0

NFPA 780 - Table L.5.1.2(c) - Determination of Structure occupancy Coefficient, C_4

9.2.36 LIGHTNING CONSEQUENCE COEFFICIENT (C5)

Lightning Consequence	C_5
Continuity of facility services not required, no environmental impact	1.0
Continuity of facility services required, no environmental impact	5.0
Consequences to the environment	10.0

NFPA 780 - Table L.5.1.2 (d) - Determination of Lightning Consequence Coefficient, C_5

	<p>نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های روزمینی در بسته های کاری تحت الارض عمومی و مشترک</p>																	
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	CALCULATION NOTE FOR EARTHING & LIGHTNING SYSTEM OF WELL PADS <table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>SSGRL</td> <td>PEDCO</td> <td>110</td> <td>EL</td> <td>CN</td> <td>0007</td> <td>D00</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	SSGRL	PEDCO	110	EL	CN	0007	D00	شماره صفحه: ۲۱ از ۲۱
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	SSGRL	PEDCO	110	EL	CN	0007	D00											

9.2.37 CONCLUSION

if:

$N_c < N_d$ Lightning protection is required

$N_c \geq N_d$ Lightning protection is not required.



9.2.38 LIGHTNING PROTECTION SYSTEM CALCULATION

No	Structure Name	Structure Dimension			A_e	C_1	N_d ($N_{g=1.5}$)	C_2	C_3	C_4	C_5	C	N_c	LPS Required
		L(m)	W(m)	H(m)										
RECEIVING AREA														
1	Switchgear Building	10.3	8.9	6.65	2108	1	3.1×10^{-3}	1	1	1	5	5	0.3×10^{-3}	Yes
2	Security Shelter	8.4	5	4.95	1132	1	1.6×10^{-3}	1	1	1	1	1	1.5×10^{-3}	Yes

The installation of lightning system for required structures will be done according to BS 6651.