







شماره صفحه: ۱ از ۳۶



# عمومی و مشترک

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۰۵۳

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D01		

# طرح نگهداشت و افزایش تولید ۲۷ مخزن

## **HAZID REPORT FOR WHF & FLOW LINES**

نگهداشت و افزایش تولید میدان نفتی بینک

D01 OCT. 2022 D00 JUL. 2022 Rev. Date F	Class: 2 CLIENT Doc Number: E07 707220						
	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval		
D01 OCT. 2022	IFI	F. Nourai	M.Fakharian	M.Mehrshad			
	FI	F. Nourai	M.Fakharian	M.Mehrshad			

Class: 3 CLIENT Doc. Number: F0Z-707339

#### Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for CLIENT Review
AB-A: As-Built —Approved

FI: Final Issue









# عمومی و مشترک

شماره پیمان:

۹۱۸۴ - ۲۷۰ - ۳۵۰

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D01		

شماره صفحه: ۲ از ۳۶

### **REVISION RECORD SHEET**

PAGE	D00	D01	D02	D03	D04
1	Х	Х			
2	X	Χ			
3	X				
4	X				
5	X				
<u>6</u> 7	X	X			
8	X				
9	X				
10	X				
11	X	X			
12	Х	- 71			
13	Х				
14	X				
15	Х				
16	X X X				
17					
18	X				
19	X X X				
20	X				
21 22	X				
23	X				
24	X				
25	X				
26	X				
27	X				
28	X X X				
29	X				
30	Х				
31	X				
32	X				
33	X				
34	X				
35					
36					
37					
38 39					
40					
41					
42	1				
43					
44	1			1	
45					
46					
47					
48					
49	<u> </u>				
50	<u> </u>				
51	-				
52 53	<del>                                     </del>				
53 54	1				-
55 55	1				
56	1				
57	1				<b> </b>
58	1				
59	1				
60					
61	1				
62 63					
63					
64				1	1

PAGE	D00	D01	D02	D03	D04
66					
67					
68					
69					
70					
71 72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85 86					
86					
87 88					
89					
90			1		
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102 103					
103					
105					
106					
107					
108					
109			1		
110					
111					
112					
113					
114					
115					
116					
117					
118 119					
120			1		
121			<b> </b>		
122			1		
123					
124					
125					
126			1		
127					
128					
129					
130					











# عمومی و مشترک

شماره پیمان: ۱۸۴ – ۱۸۳ – ۲۷۰ – ۵۳۰

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D01		

شماره صفحه: ۳ از ۳۶

## **CONTENTS**

1.0	INT	RODUCTION	4
2.0	SC	OPE	4
3.0	NOI	RMATIVE REFERENCES	5
	3.1 3.2	International Codes and Standards The Project Documents	5 5
4.0	HAZ	ZID STUDY OVERVIEW	5
5.0	ABI	BREVIATIONS	5
6.0	PRO	OCEDURE	6
	6.1 6.2	STUDY METHODOLOGYHAZID REPORTING FORMAT	7
7.0	HAZ	ZID STUDY OUTCOMES	8
8.0	AT1	FACHMENTS	9
	8.1	APPENDIX A —TEAM MEMBERS	9
	8.1	Appendix B —Hazard Categories (ISO 17776)	10
	8.1	APPENDIX C – RECOMMENDATIONS LIST	11
	8.2	ATTACHMENT F – HAZID WORKSHEFTS	











## عمومی و مشتر ک

شماره پیمان: · 54 - · 74 - 9114

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D01		

شماره صفحه: ٤ از ٣٤

#### 1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also, PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, construction of well location, access road, wellhead facilities (with electric power supply) for W007S shall be done. In addition, construction of new flowline from aforementioned well location to Binak B/C unit (with extension of relevant manifold) are in the Project scope of work.

### **GENERAL DEFINITION**

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

Binak Oilfield Development - Construction of Well PROJECT:

> Location, Wellhead Facilities, Electrification Facilities, Flowlines for W007S and Extension of Binak B/C

Manifold

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

**EPC CONTRACTOR:** Joint Venture of: Hirgan Energy - Design &

Inspection(D&I) Companies

**VENDOR:** The firm or person who will fabricate the equipment or

material.

**EXECUTOR:** Executor is the party which carries out all or part of

construction and/or commissioning for the project.

The firm appointed by EPD/EPC CONTRACTOR (GC) THIRD PARTY INSPECTOR (TPI):

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory. SHOULD: Is used where a provision is advisory only.

Is normally used in connection with the action by WILL:

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

Is used where a provision is completely discretionary. MAY:

#### 2.0 SCOPE

The scope of HAZID Study covers Extension of Binak B/C Manifold.











## عمومي و مشترك

	شماره پیمان:
۰۵۳ –	۹۱۸۴ – ۲۷۰

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D01		

شماره صفحه: ٥ از ٣٤

#### 3.1 NORMATIVE REFERENCES

ISO 17776

### 3.2 INTERNATIONAL CODES AND STANDARDS

Petroleum and natural gas industries — Offshore production installations — Major accident hazard management during the design of new installations

#### 3.3 THE PROJECT DOCUMENTS

- BK-GNRAL-HD-000-PR-DB-0001-D05 Process Basis of Design
- BK-W007S-PEDCO-110-PI-PY-0001 Plot Plan Drawing Extension of Binak B/C Manifold
- BK-W007S-PEDCO-110-PI-PY-0002 Plot Plan Drawing W007S

#### 4.0 HAZID STUDY OVERVIEW

Meetings were conducted in two sessions on July 23, 2022 held in Hirgan Energy company office, Tehran.

A team comprising of experts from different disciplines of National Iranian South Oilfields Company (NISOC), Petro Iran Development Company (PEDCO) and Hirgan Energy Company conducted the study with a third-party HAZID Chairman. The list of team members is presented in appendix A.

### 5.0 ABBREVIATIONS

A/C Air-Conditioning

AC/DC Alternating Current/Direct Current

ALARP As Low As Reasonably Practicable

CBA Cost-Benefit Analysis

EMC Electromagnetic Compatibility

ESD Emergency Shut Down

F&G Fire and Gas
HC Hydrocarbon
HV High Voltage

ICAO International Civil Aviation Organization

IP Ingress Protection
IRP Sucker-Rod Pump
LBV Line Break Valve

LDAR Leak Detection and Repair









# عمومي و مشترك

شماره پیمان:

· 54 - · 74 - 4176

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سر يال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D01		

شماره صفحه: ٦ از ٣٤

LV Low Voltage

MV Medium Voltage

OSBL Outside Battery Limit

PACS Project Applicable Codes and Standards

PPE Personal Protective Equipment

RCD/P Residual Current Device/Protection

ROW Right of Way

SCBA Self-Contained Breathing Apparatus

SIL Safety Integrity Level

SoW Scope of Work

SSSV Sub-Surface Safety Valve

TPD Third-Party Damage

UPS Uninterruptible Power Supply

Load Break Switches

VOC Volatile Organic Carbon WHCP Wellhead Control Panel

WITCE Weiliteau Control Fair



VCB Vacuum Circuit Breaker



### 6.1 PROCEDURE

HAZID methodology is in accordance with "HAZID Study Procedure" defined by ISO 17776 checklist.

HAZID study is a tool for hazard identification, used early in a project as soon as process flow diagrams, heat and material balances, and plot layouts are available. Existing site infrastructure, weather, and geotechnical data are also required, these being a source of external hazards. The method is a design-enabling tool, influencing HSE deliverables in the project.

HAZID study is undertaken in order to deliver a good identification of hazard, threat control and recovery measures. This Study helps to ensure that:

- ✓ Major Hazards with potential to affect personnel, environment and assets are revealed and identified at an early stage in the project, before significant costs have been incurred
- ✓ Hazards are recorded so that they can be avoided, mitigated or highlighted during design
- ✓ Design or construction delays and budget over-runs are avoided
- √ Fewer hazards remain un-revealed at commissioning and operation of facilities.









## عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۰۷۳ – ۰۵۳

HAZID REPORT FOR WHF & FLOW LINES									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	SSGRL	PEDCO	110	GE	RT	0003	D01		

شماره صفحه: ۷ از ۳۶

#### 6.2 STUDY METHODOLOGY

A structured approach to identify hazards will be utilized based on studying the various operational phases of the under-study plant through:

- ✓ Identifying hazards.
- ✓ Describing their failure modes.
- ✓ Suggesting risk reducing measures that can prevent or mitigate each hazard.

The approach to HAZID is using generic guidewords, generic hazard specified for each hazard identified, the causes (threats), consequences and preventative/mitigation measures identified for the event. Recommendations are recorded when the preventative/mitigation measures do not adequately reduce the risk of the hazard.

HAZID formulates a list of hazards and generic hazardous situations by considering the following process characteristics:

- ✓ Impact of the facility to its surroundings.
- ✓ Impact of the surroundings to the facility
- ✓ Interference between main units
- ✓ Location / orientation of plant and equipment
- ✓ Location / orientation of plant and equipment
- ✓ Unplanned releases for isolatable sections or units
- ✓ Environmental hazards and natural hazards.

As each hazardous situation is identified, the causes (threats), consequences, and threats control, recovery measures are listed.

For this study, safety analysis will be performed using selected items from the checklist of ISO 17776 standard for hazard categories and guidewords that lead to create a picture of hazardous situations and then to analyze and specify preventative/mitigation measures typical to the facilities under study. The checklist is presented in Appendix B. Brainstorming approach is an integral part of HAZID study, which is to be performed using a team composed of client, contractors, and subcontractors delegates and a HAZID Leader.

### 6.3 HAZID REPORTING FORMAT

Results of the HAZID study will be presented in a worksheet that tabulates the causes (threats), consequences, safeguards (Threat Control & Recovery Measures) and recommendations for each hazard identified. The method used for recording is full recording, i.e., all hazard hierarchy relevant to the context were considered and all operational issues or hazardous consequences were recorded along with any other outcome that may not raise a concern, for the sake of completeness and audit ability.









## عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۵۳۰

HAZID REPORT FOR WHF & FLOW LINES							ı	
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	ı
BK	SSGRL	PEDCO	110	GE	RT	0003	D01	1

شماره صفحه: ۸ از ۳۶

Where the existing safeguards are found to be inadequate for the hazard, recommendations will be raised. Therefore, from the worksheets it should be inferred that wherever the hazard has no recommendation, its corresponding safeguards are considered adequate.

### Sample Format for HAZID worksheets

Section:

Hazard Category:

Guideword	Threats (Cause)	Consequences	Threat Control/Recovery Measures	Recommendations

### 7.0 HAZID STUDY OUTCOMES

A total of 16 recommendations were obtained that are shown in Appendix C. Recommendations are either closed type, i.e., they are final in their description, or open type, which means the final action depends on a study as clearly indicated in the recommendation. One shall note that all recommendations, open or closed, shall be followed up and finalized. Appendix D consists of detailed HAZID Worksheets of the study.



.04-.04-.04

# نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های رو زمینی در بسته های کاری تحت الارض







# عمومی و مشترک

شماره پیمان:

HAZID REPORT FOR WHF & FLOW LINES							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سر يال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۹ از ۳۶

# 8.1 ATTACHMENTS

## 8.2 APPENDIX A –TEAM MEMBERS

First Name	Last Name	Company	Expertise
Fatemeh	Ghodsi	NISOC	Head of I&C
Sahar	Saba	NISOC	Process
Peyman	Sarvarian	NISOC	Mechanic
Mohammad	Khamisi	NISOC	HSE
Farid	Hedayat Rad	NISOC	Instrument
Hasan	Salari	NISOC	Process
Bahman	Zarei	NISOC	Maintenance
Ghasem	Shahrooei	NISOC	Engineering
Seyed Ali	Mousavi	Gachsaran NISOC	Process
Mohammad	Navid	Gachsaran NISOC	Production Engineer
Mohammad	Fakoor	PEDCO	Process Engineer
Farshid	Amiri	PEDCO	Process
Sepideh	Akbari	PEDCO	I&C Engineer
Sasan	Faramarzpour	PEDCO	Head of Process and Safety Department
Mehdi	Sadeghian	PEDCO	Surface Manager
Fereidoun	Noei	PEDCO	Process
Sadegh	Gharacheh	PEDCO	Process
Mohammad	Fakharian	Hirgan Energy	Project Manager
Masoud	Asgharnejad	Hirgan Energy	Engineering Manager
Mohsen	Aryafar	Hirgan Energy	Process
Parisa	Haji Sadeghi	Hirgan Energy	Head of I&C
Amir Hossein	Saber	Hirgan Energy	Process Safety
Faramarz	Mosayeb Nejad	Hirgan Energy	Piping
Farshad	Nourai	Consultant	HAZID Leader





# عمومی و مشترک

	شماره پیمان:
• 24 - • 14 -	- 9114

HAZID REPORT FOR WHF & FLOW LINES								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	SSGRL	PEDCO	110	GE	RT	0003	D01	

شماره صفحه: ۱۰ از ۳۶

# 8.1 APPENDIX B -HAZARD CATEGORIES (ISO 17776)

Hazard Category				
1. Hydrocarbons				
2. Refined Hydrocarbons				
3. Other Flammable Materials				
4. Hazards Associated with Difference in Height				
5. Environmental Hazards				
6. Dynamic Situation Hazards				
7. Open Flame				
8. Electricity				
9. Toxic Gases				
10. Entrapment				







سر يال

0003

D01





# عمومی و مشترک

شماره پیمان:	HAZID REPORT FOR WHF & FLOW				OW LINES	
· DT - · VT - 9 1 AF	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك
<b>3</b> )	BK	SSGRL	PEDCO	110	GE	RT

شماره صفحه: ۱۱ از ۳۶

#### 8.1 APPENDIX C – RECOMMENDATIONS LIST

Recommendations	Responsibility	Place(s) Used
Client insists on performing SIL verification on ESD system based on IEC 61511.  Contractor justification for not performing SIL verification will be submitted to Client subsequently.	N-C	Consequences: 1.1.1.1
Ensure operators (end-user) to be present in the forthcoming 3D model review (90%).	N-C	Consequences: 1.1.3.1, 4.1.1.1
3. Consider LDAR program for operation phase.	N	Consequences: 1.1.4.1
Verify whether or not automatic fire alarm for transformers in electrical buildings in wellhead areas are provided.	С	Consequences: 2.2.1.1
<ol> <li>Prepare a cost-benefit analysis (CBA) report for increasing safety of transformers in wellhead area by replacing LBS with VCB and its requirements, acc. to PACS and considering ALARP area requirements.</li> </ol>	С	Consequences: 2.2.2.1
6. Study and report application and costs of providing F&G (H <sub>2</sub> and other detectors) acc. to PACS, regarding ALARP requirements and practical limitations and also referencing relevant SOW.	С	Consequences: 3.1.1.1, 8.2.1.2
7. Plan for development of environmental contingency plans incl. communication with local meteorological institute.	N	Consequences: 5.2.1.2, 8.1.1.2
Study application of latest water pollution minimization techniques and tools, including dispersant or anti-static agents and spill collection and containment equipment.	N	Consequences: 5.2.1.2
Provide sunshade for electrical motor of manifold area sump pump exposed to sunlight.	С	Consequences: 5.2.3.2
10. Develop a procedure for minimizing site work in times of extreme environmental conditions and provide adequate and appropriate PPE.		Consequences: 5.2.4.4
11. Include fire protection requirements for helipads at wellhead areas in Operating Manual.	С	Consequences: 6.2.1.1
12. In consultation with IRP vendor, consider separate discharge wells for electrical, lightning and instrumentation earthing systems with surge diverters.		Consequences: 8.1.1.1
13. Study application of RCPs in wellhead and manifold areas acc. to PACS and relevant SOW.	С	Consequences: 8.2.2.1











# عمومی و مشترک

	شماره پیمان:
٠٥٣ - ٢٧٠ -	- 9114

HAZID REPORT FOR WHF & FLOW LINES							
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه						
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۱۲ از ۳۶

14. Ensure that armored LV cables, if any, are armored off and connected to earth system, as required by PACS.	С	Consequences: 8.2.3.1
15. Plan for improving process safety culture, and effectiveness of training incl. H <sub>2</sub> S awareness, and enforcing appropriate PPE.	N	Consequences: 9.1.1.1, 9.1.2.1, 9.2.1.1, 10.1.1.1
16. Check and report whether or not electrical and instrument cable covers in the existing Manifold Area Control Building are low-smoke type, subject to availability of documents.	С	Consequences: 10.1.1.2



عمومي و مشترك

110

GE

RT



سريال

0003

نسخه

D01





شماره پیمان:

BK

SSGRL

· DT - · VT - 91AF

**HAZID REPORT FOR WHF & FLOW LINES** نوع مدرك پروژه بسته کاری صادر کننده تسهيلات رشته

PEDCO

شماره صفحه: ۱۳ از ۳۶

#### 8.2 ATTACHMENT E - HAZID WORKSHEETS

11	0	0	Ris	sk Mat	trix	O-fo-manda	Ris	k Ma	atrix	December detion	Dann
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
1. Gas and condensate	Leakage due to corrosion, erosion, or rupture due to TPD, etc.	1.1. Fire and explosion with possibility of injury/fatality	1	В		1.1.1.  1.1.2.  Corrosion coupons and 1.1.3.  1.1.4.  Minimizing dead points and pockets in piping 1.1.5.  Drain connections at 1.1.6.  Maximum allowable fluid velocity to minimize 1.1.7.  Stone trap at wellhead 1.1.8.  Controlled entry of vehicles in wellhead area (fence) and 1.1.9.  Access roads to flowlines have standard 1.1.10. Considerable	3	С	M	Client insists on performing SIL verification on ESD system based on IEC 61511.      Contractor justification for not performing SIL verification will be submitted to Client subsequently.	N-C





نسخه

D01

0003







# عمومي و مشترك

GE

RT

شماره پیمان:

· 24 - · 74 - 9114

	HA	AZID REPOR	T FOR W	HF & FL	OW LINES	
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال

110

PEDCO

SSGRL

BK

شماره صفحه: ۱۶ از ۳۶

Howard	Caucas	Canagaganasa	Ris	k Mat	rix	Cofemunado	Ris	k Ma	ıtrix	Decemmendation	Been
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						thickness of the flow lines acc. to their pressure class in case of physical damage					
						1.1.11. In manifold area, maximum available space is used for clearance					
						1.1.12. Fail safe design of WHCP in case of rupture					
						1.1.13. Fusible plugs on X- mas trees in wellhead area that initiate wellhead shutdown through WHCP					
						1.1.14. Manual shut down through WHCP push buttons					
						1.1.15. Paving is provided instead of gravel to minimize probability of explosion upon gas leakage					
						1.1.16. Slope and open drain connection for					









# عمومي و مشترك

شماره پیمان:

.04 - . 14 - 9114

	HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه							
BK	SSGRL	PEDCO	110	GE	RT	0003	D01							

شماره صفحه: ۱۵ از ۳۶

Harard	Course	C	Ris	k Mat	rix	Cafaguanda	Ris	k Ma	trix	Dagammandation	Daan
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						collection and disposal of liquid leaks in X-mas tree cellar and peripheral area					
						1.1.17. Hazardous area classification					
						1.1.18. Portable and wheeled fire extinguishers and other necessary devices (fire shed for wellheads with IRP)					
						1.1.19. See also Entrapment category					
		1.2. Toxic release with possibility of fatality; see Toxic Gas category									
		1.3. Environmental	2	В	Н	1.3.1. Material selection	3	С	M		
		pollution				1.3.2. Corrosion coupons and probes in manifold area					
						1.3.3. Corrosion allowance					
						Minimizing dead points     and pockets in piping     design					
						1.3.5. Drain connections at					









# عمومي و مشترك

شماره پیمان:

.04 - .14 - 4114

HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه						
BK	SSGRL	PEDCO	110	GE	RT	0003	D01						

شماره صفحه: ۱٦ از ۳٤

Causas	Concomuences	Ris	sk Ma	trix	Cofoguerdo	Ris	k Ma	trix	Documendation	Doon
Causes	Consequences	S	L	RR	Saleguards	S	L	RR	Recommendation	Resp.
					dead points					
					1.3.6.					
					Maximum allowable					
					area (fence) and					
					1.3.9.					
					Access roads to					
					clearance					
					1.3.11. Fail safe design of					
					WHCP in case of					
					·					
	Causes	Causes Consequences	Causes Consequences	Causes Consequences	S L RR	Causes  Consequences  S L RR  dead points  1.3.6.  Maximum allowable fluid velocity to minimize  1.3.7.  Stone tran at wellhead  1.3.8.  Controlled entry of vehicles in wellhead area (fence) and  1.3.9.  Access roads to flowlines have standard  1.3.10. In manifold area, maximum available space is used for clearance  1.3.11. Fail safe design of	Causes  Consequences  S L RR  dead points  1.3.6.  Maximum allowable fluid velocity to minimize  1.3.7.  Stone trap at wellhead  1.3.8.  Controlled entry of vehicles in wellhead area /fencel and  1.3.9.  Access roads to flowlines have standard  1.3.10. In manifold area, maximum available space is used for clearance  1.3.11. Fail safe design of WHCP in case of rupture  1.3.12. Manual shut down through WHCP push buttons  1.3.13. Slope and open drain connection for	Causes  Consequences  S L RR  dead points  1.3.6.  Maximum allowable fluid velocity to minimize  1.3.7.  Stone trap at wellhead  1.3.8.  Controlled entry of vehicles in wellhead area (fence) and  1.3.9.  Access roads to flowlines have standard  1.3.10. In manifold area, maximum available space is used for clearance  1.3.11. Fail safe design of WHCP in case of rupture  1.3.12. Manual shut down through WHCP push buttons  1.3.13. Slope and open drain connection for	Consequences  S L RR  dead points  1.3.6.  Maximum allowable fluid velocity to minimize  1.3.7.  Stone tran at wellhead  1.3.8.  Controlled entry of vehicles in wellhead area ffencel and  1.3.9.  Access roads to flowlines have standard  1.3.10. In manifold area, maximum available space is used for clearance  1.3.11. Fail safe design of WHCP in case of rupture  1.3.12. Manual shut down through WHCP push buttons  1.3.13. Slope and open drain connection for	Causes  Consequences S L RR  dead points  1.3.6.  Maximum allowable fluid velocity to minimize  1.3.7.  Stone trap at wellhead  1.3.8.  Controlled entry of vehicles in wellhead  area (fence) and  1.3.9.  Access roads to flowlines have standard  1.3.10. In manifold area, maximum available space is used for clearance  1.3.11. Fail safe design of WHCP in case of rupture  1.3.12. Manual shut down through WHCP push buttons  1.3.13. Slope and open drain connection for











# عمومي و مشترك

شماره پیمان:

· 24 - · 74 - 9114

	HAZID REPORT FOR WHF & FLOW LINES													
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه							
BK	SSGRL	PEDCO	110	GE	RT	0003	D01							

شماره صفحه: ۱۷ از ۳۶

Hazard	Causas	Canagaganaga	Ris	k Mat	rix	Cofeminardo	Ris	k Ma	trix	Recommendation	Door
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						of liquid leaks in X-mas tree cellar and peripheral area					
		1.4. Loss of product,	2	В	Н	1.4.1.	3	С	M		
		loss of production and damage to				1.4.2.  Corrosion coupons and					
		assets in case of fire/explosion,				1.4.3.					
		which also				1.4.4.					
		causes loss of				Minimizing dead points					
		reputation				and nockets in nining 1.4.5.					
						Drain connections at					
						1.4.6.					
						Maximum allowable fluid velocity to minimize					
						1.4.7.					
						Stone trap at wellhead					
						1.4.8.					
						Controlled entry of 1.4.9.					
						Controlled entry of					
						vehicles in wellhead					
						area (fence) and					
						1.4.10. Access roads to flowlines have					











عمومی و مشترک

شماره پیمان:

· 24 - · 74 - 9114

	HA	ZID REPOR	T FOR W	HF & FL	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۱۸ از ۳۶

Hamand	Courses	C	Ris	k Mat	rix	Cofomicando	Ris	k Ma	trix	Dagamman dation	Daan
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						standard clearance to avoid TPD					
						1.4.11. In manifold area, maximum available space is used for clearance					
						1.4.12. Fail safe design of WHCP in case of rupture					
						1.4.13. Manual shut down through WHCP push buttons					
	See also     Environmental     Hazards category										
		3.1. Extreme process	2	С	S	3.1.1. Operating manual	3	D	M	2. Ensure operators (end-	N-C
	Maintenance due to human error	conditions or overload of equipment, also				3.1.2. Maintenance requirements are foreseen in plant layout				user) to be present in the forthcoming 3D model review (90%).	
		damage due to impact and similar events,				3.1.3. Training for the operation phase					
		which leads to leakage and fire/explosion or toxic release				3.1.4. Level of automation to minimize human error					









# عمومي و مشترك

شماره پیمان:

.04 - . 14 - 914

	HA	AZID REPOR	T FOR W	HF & FI	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۱۹ از ۳۶

Hazard Gategory.		Component	Ris	k Mat	rix	Cafamuanda	Ris	k Ma	trix	Decemberdation	Daan
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
		3.2. See also HAZOP Report									
	4. VOC	4.1. Personnel exposure may cause chronic health problems and also environmental problem	3	В	S	4.1.1. Operational controls like training and PPE	3	С	M	Consider LDAR program for operation phase.	N
	5. Damage to pipeline due to surge; see HAZOP Report										
	See also Toxic Gas category										
	7. Dispersion of HC vapors upon draining into Open Drain in routine operations										











# عمومي و مشترك

شماره پیمان:

. 24 - . 74 - 9176

	HA	AZID REPOR	T FOR W	HF & FI	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۲۰ از ۳۶

Hazard Category: 2. Refined Hydrocarbons

	Hamand	0	0	Ris	sk Mat	rix	Oofe weeds	Ris	k Ma	trix	Danaman dation	Dann
	Hazard	Causes	Consequences	S	Ы	RR	Safeguards	S	Ы	RR	Recommendation	Resp.
1	Diesel Fuel for Emergency Generator (only in wellheads with IRP, which	Leakage or spillage due to TPD	1.1. Environmental pollution due to soil contamination in case of spillage	3	В	S	1.1.1. Paved area	4	В	M		
	are also manned)		1.2. Small local fire in case of ignition	3	С	M	Portable and wheeled type fire extinguishers are provided	4	С	L		
2	. Transformer Oil (only in wellheads with IRP, which are also manned)	Leakage due to corrosion, TPD, maloperation, etc.	1.1. Local fire with possibility of damage to transformer	4	С	L	1.1.1. Portable and wheeled fire extinguishers	4	С	L	Verify whether or not automatic fire alarm for transformers in electrical buildings in wellhead areas are provided.	С
		Transformer oil     evaporation due to     overcurrent	2.1. Severe damage to transformers	2	D	M	2.1.1. Buchholz relay and relief valve	3	D	M	5. Prepare a cost-benefit analysis (CBA) report for increasing safety of transformers in wellhead area by replacing LBS with VCB and its requirements, acc. to PACS and considering ALARP area requirements.	С
3	. Hydraulic oil (WHCP)	Leakage due to TPD	1.1. Local fire with possibility of damage to	4	С	L	1.1.1. Portable and wheeled fire extinguishers     1.1.2. Fence is provided for	4	D	L		











عمومي و مشترك

	شماره پیمان:
۰۵۳ –	• • • • • • • • • • • • • • • • • • • •

	HA	ZID REPOR	T FOR W	HF & FL	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۲۱ از ۳۶

**Hazard Category: 2. Refined Hydrocarbons** 

Courses	Concominance	Ris	sk Mat	trix	Cofeessande	Ris	k Ma	atrix	Decemmen detion	Doon
Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
	WHCP				WHCP					
					1.1.3. Tubing is protected by					
					trays					
					1.1.4. Separate reservoir for					
	Causes	•	Causes Consequences S	Causes Consequences S L	WHCP S L RR	Causes  Consequences S L RR  WHCP  WHCP  1.1.3. Tubing is protected by trays	WHCP  S L RR  WHCP  1.1.3. Tubing is protected by trays  1.1.4. Separate reservoir for return oil from SSSV in case of gas mixed with	Causes  Consequences S L RR  WHCP  WHCP  1.1.3. Tubing is protected by trays 1.1.4. Separate reservoir for return oil from SSSV in case of gas mixed with	Causes  Consequences S L RR  WHCP  MHCP  1.1.3. Tubing is protected by trays 1.1.4. Separate reservoir for return oil from SSSV in case of gas mixed with	Causes  Consequences S L RR  WHCP  1.1.3. Tubing is protected by trays 1.1.4. Separate reservoir for return oil from SSSV in case of gas mixed with

**Hazard Category: 3. Other Flammable Materials** 

Hamand	Courses	Camaaa	Ris	k Mat	rix	Coformando	Ris	k Ma	trix	Dagamman dation	Deen
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
Hydrogen in Battery Room in switchgear room in wellheads with IRP	, ,	1.1. Explosion and damage to Battery Room	2	В	Н	1.1.1. Explosion-proof exhaust fan and other electrical devices for hydrogen service in Battery Room	3	D	M	<ol> <li>Study and report application and costs of providing F&amp;G (H<sub>2</sub> and other detectors) acc. to PACS, regarding ALARP requirements and practical limitations and also referencing relevant SOW.</li> </ol>	С









# عمومي و مشترك

شماره پیمان:

· ۵۳ - · ۷۳ - 9118

HA	ZID REPOR	T FOR W	HF & FL	OW LINES	
					г

 نسخه
 سریال
 نوع مدرک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 SSGRL
 PEDCO
 110
 GE
 RT
 0003
 D01

شماره صفحه: ۲۲ از ۳۶

Hazard Category: 4. Hazards Associated with Difference in Height

	0	•	Ris	k Mat	trix	0-6	Ris	k Ma	trix	B	<b>D</b>
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
Personnel     working at     height or depth	1. Trip and fall	1.1. Personnel injury with possibility of fatality	1	С	Н	1.1.1. Platforms for maintenance are provided with adequate floor, access stairway or ladders with appropriate fall protection and handrails	2	D	M	Ensure operators (end- user) to be present in the forthcoming 3D model review (90%).	N-C
						1.1.2. Monkey ladders for lighting fixtures					
						1.1.3. Access concrete stairway for wellhead cellars					
						1.1.4. Cages for monkey ladders on switchgear buildings, guard houses, potable water tank and diesel storage tank					
						1.1.5. Operational controls and PPE					
<ol> <li>Overhead equipment and objects</li> </ol>	1. Fall of load	1.1. Personnel injury with possibility of fatality, and also	1	С	Н	1.1.1. Toe boards are provided on platforms in case of hand tools, etc.	2	D	M		
		damage to equipment				1.1.2. Cross-over bridges on flow lines reduce impact from personnel movements					









# عمومي و مشترك

شماره پیمان:

.04 - . 14 - 414

	HA	ZID REPOR	T FOR W	HF & FL	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۲۳ از ۳۶

	Hamand	0	0	Ris	k Mat	rix	Oofe was de	Ris	k Ma	trix	Baarnen datien	D
	Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
1	. Tectonic	Natural disasters like earthquake or other earth movement	1.1. Damage to equipment and possible	1	В	Н	1.1.1. Geotechnical study 1.1.2. Seismic design acc. to	3	С	M		
		carin movement	injury/fatality for personnel				PACS  1.1.3. Operational controls like contingency plans, drills, etc.					
							1.1.4. For other safeguards, see Hydrocarbons category					
							1.1.5. For other safeguards, see Entrapment category					
			1.2. Possibility of spillage from flow lines or pipelines with subsequent	2	В	Н	1.2.1. For other safeguards, see Hydrocarbons category	3	С	M		
			pollution problems				Operational controls like contingency plans, drills, etc.					
2	. Weather	1. Flood	1.1. Damage to flow lines and	2	С	S	1.1.1. Environmental design data	4	Е	L		
			equipment due to flooding				1.1.2. Ground slope, ditches and trenches lead to open drain for surface					













# عمومي و مشترك

شماره پیمان: · 24 - · 74 - 9114

HAZID REPORT FOR WHF & FLOW LINES بسته کاری نوع مدرك سريال صادر کننده نسخه پروژه تسهيلات رشته PEDCO 0003 BK SSGRL 110 GE RT D01

شماره صفحه: ۲۶ از ۳۶

Hazard	Courses	Concomionaca	Ris	k Mat	rix	Safamuarda	Ris	k Ma	trix	Recommendation	Been
пагаги	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
						run-off					
						Area topology reduces     likelihood of wellhead     area flooding					
						1.1.4. Diversion channel					
						1.1.5. Flood control study based on hydrology survey results					
						1.1.6. Reinforced flow lines support for seasonal rivers in project area					
		Possibility of soil and water pollution	2	С	S	1.2.1. Surface run-off leads to Waste Pit OSBL, which accommodates annual rainfall statistics	4	D	L	<ol> <li>Plan for development of environmental contingency plans incl. communication with local meteorological institute.</li> </ol>	N
										8. Study application of latest water pollution minimization techniques and tools, including dispersant or anti-static agents and spill collection and containment equipment.	N
		1.3. Soil pollution in burn pit either by	4	E	L	1.3.1. Environmental design data	4	D	L		











# عمومي و مشترك

شماره پیمان:

· 24 - · 74 - 9 1 A F

	HA	ZID REPOR	T FOR W	HF & FL	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۲۵ از ۳۶

Hamand	Courses	6	Ris	Risk Matrix		Safeguards		k Ma	atrix	Recommendation	
Hazard	Causes	Consequences	S	L	RR	Sareguards	S	L	RR	Recommendation	Resp.
		overflow in rain or penetration				1.3.2. Burn pit capacity					
	2. High winds, storm	2.1. Possibility of damage to plant	3	С	M	2.1.1. Environmental design data	4	D	L		
		equipment and injury to personnel				2.1.2. Mechanical design for buildings and structures/piping					
	<ol><li>Temperature extremes</li></ol>	3.1. Interference in performance of	2	В	Н	3.1.1. Environmental design data	3	С	M		
		instrumentation				3.1.2. Sunshade for WHCP to avoid impact by sunlight					
						3.1.3. Electrical and control cables are either run in ducts or trays					
		3.2. Damage or performance	3	Α	S	3.2.1. Environmental design data	4	В	M	Provide sunshade for electrical motor of	С
		reduction of sun- exposed electrical equipment				3.2.2. Electrical cables are either run in ducts or trays				manifold area sump pump exposed to sunlight.	
		3.3. Fatigue, injury and increased	3	Α	S	3.3.1. Environmental design data	4	В	M		
		risk of human error in case of maintenance				3.3.2. Operational controls and PPE					
		3.4. Reduced	2	В	Н	3.4.1. Environmental design	4	С	L		









# عمومي و مشترك

شماره پیمان:

· 24 - · 74 - 9114

	HA	ZID REPOR	T FOR W	HF & FL	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۲٦ از ۳٤

Hamand	Courses	Concominance	Ris	k Mat	rix	Cofomiando	Ris	k Ma	trix	Dagammandation	Daara
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
		performance or damage to A/C equipment, which may reduce performance of indoor instrumentation and other equipment				data 3.4.2. Sunshade is provided for A/C equipment	_				
	4. Dust	4.1. Damage to electrical equipment, instrumentation/telecom equipment	2	В		4.1.1. Environmental design data  4.1.2. IP protection of instrumentation, telecom and electrical enclosures	3	С	M		
		4.2. Reduced performance of Diesel Generators	3	В		<ul> <li>4.2.1. Environmental design data</li> <li>4.2.2. Intake Air Filter for Emergency Diesel Generators</li> <li>4.2.3. Emergency Diesel Generators operation is intermittent</li> </ul>	4	С	L		
		4.3. Reduced quality of conditioned air and damage to	3	С	М	4.3.1. Environmental design data 4.3.2. Inspection &	3	С	M		









# عمومي و مشترك

شماره پیمان:

. 24 - . 74 - 9176

	HAZID REPORT FOR WHF & FLOW LINES										
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه				
BK	SSGRL	PEDCO	110	GE	RT	0003	D01				

شماره صفحه: ۲۷ از ۳۶

Hazard Category: 5. Environmental Hazards

Howard	Courses	Component	Ris	Risk Matrix		Sofomuerdo		k Ma	atrix	Recommendation	Daan
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
		A/C Compressors				maintenance procedures					
		4.4. Personnel injury and health problems and increased possibility of human error	2	В		4.4.1. Environmental design data 4.4.2. Operational controls and PPE	2	С	S	<ol> <li>Develop a procedure for minimizing site work in times of extreme environmental conditions and provide adequate and appropriate PPE.</li> </ol>	N

Hazard Category: 6. Dynamic Situation Hazards

Hamand	0	0	Ris	sk Ma	trix	Oofo woods	Ris	k Ma	trix	Danaman dation	Dann
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
1. Vehicles in Wellheads/manifold Area	1. TPD	1.1. Leakage or spillage due to impact; see Hydrocarbons category for details [Note: No pipe racks in wellheads/manifold area]		С		1.1.1. Controlled entry of vehicles in wellhead area (fence) and manifold area  1.1.2. Access roads to flowlines have standard clearance to avoid TPD  1.1.3. In manifold area, maximum available space is used for clearance  1.1.4. Operational controls for in-site traffic	3	D	M		



عمومي و مشترك







## شماره پیمان:

· 24 - · 74 - 9114

,		H.A	ZID REPOR	T FOR W	HF & FL	OW LINES		
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
	BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۲۸ از ۳۶

Hazard Category: 6. Dynamic Situation Hazards

Hamand	C	C	Ris	k Mat	trix	Cofomicando	Ris	k Ma	trix	December detion	Daan
Hazard	Causes	Consequences	S	Ш	RR	Safeguards	S	L	RR	Recommendation	Resp.
						<ul><li>1.1.5. Safety signs, incl. traffic</li><li>1.1.6. For other safeguards, see Hydrocarbons category</li></ul>					
Helicopter at wellhead areas	Ground impact,     especially during     landing	1.1. Damage to helicopter and possibility of fire/explosion and personnel injury/fatality	1	D		1.1.1. Area lighting in wellheads with IRP  1.1.2. Helipad design based on Iranian ICAO guidelines	1	Е	M	11. Include fire protection requirements for helipads at wellhead areas in Operating Manual.	С

Hazard Category: 7. Open Flame

Hamand	0	0	Ris	Risk Matrix		0-1		k Ma	atrix	Recommendation	D
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
1. Burn Pit	Exposure of grass in nearby area	1.1. Fire and subsequent pollution and injury to personnel and fauna	4	С		<ul> <li>1.1.1. Operational controls like regular inspection and removal of excess grass</li> <li>1.1.2. Burn pit location and clearance acc. to standard drawings and requirements</li> </ul>	4	С	L		









# عمومي و مشترك

شماره پیمان:

.04 - . 14 - 9114

	HA	ZID REPOR	T FOR W	HF & FL	LOW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۲۹ از ۳۶

	Hazard	Causes	Consequences	Ris	sk Mat	rix	Safeguards	Ris	k Ma	trix	Recommendation	Boon
	пагаги	Causes	Consequences	S	L	RR	Salegualus	S	L	RR	Recommendation	Resp.
	. Lightning Discharge	Local atmospheric conditions cause lightning strike	1.1. Damage to electrical equipment and instrumentation	1	В	Н	1.1.1. Lightning arrester for wellhead areas with (electrical) IRP	3	D	M	12. In consultation with IRP vendor, consider separate discharge wells for electrical, lightning and instrumentation earthing systems with surge diverters.	С
			1.2. Personnel injury with possibility of fatality	1	С	Н	1.2.1. Lightning arrester for wellhead areas with (electrical) IRP	3	D	M	Plan for development of environmental contingency plans incl.	N
							1.2.2. Operational controls				communication with local meteorological institute.	
			1.3. Possibility of fire/explosion	1	В	Н	1.3.1. Lightning arrester for wellhead areas with (electrical) IRP	3	D	M		
							1.3.2. For safeguards, see Hydrocarbons category					
2	2. Electrical	<ol> <li>Electrical fire and</li> </ol>	1.1. In case of	2	С	S	1.1.1. Protection relays	3	D	M		
	equipment including but not limited to Diesel	explosion (indoors/outdoors)	outdoors, damage to electrical				1.1.2. Electrical and control cables are either run in ducts or trays					
	Generator, electric motor, panels, transformers,		equipment, which can lead to loss of production				1.1.3. Buried cables are less sensitive to damage by fire					
	tianolomicio,						1.1.4. In manifold area, ESD					











# عمومی و مشترک

شماره پیمان:

. 24 - . 14 - 9114

HA	ZID REPOR	T FOR W	HF & FI	OW LINES	

 نسخه
 سریال
 نوع مدرک
 رشته
 تسهیلات
 صادرکننده
 بسته کاری
 پروژه

 BK
 SSGRL
 PEDCO
 110
 GE
 RT
 0003
 D01

شماره صفحه: ۳۰ از ۳۶

Howard	Coupea	Canagaganaga	Ris	k Mat	rix	Cofoguardo	Ris	k Ma	trix	Recommendation	Been
Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
AC/DC UPS, lighting towers and cables						cables are fire-resistant  1.1.5. Electrical and control cables are flame retardant, except for lighting towers					
						1.1.6. Fire protection in wellhead/manifold area in the form of ABC fire portable and wheeled extinguishers					
		1.2. In case of	1	С	Н	1.2.1. Protection relays	3	D	M	6. Study and report	С
		indoors, damage to electrical equipment; also,				1.2.2. ESD and F&G cables are fire-resistant in manifold area				application and costs of providing F&G (H <sub>2</sub> and other detectors) acc. to	
		personnel injury with possibility of fatality				Electrical and control cables are flame retardant in manifold area				PACS, regarding ALARP requirements and practical limitations and also referencing relevant SOW.	
						1.2.4. Smoke and Heat- Smoke detectors in Manifold Area Control Room				SOW.	
						1.2.5. Fire protection in  Manifold Area Control  Room and wellhead  area buildings in the					









# عمومي و مشترك

شماره پیمان:

· ۵۳ - · ۷۳ - 9118

H.	AZID REPOR	T FOR W	HF & FL	OW LINES	
					7

 نسخه
 سریال
 نوع مدرک
 رشته
 تسهیلات
 صادرکننده
 بسته کاری
 پروژه

 BK
 SSGRL
 PEDCO
 110
 GE
 RT
 0003
 D01

شماره صفحه: ۳۱ از ۳۶

Howard	Causas	Canagauanaga	Ris	Risk Matri		Risk Matrix		Safeguards		Risk Matrix		trix	Dacammandation	Been
Hazard	Causes	Consequences	S	L	RR		Sareguards	S	L	RR	Recommendation	Resp.		
							form of ABC fire extinguishers							
	2. Electrocution	2.1. Personnel injury	1	С	Н	2.1.1.	Earthing	3	D	M	13. Study application of	С		
		with possibility of fatality					Protection relays				RCPs in wellhead and manifold areas acc. to			
		ratunty					Cable termination				PACS and relevant			
						2.1.4.	Limited exposure in electrical panels				SOW.			
						2.1.5.	Personnel protection earth relays in electrical racks							
						2.1.6.	Existing plant clinic							
	3. Induction	3.1. Interference in performance of instrumentation	2	С	S	3.1.1.	Segregation between instrument and LV electrical cables	3	D	M	<ol> <li>Ensure that armoured LV cables, if any, are armoured off and</li> </ol>	С		
						3.1.2.	Instrument cables screen shields				connected to earth system, as required by			
						3.1.3.	3-core arrangement for electrical cables				PACS.			
						3.1.4.	EMC level of instrumentation							
						3.1.5.	Minimum safe distance between existing and new cables in case of crossings, to minimize EMC influence							









# عمومي و مشترك

شماره پیمان:

. 24 - . 74 - 9176

	HA	ZID REPOR	T FOR W	HF & FL	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۳۲ از ۳۶

Hamand	Causas	Causes Consequences		sk Ma	trix	Cofemulando	Ris	k Ma	trix	ix Recommendation	Daar
Hazard	Causes	Consequences	S	L	RR	Safeguards		L	RR	Recommendation	Resp
	4. Power failure	4.1. Severe disturbance in production with	1	Α	Н	4.1.1. Fail safe design of IRP pumps and ESD system at manifold area	3	D	M		
		risk of accidents, and also loss of production				4.1.2. 100% redundancy in power supply through Emergency Diesel Generators, which supports LV relays, emergency lighting and DC UPS at wellhead areas					
	5. Existing aerial HV line in case of crane operation; no major concern, as the line only crosses an access road and crane passes through the road in non-operational condition.										











# عمومي و مشترك

شماره پیمان:

· 24 - · 74 - 9114

	HA	ZID REPOR	T FOR W	HF & FL	OW LINES		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	GE	RT	0003	D01

شماره صفحه: ۳۳ از ۳۶

**Hazard Category: 9. Toxic Gases** 

		0	0	Ris	k Mat	trix	0-6	Ris	k Ma	trix	Barraman Jadan	D
	Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
•	1. H <sub>2</sub> S in Process Streams	1. Leakage	1.1. Personnel injury with possibility of	1	С	Н	1.1.1. Operational controls and PPE	2	D	М	15. Plan for improving process safety culture,	N
			fatality				1.1.2. Portable H <sub>2</sub> S detector				and effectiveness of	
							1.1.3. For other safeguards, see Hydrocarbons category				training incl. H <sub>2</sub> S awareness, and enforcing appropriate PPE.	
							1.1.4. Safety signs for H <sub>2</sub> S service				FFE.	
		2. Burn pit flame out	2.1. Personnel injury with possibility of	1	С	Н	2.1.1. Operational controls and PPE	2	D	M	15. Plan for improving process safety culture,	N
			fatality				2.1.2. Portable H₂S detector				and effectiveness of	
							2.1.3. For other safeguards, see Hydrocarbons category				training incl. H <sub>2</sub> S awareness, and enforcing appropriate PPE.	
							2.1.4. Safety signs for H <sub>2</sub> S service				11 2.	
4	2. SO <sub>2</sub>	1. Burn pit	1.1. Personnel exposure may	3	С	M	1.1.1. Safety signs for toxic service	3	С	M	15. Plan for improving process safety culture,	N
			cause health problems and also environmental problem				1.1.2. Operational controls and PPE				and effectiveness of training incl. H <sub>2</sub> S awareness, and enforcing appropriate PPE.	











# عمومي و مشترك

شماره پیمان:

· 24 - · 74 - 9 1 A F

Н	AZID	REPOR	T FOR	WHF	& FLOV	V LINES	

بسته کاری صادر کننده تسهيلات نوع مدرك سريال پروژه نسخه GE SSGRL PEDCO 110 RT 0003 BK D01 شماره صفحه: ۳۵ از ۳۶

**Hazard Category: 10. Entrapment** 

	Hamand	0	0	Ris	Risk Matrix		Coformando	Ris	k Ma	atrix		D
	Hazard	Causes	Consequences	S	L	RR	Safeguards	S	L	RR	Recommendation	Resp.
1	. Emergency	1. Limited access to	1.1. In case of	1	С	Н	1.1.1. Portable H₂S detector	2	С	S	15. Plan for improving	N
	Case	escape routes	accidents in manifold and				1.1.2. Escape routes with safety signs				process safety culture, and effectiveness of	
			wellheads areas, personnel injury				1.1.3. Wind sock				training incl. H <sub>2</sub> S awareness, and	
			with possibility of fatality				1.1.4. Escape mask as regular PPE (not regularly used)				enforcing appropriate PPE.	
							1.1.5. SCBA					
							1.1.6. Photo-luminescent escape route signs in process area					
							1.1.7. For other safeguards, see Hydrocarbons category					
							1.1.8. For other safeguards, see Environment category					
			1.2. In case of accidents inside Manifold Area Control Building,	1	С	Н	1.2.1. Relatively small size of Manifold Area Control Building means quick access to exit door	2	С	S	16. Check and report whether or not electrical and instrument cable covers in the existing	С
			personnel injury with possibility of fatality				1.2.2. For other safeguards, see Electricity category				Manifold Area Control Building are low-smoke type, subject to availability of documents.	