

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 1 از 21	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	BK14	PEDCO	110	HV	CN	0002		D00

طرح نگهداشت و افزایش تولید 27 مخزن

HVAC CALCULATION NOTE FOR SECURITY BUILDING - BK14

نگهداشت و افزایش تولید میدان نفتی بینک

D00	JAN. 2023	IFC	H.Adineh	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
Class: 2		CLIENT Doc. Number: F0Z-708191				

Status:

IDC: Inter-Discipline Check
 IFC: Issued For Comment
 IFA: Issued For Approval
 AFD: Approved For Design
 AFC: Approved For Construction
 AFP: Approved For Purchase
 AFQ: Approved For Quotation
 IFI: Issued For Information
 AB-R: As-Built for CLIENT Review
 AB-A: As-Built –Approved

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D00</td><td>0002</td><td>CN</td><td>HV</td><td>110</td><td>PEDCO</td><td>BK14</td><td>BK</td></tr></table>	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D00	0002	CN	HV	110	PEDCO	BK14	BK	شماره صفحه: 2 از 21
HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D00	0002	CN	HV	110	PEDCO	BK14	BK																			

REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	X				
2	X				
3	X				
4	X				
5	X				
6	X				
7	X				
8	X				
9	X				
10	X				
11	X				
12	X				
13	X				
14	X				
15	X				
16	X				
17	X				
18	X				
19	X				
20	X				
21	X				
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					

PAGE	D00	D01	D02	D03	D04
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					
129					
130					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: 053- 073- 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه 3 از 21
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	BK14	PEDCO	110	HV	CN	0002	
								D00

CONTENTS

1.0	INTRODUCTION.....	4
2.0	SCOPE.....	4
3.0	NORMATIVE REFERENCES	5
3.1	LOCAL CODES AND STANDARDS.....	5
3.2	INTERNATIONAL CODES AND STANDARDS	5
3.3	ENVIRONMENTAL DATA	5
4.0	HVAC CALCULATION	6
4.1	DESIGN WEATHER PARAMETERS:	6
4.2	CONSTRUCTIONS U-VALUE:	8
4.3	SPACE INPUT DATA:	9
4.4	SYSTEM INPUT DATA:	12
5.0	EQUIPMENT SELECTION	20
5.1	AIR CONDITIONING UNIT	20
5.2	EXHAUST FAN SELECTION	21

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 4 از 21	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	BK14	PEDCO	110	HV	CN	0002		D00

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO).Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – General Facilities
GENERAL CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of :Hirgan Energy – Design & Inspection(D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC CONTRACTOR(GC) and approved by CLIENT (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by CLIENT rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR
MAY:	Is used where a provision is completely discretionary.

2.0 SCOPE

This document covers minimum necessary requirements for basis of design and main equipment's to be used for the Heating, Ventilating, Air-Conditioning and pressurizing and plumbing system for buildings for project

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 5 از 21	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	BK14	PEDCO	110	HV	CN	0002		D00

3.0 NORMATIVE REFERENCES

3.1 LOCAL CODES AND STANDARDS

- IPS Iranian petroleum standards
- INBC Iranian National Building Code

3.2 INTERNATIONAL CODES AND STANDARDS

- ASTM American Society for Testing Materials Relevant Parts
- API 610 Centrifugal Pumps for General Refinery Service, 10th Edition
- ISO 15156 Petroleum and Natural Gas Industries. Materials for use in H2S Containing Environments in Oil and Gas Production
- AMCA Air Movement and Control Association
- ANSI American National Standards Institute.
- ASHRAE American Society of Heating, Refrigeration and Air-conditioning Engineer
- ASTM American Society for Testing and Material
- BOCA Building Officials and Code Administrators international
- BS British Standards
- CIBSE Chartered Institute of Building Services Engineers.
- NFPA National fire protection association
- SBCCI Southern Building Code Congress International
- SMACNA Sheet Metal and Air Conditioning Contractors' National Association
- AWWA American Water Works Association
- ASME The American Society of Mechanical Engineers

Note: The latest issued or revised edition of all above mentioned codes and standards shall be considered as reference.

3.3 ENVIRONMENTAL DATA

Refer to "Process Basis of Design; Doc. No BK-GNRAL-PEDCO-000-PR-DB-0001 .

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: 053 - 073 - 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 6 از 21
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	BK14	PEDCO	110	HV	CN	0002	
							D00	

4.0 HVAC CALCULATION

4.1 DESIGN WEATHER PARAMETERS:

DESIGN PARAMETERS:

City Namebink

Location.....IRAN

Latitude.....30.3

Deg.Longitude.....-50.2

Deg.Elevation.....10.0 m

Summer Design Dry-Bulb.....41.0 °C

Summer Coincident Wet-Bulb.....30.5 °C

Summer Daily Range.....15.0

°K Winter Design Dry-Bulb.....6.0 °C

Winter Design Wet-Bulb.....6.0 °C

Atmospheric Clearness Number.....1.00

Average Ground Reflectance.....0.20

Soil Conductivity.....1.385

W/(m.°K)Local Time Zone (GMT +/- N hours).....-1.0 hours

Consider Daylight Savings Time.....No

Simulation Weather Data.....none N/A

Current Data is.....User Modified

Design Cooling Months.....January to December

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 7 از 21
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	BK14	PEDCO	110	HV	CN	0002	
								D00

DESIGN DAY MAXIMUM SOLAR HEAT GAINS

(The MSHG values are expressed in W/m²)

Month	N	NNE	NE	ENE	E	ESE	SE	SSE	S
January	76.4	76.4	104.1	335.1	577.4	722.3	796.4	786.7	764.0
February	88.0	88.0	230.9	458.1	662.9	773.4	774.9	717.7	674.9
March	100.7	108.6	368.7	585.3	707.6	758.3	705.1	595.4	528.1
April	113.1	256.3	472.2	642.7	716.0	679.9	580.0	422.9	334.5
May	124.2	353.9	534.8	663.8	694.2	620.4	475.0	290.9	209.6
June	157.8	384.6	558.6	667.1	676.8	585.8	428.0	240.6	172.3
July	127.6	344.7	537.1	656.3	678.1	598.4	463.4	281.6	203.3
August	118.2	248.3	466.5	623.6	687.8	654.3	558.9	407.2	322.5
September	104.5	113.3	336.6	555.0	683.3	716.4	681.4	580.5	517.4
October	90.9	90.9	201.8	462.7	636.7	736.7	756.5	701.7	660.0
November	77.8	77.8	98.3	345.3	551.3	718.6	773.6	774.1	756.1
December	71.4	71.4	71.4	269.7	530.8	696.4	785.4	795.0	786.8
Month	SSW	SW	WSW	W	WNW	NW	NNW	HOR	Mult
January	789.5	796.9	721.1	569.2	354.1	83.2	76.4	579.3	1.00
February	722.0	781.4	766.3	669.5	467.5	224.5	88.0	702.0	1.00
March	596.6	704.4	761.1	720.6	569.4	368.1	116.6	809.9	1.00
April	421.4	576.3	689.2	714.5	631.4	476.0	257.9	863.7	1.00
May	289.5	470.8	624.0	691.1	655.0	542.6	355.7	877.6	1.00
June	238.3	421.9	590.9	670.1	656.4	565.4	389.3	873.7	1.00
July	278.1	456.2	609.2	671.7	644.3	540.2	353.4	863.9	1.00
August	405.5	554.8	664.2	689.2	610.9	463.3	256.0	845.0	1.00
September	580.7	681.6	714.0	684.8	554.4	333.4	114.2	785.9	1.00
October	698.5	750.4	744.7	624.3	458.7	216.5	90.9	693.3	1.00
November	770.3	775.6	718.6	559.7	335.4	103.0	77.8	579.1	1.00
December	796.5	774.3	701.4	517.9	296.9	71.4	71.4	527.6	1.00

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14								شماره صفحه: 8 از 21
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	BK14	PEDCO	110	HV	CN	0002	D00	

4.2 CONSTRUCTIONS U-VALUE:

External Wall

Wall Details

Outside Surface Color Medium
Absorptivity 0.675
Overall U-Value 0.589 W/(m²-°K)

Wall Layers Details (Inside to Outside)

Layers	Thickness mm	Density kg/m ³	Specific Ht. kJ / (kg - °K)	R-Value (m ² -°K)/W	Weight kg/m ²
Inside surface resistance	0.000	0.0	0.00	0.12064	0.0
concrete block	250.000	2000.0	0.84	0.23750	500.0
insulation	50.000	40.0	0.92	1.19000	2.0
100mm face brick	100.000	2002.3	0.92	0.09000	200.2
Outside surface resistance	0.000	0.0	0.00	0.05864	0.0
Totals	400.000	-		1.69678	702.2

External Roof

Roof Details

Outside Surface Color Dark
Absorptivity 0.900
Overall U-Value 0.642 W/(m²-°K)

Roof Layers Details (Inside to Outside)

Layers	Thickness mm	Density kg/m ³	Specific Ht. kJ / (kg - °K)	R-Value (m ² -°K)/W	Weight kg/m ²
Inside surface resistance	0.000	0.0	0.00	0.12064	0.0
50mm HW concrete	50.000	2242.6	0.84	0.03000	112.1
poly styrene block	200.000	10.0	0.84	0.59000	2.0
Built-up roofing	100.000	1121.3	1.47	0.61467	112.1
terrazzo	25.000	0.0	0.84	0.14449	0.0
Outside surface resistance	0.000	0.0	0.00	0.05864	0.0
Totals	375.000	-		1.55843	226.3

DOOR (1.0 x 2.2)

Door Details:

Gross Area 2.2 m²
Door U-Value 4.000 W/(m²-°K)

Glass Details:

Glass Area 0.0 m²
Glass U-Value 3.293 W/(m²-°K)
Glass Shade Coefficient 0.880
Glass Shaded All Day? No

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14								شماره صفحه: 9 از 21
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	BK14	PEDCO	110	HV	CN	0002	D00	

WINDOWS

WIN1

Window Details:

Detailed Input No
 Height 1.80 m
 Width 1.50 m
 Overall U-Value 3.339 W/(m²-°K)
 Overall Shade Coefficient 0.500

WIN2

Window Details:

Detailed Input No
 Height 1.20 m
 Width 1.50 m
 Overall U-Value 3.339 W/(m²-°K)
 Overall Shade Coefficient 0.500

4.3 SPACE INPUT DATA:

GAURD ROOM

1. General Details:

Floor Area 21.0 m²
 Avg. Ceiling Height 3.2 m
 Building Weight 341.8 kg/m²

1.1. OA Ventilation Requirements:

Space Usage User-Defined
 OA Requirement 1 0.0 L/s
 OA Requirement 2 0.0 L/s
 Space Usage Defaults . ASHRAE Standard 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
 Wattage 288.0 Watts
 Ballast Multiplier 1.20
 Schedule Lighting

2.4. People:

Occupancy 2.0 People
 Activity Level Office Work
 Sensible 71.8 W/person
 Latent 60.1 W/person
 Schedule People

2.2. Task Lighting:

Wattage 0.00 W/m²
 Schedule None

2.5. Miscellaneous Loads:

Sensible 0 W
 Schedule None
 Latent 0 W
 Schedule None

2.3. Electrical Equipment:

Wattage 200.0 Watts
 Schedule Equipment

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (m ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
WNW	19.5	2	0	0
NNE	13.7	1	0	1
SSW	19.5	1	0	1

3.1. Construction Types for Exposure WNW

Wall Type External Wall
 1st Window Type WIN1
 1st Window Shade Type shade1

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14								شماره صفحه: 10 از 21
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	BK14	PEDCO	110	HV	CN	0002	D00	

3.2. Construction Types for Exposure NNE

Wall Type External Wall
 1st Window Type WIN1
 1st Window Shade Type shade2
 Door Type 1*2.2

3.3. Construction Types for Exposure SSW

Wall Type External Wall
 1st Window Type WIN1
 1st Window Shade Type shade3
 Door Type 1*2.2

4. Roofs, Skylights:

Exp.	Roof Gross Area (m ²)	Roof Slope (deg.)	Skylight Qty.
H	21.0	0	0

4.1. Construction Types for Exposure H

Roof Type External Roof

5. Infiltration:

Design Cooling 35.00 L/s
 Design Heating 35.00 L/s
 Energy Analysis 0.00 L/s
 Infiltration occurs at all hours.

6. Floors:

Type Slab Floor On Grade
 Floor Area 21.0 m²
 Total Floor U-Value 2.000 W/(m²-°K)
 Exposed Perimeter 12 m
 Edge Insulation R-Value 0.00 (m²-°K)/W

7. Partitions:

7.1. 1st Partition Details:

Partition Type Wall Partition
 Area 10.0 m²
 U-Value 2.839 W/(m²-°K)
 Uncondit. Space Max Temp 35.0 °C
 Ambient at Space Max Temp 41.0 °C
 Uncondit. Space Min Temp 14.0 °C
 Ambient at Space Min Temp 6.0 °C

7.2. 2ND Partition Details:

REST ROOM & PANTRY

1. General Details:

Floor Area 22.0 m²
 Avg. Ceiling Height 3.2 m
 Building Weight 341.8 kg/m²

1.1. OA Ventilation Requirements:

Space Usage User-Defined
 OA Requirement 1 0.0 L/s
 OA Requirement 2 0.00 L/(s-m²)
 Space Usage Defaults . ASHRAE Standard 62.1-2007

2. Internals:

2.1. Overhead Lighting:

Fixture Type Free Hanging
 Wattage 216 watts
 Ballast Multiplier 1.20
 Schedule Lighting

2.2. Task Lighting:

Wattage 0.00 W/m²
 Schedule None

2.4. People:

Occupancy 1.0 Person
 Activity Level Office Work
 Sensible 71.8 W/person
 Latent 60.1 W/person
 Schedule People

2.5. Miscellaneous Loads:

Sensible 480 W
 Schedule Equipment
 Latent 250 W

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 11 از 21	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	BK14	PEDCO	110	HV	CN	0002		D00

Schedule Equipment

2.3. Electrical Equipment:

Wattage 200.0 Watts

Schedule Equipment

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (m ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
ESE	19.5	1	0	0
NNE	17.1	1	0	0
SSW	17.1	0	0	0

3.1. Construction Types for Exposure ESE

Wall Type External Wall

1st Window Type WIN2

3.2. Construction Types for Exposure NNE

Wall Type External Wall

1st Window Type WIN2

3.3. Construction Types for Exposure SSW

Wall Type External Wall

4. Roofs, Skylights:

Exp.	Roof Gross Area (m ²)	Roof Slope (deg.)	Skylight Qty.
H	22.0	0	0

4.1. Construction Types for Exposure H

Roof Type External Roof

5. Infiltration:

Design Cooling 35.00 L/s

Design Heating 35.00 L/s

Energy Analysis 0.00 L/s

Infiltration occurs at all hours.

6. Floors:

Type Slab Floor On Grade

Floor Area 21.0 m²

Total Floor U-Value 2.000 W/(m²-°K)

Exposed Perimeter 13.2 m

Edge Insulation R-Value 0.00 (m²-°K)/W

7. Partitions:

7.1. 1st Partition Details:

Partition Type Wall Partition

Area 7.0 m²

U-Value 2.839 W/(m²-°K)

Uncondit. Space Max Temp 35.0 °C

Ambient at Space Max Temp 41.0 °C

Uncondit. Space Min Temp 14.0 °C

Ambient at Space Min Temp 6.0 °C

7.2. 2nd Partition Details:

(No partition data).

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">HVAC CALCULATION NOTE FOR SWITCHGEAR BUILDING – bk14</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D01</td><td>0001</td><td>CN</td><td>HV</td><td>110</td><td>PEDCO</td><td>Bk14</td><td>BK</td></tr></table>	HVAC CALCULATION NOTE FOR SWITCHGEAR BUILDING – bk14								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D01	0001	CN	HV	110	PEDCO	Bk14	BK	شماره صفحه: 12 از 21
HVAC CALCULATION NOTE FOR SWITCHGEAR BUILDING – bk14																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
D01	0001	CN	HV	110	PEDCO	Bk14	BK																			

4.4 SYSTEM INPUT DATA:

1. General Details:

Air System Name SECURITY BUILDING OF WELL PAD 14
Equipment Type Terminal Units
Air System Type Split DX Fan Coil
Number of zones 1
Ventilation Direct Ventilation

2. Ventilation System Components:

(Common Ventilation System not used: no inputs)

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
GAURD ROOM	x1
REST ROOM	x1

Thermostats and Zone Data:

Zone	Cooling T-Stat Occ. (°C)	Cooling T-Stat Unocc. (°C)	Heating T-Stat Occ. (°C)	Heating T-Stat Unocc. (°C)	T-Stat Throttling Range (°C)
1	24.0	24.0	22.0	22.0	0.83

Thermostat Schedule Fan
Unoccupied Cooling is Available

Common Terminal Unit Data:

Cooling Coil:

Design Supply Temperature 14.0 °C
Coil Bypass Factor 0.100
Cooling Source Air-Cooled DX
Schedule JFMAMJJASOND

Heating Coil:

Design Supply Temperature 35.0 °C
Heating Source Electric Resistance
Schedule JFMAMJJASOND

Fan Control Fan On
Ventilation Sizing Method Sum of Space OA Airflows

Terminal Units Data:

Zone All
Terminal Type Fan Coil
Minimum Airflow 0.00 L/s/person
Fan Performance 1000 Pa
Fan Overall Efficiency 50 %

4. Sizing Data (Computer-Generated):

System Sizing Data:

Sizing Data:

Cooling Supply Temperature 14.0 °C
Heating Supply Temperature 35.0 °C

Hydronic Sizing Specifications:

Chilled Water Delta-T 5.6 °K
Hot Water Delta-T 11.1 °K

Safety Factors:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SWITCHGEAR BUILDING – bk14								شماره صفحه: 13 از 21
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	Bk14	PEDCO	110	HV	CN	0001	D01	

Cooling Sensible 10 %
Cooling Latent 10 %
Heating 10 %

Zone Sizing Data:

Zone Airflow Sizing Method Sum of space airflow rates
Space Airflow Sizing Method Individual peak space loads

Zone	Supply Airflow (L/s)	Zone Htg Unit (kW)	Reheat Coil (kW)	Ventilation (L/s)
1	628.4	-	-	0.0

5. Equipment Data

Terminal Cooling Units - Air-Cooled DX

Zone	Estimated Maximum Load (kW)	Design OAT (°C)	Equipment Sizing	Gross Cooling Capacity (kW)	Capacity Oversizing Factor (%)	Compressor + OD Fan Power (kW)	ARI Performance Rating	Unit s	Conventional Cutoff OAT (°C)
1	11.7	35.0	Auto-Sized	-	0	-	3.224	EER	-17.8

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073 – 9184	HVAC CALCULATION NOTE FOR SWITCHGEAR BUILDING – BK14							شماره صفحه: 14 از 21	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	BK14	PEDCO	110	HV	CN	0002		D00

Air System Information

Air System Name **SECURITY BUILDING OF WELL PAD 14**
Equipment Class **TERM**
Air System Type **SPLT-FC**

Number of zones **1**
Floor Area **43.0** m²
Location **binak, IRAN**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14								شماره صفحه: 15 از 21
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه	
	BK	BK14	PEDCO	110	HV	CN	0002	D00	

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (kW)	Design Airflow (L/s)	Minimum Airflow (L/s)	Time of Peak Load	Maximum Heating Load (kW)	Zone Floor Area (m²)	Zone L/(s-m²)
Zone 1	7.6	628	628	Jul 1500	4.8	43.0	14.61

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 5.6 °K (L/s)	Time of Peak Load
Zone 1	11.7	8.5	26.3 / 19.8	15.1 / 14.5	-	Jun 1500

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 °K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	3.5	23.4 / 28.1	-	628	1.584	1.257	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s-m²)
Zone 1							
GAURD ROOM	1	4.3	Jul 1500	354	2.7	21.0	16.87
REST ROOM	1	3.3	Jul 1500	274	2.1	22.0	12.46

Ventilation Sizing Summary

1. Summary

Ventilation Sizing Method Sum of Space OA Airflows

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (m²)	Maximum Occupant s	Maximum Supply Air (L/s)	Required Outdoor Air (L/s/person)	Required Outdoor Air (L/(s-m²))	Required Outdoor Air (L/s)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (L/s)
Zone 1									
GAURD ROOM	1	21.0	2.0	354.4	0.00	0.00	0.0	0.0	0.0
REST ROOM	1	22.0	1.0	274.0	0.00	0.00	0.0	0.0	0.0
Totals (incl. Space Multipliers)				628.4					0.0

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14								شماره صفحه: 16 از 21
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	BK14	PEDCO	110	HV	CN	0002	D00	

Air System Design Load Summary

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jun 1500			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 40.4 °C / 30.5 °C			HEATING OA DB / WB 6.0 °C / 6.0 °C		
ZONE LOADS	Details	Sensible (W)	Latent (W)	Details	Sensible (W)	Latent (W)
Window & Skylight Solar Loads	14 m²	1097	-	14 m²	-	-
Wall Transmission	88 m²	652	-	88 m²	826	-
Roof Transmission	43 m²	613	-	43 m²	441	-
Window Transmission	14 m²	661	-	14 m²	769	-
Skylight Transmission	0 m²	0	-	0 m²	0	-
Door Loads	4 m²	242	-	4 m²	282	-
Floor Transmission	42 m²	0	-	42 m²	307	-
Partitions	17 m²	437	-	17 m²	386	-
Ceiling	0 m²	0	-	0 m²	0	-
Overhead Lighting	605 W	605	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	400 W	400	-	0	0	-
People	3	215	180	0	0	0
Infiltration	-	1388	2468	-	1350	0
Miscellaneous	-	480	250	-	0	0
Safety Factor	10% / 10%	679	290	10%	436	0
>> Total Zone Loads	-	7470	3188	-	4798	0
Zone Conditioning	-	7262	3188	-	4797	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Exhaust Fan Load	0 L/s	0	-	0 L/s	0	-
Ventilation Load	0 L/s	0	0	0 L/s	0	0
Ventilation Fan Load	0 L/s	0	-	0 L/s	0	-
Space Fan Coil Fans	-	1257	-	-	-1257	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	8519	3188	-	3540	0
Terminal Unit Cooling	-	8519	3208	-	0	0
Terminal Unit Heating	-	0	-	-	3540	-
>> Total Conditioning	-	8519	3208	-	3540	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 - 073 - 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14								شماره صفحه: 17 از 21
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	BK14	PEDCO	110	HV	CN	0002	D02	

Zone Design Load Summary

Zone 1		DESIGN COOLING			DESIGN HEATING		
		COOLING DATA AT Jul 1500			HEATING DATA AT DES HTG		
		COOLING OA DB / WB 41.0 °C / 30.5 °C			HEATING OA DB / WB 6.0 °C / 6.0 °C		
		OCCUPIED T-STAT 24.0 °C			OCCUPIED T-STAT 22.0 °C		
ZONE LOADS	Details	Sensible (W)	Latent (W)		Details	Sensible (W)	Latent (W)
Window & Skylight Solar Loads	14 m ²	1069	-		14 m ²	-	-
Wall Transmission	88 m ²	679	-		88 m ²	826	-
Roof Transmission	43 m ²	612	-		43 m ²	441	-
Window Transmission	14 m ²	688	-		14 m ²	769	-
Skylight Transmission	0 m ²	0	-		0 m ²	0	-
Door Loads	4 m ²	252	-		4 m ²	282	-
Floor Transmission	42 m ²	0	-		42 m ²	307	-
Partitions	17 m ²	453	-		17 m ²	386	-
Ceiling	0 m ²	0	-		0 m ²	0	-
Overhead Lighting	605 W	605	-		0	0	-
Task Lighting	0 W	0	-		0	0	-
Electric Equipment	400 W	400	-		0	0	-
People	3	215	180		0	0	0
Infiltration	-	1435	2390		-	1350	0
Miscellaneous	-	480	250		-	0	0
Safety Factor	10% / 10%	689	282		10%	436	0
>> Total Zone Loads	-	7577	3102		-	4798	0

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 18 از 21	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	BK14	PEDCO	110	HV	CN	0002		D00

Space Design Load Summary

TABLE 1.1.A. COMPONENT LOADS FOR SPACE " GAURD ROOM " IN ZONE " Zone 1 "						
	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1500 COOLING OA DB / WB 41.0 °C / 30.5 °C OCCUPIED T-STAT 24.0 °C			HEATING DATA AT DES HTG HEATING OA DB / WB 6.0 °C / 6.0 °C OCCUPIED T-STAT 22.0 °C		
		Sensible	Latent		Sensible	Latent
SPACE LOADS	Details	(W)	(W)	Details	(W)	(W)
Window & Skylight Solar Loads	11 m ²	859	-	11 m ²	-	-
Wall Transmission	38 m ²	285	-	38 m ²	354	-
Roof Transmission	21 m ²	299	-	21 m ²	216	-
Window Transmission	11 m ²	516	-	11 m ²	577	-
Skylight Transmission	0 m ²	0	-	0 m ²	0	-
Door Loads	4 m ²	252	-	4 m ²	282	-
Floor Transmission	21 m ²	0	-	21 m ²	150	-
Partitions	10 m ²	267	-	10 m ²	227	-
Ceiling	0 m ²	0	-	0 m ²	0	-
Overhead Lighting	346 W	346	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	200 W	200	-	0	0	-
People	2	144	120	0	0	0
Infiltration	-	717	1195	-	675	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 10%	388	132	10%	248	0
>> Total Zone Loads	-	4273	1447	-	2728	0

TABLE 1.1.B. ENVELOPE LOADS FOR SPACE " GAURD ROOM " IN ZONE " Zone 1 "						
				COOLING	COOLING	HEATING
	Area	U-Value	Shade	TRANS	SOLAR	TRANS
	(m ²)	(W/(m ² ·°K))	Coeff.	(W)	(W)	(W)
WNW EXPOSURE						
WALL	14	0.589	-	116	-	133
WINDOW 1	5	3.339	0.500	258	643	288
NNE EXPOSURE						
WALL	9	0.589	-	65	-	83
WINDOW 1	3	3.339	0.500	129	110	144
DOOR	2	4.000	-	126	-	141
SSW EXPOSURE						
WALL	15	0.589	-	104	-	138
WINDOW 1	3	3.339	0.500	129	105	144
DOOR	2	4.000	-	126	-	141
H EXPOSURE						
ROOF	21	0.642	-	299	-	216

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 - 073 - 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 19 از 21	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	BK14	PEDCO	110	HV	CN	0002		D00

TABLE 1.2.A. COMPONENT LOADS FOR SPACE " REST ROOM " IN ZONE " Zone 1 "						
	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1500 COOLING OA DB / WB 41.0 °C / 30.5 °C OCCUPIED T-STAT 24.0 °C			HEATING DATA AT DES HTG HEATING OA DB / WB 6.0 °C / 6.0 °C OCCUPIED T-STAT 22.0 °C		
		Sensible	Latent		Sensible	Latent
SPACE LOADS	Details	(W)	(W)	Details	(W)	(W)
Window & Skylight Solar Loads	4 m ²	210	-	4 m ²	-	-
Wall Transmission	50 m ²	394	-	50 m ²	472	-
Roof Transmission	22 m ²	313	-	22 m ²	226	-
Window Transmission	4 m ²	172	-	4 m ²	192	-
Skylight Transmission	0 m ²	0	-	0 m ²	0	-
Door Loads	0 m ²	0	-	0 m ²	0	-
Floor Transmission	21 m ²	0	-	21 m ²	157	-
Partitions	7 m ²	187	-	7 m ²	159	-
Ceiling	0 m ²	0	-	0 m ²	0	-
Overhead Lighting	259 W	259	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	200 W	200	-	0	0	-
People	1	72	60	0	0	0
Infiltration	-	717	1195	-	675	0
Miscellaneous	-	480	250	-	0	0
Safety Factor	10% / 10%	300	151	10%	188	0
>> Total Zone Loads	-	3304	1656	-	2070	0

TABLE 1.2.B. ENVELOPE LOADS FOR SPACE " REST ROOM " IN ZONE " Zone 1 "						
				COOLING	COOLING	HEATING
	Area	U-Value	Shade	TRANS	SOLAR	TRANS
	(m ²)	(W/(m ² ·°K))	Coeff.	(W)	(W)	(W)
ESE EXPOSURE						
WALL	18	0.589	-	159	-	167
WINDOW 1	2	3.339	0.500	86	129	96
NNE EXPOSURE						
WALL	15	0.589	-	112	-	144
WINDOW 1	2	3.339	0.500	86	81	96
SSW EXPOSURE						
WALL	17	0.589	-	122	-	161
H EXPOSURE						
ROOF	22	0.642	-	313	-	226

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: 053 - 073- 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 20 از 21
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	BK14	PEDCO	110	HV	CN	0002	D00

5.0 Equipment Selection

5.1 AIR CONDITIONING UNIT

- **Guard Room** Total Cooling Load= 5720 w

Actual Total Cooling Load with considering 10% over capacity = 6292 w $\approx$ 21468 btu/hr

Actual Total heating Load with considering 10% over capacity = 2728 * 1.1 * 3.412=10238 btu/hr

Split Unit Actual Cooling/Heating Capacity= 21468 / 10238 btu/hr

Guard Room load ÷ Quantity = 21468 btu/hr ÷ 1 = 21468 btu/hr → 1*split unit 24000 nominal load-wall mounted

(Tropical-heat pump type)

(nominal capacity will be checked by vendor according to ambient temperature)

Indoor Unit Equipment No: 1301-BK-14-SUI-01

Quantity: 1

Type : wall mounted

Outdoor Unit Equipment No: 1301-BK14-SUO-01

- **Rest Room & Pantry** Total Cooling Load= 4960 w

Actual Total Cooling Load with considering 10% over capacity = 5456 w $\approx$ 18615 btu/hr

Actual Total heating Load with considering 10% over capacity = 2070 * 1.1 * 3.412=7769 btu/hr

Split Unit Actual Cooling/Heating Capacity= 18615 / 7769 btu/hr

Guard Room load ÷ Quantity = 18615 btu/hr ÷ 1 = 18615 btu/hr → 1*split unit 24000 nominal load-wall mounted

(Tropical-heat pump type)

(nominal capacity will be checked by vendor according to ambient temperature)

Indoor Unit Equipment No: 1301-BK-14-SUI-02

Quantity: 1

Type : wall mounted

Outdoor Unit Equipment No: 1301-BK14-SUO-02

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 - 073- 9184	HVAC CALCULATION NOTE FOR SECURITY BUILDING – BK14							شماره صفحه: 21 از 21	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	BK14	PEDCO	110	HV	CN	0002		D00

5.2 EXHAUST FAN SELECTION

Equipment No:	1301-BK14-EF-01	1301-BK14-EF-02
Quantity	1	1
Type	AXIAL(PIPE MOUNTED)	Wall Mounted
Flow Rate(litr/s)	35	35
Static Pressure	Pvc pipe:15 pa	15 pa
Service Area	Toilet (Indoor)	Toilet
Remarks		