

· 27 - · 77 - 9114

#### نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های رو زمینی در بسته های کاری تحت الارض

#### عمومي و مشترك

شماره پیمان:

**CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS SWITCHGEAR BUILDING** 

بسته کاری

SSGRL

پروژه

BK

صادر کننده تسهيلات رشته نوع مدرك سريال PEDCO CN D02 110 0002

شماره صفحه: ۱ از ۸

### طرح نگهداشت و افزایش تولید ۲۷ مخزن

### CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS **SWITCHGEAR BUILDING**

نگهداشت و افزایش تولید میدان نفتی بینک

Class: 2		CLIENT Doc Number: F07	7_707378			
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
D00	May. 2022	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	
D01	Oct. 2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D02	Dec. 2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	

CLIENT Doc. Number: FUZ-70/3/8

Status:

**IDC: Inter-Discipline Check IFC: Issued For Comment** IFA: Issued For Approval AFD: Approved For Design **AFC: Approved For Construction** AFP: Approved For Purchase AFQ: Approved For Quotation IFI: Issued For Information AB-R: As-Built for CLIENT Review AB-A: As-Built -Approved



· 27 - · 77 - 9114

### نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های رو زمینی در بسته های کاری تحت الارض

### عمومي و مشترك



شماره پیمان:

## CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS SWITCHGEAR BUILDING

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 SSGRL
 PEDCO
 110
 EL
 CN
 0002
 D02

شماره صفحه: ۲ از ۸

### REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	Х	Х	Х		
2	X	X	X		
3	X				
4	X				
5	Х	Х	Х		
6	Х	Х	Х		
7	Х				
8	Х				
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34	1				
35	<u> </u>			<u> </u>	
36	<u> </u>			<u> </u>	
37	<u> </u>			<u> </u>	
38	1				
39				-	
40				-	
41				-	
42				-	
43				-	
44				-	
45				-	
46	1			<u> </u>	
47				<del>                                     </del>	
48				1	
49 50	1			<b></b>	ļ

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86			ļ		
87					
88					
89					
90					
91 92					
93 94					
95					
95 96			1		
96			1		
98			1		
98			-		
100					
100			<u> </u>		





### عمومي و مشترك

شماره پیمان:

## CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS SWITCHGEAR BUILDING

شماره صفحه: ۳ از ۸

· 27 - · 77 - 9114

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 SSGRL
 PEDCO
 110
 EL
 CN
 0002
 D02

### **CONTENTS**

1.0	INTRODUCTION	4
2.0	SCOPE	
3.0	NORMATIVE REFERENCES	5
3.1 3.2	CODES AND STANDARDSTHE PROJECT REFERENCE DOCUMENTS	5 5
4.0	LANGUAGE AND SYSTEM OF UNITS	5
5.0	LIGHTING SYSTEM	5
6.0	DESIGN SOFTWARE	8
7.0	LIGHTING CALCULATION – DETAIL REPORT	8



111P - 77. - 7A.

### نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های رو زمینی در بسته های کاری تحت الارض

#### عمومي و مشترك



شماره پیمان:

## CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS SWITCHGEAR BUILDING

نوع مدرک صادر کننده تسهيلات بسته کاری رشته سريال نسخه پروژه PEDCO EL D02 BK SSGRL 110 CN 0002

شماره صفحه: ۴ از ۸

#### 1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

#### **GENERAL DEFINITION**

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)
PROJECT: Binak Oilfield Development – General Facilities

EPD/EPC CONTRACTOR(GC) Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy - Design &

Inspection(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR(GC)

and approved by COMPANY (in writing) for the

inspection of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.



#### عمومي و مشترك



شماره پیمان:

CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS SWITCHGEAR BUILDING

نوع مدر*ک* صادر کننده پروژه بسته کاری تسهيلات رشته نسخه سريال BK PEDCO EL D02 SSGRL 110 CN 0002

شماره صفحه: ۵ از ۸

#### 2.0 SCOPE

24.16 - 21.4 - 27.4 - 27.4

This specification describes the practices that shall be employed and the Standards that will be required to be met for the Indoor Lightings Illumination

#### 3.0 NORMATIVE REFERENCES

#### 3.1 CODES AND STANDARDS

 IPS-E-EL-100 Engineering Standard For Electrical System Design (Industrial And Non-Industrial)

#### 3.2 THE PROJECT REFERENCE DOCUMENTS

BK-GNRAL-PEDCO-000-PR-DB-0001 Process Basis Of Design
 BK-GNRAL-PEDCO-000-EL-DC-0001 Electrical System Design Criteria
 BK-GNRAL-PEDCO-000-EL-SP-0007 Specification For Lighting & Small Power System
 BK-W046S-PEDCO-110-AR-DW-0003 Architectural Drawing for Switchgear Building of Well Pads - W046S

BK-W046S-PEDCO-110-SA-PY-0001 Hazardous Area Classification W046S

#### 4.0 LANGUAGE AND SYSTEM OF UNITS

All documentation, drawings, data, etc. furnished by the manufacturer shall be in English. SI metric system of measurement shall be used except for pipe and pipe fitting sizes, flange ratings and nozzle dimensions in which inch will be used.

#### 5.0 LIGHTING SYSTEM

The lighting system will provide a uniform and adequate light distribution in all working areas, the minimum average illumination levels will be as per IPS-E-EL-100(1). Major areas indicated in the below table:



## عمومي و مشترك



شماره پیمان:

# CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS SWITCHGEAR BUILDING

شماره صفحه: ۶ از ۸

 $\bullet \Delta \Upsilon - \bullet V \Upsilon - 91 \lambda \Upsilon$ 

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	SSGRL	PEDCO	110	EL	CN	0002	D02

#### **TABLE 15 - ILLUMINANCES LEVELS**

AREA OR ACTIVITY	MINIMUM ILLUMINANCE	ELEVATION		
AUCEN SIGNATURE	LUX	MILLIMETER		
I PROCESS AREAS				
A) General process units				
Pump rows, valves, manifolds				
Heat exchangers	50	Ground		
Maintenance platforms	30	Ground		
Operating platforms Cooling towers (equipment areas)	10 50	Floor Floor		
Furnaces	50	Ground		
Ladders and stairs (inactive)	30	Ground		
Ladders and stairs (active)	30	Floor		
Gage glasses	50	Floor		
Instruments (on process units)	50	Eye level		
Compressor houses	50	Eye level		
Separators General area	200 50	Floor Top of bay		
General alea	10	Ground		
B) Control rooms and houses	10	Oround		
Ordinary control house				
Instrument panel	300	Floor		
Console	300	1700		
Back of panel	300	760		
Central control house Instrument	100 500	760 Floor		
Back of pane	500	1700		
Buck of pune	100	900		
C) Specialty process units				
Conveyors				
Conveyor transfer points	20	Surface		
II NONPROCESS AREA	50	Surface		
II NONPROCESS AREA				
A) Loading, unloading, and cooling water				
pump houses, Pump area				
General control area	50	Ground		
Control panel	150	Floor		
B) Boiler and air compressor plants	200	1100		
Indoor				
Outdoor equipment 50	200	Floor		
	50	Ground		
C) Tank fields (where lighting is required)				
Ladders and stairs	_			
Gating area	5	Floor		
Manifold area	10	Ground Floor		
D) Loading racks		1 1001		
General area				
Tank car	50	Floor		
Tank trucks, loading point	100	Point		
F. F. J. J. J. C. 100	100	Point		
E) Tanker dock facilities				
	1			



## عمومی و مشترک



شماره پیمان:

# CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS SWITCHGEAR BUILDING

· 24 - · 74 - 9114

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	١
BK	SSGRL	PEDCO	110	EL	CN	0002	D02	

شماره صفحه: ۷ از ۸

F) Electrical substations and switch yardsd		
Outdoor switch yards		
General substation (outdoor)	20	Ground
Substation operating aisles	20	Ground
General substation (indoor)	150	Floor
Switch racks	50	Floor
SWILLITTACKS		
G) Plantroad lighting (where lighting is	50	1200
requiredd)		
Frequent use (trucking)		
Infrequent use	4	Ground
·	2	Ground
H) Plant parking lotsd		
,	1	Ground
I) Aircraft obstruction lightinge		
III Buildings		
_		
A) Offices		
	500	
B) Laboratories		
Qualitative, quantitative and physical test		
Research, experimental	500	900
Pilot plant, process and specialty	500	900
Glassware, washrooms	300	Floor
Fume hoods	300	900
Stock rooms	300	900
Stock rooms	150	Floor
C) Warehouses and stock rooms	100	11001
Indoor bulk storage		
Outdoor bulk storage	50	Floor
	5	Ground
Large bin storage Small bin storage	50	760
Small parts storage	100	760
Counter tops	200	760
D/ D : 1	300	1200
D) Repair shop		
Large fabrication		
Bench and machine work	200	Floor
Crane way, aisles	500	760
Small machine	150	Floor
Sheet metal	300	760
Electrical	200	760
Instrument	200	760
	300	760
E) Change housed		
Locker room, shower		
Lavatory	100	Floor
Latatory	100	Floor
F) Clock house and entrance gatehouse	1.00	
Card rack and clock area		
Entrance gate, inspection	100	Floor
General	150	Floor
General		
	50	Floor



· 27 - · 77 - 9114

#### نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های رو زمینی در بسته های کاری تحت الارض

## عمومی و مشترک



شماره پیمان:

CALCULATION NOTE FOR LIGHTING SYSTEM OF WELL PADS SWITCHGEAR BUILDING

بسته کاری صادر کننده تسهيلات رشته نوع مدرك نسخه پروژه سر يال BK SSGRL PEDCO 110 EL CN 0002 D02 شماره صفحه: ۸ از ۸

G) Cafeteria Eating Serving area Food preparation	300 300 300	760 900 900
General, halls, etc.	100	Floor
H) Garage and firehouse Storage and minor repairs	100	Floor
I) First aid roomed	700	760



According to above table, the required luminance shall be about 150 LUX in operating aisles while in calculation, Eav is 149 lux on Floor.

#### 6.0 DESIGN SOFTWARE

Calculation is performed with version 4.13 of DIALUX Software.

#### 7.0 LIGHTING CALCULATION – DETAIL REPORT

DIALUX report has been attached in "Attachment"

### **SWITCHGEAR BUILDING OF WELL PADS**

BINAK OILFIELD DEVELOPMENT SUB-SURFACE WORK PACKAGES

**BK14 WHF MODIFICATIONS** 

Partner for Contact: Order No.: Company: Customer No.:

Date: 26.12.2022 Operator:



#### **Table of contents**

WITCHGEAR BUILDING OF WELL PADS	
Project Cover	1
Table of contents	2
Luminaire parts list	3
SWITCHGEAR ROOM	_
Summary	4
3D Rendering	5
False Color Rendering	6
Room Surfaces	0
Workplane	
Isolines (E)	7
BATTERY ROOM	ı
	0
Summary	8
3D Rendering	9
Room Surfaces	
Workplane	
Isolines (E)	10
TRANSFORMER SHELTER	
Summary	11
3D Rendering	12
False Color Rendering	13
Room Surfaces	
Workplane	
Isolines (E)	14
	• • •



#### SWITCHGEAR BUILDING OF WELL PADS / Luminaire parts list

3 Pieces Mazinoor M212A2GLED3 ROCKY 2000Lm 20W

Oval shaped bulk head, Glass Diffuser with guard


Article No.: M212A2GLED3 Luminous flux (Luminaire): 2000 lm Luminous flux (Lamps): 2000 lm Luminaire Wattage: 20.0 W

Luminaire classification according to CIE: 94

CIE flux code: 47 83 95 94 100

Fitting: 1 x LED (Correction Factor 1.000).





3 Pieces MAZINOOR M425SJ236B 2x36 W JUPITER

Suspended Fl. Luminaire with Semi-Specular

Anodized Aluminium Louvre Article No.: M425SJ236B

Luminous flux (Luminaire): 3320 lm Luminous flux (Lamps): 5000 lm Luminaire Wattage: 88.0 W


Luminaire classification according to CIE: 85

CIE flux code: 61 93 99 85 66

Fitting: 2 x 36 W T8 Fluorescent Lamp with G13 Base (26mm Tube Diameter) (Correction Factor

1.000).





4 Pieces MAZINOOR MSEALA218 2x18 W SEALA Dust &

Moisture Proof Fl. Luminaire with PC Body and

Diffuser

Article No.: MSEALA218

Luminous flux (Luminaire): 1904 lm Luminous flux (Lamps): 2400 lm Luminaire Wattage: 54.0 W


Luminaire classification according to CIE: 92

CIE flux code: 40 70 89 92 79

Fitting: 2 x 18 W T8 Fluorescent Lamp with G13 Base (26mm Tube Diameter) (Correction Factor

1.000).





1 Pieces

Mazinoor MSEXe840236 2x36 W Zone1 /Zone

21 Explosion-Proof Fluorescent Luminaire

Article No.: MSEXe840236 Luminous flux (Luminaire): 3985 lm

Luminous flux (Luminaire): 3985 Ir Luminous flux (Lamps): 5000 Im Luminaire Wattage: 65.7 W


Luminaire classification according to CIE: 87

CIE flux code: 36 64 85 87 80

Fitting: 2 x 36 W T8 Fluorescent Lamp with G13 Base (26mm Tube Diameter) (Correction Factor


1.000).







#### **SWITCHGEAR ROOM / Summary**



Height of Room: 5.000 m, Light loss factor: 0.80

Values in Lux, Scale 1:72

Surface	ρ [%]	E <sub>av</sub> [lx]	E <sub>min</sub> [lx]	E <sub>max</sub> [lx]	u0
Workplane	1	149	102	177	0.687
Floor	20	149	101	177	0.682
Ceiling	80	69	30	273	0.436
Walls (4)	50	89	36	4585	1

Workplane:

Height: 0.000 m

Grid: 64 x 32 Points

Boundary Zone: 0.000 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.606, Ceiling / Working Plane: 0.466.


#### **Luminaire Parts List**

No.	Pieces	Designation (Correction Factor)	Φ (Luminaire	e) [lm]	Φ (Lam	ps) [lm]	P [W]
1	3	MAZINOOR M425SJ236B 2x36 W JUPITER Suspended FI. Luminaire with Semi-Specular Anodized Almana Louvre (1.000)		3320		5000	88.0
2	4	MAZINOOR MSEALA218 2x18 W SEALA Dust & Moisture Proof FI. Luminaire with PC Body and Diffuser (1.000)		1904		2400	54.0
		, ,	Total: 1	17576	Total:	24600	480.0

Specific connected load: 9.24 W/m<sup>2</sup> = 6.21 W/m<sup>2</sup>/100 lx (Ground area: 51.97 m<sup>2</sup>)





### **SWITCHGEAR ROOM / 3D Rendering**





### **SWITCHGEAR ROOM / False Color Rendering**






lx



#### SWITCHGEAR ROOM / Workplane / Isolines (E)



Values in Lux, Scale 1:72

Position of surface in room: Marked point:

(1.010 m, 0.300 m, 0.000 m)

Grid: 64 x 32 Points

 $E_{av}[lx]$ 149 E<sub>min</sub> [lx] 102


E<sub>max</sub> [lx] 177

u0 0.687

 $\rm E_{min} \, / \, E_{max} \\ 0.578$ 



#### **BATTERY ROOM / Summary**



Height of Room: 5.000 m, Mounting Height: 4.160 m, Light loss factor:

Values in Lux, Scale 1:45

0.80

Surface	ρ [%]	E <sub>av</sub> [lx]	E <sub>min</sub> [lx]	E <sub>max</sub> [lx]	u0
Workplane	1	60	47	70	0.790
Floor	20	60	46	70	0.769
Ceiling	80	75	29	174	0.387
Walls (4)	50	70	23	928	/

#### Workplane:

Height: 0.000 m Grid: 32 x 32 Points Boundary Zone: 0.000 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 1.171, Ceiling / Working Plane: 1.249.

#### **Luminaire Parts List**

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	1	Mazinoor MSEXe840236 2x36 W Zone1 /Zone 21 Explosion-Proof Fluorescent Luminaire (1.000)	3985	5000	65.7
			Total: 3985	Total: 5000	65.7

Specific connected load: 5.69 W/m<sup>2</sup> = 9.48 W/m<sup>2</sup>/100 lx (Ground area: 11.55 m<sup>2</sup>)




### **BATTERY ROOM / 3D Rendering**






#### BATTERY ROOM / Workplane / Isolines (E)



Values in Lux, Scale 1:28

Position of surface in room: Marked point: (1.000 m, 5.500 m, 0.000 m)



Grid: 32 x 32 Points

 $E_{av}[Ix]$ 


E<sub>min</sub> [lx] 47

E<sub>max</sub> [lx] 70

u0 0.790  $\rm E_{min} \, / \, E_{max} \\ 0.674$ 



#### TRANSFORMER SHELTER / Summary



Height of Room: 3.400 m, Mounting Height: 2.860 m, Light loss factor:

Values in Lux, Scale 1:43

0.80

Surface	ρ [%]	E <sub>av</sub> [lx]	E <sub>min</sub> [lx]	E <sub>max</sub> [lx]	u0
Workplane	1	169	124	197	0.735
Floor	20	169	123	196	0.729
Ceiling	80	95	59	125	0.617
Walls (4)	50	149	74	1430	/

#### Workplane:

Height: 0.000 m Grid: 64 x 64 Points Boundary Zone: 0.000 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.878, Ceiling / Working Plane: 0.565.

#### **Luminaire Parts List**

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm	] $\Phi$ (Lamps) [lm]	P [W]
1	3	Mazinoor M212A2GLED3 ROCKY 2000Lm 20W Oval shaped bulk head, Glass Diffuser with guard (1.000)	2000	2000	20.0
		,	Total: 6000	Total: 6000	60.0

Specific connected load: 6.06 W/m<sup>2</sup> = 3.59 W/m<sup>2</sup>/100 lx (Ground area: 9.90 m<sup>2</sup>)



### TRANSFORMER SHELTER / 3D Rendering






### TRANSFORMER SHELTER / False Color Rendering








## TRANSFORMER SHELTER / Workplane / Isolines (E)



Values in Lux, Scale 1:26

Position of surface in room: Marked point:

(4.760 m, 5.750 m, 0.000 m)



Grid: 64 x 64 Points

E<sub>av</sub> [lx] 169

E<sub>min</sub> [lx] 124

E<sub>max</sub> [lx] 197

u0 0.735

 $\rm E_{min} \, / \, E_{max} \\ 0.631$