



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
D02	0002	CN	EL	120	PEDCO	GCS	BK

شماره صفحه: ۱ از ۸

طرح نگهداشت و افزایش تولید ۲۷ مخزن

CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM

نگهداشت و افزایش تولید میدان نفتی بینک

Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	Client Approval
D02	Jan.2023	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D01	Nov. 2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D00	Apr. 2022	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	

Class:2

Client Doc. Number: F0Z-709008

Status:

- IDC: Inter-Discipline Check
- IFC: Issued For Comment
- IFA: Issued For Approval
- AFD: Approved For Design
- AFC: Approved For Construction
- AFP: Approved For Purchase
- AFQ: Approved For Quotation
- IFI: Issued For Information
- AB-R: As-Built for Client Review
- AB-A: As-Built –Approved

REVISION RECORD SHEET



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴



CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
D02	0002	CN	EL	120	PEDCO	GCS	BK

شماره صفحه: ۲ از ۸

PAGE	D00	D01	D02	D03	D04
1	X	X	X		
2	X	X	X		
3	X				
4	X				
5	X	X			
6		X			
7		X			
8		X	X		
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM</p> <table border="1"> <thead> <tr> <th>پروژه</th> <th>بسته کاری</th> <th>صادر کننده</th> <th>تسهیلات</th> <th>رشته</th> <th>نوع مدرک</th> <th>سریال</th> <th>نسخه</th> </tr> </thead> <tbody> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>EL</td> <td>CN</td> <td>0002</td> <td>D02</td> </tr> </tbody> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	EL	CN	0002	D02	<p>شماره صفحه: ۳ از ۸</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	EL	CN	0002	D02											

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL DEFINITION	4
3.0	SCOPE	5
4.0	NORMATIVE REFERENCES	5
4.1	CODES AND STANDARDS	5
4.2	THE PROJECT REFERENCE DOCUMENTS	5
5.0	LANGUAGE AND SYSTEM OF UNITS.....	5
6.0	DESIGN SOFTWARE.....	6
7.0	CONCLUSION	6
8.0	LIGHTING CALCULATION – DETAIL REPORT.....	8

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>EL</td> <td>CN</td> <td>0002</td> <td>D02</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	EL	CN	0002	D02	<p>شماره صفحه: ۴ از ۸</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	EL	CN	0002	D02											

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.



With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

2.0 GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – Surface Facilities; New Gas Compressor Station
EPD/EPC CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of : Hirgan Energy – Design & Inspection (D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC Contractor (GC) and approved by COMPANY (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by Client rather than by an EPC/EPD Contractor, supplier or Vendor.
MAY:	Is used where a provision is completely discretionary.

 <p>NISOC</p>	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																	
<p>شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴</p>	<p>CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>پروژه</th> <th>بسته کاری</th> <th>صادر کننده</th> <th>تسهیلات</th> <th>رشته</th> <th>نوع مدرک</th> <th>سریال</th> <th>نسخه</th> </tr> </thead> <tbody> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>EL</td> <td>CN</td> <td>0002</td> <td>D02</td> </tr> </tbody> </table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	EL	CN	0002	D02	<p>شماره صفحه: ۵ از ۸</p>
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	EL	CN	0002	D02											

3.0 SCOPE

This specification describes the practices that shall be employed and the Standards that will be required to be met for the Indoor Lightings Illumination

4.0 NORMATIVE REFERENCES

4.1 CODES AND STANDARDS

- IPS-E-EL-100 Engineering Standard For Electrical System Design (Industrial And Non-Industrial)

4.2 THE PROJECT REFERENCE DOCUMENTS

- BK-GNRAL-PEDCO-000-PR-DB-0001 Process Basis Of Design
- BK-GNRAL-PEDCO-000-EL-DC-0001 Electrical System Design Criteria
- BK-GNRAL-PEDCO-000-EL-SP-0007 Specification For Lighting & Small Power System
- BK-GCS-PEDCO-120-SA-PY-0002 Hazardous Area Classification Layout
- BK-GCS-PEDCO-120-AR-DW-0001 Architectural Detail Drawing for Control Building
- BK-GCS-PEDCO-120-AR-DW-0002 Architectural Detail Drawing for Extension of Existing Electrical Building
- BK-GCS-PEDCO-120-AR-DW-0003 Architectural Drawing for Gas Compressors Shelter
- BK-GCS-PEDCO-120-AR-DW-0004 Architectural Drawing for Chemical Injection Packages/Chemical Storage Shelter
- BK-GCS-PEDCO-120-AR-DW-0005 Architectural Drawing for Utility Shelter
- BK-GCS-PEDCO-120-AR-DW-0006 Architectural Drawing for Fire Water Pumps Shelter
- BK-GCS-PEDCO-120-AR-DW-0008 Architectural Drawing for CCTV Control Room-Binak GCS
- BK-GCS-PEDCO-120-AR-DW-0009 Architectural Drawing for CCTV Control Room-Binak DU
- BK-GCS-PEDCO-120-AR-DW-0010 Architectural Drawing for CCTV Rack Room- Binak PU

5.0 LANGUAGE AND SYSTEM OF UNITS

All documentation, drawings, data, etc. furnished by the manufacturer shall be in English. SI metric system of measurement shall be used except for pipe and pipe fitting sizes, flange ratings

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک	 شرکت توسعه نیروهای ایران HIRGAN ENERGY																
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM	شماره صفحه: ۶ از ۸																
	<table border="1" style="width: 100%; text-align: center;"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادرکننده</td> <td>تسهیلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سریال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>EL</td> <td>CN</td> <td>0002</td> <td>D02</td> </tr> </table>	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	EL	CN	0002	D02	
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	PEDCO	120	EL	CN	0002	D02											

and nozzle dimensions in which inch will be used.

6.0 DESIGN SOFTWARE

Calculation is performed with version 4.13 of DIALUX Software.

7.0 CONCLUSION

According to IPS-E-EL-100, illumination level for each area has been lighted.

TABLE 15 - ILLUMINANCES LEVELS

AREA OR ACTIVITY	MINIMUM ILLUMINANCE LUX	ELEVATION MILLIMETER
I PROCESS AREAS		
A) General process units		
Pump rows, valves, manifolds	50	Ground
Heat exchangers	30	Ground
Maintenance platforms	10	Floor
Operating platforms	10	Floor
Cooling towers (equipment areas)	50	Floor
Furnaces	50	Ground
Ladders and stairs (inactive)	30	Ground
Ladders and stairs (active)	30	Floor
Gage glasses	50	Floor
Instruments (on process units)	50	Eye level
Compressor houses	50	Eye level
Separators	200	Floor
General area	50	Top of bay
	10	Ground
B) Control rooms and houses		
Ordinary control house		
Instrument panel	300	Floor
Console	300	1700
Back of panel	300	760
Central control house	100	760
Instrument	500	Floor
Back of pane	500	1700
	100	900
C) Specialty process units		
Conveyors		
Conveyor transfer points	20	Surface
	50	Surface
II NONPROCESS AREA		
A) Loading, unloading, and cooling water pump houses, Pump area		
General control area	50	Ground
Control panel	150	Floor
	200	1100
B) Boiler and air compressor plants		
Indoor		
Outdoor equipment 50	200	Floor
	50	Ground
C) Tank fields (where lighting is required)		
Ladders and stairs		
Gating area	5	Floor
Manifold area	10	Ground
	5	Floor
D) Loading racks		
General area		
Tank car	50	Floor
Tank trucks, loading point	100	Point
	100	Point
E) Tanker dock facilities		



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴



CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
D02	0002	CN	EL	120	PEDCO	GCS	BK

شماره صفحه: ۷ از ۸

F) Electrical substations and switch yards		
Outdoor switch yards	20	Ground
General substation (outdoor)	20	Ground
Substation operating aisles	150	Floor
General substation (indoor)	50	Floor
Switch racks	50	1200
G) Plant road lighting (where lighting is required)		
Frequent use (trucking)	4	Ground
Infrequent use	2	Ground
H) Plant parking lots		
	1	Ground
I) Aircraft obstruction lighting		

III Buildings		
A) Offices	500	
B) Laboratories		
Qualitative, quantitative and physical test	500	900
Research, experimental	500	900
Pilot plant, process and specialty	300	Floor
Glassware, washrooms	300	900
Fume hoods	300	900
Stock rooms	150	Floor
C) Warehouses and stock rooms		
Indoor bulk storage	50	Floor
Outdoor bulk storage	5	Ground
Large bin storage	50	760
Small bin storage	100	760
Small parts storage	200	760
Counter tops	300	1200
D) Repair shop		
Large fabrication	200	Floor
Bench and machine work	500	760
Crane way, aisles	150	Floor
Small machine	300	760
Sheet metal	200	760
Electrical	200	760
Instrument	300	760
E) Change housed		
Locker room, shower	100	Floor
Lavatory	100	Floor
F) Clock house and entrance gatehouse		
Card rack and clock area	100	Floor
Entrance gate, inspection	150	Floor
General	50	Floor
G) Cafeteria		
Eating	300	760
Serving area	300	900
Food preparation	300	900
General, halls, etc.	100	Floor
H) Garage and firehouse		
Storage and minor repairs	100	Floor
I) First aid roomed	700	760

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک	 شرکت توسعه و پیمانکاری انرژی HIRGAN ENERGY																
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	CALCULATION NOTE FOR INDOOR AREA LIGHTING SYSTEM	شماره صفحه: ۸ از ۸																
	<table border="1" style="width: 100%; text-align: center;"> <tr> <td>نسخه</td> <td>سریال</td> <td>نوع مدرک</td> <td>رشته</td> <td>تسهیلات</td> <td>صادر کننده</td> <td>بسته کاری</td> <td>پروژه</td> </tr> <tr> <td>D02</td> <td>0002</td> <td>CN</td> <td>EL</td> <td>120</td> <td>PEDCO</td> <td>GCS</td> <td>BK</td> </tr> </table>	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D02	0002	CN	EL	120	PEDCO	GCS	BK	
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه											
D02	0002	CN	EL	120	PEDCO	GCS	BK											

D02

Comparison of Lighting Between Standard & Calculation (LUX)				
Item	Building	Room	Standard	Calculation (Av)
1	Control	Control	300	511
		Auxiliary	300	398
		UPS	50	259
		Battery	50	153
		Management	500	444
		Instrument	500	464
		Office 1	500	406
		Office 2	500	475
		In Charge + Archive	500	372
2	Switchgear	Capacitor	50	145
		CO2	50	116
		Transformer	20	111
3	CCTV GCS	-	500	417
4	CCTV DU	-	500	417
5	CCTV PU	-	500	597
6	Compressor	Shelter	200	180
7	Chemical Package	Shelter	200	217
8	Utility	Shelter	200	166
9	Fire Water Pump	Shelter	200	238

8.0 LIGHTING CALCULATION – DETAIL REPORT

DIALUX report has been attached in “Attachments”

Attachment “A” -GCS New Control Building

Attachment “B” -GCS Exiting Switchgear

Attachment “C” -Outdoor Area (Gas Compressor Shelter, Chemical Injection Packages & Storage Shelter, Fire Water Pump House, Utility Shelter)