

ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 24 - · 74 - 9114

PMR FOR LIGHTING & DISTRIBUTION MA	IN PANELS - WOASS
FINIT FOR LIGHTING & DISTRIBUTION MA	IIIN FAINELS - WU4US

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	W046S	PEDCO	110	EL	MR	0007	D00

شماره صفحه: ۱ از ۱۵

طرح نگهداشت و افزایش تولید ۲۷ مخزن

PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046S

نگهداشت و افزایش تولید میدان نفتی بینک

	. 2023 ate	IFI Purpose of Issue/Status	H.Shakiba Prepared by:	M.Fakharian Checked by:	M.Mehrshad Approved by:	Client Approval
D00 Jan	. 2023	IFI	H.Shakiba	M.Fakharian	M.Mehrshad	
		!				

Class: 3 Client Doc. Number: F0Z-707716

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for Client Review
AB-A: As-Built –Approved



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

۰۵۳ - ۲۷۰ - ۳۸۰

PMR	FOR LIGH	HTING & DI	STRIBU	TION N	IAIN PANE	LS - W04	46S

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W046S
 PEDCO
 110
 EL
 MR
 0007
 D00

شماره صفحه: ۲ از ۱۵

REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04	F	PAGE	D00	D01	D02	D03	D04
1	Х						51					
2	Х						52					
3	Х						53					
4	Х						54					
5	Х						55					
6	Х						56					
7	Х						57					
8	Х						58					
9	Х						59					
10	Х						60					
11	X						61					
12	X						62					
13	X						63					
14	X						64					
15	X						65					
16	_ ^				 		66			 		
17	1				 		67					
18					-		68					
19							69					
												-
20							70					
21							71					
22							72					
23							73					
24							74					
25							75					
26							76					
27							77					
28							78					
29							79					
30							80					
31							81					
32							82					
33							83					
34							84					
35					t		85			<u> </u>		
36					<u> </u>		86					
37							87					
38							88					
39	1				 		89					
40					-		90					-
					-	<u> </u>				-		
41				-	-		91			 		
42					-		92			ļ		
43					ļ	<u> </u>	93			ļ		
44	ļ				ļ		94					
45							95					
46							96					
47							97					
48							98					
49							99					
50							100					



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

 \cdot Δ τ - \cdot \vee τ - τ Δ \cdot

PMR FOR LIGHTING &	DISTRIBUTION MAIN	PANELS - W046S

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	W046S	PEDCO	110	EL	MR	0007	D00

شماره صفحه: ۳ از ۱۵

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	REFERENCE / ATTACHED DOCUMENTS	5
4.0	SUBJECT OF THE SUPPLY	6
5.0	LIMITS OF SUPPLY	6
5.1	SCOPE OF SUPPLY	6
5.1.1	MAIN DESCRIPTION	6
5.1.2	Spare parts	7
5.1.3	Other items	7
5.2	EXCLUSIONS	7
5.3	BATTERY LIMITS	8
6.0	INSPECTION AND TESTS	8
7.0	VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE	8
8.0	UNIT RESPONSIBILITY	8
9.0	GUARANTEE AND WARRANTY	9
10.0	DEVIATION	9
11.0	PRICE BREAKDOWN	
ATTAC	CHMENT 1	11
11.1	,	
ATTAC	CHMENT 2	11
11.2	VENDOR DOCUMENTS MIN. REQUIREMENT	11
ATTAC	CHMENT 3	14
11.3	•	
ATTAC	CHMENT 4	15
11.4	ALTERNATIVES TO JOB SPECIFICATION	15



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 27 - · 77 - 9114

PINIK	PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W0465								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	W046S	PEDCO	110	EL	MR	0007	D00		

شماره صفحه: ۴ از ۱۵

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, construction of well location, access road, wellhead facilities (with electric power supply) for W046S shall be done. In addition, construction of new flowline from aforementioned well location to Binak B/C unit is in the Project scope of work.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development - Construction of Well

Location, Wellhead Facilities, Electrification Facilities,

& Flowlines for W046S

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy - Design &

Inspection(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 24 - · 74 - 9114

PINK	PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W0465								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	W046S	PEDCO	110	EL	MR	0007	D00		

شماره صفحه: ۵ از ۱۵

2.0 GENERAL

- This document presents the item material requisitions for Contractor's use as appropriate.
- This material requisition covers the requirements for the design, manufacturing, testing and supply of Distribution Panel as listed below. All equipment/devices/items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.
- The vendor's supply shall include:

No.	Item	Description	Total QTY.
1	Distribution Panel for Switchgear Building	 Tag Number: Well WS046S-DP01 Indoor 400/230, 63A, 50Hz, 10KA, 1S 	1
2	Distribution Panel for Security Building	 Tag Number: Well WS046S -DP02 Indoor 400/230, 40A, 50Hz, 10KA, 1S 	1

3.0 REFERENCE / ATTACHED DOCUMENTS

- **a.** Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- **b.** All codes and standards which have been referenced in above mentioned specs shall be considered.
- **c.** In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.

d. Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 27 - · 77 - 9114

PMR	PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046S								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	W046S	PEDCO	110	EL	MR	0007	D00		

شماره صفحه: ۶ از ۱۵

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.

If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, the supplier shall be considered to be in full compliance with the relevant document.

The supplier may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY

The supplier shall supply distribution power transformer of wellpads. The scope of supply is detailed at para. 5. The supplier shall include in the supply, all other equipment/devices/items not listed in the following, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.

5.0 LIMITS OF SUPPLY

5.1 SCOPE OF SUPPLY

5.1.1 MAIN DESCRIPTION

Distribution Panels of well BK-05 Acc. to "Single Line Diagram for LV Power Distribution Panel of Well Pads", "BK-SSGRL-PEDCO-110-EL-SL-0003". The supplier shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 27 - · 77 - 9114

PMR	PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046S										
ه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه											
BK	W046S	PEDCO	110	EL	MR	0007	D00				

شماره صفحه: ۷ از ۱۵

- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.
- Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:
 - QA/QC organization and procedures that shall be submitted for approval.
 - Plan for HOLD points in the production process proposed to PURCHASER for witness or approval particular activities.
 - Production schedule indicating main quality manufacturing processes, inspection and tests.
 - Qualification of all personnel performing tests to be reviewed by the inspector
 - Supplier shall also provide the description of the following quality activities:
 - Sub suppliers products quality
 - Quality check and identification of the materials and equipment entering in their manufacturing shop.
- Calibration of test instruments and equipment
- Provide detailed specifications and data sheets.

5.1.2 SPARE PARTS

Following items shall be considered (supplied) and included in the bid documentation:

- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Capital spare parts (as option / if any)

5.1.3 OTHER ITEMS

Special tools required for installation and maintenance

5.2 EXCLUSIONS

The following items are excluded by the supplier scope of supply and will be provided by purchaser:

Not Applicable.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· ۵۳ - · ۷۳ - 9114

PIVIR	PINIR FOR LIGHTING & DISTRIBUTION MAIN PANELS - WU405									
سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه							نسخه			
BK	W046S	PEDCO	110	EL	MR	0007	D00			

شماره صفحه: ۸ از ۱۵

5.3 BATTERY LIMITS

The battery limits are summarized as follows: Not Applicable.

6.0 INSPECTION AND TESTS

The equipment shall be inspected and tested in accordance with the quality control plan issued by the supplier and approved by the PURCHASER before the award of the order. The QC plan shall at least be according to the PROJECT ITP PROCEDURE (Doc. No. ICE-EID-MI-SP01-Rev01 & ICE-EID-MI-SP02-Rev01) and data sheets (if any).

The supplier shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE

- Vendor document shall be according to attachment 2 of this document.
- All documents, preliminary or final, are to be stamped and signed by the supplier.
- Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.
- PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.
- All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 "GENERAL DEFINITION"

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, testing, final check-out and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.

Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-suppliers.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 27 - · 77 - 9114

PMR	PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046S										
عه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه											
BK	W046S	PEDCO	110	EL	MR	0007	D00				

شماره صفحه: ۹ از ۱۵

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.

The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/packages at site

VENDOR shall guarantee the performance of supplied items (if any).

VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period.

Vendor shall ensure a correct and safe operation of the unit, providing all safety protection Devices.

Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION

VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 24 - · 74 - 9114

PMK	PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046S										
ه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه											
BK	W046S	PEDCO	110	EL	MR	0007	D00				

شماره صفحه: ۱۰ از ۱۵

VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for PURCHASER's approval.

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (END-QC-SP-1)
- 3) 2 years operational spare parts (END-QC-SP-1)
- 4) Packing & transportation
- 5) Other fee (if any)



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

 $\cdot \Delta T - \cdot VT - 911F$

PMR	PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046S									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه									
BK	W046S	PEDCO	110	EL	MR	0007	D00			

شماره صفحه: ۱۱ از ۱۵

ATTACHMENT 1

11.1 LIST OF REFERENCE / APPLICABLE DOCUMENTS

No.	Document No.	Document Title	Rev.
Proc	ess		
1	BK-GNRAL-PEDCO-000-PR-DB-0001	Process Basis of Design	D08
Elect	trical		
2	BK-GNRAL-PEDCO-000-EL-SP-0013	Specification for Distribution & Lighting Panels	D03
3	BK-SSGRL-PEDCO-110-EL-SL-0003	Single Line Diagram for LV Power Distribution Panel of Well Pads	D02
Gene	eral		
4	BK-GNRAL-PEDCO-000-QC-PR-0022	Specification for Final Data Book (FDB) Requirements	D00
5	BK-GNRAL-PEDCO-000-QC-PR-0045	Packing , Marking , Transportation Procedure	D00
6	ICE-EID-MI-SP01-Rev01	دستورالعمل بازرسی، خرید و ساخت کالا	
7	ICE-EID-MI-SP02-Rev01	سطح بازرسی کالا و تجهیزات	-
8	E&C-QC-SP-1	دستورالعمل تامین قطعات یدکی راه اندازی و راهبری دو سالانه	-
9	BK-GNRAL-PEDCO-000-PI-SP-0006	Specification For Painting	D04
10	BK-GNRAL-HD-000-PM-PR-0003	Document Numbering Procedure	G04

ATTACHMENT 2

11.2 <u>VENDOR DOCUMENTS MIN. REQUIREMENT</u>

		With Bid	TIME SCHEDULE				
ġ		With Bid	For Re	eview	Final Issue		
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)	
MANA	GEMENT						
1	Vendor Document Index and Schedule	4N	6C+E		6C+E		
2	Organization Brief	3N	6C+E				
3	Schedule Level 1, 2, 3 & 4 showing Engineering, Procurement, Fabrication, Inspection, Testing, and Delivery Plan.	4N	6C+E		6C+E		
4	Physically Progress Report (Every 2 Weeks))		6C+E				
5	Project Organization Chart	3N	6C+E			_	
6	Reference List	3N					



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 27 - · 77 - 9114

_
46S
J

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W046S
 PEDCO
 110
 EL
 MR
 0007
 D00

شماره صفحه: ۱۲ از ۱۵

		Wat Did		TIME S	CHEDULE	
ō.		With Bid	For Review		Final Issue	
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
7	Vendor Catalogue	3N				
8	Sub-vendors list	3N				
QUALI	ТҮ				_	
9	Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO)	4N			6C+E	
10	Preliminary Inspection and Test Plan	4N				
11	Inspection and Test Plan		6C+E		6C+E	
HSE						
12	HSE Procedure		6C+E		6C+E	
ENGIN	EERING					
13	Wiring & Terminal Diagram For Distribution Panel		6C+E		6C+E	
14	Data Sheet for Distribution Panel		6C+E		6C+E	
15	Outline Drawing for Distribution Panel		6C+E		6C+E	
16	Name Plate Drawing for Distribution Panel		6C+E		6C+E	
17	Foundation Detail for Distribution Panel		6C+E		6C+E	
PROC	UREMENT					
18	List of Sub-Suppliers (table giving: part of equipment, tag no., sub-supplier reference)(5.1.3)	4N			6C+E	
19	Unpriced copy of sub-orders		6C+E			
MANU	FACTURING					
20	Surface Preparation and Painting Procedures		6C+E		6C+E	
21	Welder Qualification Procedure		6C+E		6C+E	
TESTII	NG					
22	Factory Acceptance Test (FAT) Procedure		6C+E		6C+E	
RECO	RDS, REPORTS & CERTIFICATES					
23	Type Test Certificate		6C+E		6C+E	



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 24 - · 74 - 9114

PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046
--

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	W046S	PEDCO	110	EL	MR	0007	D00

شماره صفحه: ۱۳ از ۱۵

		With Did	TIME SCHEDULE				
è.		With Bid	For Review		Final Issue		
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)	
INSTA	LLATION						
24	Sub-Assembly Documentation		6C+E		6C+E		
25	Sub-Assembly Drawings		6C+E		6C+E		
26	Erection/Installation Manual (if required)		6C+E		6C+E		
27	Handling, Transportation & Storage Instructions & Preservation		6C+E		6C+E		
28	Unpacking & Inspection Instructions		6C+E				
29	Packing List		6C+E		6C+E		
OPERA	ATION & MAINTENANCE						
30	Operating Instructions		6C+E		6C+E		
31	Maintenance Instructions (if required)		6C+E		6C+E		
32	Commissioning & Start-up Manual		6C+E		6C+E		
33	List of Spare Parts Commissioning & Start-up	4N	6C+E		6C+E		
34	List of Spare Parts 2 Years Operation	4N	6C+E		6C+E		
35	List of Special Tools	4N	6C+E		6C+E		
36	Software Manual (incl. Troubleshooting)		6C+E		6C+E		
37	Function Test Procedure		6C+E		6C+E		
OTHER	RS						
38	All others documents (if required) will be listed in the order		6C+E				

NOTES:

- (1) N= Number of document, C=Copy, E=Electronic Copy
- (2) Starting from date of order placement
- (3) Starting from reception of documentation without comments
- (4) First issue of the document is subjected to the release of payment milestone as per purchase order
- (5) Calendar days after reception of drive data
- (6) Prior to testing
- (7) One copy each bid copy



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· ۵۳ - · ۷۳ - 9114

PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046S							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	W046S	PEDCO	110	EL	MR	0007	D00

شماره صفحه: ۱۴ از ۱۵

ATTACHMENT 3

Requisition No.:

Equipment No.:

Description:

11.3 <u>DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION</u>

Item No.	Description of proposed exception	Recommended revision to job specification	Reason for proposed exception	Effect on base proposal if CONTRACTOR		
		Specification	exception	rejects exception		



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، و تسهیلات برق رسانی مربوط به موقعیت W046S



شماره پیمان:

· 27 - · 77 - 9114

PMR FOR LIGHTING & DISTRIBUTION MAIN PANELS - W046S							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	W046S	PEDCO	110	EL	MR	0007	D00

شماره صفحه: ۱۵ از ۱۵

ATTACHMENT 4

Requisition No.:

Description:

11.4 ALTERNATIVES TO JOB SPECIFICATION

Item No.	Job Specification No. & Paragraph No.	Requirements of Job Specification	Description of Proposed Alternative	Reason for Proposed Alternative	