

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک بسته‌های کاری تحت‌الارض احداث خطوط انتقال گاز/مایعات گازی از ایستگاه تقویت فشار گاز بینک تا ایستگاه تزریق گاز سیاه‌مکان/واحد بهره‌برداری بینک							 
	INSTRUMENT INDEX							
شماره پیمان: 053 - 073 - 9184	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
	BK	PPL	PEDCO	320	IN	LI	0001	D02
شماره صفحه: 1 از 4								

طرح نگهداشت و افزایش تولید 27 مخزن

INSTRUMENT INDEX

نگهداشت و افزایش تولید میدان نفتی بینک

D02	FEB.2023	IFA	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
D01	APR.2022	IFA	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
D00	JAN.2022	IFC	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 1 CLIENT Doc. Number: F0Z-708608

status:

- IDC: Inter-Discipline Check
- IFC: Issued For Comment
- IFA: Issued For Approval
- AFD: Approved For Design
- AFC: Approved For Construction
- AFP: Approved For Purchase
- AFQ: Approved For Quotation
- IFI: Issued For Information
- AB-R: As-Built for CLIENT Review
- AB-A: As-Built -Approved



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
بسته‌های کاری تحت‌الارض

احداث خطوط انتقال گاز/مایعات گازی از ایستگاه تقویت فشار گاز بینک تا
ایستگاه تزریق گاز سیاه‌مکان/واحد بهره برداری بینک



INSTRUMENT INDEX

شماره پیمان:

053 - 073 - 9184

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
D02	0001	LI	IN	320	PEDCO	PPL	BK

شماره صفحه: 2 از 4

REVISION RECORD SHEET

Page	D00	D01	D02	D03	D04
1	X	X	X		
2	X	X	X		
3	X	X	X		
4	X	X	X		
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					

Page	D00	D01	D02	D03	D04
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
بسته‌های کاری تحت‌الارض

احداث خطوط انتقال گاز/مايعات گازی از ایستگاه تقویت فشار گاز بینک تا
ایستگاه تزریق گاز سیاه‌مکان/واحد بهره برداری بینک



INSTRUMENT INDEX

شماره پیمان:	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
053 - 073 - 9184	D02	0001	LI	IN	320	PEDCO	PPL	BK

شماره صفحه: 3 از 4

REFERENCES:

P&ID - GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-PR-PI-0001_D02
P&ID - CONDENSATE PIPELINE (TO BINAK PU)	BK-PPL-PEDCO-320-PR-PI-0002_D02
P&ID - SYMBOL & LEGEND for PFD and P&ID	BK-PPL-PEDCO-320-PR-PI-0003_D01

ABBREVIATIONS:

CC	CORROSION COUPON
CP/T	CORROSION PROBE/ TRANSMITTER
PSHH/PSL	PRESSURE SWITCH HIGH HIGH/LOW LOW LEVEL SHUTDOWN
PRV/PSV	PRESSURE RILIEF/SAFTEY VALVE
PT	PRESSURE TRANSMITTER
PCV	PRESSURE CONTROL VALVE
PG	PRESSURE GAUGE
TRV	TEMPERATURE RILIEF VALVE
TG	TEMPERATURE GAUGE
TT	TEMPERATURE TRANSMITTER
XV	ON/OFF VALVE
ESDV	EMERGENCY SHUTDOWN VALVE
BDV	BLOWDOWN VALVE
FE	FLOW ELEMENT
FT	FLOW TRANSMITTER
FCV	FLOW CONTROL VALVE
ZI	PIG SIGNALER INDICATOR
ZS	PIG SIGNALER SWITCH
DS	DOOR OPEN SWITCH
TDS	TOTAL DISSOLVED SOLID
IS	INTRINSICALLY SAFE
NIS	NON INTRINSICALLY SAFE
R	REDUNDANT
NR	NON REDUNDANT
IO	INPUT / OUTPUT
DI	DIGITAL INPUT SIGNAL
DO	DIGITAL OUTPUT SIGNAL
AI	ANALOGUE INPUT SIGNAL
AO	ANALOGUE OUTPUT SIGNAL
DCS	DISTRIBUTED CONTROL SYSTEM
ESD	EMERGENCY SHUT DOWN SYSTEM

NOTES:

NOTE 1:	Over Pressure Protection Shall Be Provided For The Device Considering Design Pressure.
NOTE 2:	HART COMMUNICATOR DEVICE" provided in GCS work pack will be used for Calibrating of the transmitters.
NOTE 3:	Portable Meter, provided in GCS work pack will be used reading the measure of corrosion Probes.
NOTE 3:	Rotameter process data will be finilized after receiving the data from client.
NOTE 4:	The ESDV -3202 Shall Be Connected To Existing Control & Emergency Shutdown Systems.
NOTE 5:	This Rotameter to be considered in datasheet 'BK-GCS-PEDCO-120-IN-DT-0018' and to be supplied with Binak GCS Rotameters.

D02

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک بنس‌های کاری تحت‌الارض								 			
	احداث خطوط انتقال گاز/ایمپات گازی از ایستگاه تقویت فشار گاز بینک تا ایستگاه تزریق گاز ساهمکان/واحد بهره برداری بینک											
	INSTRUMENT INDEX											
شماره پیمان:		بروز	بنس کاری	ساخته شده	شمارات	رشته	نوع متر	سریال	شماره صفحه: 4 از 4			
053 - 073 - 9184		BK	PPL	PEDCO	320	IN	LI	0001	D02			

IDENTIFICATION			REFERENCE							PRESSURE (Barg)		TEMPERATURE (°C)		INSTRUMENT RANGE	CALIBRATION RANGE	INSTRUMENT UNIT	SYSTEM CONTROL	I/O TYPE	SIGNAL TYPE	REMARK	REV.
ITEM	TAG	DESCRIPTION	LINE/ EQUIPMENT	P&ID	SERVICE	LOCATION/ PACKAGE NAME	DATA SHEET NO.	HOOK UP DWG. NO.	LOOP DWG NO.	LOCAION LAYOUT DWG NO.	DESIGN Barg	OPER. Barg	DESIGN	OPER. °C							
1	CG-3201	CORROSION COUPON	GAS-111-0072-FN05-6"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0003	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-DT-0002	62	50.9	85	58.3	-	-	-	-	-	-	-
2	CP-3201	CORROSION PROBE	GAS-111-0072-FN05-6"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0003	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0005	BK-PPL-PEDCO-320-IN-PI-0002	62	50.9	85	58.3	-	-	-	-	-	Note-3	-
3	ESDV-3201	Emergency Shutdown Valve (Body)	GAS-111-0072-FN05-6"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PI-0002	62	50.9	85	58.3	-	-	-	-	-	-	-
4	EZSC-3201	Limit Switch Close	GAS-111-0072-FN05-6"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	-	ESD (of new GCS)	DI-NIS-R	24 VDC	-
5	EZSO-3201	Limit Switch Open	GAS-111-0072-FN05-6"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	-	ESD (of new GCS)	DI-NIS-R	24 VDC	-
6	PSOV-3201	Solenoid Valve	GAS-111-0072-FN05-6"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0005	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	-	DCS (of new GCS)	DO-NIS-NR	24VDC LOOP POWER	-
7	ESOV-3201	ESD Solenoid Valve	GAS-111-0072-FN05-6"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	-	ESD (of new GCS)	DO-NIS-R	24VDC LOOP POWER	-
8	PT-3201A	PRESSURE TRANSMITTER	GAS-113-0072-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0003	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	Barg	ESD (of new GCS)	AI-IS-R	4-20 mA	Note 2
9	PT-3201B	PRESSURE TRANSMITTER	GAS-113-0072-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0003	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	Barg	ESD (of new GCS)	AI-IS-R	4-20 mA	Note 2
10	PT-3201C	PRESSURE TRANSMITTER	GAS-113-0072-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0003	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	Barg	ESD (of new GCS)	AI-IS-R	4-20 mA	Note 2
11	DS-3201	DOOR LIMIT SWITCH	PL-3201	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) PIG LAUNCHER	-	-	-	-	62	50.9	85	58.3	-	-	-	DCS (of new GCS)	DI-NIS-NR	24 VDC	BY VENDOR
12	PG-3201	PRESSURE GAUGE	PL-3201	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) PIG LAUNCHER	BK-PPL-PEDCO-320-IN-DT-0001	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	Barg	-	-	-	NOTE 1
13	PSV-3201	PRESSURE SAFETY VALVE	GAS-113-0003-FN05-2"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) PIG LAUNCHER	BK-PPL-PEDCO-320-IN-DT-0005	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	-	-	-	-	-
14	FG-3201	FLOW GAUGE ROTAMETER	CHM-112-0007-FS00-3/4"-NP	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	FROM METHANOL HEADER (TO SIAHMAKAN G.I. STATION)	BK-GCS-PEDCO-120-IN-DT-0018	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	NOTE 3	NOTE 3	NOTE 3	NOTE 3	-	-	-	-	-	-	NOTE 5
15	PG-3202	PRESSURE GAUGE	GAS-113-0005-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) AFTER PIG LAUNCHER	BK-PPL-PEDCO-320-IN-DT-0001	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	Barg	-	-	-	-
16	ZI-3201	PIG INDICATOR	GAS-113-0005-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (1/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) AFTER PIG LAUNCHER	BK-PPL-PEDCO-320-IN-DT-0010	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	50.9	85	58.3	-	-	-	-	-	-	-
17	LBV-3201	LINE BREAK VALVE	GAS-113-0007-FN27-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (2/3)	GAS	AFTER PIG LAUNCHER, NEAR THE BEGINNING OF PIPELINE	BK-PPL-PEDCO-320-IN-DT-0012	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	43.9	85	31.78	-	-	-	-	-	-	-
18	LBV-3202	LINE BREAK VALVE	GAS-113-0009-FN27-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (2/3)	GAS	BEFOR PIG RECEIVER, NEAR THE END OF PIPELINE	BK-PPL-PEDCO-320-IN-DT-0012	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	43.9	85	31.78	-	-	-	-	-	-	-
19	CC-3202	CORROSION COUPON	CDH-113-0004-AN07-2"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) BEFOR PIG RECEIVER	BK-PPL-PEDCO-320-IN-DT-0009	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	-	-	-	-
20	PG-3203	PRESSURE GAUGE	GAS-113-0011-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) BEFOR PIG RECEIVER	BK-PPL-PEDCO-320-IN-DT-0001	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	Barg	-	-	-	-
21	TG-3202	TEMPERATURE GAUGE	GAS-113-0015-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) BEFOR PIG RECEIVER	BK-PPL-PEDCO-320-IN-DT-0002	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	°C	-	-	-	-
22	ZI-3202	PIG INDICATOR	PR-3201	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) BEFOR PIG RECEIVER	BK-PPL-PEDCO-320-IN-DT-0010	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	-	-	-	-
23	PG-3204	PRESSURE GAUGE	PR-3201	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) BEFOR PIG RECEIVER	BK-PPL-PEDCO-320-IN-DT-0001	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	Barg	-	-	-	-
24	ZI-3203	PIG INDICATOR	PR-3201	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) PIG RECEIVER	BK-PPL-PEDCO-320-IN-DT-0010	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	-	-	-	-
25	PG-3205	PRESSURE GAUGE	PR-3201	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) PIG RECEIVER	BK-PPL-PEDCO-320-IN-DT-0001	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	Barg	-	-	-	-
26	PSV-3202	PRESSURE SAFETY VALVE	GAS-113-0014-FN05-2"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION) PIG RECEIVER	BK-PPL-PEDCO-320-IN-DT-0005	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	-	-	-	-
27	ESDV-3202	Emergency Shutdown Valve (Body)	GAS-113-0115-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	-	-	-	-
28	EZSC-3202	Limit Switch Close	GAS-113-0115-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	EXISTING ESD/DCS	DI-NIS-R	24 VDC	NOTE 4
29	EZSO-3202	Limit Switch Open	GAS-113-0115-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	EXISTING ESD/DCS	DI-NIS-R	24 VDC	NOTE 4
30	PSOV-3202	Solenoid Valve	GAS-113-0115-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0005	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	EXISTING ESD/DCS	DO-NIS-NR	24VDC LOOP POWER	NOTE 4
31	ESOV-3202	ESD Solenoid Valve	GAS-113-0115-FN05-8"-PT	BK-PPL-PEDCO-320-PR-PI-0001 (3/3)	GAS	GAS PIPELINE (TO SIAHMAKAN G.I. STATION)	BK-PPL-PEDCO-320-IN-DT-0006	BK-PPL-PEDCO-320-IN-DG-0002	BK-PPL-PEDCO-320-IN-DG-0004	BK-PPL-PEDCO-320-IN-PY-0002	62	40	85	31.3	-	-	-	EXISTING ESD/DCS	DO-NIS-R	24VDC LOOP POWER	NOTE 4
32	PG-3210	PRESSURE GAUGE	CDH-113-0016-FN05-4"-PT	BK-PPL-PEDCO-320-PR-PI-0002	OIL (CONDENSATE)	CONDENSATE PIPELINE (TO BINAK PUL)	BK-PPL-PEDCO-320-IN-DT-0001	BK-PPL-PEDCO-320-IN-DG-0002	-	BK-PPL-PEDCO-320-IN-PY-0002	62	12.78	85	49.9	-	-	Barg	-	-	-	-