





DETAIL A

SC: 1/100


NOTES

1. IN CASE OF OUTDOOR INSTALLATION, CANOPY/CABINET SHOULD BE CONSIDERED FOR WHEELED AND PORTABLE EXTINGUISHERS, RESPECTIVELY.
2. FOR INSTALLATION DETAILS OF FIRE EXTINGUISHERS, NFPA 10 SHOULD BE FOLLOWED.

LEGEND & ABBREVIATIONS		
SYMBOL	QTY.	DESCRIPTION
 120kg	2	PORTABLE DRY CHEMICAL POWDER EXTINGUISHER
 30kg	1	CO2 EXTINGUISHER (PORTABLE)
 750kg	2	WHEELED DRY CHEMICAL POWDER EXTINGUISHER
	1	WIND SOCK

REFERENCE DRAWING	DRG. No.
PLOT PLAN DRAWING - W008N	BK-W008N-PEDCO-110-PI-DW-0001

KEY PLAN

[illegible]