

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								 شماره صفحه: ۱ از ۱۱
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS								
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00	

طرح نگهداشت و افزایش تولید ۲۷ مخزن

SPECIFICATION FOR FLEXIBILITY ANALYSIS

نگهداشت و افزایش تولید میدان نفتی بینک

D00	Aug. 2021	IFC	M.Asgharnejad	M.Fakharian	Sh.Ghalikar	
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	COMPANY Approval

Class: COMPANY Doc. Number:

Status:

IDC: Inter-Discipline Check
 IFC: Issued For Comment
 IFA: Issued For Approval
 AFD: Approved For Design
 AFC: Approved For Construction
 AFP: Approved For Purchase
 AFQ: Approved For Quotation
 IFI: Issued For Information
 AB-R: As-Built for COMPANY Review
 AB-A: As-Built –Approved

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS							شماره صفحه: ۲ از ۱۱
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00

REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	X				
2	X				
3	X				
4	X				
5	X				
6	X				
7	X				
8	X				
9	X				
10	X				
11	X				
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					

PAGE	D00	D01	D02	D03	D04
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					
129					
130					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS							شماره صفحه: ۳ از ۱۱
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00

CONTENTS

1.0	SCOPE (MOD.)	5
2.0	NORMATIVE REFERENCES (MOD.)	5
2.1	LOCAL CODES AND STANDARDS (ADD.)	5
2.2	THE PROJECT DOCUMENTS (ADD.)	5
2.3	THE PROJECT DOCUMENTS (ADD.)	6
2.4	ENVIRONMENTAL DATA	6
3.0	DEFINITION AND TERMINOLOGY	6
4.0	UNITS	6
5.0	PIPING STRESS ANALYSIS (MOD.)	6
5.1	DESIGN CONDITIONS (MOD.)	6
6.0	LOAD AND STRESS CONSIDERATION IN PIPE STRESS ANALYSIS (MOD.)	6
6.1	WEIGHT EFFECT	6
6.2	HYDRO TEST	7
6.3	THERMAL EXPANSION AND CONTRACTION EFFECTS	7
6.4	FRICTION EFFECT	7
6.5	DYNAMIC EFFECTS (MOD.)	7
7.5.2	WIND (MOD.)	7
7.5.3	EARTHQUAKE (MOD.)	7
7.0	FLANGE LEAKAGE CRITERIA (MOD.)	7
8.0	ALLOWABLE LOADS ON EQUIPMENT NOZZLES (MOD.)	7
9.0	DESIGN CONSIDERATION (MOD.)	7
9.1	EXPANSION JOINTS (MOD.)	7
9.2	FIRE CASE (ADD.)	8
10.0	EXTENT OF ANALYSIS	8
11.0	ANALYSIS SOFTWARE (ADD.)	8
11.1	GEOMETRIC DATABASE	8
11.2	CAESARII CONFIGURATION FILE AND UNIT FILES	8

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							 شرکت توسعه و پارس  HIRGAN ENERGY 
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS							شماره صفحه : ۴ از ۱۱
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00

0.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

GENERAL DEFINITION

The following terms shall be used in this document.

COMPANY:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – General Facilities
EPD/EPC CONTRACTOR:	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of : Hirgan Energy – Design & Inspection(D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPC CONTRACTOR and approved by GC & COMPANY (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by COMPANY rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR.
MAY:	Is used where a provision is completely discretionary.

GUIDANCE FOR USE OF THIS DOCUMENT

The amendments/supplement to the related IPS Standard(s) given in this document are directly related to the equivalent sections or clauses in the IPS Standard(s). For clarity, the section and paragraph numbering of the IPS Standard(s) has been used as long as possible. Where clauses

in IPS are referenced within this document, it shall mean those clauses are amended by this

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS							شماره صفحه : ۵ از ۱۱
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00

document. Clauses in" IPS" that are not amended by this document shall remain valid as written.

For ease of reference, the clause or section numbering of the related IPS Standard(s) has been used throughout this specification. For the purpose of this specification, the following definitions shall hold:

Sub. (Substitution): The IPS Std. Clause is deleted and replaced by a new clause.

Del. (Deletion): The IPS Std. Clause is deleted without any replacement.

Add. (Addition): A new clause with a new number is added.

Mod. (Modification): Part of the IPS Std. Clause is modified, and/or a new description and/or condition is added to that clause.

1.0 SCOPE (MOD.)

This specification gives amendment and supplement to IPS-E-PI-200(1), "Engineering Standard for Flexibility Analysis".

It shall be used in conjunction with data/requisition sheets for present document subject.

IPS-E-PI-200(1), covers the basic requirements for the flexibility analysis of piping systems in Oil, Gas and Petrochemical Industries.

The analysis shall consider the effects of Temperature, Pressure, Vibration, Loads, Fluid, Reactions and Environmental Factors.

2.0 NORMATIVE REFERENCES (MOD.)

Following Codes, Standards and Documents shall be added to the IPS-E-PI-200.

2.1 LOCAL CODES AND STANDARDS (ADD.)

- IPS-E-PI-240(2) "Engineering Standard for Plant Piping Systems"

2.2 THE PROJECT DOCUMENTS (ADD.)

- ASME Section VIII Div. 2 (Boiler and Pressure Vessel Codes)
- API 620 "Design and Construction of Large, Welded, Low-Pressure Storage Tanks"
- UBC (1997+Addendum) (Uniform Building Code)
- WRC (Welding Research Council)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS							شماره صفحه: ۶ از ۱۱
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00

- 107/297

"Lo

Lo

2.3 THE PROJECT DOCUMENTS (ADD.

BK-GNRAL-PEDCO-000-PR-DB-0001 Process Basis of Design

2.4 ENVIRONMENTAL DATA

Refer to "Process Basis of Design; Doc. No. BK-GNRAL-PEDCO-000-PR-DB-0001".

3.0 DEFINITION AND TERMINOLOGY

No amendments or supplements are to state.

4.0 UNITS

No amendments or supplements are to state.

5.0 PIPING STRESS ANALYSIS (MOD.)

The following specifications shall be complied with:

- Pipe support design based on IPS-G-PI-280 and Specification For Pipe Support (BK-GNRAL-PEDCO-000-PI-SP-0014).(MOD)

5.1 DESIGN CONDITIONS (MOD.)

Installation temperature for stress analysis calculation shall be considered 21°C.

Why installation temperature=21°C ?, reference shall be submitted.

6.0 LOAD AND STRESS CONSIDERATION IN PIPE STRESS ANALYSIS (MOD.)

6.1 WEIGHT EFFECT

No amendments or supplements are to state.

The following standard shall be added:

- WRC 537 Precision equations and enhanced diagrams for local stresses in spherical and cylindrical shells due to external loadings for implementation of WRC Bulletin 107

21 deg C is normal ambient temperaturure .

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS							شماره صفحه: ۷ از ۱۱
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00

6.2 HYDRO TEST

No amendments or supplements are to state.

6.3 THERMAL EXPANSION AND CONTRACTION EFFECTS

No amendments or supplements are to state.

6.4 FRICTION EFFECT

No amendments or supplements are to state.

6.5 DYNAMIC EFFECTS (MOD.)

6.5.2 WIND (MOD.)

6.5.2.1. Wind Load analysis will be performed for exposed lines connected to tall columns and structures.

6.5.3 EARTHQUAKE (MOD.)

6.5.3.1. According to site condition, the seismic coefficient with forced acceleration shall be considered. (ADD.)

6.5.3.2. All critical piping systems (Level 3) shall be analyzed for seismic loads.
(ADD.)

7.0 FLANGE LEAKAGE CRITERIA (MOD.)

add "or/and which carry dangerous and toxic fluid"

The flange leakage shall be evaluated for all flanges on critical lines with rating $\geq 600\#$. (ADD.)

NOTED.

The flange load checking shall be considered in operating temperature and operating pressure. (ADD.)

8.0 ALLOWABLE LOADS ON EQUIPMENT NOZZLES (MOD.)

For all nozzle loads calculation shall be based on operating temperature. (MOD.)

9.0 DESIGN CONSIDERATION (MOD.)

9.1 EXPANSION JOINTS (MOD.)

Expansion Joints must be rated and evaluated against manufacture's allowable.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS							شماره صفحه: ۸ از ۱۱
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00

9.2 FIRE CASE (ADD.)

To be considered for flare lines. Temperature for the same to be considered as identified in the line list.

10.0 EXTENT OF ANALYSIS

No amendments or supplements are to state.

11.0 ANALYSIS SOFTWARE (ADD.)

Computer stress analysis for critical systems will be carried out using CAESAR-II (2018).

11.1 GEOMETRIC DATABASE

- CAESAR II library of piping will be utilized with nominal bore and schedule no. For pipe size above 42" and for non-standard schedules, piping material spec. (PMS), relevant pipe/fitting/valves vendor catalogues will be used for entering outside diameter, pipe thickness and weigh.
- Actual density shall be entered as per Line list.
- Insulation thickness shall be entered as per the line list.

11.2 CAESARII CONFIGURATION FILE AND UNIT FILES

- SI units will be followed for this project.
- The load combination cases is also attached in Appendix C

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS								شماره صفحه : ۹ از ۱۱
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00	

APPENDIX A “STRESS ANALYSIS LEVEL REQUIREMENTS”

No amendments or supplements are to state.

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS								شماره صفحه : ۱۰ از ۱۱
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00	

APPENDIX B “STRESS ANALYSIS REPORTS”

No amendments or supplements are to state.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR FLEXIBILITY ANALYSIS							شماره صفحه : ۱۱ از ۱۱
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GNRAL	PEDCO	000	PI	SP	0012	D00

APPENDIX C "LOAD COMBINATION CASES" (ADD.)

SL.NO.	Combinations	Case	Remarks
1	WW+HP	HYD	HYDRO TEST
2	W+T1+P1	OPE	DESIGN
3	W+T2+P1	OPE	OPE.
4	W+T2+P1+U1	OPE	EARTHQUAKE(N/S)
5	W+T2+P1+U2	OPE	EARTHQUAKE(E/W)
6	W+T2+P1+WIN1	OPE	WIND(N)
7	W+T2+P1+WIN2	OPE	WIND(S)
8	W+T2+P1+WIN3	OPE	WIND(W)
9	W+T2+P1+WIN4	OPE	WIND(E)
10	W+T2+P1+F1	OPE	PSV REACTION FORCE
11	W+P1	SUS	SUSTAINED
12	L4-L3	OCC	ALG
13	L5-L3	OCC	ALG
14	L6-L3	OCC	ALG
15	L7-L3	OCC	ALG
16	L8-L3	OCC	ALG
17	L9-L3	OCC	ALG
18	L10-L3	OCC	ALG
19	L11+L12	OCC	SCA
20	L11+L13	OCC	SCA
21	L11+L14	OCC	SCA
22	L11+L15	OCC	SCA
23	L11+L16	OCC	SCA
24	L11+L17	OCC	SCA
25	L11+L18	OCC	SCA
26	L2-L11	EXP	EXPANSION1 (ALG)
27	L3-L11	EXP	EXPANSION2 (ALG)

Designations

W: weight with content

WW: hydro weight

P1: design pressure

HP: hydro pressure

T1: Design Temperature

T2: Ope. temperature

U1: seismic coefficient in N/S direction

U2: seismic coefficient in E/W direction

WIN1: wind pressure in N direction

WIN2: wind pressure in S direction

WIN3: wind pressure in W direction

WIN4: wind pressure in E direction

F1=force

ALG: algebraic

ABS: absolute

SCA: scalar

In addition to the above, WNC (weight with no content) may be added with P1 at appropriate case.