



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

		PINK FOR	CAPAC	HOR	BANK			ĺ
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	l
BK	GCS	PEDCO	120	EL	MR	0011	D00	

شماره صفحه: ۱ از ۱۴

طرح نگهداشت و افزایش تولید ۲۷ مخزن

PMR FOR CAPACITOR BANK

نگهداشت و افزایش تولید میدان نفتی بینک

D00 Mar.	te Purpose o	of Issue/Status	Prepared by:	Checked by:	Approved by:	Client Approval
	2023	IFI	H.Shakiba	M.Fakharian	M.Mehrshad	

Class:3 Client Doc. Number: F0Z-709347

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for Client Review
AB-A: As-Built –Approved



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



ئىمارە پىمان:	٥

• 24 - • 44 - • 41 - 41

		PMR FOR	R CAPAC	HOR	BANK		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	MR	0011	D00

شماره صفحه: ۲ از ۱۴

REVISION RECORD SHEET

				•	REVISI
PAGE	D00	D01	D02	D03	D04
1	Х				
2	Х				
3	X				
4	X				
5	X				
6	X				
7	X				
8	X				
	X				
9	X				
10	X				
11	X				
12					
13	X				
14	Х				
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
38 39				-	
				-	
40	-			-	
41				-	
42				<u> </u>	
43				-	
44	-				
45					
46					
47					
48					
49					
50		-			

DAGE	D00	D01	D02	D03	D04
PAGE 51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88	1		-		1
89	1		-		1
90	1				<u> </u>
91	1				<u> </u>
92	1				-
93	-				
94	-				
95	1				ļ
96	ļ				
97					
98					
99					
100					





احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

شماره پیمان:

 \cdot Δ τ - \cdot \vee τ - τ Δ \cdot

		PINK FOR	CAPAC	HOR	BANK		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	MR	0011	D00

شماره صفحه: ۳ از ۱۴

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	REFERENCE / ATTACHED DOCUMENTS	5
4.0	SUBJECT OF THE SUPPLY	6
5.0	LIMITS OF SUPPLY	6
5.1	SCOPE OF SUPPLY	6
5.1.1	MAIN DESCRIPTION	6
5.1.2	Spare parts	7
5.1.3	OTHER ITEMS	7
5.2	EXCLUSIONS	7
5.3	BATTERY LIMITS	7
6.0	INSPECTION AND TESTS	7
7.0	VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE	8
8.0	UNIT RESPONSIBILITY	8
9.0	GUARANTEE AND WARRANTY	8
10.0	DEVIATION	9
11.0	PRICE BREAKDOWN	
ATTAC		
	CHMENT 1	10
11.1	LIST OF REFERENCE / APPLICABLE DOCUMENTS	10
		10
ATTAC 11.2	LIST OF REFERENCE / APPLICABLE DOCUMENTS CHMENT 2 VENDOR DOCUMENTS MIN. REQUIREMENT	10 10
ATTAC 11.2	LIST OF REFERENCE / APPLICABLE DOCUMENTS	10 10
11.2 ATTAC ATTAC	LIST OF REFERENCE / APPLICABLE DOCUMENTS CHMENT 2 VENDOR DOCUMENTS MIN. REQUIREMENT CHMENT 3 DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION	10 10 10 13
11.2 ATTAC ATTAC	LIST OF REFERENCE / APPLICABLE DOCUMENTS CHMENT 2 VENDOR DOCUMENTS MIN. REQUIREMENT CHMENT 3	10 10 10 13



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

· 27 - · 77 - 9114

		PINK FOR	R CAPAC	HOR	BANK		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	MR	0011	D00

شماره صفحه: ۴ از ۱۴

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development – Surface Facilities; New

Gas Compressor Station

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy – Design & Inspection

(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



	شماره پیمان:
۰۵۳ - ۰۷۳ -	- 9114

		PMR FOR	R CAPAC	CITOR	BANK		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	MR	0011	D00

شماره صفحه: ۵ از ۱۴

2.0 GENERAL

- This document presents the item material requisitions for Contractor's use as appropriate.
- This material requisition covers the requirements for the design, manufacturing, testing and supply of Capacitor Bank as listed below. All equipment/devices/items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.
- The vendor's supply shall include:

No	Item	Description	Tag Number
1	LV Capacitor Bank	120 KVAR, 0.4 KV, Group Compensation on LV Switchgear	2 Sets (One for each Normal Bus section)
2	MV Capacitor Bank	pacitor Bank 500 KVAR, 11 KV, Individual Compensation on MV Switchgear	

3.0 REFERENCE / ATTACHED DOCUMENTS

- **a.** Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- **b.** All codes and standards which have been referenced in above mentioned specs shall be considered.
- **c.** In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.

d. Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



پیمان:	شماره

· 24 - · 74 - 9114

PMR FOR CAPACITOR BANK								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	PEDCO	120	EL	MR	0011	D00	

شماره صفحه: ۶ از ۱۴

If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, the supplier shall be considered to be in full compliance with the relevant document.

The supplier may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY

The supplier shall supply Capacitor Bank. The scope of supply is detailed at para. 5. The supplier shall include in the supply, all other equipment/devices/items not listed in the following, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.

5.0 LIMITS OF SUPPLY

5.1 SCOPE OF SUPPLY

5.1.1 MAIN DESCRIPTION

Capacitor Bank according to "Calculation Note for Capacitor Banks (BK-GCS-PEDCO-120-EL-CN-0011)" & "Data Sheets for Capacitor Bank (BK-GCS-PEDCO-120-EL-DT-0007)". The supplier shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.
- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.
- Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:	
۹۱۸۴ – ۳۲۰ – ۳۵۰	

PMR FOR CAPACITOR BANK									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	GCS	PEDCO	120	EL	MR	0011	D00		

شماره صفحه: ۷ از ۱۴

- QA/QC organization and procedures that shall be submitted for approval.
- Plan for HOLD points in the production process proposed to PURCHASER for witness or approval particular activities.
- Production schedule indicating main quality manufacturing processes, inspection and tests.
- Qualification of all personnel performing tests to be reviewed by the inspector
- Supplier shall also provide the description of the following quality activities:
 - Sub suppliers products quality
 - Quality check and identification of the materials and equipment entering in their manufacturing shop.
- · Calibration of test instruments and equipment
- · Provide detailed specifications and data sheets.

5.1.2 SPARE PARTS

Following items shall be considered (supplied) and included in the bid documentation:

- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Capital spare parts (as option / if any)

5.1.3 OTHER ITEMS

Special tools required for installation and maintenance

5.2 EXCLUSIONS

The following items are excluded by the supplier scope of supply and will be provided by purchaser:

Not Applicable

5.3 BATTERY LIMITS

The battery limits are summarized as follows:

Not Applicable

6.0 INSPECTION AND TESTS

The equipment shall be inspected and tested in accordance with the quality control plan issued by the supplier and approved by the PURCHASER before the award of the order. The QC plan



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



	شماره پیمان:
- ۵۳ –	۹۱۸۴ – ۳۲۰

PMR FOR CAPACITOR BANK									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	GCS	PEDCO	120	EL	MR	0011	D00		

شماره صفحه: ۸ از ۱۴

shall at least be according to the PROJECT ITP PROCEDURE (Doc. No. ICE-EID-MI-SP01-Rev01 & ICE-EID-MI-SP02-REV-01) and data sheets (if any).

The supplier shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE

- Vendor document shall be according to attachment 2 of this document.
- All documents, preliminary or final, are to be stamped and signed by the supplier.
- Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.
- PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.
- All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 "GENERAL DEFINITION"

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, testing, final check-out and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.

Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-suppliers.

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.

The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/packages at site

VENDOR shall guarantee the performance of supplied items (if any).

VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



مان:	پيە	شماره

٠	۵٣	-	۰۷۳	– ٩	١	14

PMR FOR CAPACITOR BANK									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	GCS	PEDCO	120	EL	MR	0011	D00		

شماره صفحه: ۹ از ۱۴

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period. Vendor shall ensure a correct & safe operation of the unit, providing all safety protection Devices. Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION

VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.

VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for PURCHASER's approval.

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (END-QC-SP-1)
- 3) 2 years operational spare parts (END-QC-SP-1)
- 4) Packing & transportation
- 5) Other fee (if any)



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



	ماره پیمان:
۰۵۳ - ۲۰	"— 91 <i>1</i> 16

PMR FOR CAPACITOR BANK									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	GCS	PEDCO	120	EL	MR	0011	D00		

شماره صفحه: ۱۰ از ۱۴

ATTACHMENT 1

11.1 LIST OF REFERENCE / APPLICABLE DOCUMENTS

No.	Document No.	Document Title			
Proc	ess				
1.	BK-GNRAL-PEDCO-000-PR-DB-0001	Process Basis of Design	D08		
Elec	trical				
2.	BK-GNRAL-PEDCO-000-EL-DC-0001	Electrical Design Criteria	D02		
3.	BK-GNRAL-PEDCO-000-EL-SP-0012	Specification for Capacitor Bank	D03		
4.	BK-GCS-PEDCO-120-EL-CN-0011	Calculation Note for Capacitor Banks	D02		
5.	BK-GCS-PEDCO-120-EL-DT-0007	Data Sheets for Capacitor Bank	D01		
6.	BK-GCS-PEDCO-120-EL-SL-0007	Capacitor Banks Single Line Diagram	D01		
7.	BK-GCS-PEDCO-120-EL-SL-0002	LV Switchgear/MCC Single Line Diagram	D04		
8.	BK-GCS-PEDCO-120-EL-SL-0003	Existent MV Switchgear Expansion Single Line Diagram	D04		
Arch	itect				
9.	BK-GCS-PEDCO-120-AR-DW-0002	Architectural Detail Drawing For Extension of Existing Elect. Building	D02		
Gene	eral				
10.	BK-GNRAL-PEDCO-000-QC-PR-0022	Specification for Final Data Book (FDB) Requirements	D00		
11.	BK-GNRAL-PEDCO-000-QC-PR-0045	Packing , Marking , Transportation Procedure	D00		
12.	ICE-EID-MI-SP01-Rev01	دستورالعمل بازرسی، خرید و ساخت کالا	-		
13.	ICE-EID-MI-SP02-Rev01	سطح بازرسی کالا و تجهیزات	-		
14.	E&C-QC-SP-1	دستورالعمل تامین قطعات یدکی راه اندازی و راهبری دو سالانه	-		
15.	BK-GNRAL-PEDCO-000-PI-SP-0006	Specification For Painting	D04		
16.	BK-GNRAL-HD-000-PM-PR-0003	Document Numbering Procedure	G04		

ATTACHMENT 2

11.2 <u>VENDOR DOCUMENTS MIN. REQUIREMENT</u>

		With Bid	TIME SCHEDULE					
o S		With Bid	For Re	view	Fina	l Issue		
Item	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)		
MAN	AGEMENT							
1	Vendor Document Index and Schedule	4N	6C+E		6C+E			
2	Organization Brief	3N	6C+E					



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

· 24 - · 74 - 9114

	PMR FOR CAPACITOR BANK										
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه				
BK	GCS	PEDCO	120	EL	MR	0011	D00				

شماره صفحه: ۱۱ از ۱۴

		With Did		TIME S	SCHEDULE	
9		With Bid	For Re	view	Fina	Issue
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
3	Schedule Level 1, 2, 3 & 4 showing Engineering, Procurement, Fabrication, Inspection, Testing, and Delivery Plan.	4N	6C+E		6C+E	
4	Physically Progress Report (Every 2 Weeks))		6C+E			
5	Project Organization Chart	3N	6C+E			
6	Reference List	3N				
7	Vendor Catalogue	3N				
8	Sub-vendors list	3N				
QUA	LITY					
9	Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO)	4N			6C+E	
10	Preliminary Inspection and Test Plan	4N				
11	Inspection and Test Plan		6C+E		6C+E	
HSE						
12	HSE Procedure		6C+E		6C+E	
ENG	NEERING					
13	Wiring & Terminal Diagram for Capacitor Bank		6C+E		6C+E	
14	Calculation sizing of Capacitor Bank		6C+E		6C+E	
15	Data Sheet for Capacitor Bank		6C+E		6C+E	
16	Outline Drawing for Capacitor Bank		6C+E		6C+E	
17	Name Plate Drawing for Capacitor Bank		6C+E		6C+E	
18	Foundation Detail for Capacitor Bank		6C+E		6C+E	
PRO	CUREMENT					
19	List of Sub-Suppliers (table giving: part of equipment, tag no., sub-supplier reference)(5.1.3)	4N			6C+E	
20	Unpriced copy of sub-orders		6C+E			
MAN	UFACTURING					
21	Surface Preparation and Painting Procedures		6C+E		6C+E	



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

· 27 - · 77 - 9114

	PMR FOR CAPACITOR BANK									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه			
BK	GCS	PEDCO	120	EL	MR	0011	D00			


شماره صفحه: ۱۲ از ۱۴

		With Did	TIME SCHEDULE					
ė.		With Bid	For Re	view	Final Issue			
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)		
22	Welder Qualification Procedure		6C+E		6C+E			
TES1	TING							
23	Factory Acceptance Test (FAT) Procedure		6C+E		6C+E			
REC	ORDS, REPORTS & CERTIFICATES							
24	Type Test Certificate		6C+E		6C+E			
INST	ALLATION							
25	Sub-Assembly Documentation		6C+E		6C+E			
26	Sub-Assembly Drawings		6C+E		6C+E			
27	Erection/Installation Manual (if required)		6C+E		6C+E			
28	Handling, Transportation & Storage Instructions & Preservation		6C+E		6C+E			
29	Unpacking & Inspection Instructions		6C+E					
30	Packing List		6C+E		6C+E			
OPE	RATION & MAINTENANCE							
31	Operating Instructions		6C+E		6C+E			
32	Maintenance Instructions (if required)		6C+E		6C+E			
33	Commissioning & Start-up Manual		6C+E		6C+E			
34	List of Spare Parts Commissioning & Start- up	4N	6C+E		6C+E			
35	List of Spare Parts 2 Years Operation	4N	6C+E		6C+E			
36	List of Special Tools	4N	6C+E		6C+E			
37	Software Manual (incl. Troubleshooting)		6C+E		6C+E			
38	Function Test Procedure		6C+E		6C+E			
отні	ERS							
39	All others documents (if required) will be listed in the order		6C+E					

NOTES:

- (1) N= Number of document, C=Copy, E=Electronic Copy
- (2) Starting from date of order placement
- (3) Starting from reception of documentation without comments







	شماره پیمان:
۰۵۳ – ۰۷	T - 9114

	PMR FOR CAPACITOR BANK									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه									
BK	GCS	PEDCO	120	EL	MR	0011	D00			

شماره صفحه: ۱۳ از ۱۴

	Document O	With Bid		TIMES	CHEDULE	
ġ.		Willi Biu	For Re	view	Fina	l Issue
		Copies	Copies	Solar	Copies	Calendar
프		No./Type	No./Type	days	No./Type	days
		(7)	(1)	(2)	(1)	(3)

- (4) First issue of the document is subjected to the release of payment milestone as per purchase order
- (5) Calendar days after reception of drive data
- (6) Prior to testing
- (7) One copy each bid copy
- (8) List of Documents Will be Finalized in Vendor Document index and Schedule

ATTACHMENT 3

11.3 <u>DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION</u>

Requisition No.:	
Description:	
Equipment No.:	

Item No.	Description of proposed exception	Recommended revision to job specification	Reason for proposed exception	Effect on base proposal if CONTRACTOR rejects exception





احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

:شماره پیمان PMR FOR CAPACITOR BANK									
۹۱۸۴ – ۲۷۰ – ۱۸۴	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	شماره صفحه : ۱۴ از ۱۴
· &1 = · /1 = · //	BK	GCS	PEDCO	120	EL	MR	0011	D00	

ATTACHMENT 4

Requisition No.:

Description:

11.4 ALTERNATIVES TO JOB SPECIFICATION

Equipment No.:					
	Item No.	Job Specification No. & Paragraph No.	Requirements of Job Specification	Description of Proposed Alternative	Reason for Proposed Alternative