

ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



چندراهه کلاستر بینک

شماره پیمان:

053 - 073 - 9184

| PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK | | | | | | | |
|---|--|--|--|--|--|--|--|
| B/C MANIFOLD | | | | | | | |
| | | | | | | | |

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 1 از 17

طرح نگهداشت و افزایش تولید 27 مخزن

PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK B/C MANIFOLD

نگهداشت و افزایش تولید میدان نفتی بینک

| Class: 3 CLIENT Doc Number: E07-708137 | | | | | | |
|--|-----------|-------------------------|---------------|-------------|--------------|-----------------|
| Rev. | Date | Purpose of Issue/Status | Prepared by: | Checked by: | Approved by: | CLIENT Approval |
| D00 | APR. 2023 | IFI | P.Hajisadeghi | M.Fakharian | M.Mehrshad | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

Class: 3 CLIENT Doc. Number: F0Z-708137

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for CLIENT Review

AB-A: As-Built -Approved




053 - 073 - 9184

شماره پیمان:

نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های رو زمینی در بسته های کاری تحت الارض

ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK
B/C MANIFOLD

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00



شماره صفحه: 2 از 17

REVISION RECORD SHEET

| PAGE | D00 | D01 | D02 | D03 | D04 |
|-----------|----------|-----|-----|-----|-----|
| 1 | Х | | | | |
| 2 | X | | | | |
| 3 | X | | | | |
| 4 | X | | | | |
| 5 | X | | | | |
| | | | | | |
| <u>6</u> | X | | | | |
| | | | | | |
| 8 | X | | | | |
| 9 | X | | | | |
| 10 | X | | | | |
| 11 | X | | | | |
| 12 | X | | | | |
| 13 | X | | | | |
| 14 | X | | | | |
| 15 | Χ | | | | |
| 16 | X | | | | |
| 17 | Х | | | | |
| 18 | | | | | |
| 19 | | | | | |
| 20 | | | | | |
| 21 | | | | | |
| 22 | 1 | | | | |
| 23 | 1 | | | | |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | | | | | |
| 28 | | | | | |
| 29 | | | | | |
| 30 | | | | | |
| 31 | | | | | |
| 32 | | | | | |
| 33 | | | | | |
| 34 | | | | | |
| 35 | | | | | |
| 36 | | | | | |
| 37 | | | | | |
| 38 | | | | | |
| 39 | | | | | |
| 40 | | | | | |
| 41 | | | | | |
| | | | | | |
| 42 | + | | | 1 | |
| 43 | + | | | 1 | |
| 44 | + | | | | |
| 45 | + | | | | |
| 46 | + | | | | |
| 47 | 1 | | | 1 | |
| 48 | <u> </u> | | | | |
| 49 | 1 | | | | |
| 50 | | | | | |
| 51 | | | | | |
| 52 | | | | | |
| 53 | | | | | |
| 54 | | | | | |
| 55 | | | | | |
| 56 | | | | | |
| 57 | | | | | |
| 58 | 1 | | | | |
| <u>56</u> | 1 | | | | |
| 59 | + | | | 1 | |
| 60 | 1 | | | 1 | |
| 61 | 1 | | | 1 | |
| 62 | 1 | | | | |
| 63 | ļ | | | | |
| 64 | | | | | |
| 65 | | | | | |

| PAGE | D00 | D01 | D02 | D03 | D04 |
|------------|-----|-----|----------|-----|-----|
| 66 | | | | | |
| 67 | | | | | |
| 68 69 | | | | | |
| 70 | | | | | |
| 71 | | | | | |
| 72 | | | | | |
| 73 | | | | | |
| 74 75 | | | | | |
| 76 | | | | | |
| 77 | | | | | |
| 78 | | | | | |
| 79 | | | | | |
| 80 81 | | | | | |
| 82 | | | | | |
| 83 | | | | | |
| 84 | | | | | |
| 85 | | | | | |
| 86 87 | | | | | |
| 87 88 | | | <u> </u> | | |
| 89 | | | | | |
| 90 | | | | | |
| 91 | | | | | |
| 92 | | | | | |
| 93 94 | | | | | |
| 95 | | | | | |
| 96 | | | | | |
| 97 | | | | | |
| 98 | | | | | |
| 99 100 | | | | | |
| 101 | | | | | |
| 102 | | | | | |
| 103 | | | | | |
| 104 | | | | | |
| 105 | | | | | |
| 106 107 | | | | | |
| 108 | | | | | |
| 109 | | | | | |
| 110 | ļ | | ļ | | |
| 111 | | | - | | |
| 112 113 | | | 1 | | |
| 114 | | | | | |
| 115 | | | | | |
| 116 | | | 1 | | ļ |
| 117 | | | | | |
| 118 119 | | | | | |
| 119 | | | <u> </u> | | |
| 121 | | | | | |
| 122 | | | | | |
| 123 | | | <u> </u> | | |
| 124 | | | - | | |
| 125 126 | | | 1 | | |
| 127 | | | | | |
| 128 | | | | | |
| 129 | | | | | |
| 130 | | | |] | |



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



چندراهه كلاستر بينك

شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK B/C MANIFOLD

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 3 از 17

CONTENTS

| 1.0 | INTRODUCTION | 4 |
|-------|--|-----|
| 2.0 | GENERAL | 5 |
| 3.0 | REFERENCE / ATTACHED DOCUMENTS | 5 |
| 4.0 | SUBJECT OF THE SUPPLY | 5 |
| 5.0 | LIMITS OF SUPPLY | 6 |
| 5.1 | SCOPE OF SUPPLY | 6 |
| 5.2 | EXCLUSIONS | |
| 5.3 | BATTERY LIMITS | |
| 6.0 | INSPECTION AND TESTS | 8 |
| 7.0 | VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE | . 8 |
| 8.0 | UNIT RESPONSIBILITY | 8 |
| 9.0 | GUARANTEE AND WARRANTY | . 8 |
| 10.0 | DEVIATION | 9 |
| 11.0 | PRICE BREAKDOWN | |
| | CHMENT 1 | |
| | CHMENT 2 | |
| | CHMENT 3 | |
| ATTAC | HMENT 4 | 17 |



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



چندراهه كلاستر بينك

شماره پیمان:

053 - 073 - 9184

| PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK B/C MANIFOLD | | | | | | | |
|---|-----------|------------|---------|------|----------|-------|------|
| پروژه | بسته کاری | صادر كننده | تسهيلات | رشته | نوع مدرك | سريال | نسخه |
| BK | W007S | PEDCO | 110 | IN | MR | 0018 | D00 |

شماره صفحه: 4 از 17

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, construction of well location, access road, wellhead facilities (with electric power supply) for W007S shall be done. In addition, construction of new flow line from aforementioned well location to Binak B/C unit (with extension of relevant manifold) is in the Project scope of work.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development - Construction of Well

Location, Wellhead Facilities, Electrification Facilities, Flowlines for W007S and Extension of Binak B/C

Manifold

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of: Hirgan Energy - Design &

Inspection(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



شماره پیمان:

053 - 073 - 9184

| PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK | | | | | | | |
|---|--|--|--|--|--|--|--|
| B/C MANIFOLD | | | | | | | |
| | | | | | | | |

جندراهه كلاستر بينك

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 5 از 17

2.0 GENERAL

- This document presents the item material requisitions for Contractor's use as appropriate.
- This material requisition covers the requirements for the design, manufacturing, testing and supply of Instrument Cable Tray/Ladder as listed in section 5. All equipment/devices/items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.

3.0 REFERENCE / ATTACHED DOCUMENTS

- **a.** Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- **b.** All codes and standards which have been referenced in above mentioned specs shall be considered.
- **c.** In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.
- d. Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.

If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, the supplier shall be considered to be in full compliance with the relevant document.

The supplier may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY

The supplier shall supply Instrument Cable Tray/Ladder. The scope of supply is detailed at part. 5. The supplier shall include in the supply, all other equipment/devices/items not listed in the following, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه چندراهه کلاستر بینک



شماره پیمان:

053 - 073 - 9184

| PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK | | | | | | | |
|---|--|--|--|--|--|--|--|
| B/C MANIFOLD | | | | | | | |
| | | | | | | | |

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 6 از 17

5.0 LIMITS OF SUPPLY

5.1 SCOPE OF SUPPLY

5.1.1 MAIN DESCRIPTION

The scope of supply includes:

- Cable Tray/Ladder
- Special tools for erection, maintenance and normal operation
- All other necessary components not called for here
- Painting and coating(if required)

Detail of supply is listed below:

| No. | Item | Description |
|-----|-------------------------------------|---|
| 2 | Cable Trays/Ladder with accessories | As per attached documents, "MTO For Instrument Cable Tray/Ladder - W007S & Manifold- BK-W007S-PEDCO-110-IN-MT-0005" |

The supplier shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.
- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.
- Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:
 - QA/QC Organization Chart and procedures that shall be submitted for approval.
 - Plan for HOLD points in the production process proposed to CLIENT for witness or approval particular activities.
 - Production schedule indicating main quality manufacturing processes, inspection and tests.
 - Qualification of all personnel performing tests to be reviewed by the inspector



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه چندراهه کلاستر بینک



شماره پیمان:

053 - 073 - 9184

| PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK | | | | | | | |
|---|--|--|--|--|--|--|--|
| B/C MANIFOLD | | | | | | | |
| | | | | | | | |

 B/C MANIFOLD

 نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 7 از 17

- Supplier shall also provide the description of the following quality activities:
 - Sub suppliers products quality
 - Quality check and identification of the materials and equipment entering in their manufacturing shop.
- · Calibration of test instruments and equipment
- · Provide detailed specifications and data sheets.

5.1.2 SPARE PARTS

- The Vendor shall provide certain quantities of consumable for the installation, precommissioning, commissioning, start-up and up to the end of the guarantee period.
- The quantities shall be estimated by Vendor and shall be based upon the Vendor's experience. The following two periods shall be taken into account:
 - Pre-commissioning and commissioning period where the consumption of consumable is greater
 - Normal use of the System
- The VENDOR shall provide lists of recommended spare parts, which shall include the original part numbers with prices for commissioning, start-up and two years operation. All spare parts shall be identified individually.
- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&C-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&C-QC-SP-1).
- The VENDOR shall be able to provide spares back up and support for the plant life of at least 20 years.
- SPIR form shall be approved by CLIENT prior to procurement.

5.1.3 OTHER ITEMS

No Other Items.

5.2 EXCLUSIONS

No exclusion is applicable.

5.3 BATTERY LIMITS

No battery limit is applicable.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه چندراهه کلاستر بینک



شماره پیمان:

053 - 073 - 9184

| PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK | | | | | | | |
|---|--|--|--|--|--|--|--|
| B/C MANIFOLD | | | | | | | |
| | | | | | | | |

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 8 از 17

6.0 INSPECTION AND TESTS

The equipment shall be inspected and tested in accordance with the quality control plan issued by the vendor and approved by the CLIENT/EPC CONTRACTOR before the award of the order. The QC plan shall at least be according to the Commodity Procurement and Manufacturing Inspection Instruction (Doc.s No.s E&C-QC-IN-SP-1, ICE-EID-MI-SP01) and data sheets.

The supplier shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE

- Vendor document shall be according to attachment 2 of this document.
- All documents, preliminary or final, are to be stamped and signed by the supplier.
- Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.
- PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.
- All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 "GENERAL DEFINITION"

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, testing, final check-out and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.

Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-suppliers.

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه چندراهه کلاستر بینک



شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK B/C MANIFOLD

 نسخه
 سریال
 نوع مدرک
 رشته
 تسهیلات
 صادرکننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 9 از 17

The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/packages at site

VENDOR shall guarantee the performance of supplied items.

VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period.

Vendor shall ensure a correct and safe operation of the unit, providing all safety protection Devices.

Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION

VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.

VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for CLIENT's approval.



053 - 073 - 9184

نگهداشت و افزایش تولید میدان نفتی بینک فعالیت های رو زمینی در بسته های کاری تحت الارض

ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه چندراهه کلاستر بینک



PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK شماره پیمان: **B/C MANIFOLD**

پروژه بسته کاري صادر كننده تسهيلات نوع مدرك سريال نسخه ΒK W007S PEDCO 110 MR 0018 D00

شماره صفحه: 10 از 17

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (E&C-QC-SP-1)
- 3) 2 years operational spare parts (SP-1)
- 4) Packing & transportation



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



چندراهه کلاستر بینک

شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK
B/C MANIFOLD

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 11 از 17

ATTACHMENT 1

LIST OF REFERENCE / APPLICABLE DOCUMENTS

| No. | Document No. | Document Title | Rev. | | | |
|------------|-------------------------------|--|------|--|--|--|
| Instrument | | | | | | |
| 1. | BK-GNRAL-PEDCO-000-IN-SP-0001 | Specification For Instrumentation | D04 | | | |
| 2. | BK-W007S-PEDCO-110-IN-DG-0003 | Instrument Hook-up Diagram - Extension of Binak B/C Manifold | D01 | | | |
| 3. | BK-SSGRL-PEDCO-110-IN-DC-0002 | Instrument & Control System Design Criteria | D01 | | | |
| 4. | BK-W007S-PEDCO-110-IN-MT-0005 | MTO For Instrument Cable Tray/Ladder - W007S & Manifold | D00 | | | |
| Proc | Process | | | | | |
| 5. | BK-GNRAL-PEDCO-000-PR-DB-0001 | Process Basis Of Design | D08 | | | |
| Gene | eral | | | | | |
| 6. | ICE-EID-MI-SP01-Rev01 | دستورالعمل بازرسی، خرید و ساخت کالا | D01 | | | |
| 7. | ICE-EID-MI-SP02-Rev01 | دستورالعمل انتخاب سطح بازرسي كالا و تجهيزات | D01 | | | |
| 8. | E&C-QC-SP-1 | دستورالعمل تامین قطعات ید کی راه اندازی وراهبری دو سالانه | D00 | | | |
| 9. | BK-GNRAL-PEDCO-000-QC-PR-0022 | Specification For Final Data Book (FDB) Requirements | D00 | | | |
| 10. | BK-GNRAL-PEDCO-000-QC-PR-0045 | Packing, Marking, Transportation Procedure | D00 | | | |

^{**}NOTE: THE LATEST REVISION OF PROJECT DOCUMENT IN ATTACHMENT 1 TO BE CONSIDERED AS REFERENCE BY VENDOR.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



چندراهه کلاستر بینک

شماره پیمان:

PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK **B/C MANIFOLD** بسته کاری پروژه 053 - 073 - 9184

W007S

نوع مدرك نسخه سريال رشته تسهيلات صادر كننده PEDCO 110 MR 0018 D00

شماره صفحه: 12 از 17

ATTACHMENT 2

VENDOR DOCUMENTS MIN. REQUIREMENT

BK

| | | WITH BID | | AFTER OR | DERING | | AT THE FINAL |
|-----|---|-------------|--------------------|----------------------|--------------------|----------------|-----------------------|
| NO. | DESCRIPTION | | Q./TY PE (1) | DELIVERY DATE (2) | PURPO SE (3) | FINAL ISSUE | INSPECTI ON (4) |
| | MAN | AGEMENT | | | | | |
| 1 | Vendor Document Index and Schedule | 4N | (5) | 2W | Α | (5) | Х |
| 2 | Organization Brief | 4N | (5) | 2W | I | (5) | |
| 3 | Schedule Level 1, 2, 3 & 4 showing Engineering, Procurement, Fabrication, Inspection, Testing, and Delivery Plan. | 4N | (5) | 3W | Α | (5) | Х |
| 4 | Physically Progress Report (Every 2 Weeks)) | | (5) | 2W | | | |
| 5 | Project Organization Chart | 4N | (5) | 2W | | | Х |
| 6 | Reference List | 4N | (5) | 2W | I | (5) | |
| 7 | Vendor Catalogue | 4N | (5) | 2W | 1 | (5) | Х |
| | Q | UALITY | | | | | |
| 8 | Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO) | 4N | | | А | (5) | |
| 9 | Preliminary Inspection and Test Plan | 4N | | | | | |
| 10 | Inspection and Test Plan | | (5) | 3W | Α | (5) | |
| | | HSE | | | | | |
| 11 | HSE Procedure | | (5) | 4W | А | (5) | Х |
| | ENG | INEERING | | | | | |
| 12 | Dimensional Outlines | 4N | (5) | 4W | А | (5) | Х |
| 13 | Mounting Details | | (5) | 4W | А | (5) | Х |
| 14 | General Arrangement | 4N | (5) | 4W | А | (5) | Х |



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



شماره پیمان:

053 - 073 - 9184

چندراهه کلاستر بینک PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK B/C MANIFOLD

 نسخه
 سریال
 نوع مدرک
 رشته
 تسهیلات
 صادرکننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 13 از 17

| | | | | AFTER OR | DERING | | AT THE FINAL |
|-----|--|----------------|--------------------|----------------------|--------------------|----------------|-----------------------|
| NO. | DESCRIPTION | Q./TYPE (1) | Q./TY PE (1) | DELIVERY DATE (2) | PURPO SE (3) | FINAL ISSUE | INSPECTI ON (4) |
| 15 | Hook-Up Diagrams | | (5) | 4W | Α | (5) | X |
| 16 | Parts/Material List | 4N | (5) | 4W | Α | (5) | X |
| 17 | Technical Description and Relevant Catalogues | 4N | (5) | 4W | Α | (5) | Х |
| 18 | List of Deviations from the Specification and Data Sheets | 4N | (5) | 4W | А | (5) | |
| 19 | Final Data Book | | | | Α | (5) | Х |
| | PROC | CUREMEN' | Т | | | | |
| 20 | List of Sub-Vendors (table giving: part of equipment, tag no., sub-vendor reference)(5.1.3) | 4N | (5) | 4W | А | (5) | |
| 21 | Unpriced copy of sub-orders | 4N | (5) | 4W | I | - | |
| 22 | Packing Spec. / Shipping Schedule | 4N | (5) | 4W | I | - | |
| 23 | Weight List/ Shipping List | 4N | (5) | 4W | I | (5) | |
| 24 | Mechanical & Performance Guarantees | 4N | (5) | 4W | I | - | |
| | MANU | FACTURIN | IG | | | | |
| 25 | Preliminary Project Schedule | | (5) | 4W | I | - | |
| 26 | Surface Preparation and Painting Procedures | | (5) | 4W | I | (5) | Х |
| 27 | Fabrication Degree | | (5) | 4W | I | (5) | Х |
| | TE | ESTING | | | | | |
| 28 | Manufacturing, Test & Inspection Procedures | 4N | (5) | 4W | А | (5) | Х |
| 29 | Performance & Functional Test Procedure | | (5) | 4W | А | (5) | Х |
| 30 | Non-Destructive Testing/Examination Procedures | | (5) | 4W | А | (5) | Х |
| 31 | Factory Acceptance Test (FAT) Procedure | | (5) | 4W | Α | (5) | Х |
| | RECORDS, REPO | ORTS & CE | RTIFIC | ATES | | | |
| 32 | Material Conformity Certificate | | (5) | 4W | I | (5) | Х |
| 33 | Testing Authority Approval Certificate | | (5) | 4W | I | (5) | Х |



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



شماره پیمان:

053 - 073 - 9184

چندراهه کلاستر بینک PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK B/C MANIFOLD

 نسخه
 سریال
 نوع مدرک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 W007S
 PEDCO
 110
 IN
 MR
 0018
 D00

شماره صفحه: 14 از 17

| | IO. DESCRIPTION | | | AFTER OR | DERING | | AT THE FINAL |
|-----|---|----------|--------------------|----------------------|--------------------|----------------|-----------------------|
| NO. | | | Q./TY PE (1) | DELIVERY DATE (2) | PURPO SE (3) | FINAL ISSUE | INSPECTI ON (4) |
| 34 | Hazardous Area Certificates. | | (5) | 4W | I | (5) | Х |
| 35 | Conformity Certificates (sub-vendor/equipment) | | (5) | 4W | I | (5) | Х |
| 36 | Material Certificates Identification Diagram. (cross-reference material location; certificates for critical components) | | (5) | 4W | I | (5) | Х |
| 37 | Hardness Test Reports | | (5) | 4W | Α | (5) | Х |
| 38 | Pressure Test Reports / Certificates | | (5) | 4W | А | (5) | Х |
| 39 | FAT Test Report / Certificates | | (5) | 4W | А | (5) | |
| 40 | Performance Test Report / Certificates | | (5) | 4W | Α | (5) | Х |
| 41 | Material Test Certificates | | (5) | 4W | I | (5) | Х |
| 42 | Surface Preparation & Coating Reports | | (5) | 4W | А | (5) | |
| 43 | Test & Inspection Reports | | (5) | 4W | А | (5) | |
| 44 | Rust Prevention Report | | (5) | 4W | Α | (5) | |
| 45 | Non-Conformities Report | | (5) | 4W | Α | (5) | |
| 46 | Letter of Conformity | | (5) | 4W | Α | (5) | |
| | INST | ALLATION | | | | | |
| 47 | Sub-Assembly Documentation | | (5) | 4W | А | (5) | |
| 48 | Sub-Assembly Drawings | | (5) | 4W | Α | (5) | |
| 49 | Erection/Installation Manual (if required) | | (5) | 4W | Α | (5) | |
| 50 | Handling, Transportation & Storage Instructions | 4N | (5) | 4W | Α | (5) | |
| 51 | Unpacking & Inspection Instructions | | (5) | 4W | Α | (5) | |
| 52 | Preliminary Packing List | | (5) | 4W | Α | (5) | |
| 53 | Packing List | | (5) | 4W | Α | (5) | |
| | OPERATION | & MAINTE | NANCE | | | | |
| 54 | Operating Instructions | | (5) | 4W | А | (5) | |



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



چندراهه کلاستر بینک

شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK B/C MANIFOLD

| | _, 0 0 | | | | | | |
|-------|-----------|------------|---------|------|----------|-------|------|
| پروژه | بسته کاری | صادر کننده | تسهيلات | رشته | نوع مدرك | سريال | نسخه |
| BK | W007S | PEDCO | 110 | IN | MR | 0018 | D00 |

شماره صفحه: 15 از 17

| | IO. DESCRIPTION | | WITH AFTER ORDERING | | | | | |
|-----|--|-------|---------------------|----------------------|--------------------|----------------|-----------------------|--|
| NO. | | | Q./TY PE (1) | DELIVERY DATE (2) | PURPO SE (3) | FINAL ISSUE | INSPECTI ON (4) | |
| 55 | Maintenance Instructions | | (5) | 4W | А | (5) | | |
| 56 | Commissioning & Start-up Manual | | (5) | 4W | А | (5) | | |
| 57 | List of Spare Parts Commissioning & Start-up | 4N | (5) | 4W | А | (5) | | |
| 58 | List of Spare Parts 2 Years Operation | 4N | (5) | 4W | А | (5) | | |
| 59 | List of Special Tools | 4N | (5) | 4W | Α | (5) | | |
| 60 | Consumables List | | (5) | 4W | Α | (5) | | |
| | 0 | THERS | | | | | | |
| 61 | Vendor Final Book | | (5) | 4W | А | (5) | Х | |
| 62 | All others documents (if required) will be listed in the order | | | | | | | |

NOTES:

- *** The electronic file (Native/PDF) and Hardcopy version shall be provided in all stages by vendor.
- (1) Q : QUANTITY ; TYPE : C = COPY, R = REPRODUCIBLE, P = POLYESTER, M = MICROFILM, E = ELECTRONIC, N=NUMBER OF DOCUMENT
- (2) W = CONSECUTIVE CALENDAR WEEK, M = CONSECUTIVE CALENDAR MONTH
- (3) A = FOR APPROVAL I = FOR INFORMATION
- (4) X = DOCUMENTS TO BE SUBMITTED AT THE FINAL INSPECTION
- (5) "6 C+E" COPY OF DOCUMENT.
- (6) MECHANICAL CATALOGUE INCLUDING FINAL DRAWINGS/DOCUMENTS, UNPRICED PURCHASE ORDER & SUB-

PURCHASE ORDER, MAINTENANCE DOSSIER ETC.

(7) ALL DOCUMENTS AND/OR DRAWINGS FOR THIS PROJECT SHALL ALSO BE SUBMITTED IN THE ELECTRONIC FILES BY

USING THE FOLLOWING SOFTWARE.

MS OFFICE WORD 2013 OR UPPER VERSION (ENGLISH) FOR WORD PROCESSING MS OFFICE EXCEL 2013 OR UPPER VERSION (ENGLISH) FOR SPREAD SHEET AUTO CAD 2005 (ENGLISH) FOR DRAWING

- (8) IN ORDER TO DESIGN AND MANUFACTURE THE INSTRUMENTS, VENDOR SHALL CONSIDER THE SEISMIC FACTOR,
 - SUITABLE FOR SEISMIC UBC 97 ZONE 4, AND THE RESULTS SHALL BE PROVIDED BY VENDOR.
- (9) LIST OF DOCUMENTS WILL BE FINALIZED IN VPIS.



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



چندراهه كلاستر بينك

شماره پیمان:

053 - 073 - 9184

| | | | | | - | | | |
|---|-----------|------------|---------|------|----------|-------|------|--|
| PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK | | | | | | | | |
| B/C MANIFOLD | | | | | | | | |
| پروژه | بسته کاری | صادر كننده | تسهيلات | رشته | نوع مدرك | سريال | نسخه | |
| BK | W007S | PEDCO | 110 | IN | MR | 0018 | D00 | |

شماره صفحه: 16 از 17

ATTACHMENT 3

Requisition No.:

Equipment No.:

Description:

DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION

| Item No. | Description of proposed exception | Recommended revision to job specification | Reason for proposed exception | Effect on base proposal if CONTRACTOR rejects exception |
|-------------|-----------------------------------|---|-------------------------------|---|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |



ساخت موقعیت چاه، تاسیسات سرچاهی، خطوط جریانی، تسهیلات برق رسانی مربوط به موقعیت W007S و توسعه



چندراهه كلاستر بينك

شماره پیمان:

053 - 073 - 9184

| PMR F | PMR FOR INSTRUMENT CABLE TRAY/LADDER - EXTENSION OF BINAK B/C MANIFOLD | | | | | | | | |
|-------|---|------------|---------|------|----------|-------|------|--|--|
| پروژه | بسته کاری | صادر کننده | تسهيلات | رشته | نوع مدرك | سريال | نسخه | | |
| BK | W007S | PEDCO | 110 | IN | MR | 0018 | D00 | | |

شماره صفحه: 17 از 17

ATTACHMENT 4

ALTERNATIVES TO JOB SPECIFICATION

| Requisition No.: | |
|------------------|--|
| Description: | |
| Equipment No.: | |

| Item No. | Job Specification No. & Paragraph No. | Requirements of Job Specification | Description of Proposed Alternative | Reason for Proposed Alternative |
|-------------|---------------------------------------|--------------------------------------|---|------------------------------------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |