

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D02</td><td>0003</td><td>CN</td><td>SA</td><td>120</td><td>PEDCO</td><td>GCS</td><td>BK</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D02	0003	CN	SA	120	PEDCO	GCS	BK	شماره صفحه: ۲ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D02	0003	CN	SA	120	PEDCO	GCS	BK																			

REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	X	X	X		
2	X	X	X		
3	X				
4	X				
5	X				
6	X	X			
7	X	X			
8	X	X			
9	X	X			
10	X	X			
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					

PAGE	D00	D01	D02	D03	D04
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					
129					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادرکننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>SA</td><td>CN</td><td>0003</td><td>D02</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	SA	CN	0003	D02	شماره صفحه: ۳ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	SA	CN	0003	D02																			

CONTENTS

1.0	INTRODUCTION	4
2.0	SCOPE	5
3.0	NORMATIVE REFERENCES.....	5
3.1	CODES AND STANDARDS	5
3.2	THE PROJECT DOCUMENTS.....	5
3.3	ENVIRONMENTAL DATA	5
3.4	ABBREVIATION	5
4.0	METODOLOGY	6
5.0	HYDRAULIC CALCULATION.....	6
5.1	CALCULATION SOFTWARE	6
5.2	PIPENETMODEL AND INPUT DATA	6
5.3	SCENARIOS.....	7
6.0	CALCULATION RESULTS	7
6.1	SCENARIO 1 – CALCULATE THE RING SIZE AND FIRE WATER PUMPS DISCHARGE PRESUURE BASED ON MAXIMUM FIREWATER DEMAND SCENARIOS	7
6.2	SCENARIO 2 – CALCULATE THE FIRE WATER PUMPS DISCHARGE PRESUURE BASED ON MAXIMUM FIREWATER DEMAND SCENARIOS WITH A STRATEGIC BLOCKED PIPE.....	8
6.3	SCENARIO 3 – CALCULATE THE SIZE OF EACH DELUGE LINE BASED ON CALCULATED MOST REMOTE NOZZLE CALCULATION	8
7.0	CONCLUSION.....	9
8.0	ATTACHMENTS	10

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادرکننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>SA</td><td>CN</td><td>0003</td><td>D02</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	SA	CN	0003	D02	شماره صفحه : ۴ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	SA	CN	0003	D02																			

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – Surface Facilities; New Gas Compressor Station
EPD/EPC CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of : Hirgan Energy – Design & Inspection (D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC CONTRACTOR (GC) and approved by CLIENT (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by CLIENT rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR.
MAY:	Is used where a provision is completely discretionary.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D02</td><td>0003</td><td>CN</td><td>SA</td><td>120</td><td>PEDCO</td><td>GCS</td><td>BK</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D02	0003	CN	SA	120	PEDCO	GCS	BK	شماره صفحه : ۵ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
D02	0003	CN	SA	120	PEDCO	GCS	BK																			

2.0 SCOPE

The purpose of this calculation document is to establish the hydraulic performance and fire equipment capacities for the new Fire water systems associated with the Construction of Gas Compressor station Equipment.

3.0 NORMATIVE REFERENCES

3.1 CODES AND STANDARDS

- IPS-E-SF-220 Fire Water Distribution and Storage Facilities
- API-RP 2030 Application of Fixed Water Spray Systems for Fire Protection in the Petroleum and Petrochemical Industries
- TOTAL GS-EP-SAF-322 Fixed firewater system
- NFPA 15 Standard for water spray fixed systems for fire protection

3.2 THE PROJECT DOCUMENTS

- BK-GCS-PEDCO-120-SA-DB-0001 Active Fire Protection and Safety Concept
- BK-GCS-PEDCO-120-SA-CN-0002 Calculation Note For Fire Water Demand
- BK-GCS-PEDCO-120-SA-PY-0001 Fire Water Network Layout

3.3 ENVIRONMENTAL DATA

Refer to "Process Basis of Design; Doc. No. BK-GNRL-PECO-000-PR-DB-0001".

3.4 ABBREVIATION

AFP	Active Fire Protection
ALARP	As Low As Reasonably Practicable
F&G	Fire & Gas
HAZID	Hazard Identification
HAZOP	Hazard and Operability Study
HSE	Health, Environment and Safety
ISBL	Inside Boundary Limit
OSBL	Outside Boundary Limit
PFP	Passive Fire Protection
SIL	Safety Integrity Level
CGD	Catalytic Gas Detectors
IRGD	Infrared Gas Detectors

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادر کننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>SA</td><td>CN</td><td>0003</td><td>D02</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	SA	CN	0003	D02	شماره صفحه: ۶ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	SA	CN	0003	D02																			

4.0 METODOLOGY

Demand (flow and pressure) were established as per Calculation Note For Fire Water Demand to Doc. NO. BK-GCS-PEDCO-120-SA-CN-0002.

The following methodology is followed for the hydraulics calculations for verification of the adequacy of the specified performance requirements of the firewater system.

- Generate/select various fire water demand scenarios.
- Select the proper firewater pump

5.0 HYDRAULIC CALCULATION

5.1 CALCULATION SOFTWARE

The hydraulic calculations are performed by software PIPENET VISION Spray/Sprinkler Module, Version 1.8.

5.2 PIPENETMODEL AND INPUT DATA

This section provides details of input/assumption utilized for the hydraulic calculations by software PIPENET VISION Spray/Sprinkler Module.

Piping Data: ANSI B36.10 Sch.40, C factor = 120,

Design maximum velocity (Main lines & headers) = 3.5 m/sec

Standard valves and fittings equivalent length: PIPENET built-in data as per NFPA standard

Firewater Medium: Raw water

Density = 1030 kg/m³ @15°C

Viscosity = 0.001 Pas.

Details of pipe fittings and valves present on the pipe sections, node elevations, pipe lengths and pipe configuration will be later based on piping isometrics generated from the 3D-Model. This assumption will be thus updated once isometrics are available for the network piping.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادر کننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>SA</td><td>CN</td><td>0003</td><td>D02</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	SA	CN	0003	D02	شماره صفحه: ۷ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	SA	CN	0003	D02																			

Friction losses within the system are calculated by PIPENET using the Hazen-Williams equation.

5.3 SCENARIOS

Firewater will be fed from 1 x 100% firewater pumps based on the result of firewater demand report with capacity of 454.2 m3/hr.

Below scenarios should be studied in this report to calculate the required pressure of firewater pump, ring, deluge valve and also size of the ring and other facilities. For this purpose:

1. Ring main should be studied for maximum demand of flow rate to calculate the size of ring main and deluge valve feed lines. For this case two additional conditions should be studied if the ring main is broken in some areas.
2. Calculation implemented to design the required pressure at discharge of the firewater pump.
3. Deluge valve will be studied for the size of deluge lines according to most remote nozzle required flow rate.

6.0 CALCULATION RESULTS

6.1 SCENARIO 1 – CALCULATE THE RING SIZE AND FIRE WATER PUMPS DISCHARGE PRESUURE BASED ON MAXIMUM FIREWATER DEMAND SCENARIOS

The following table reflects the required pressured at fire water pumps discharge header, size of ring main and other facilities based on PIPENET hydraulic calculation results (see attached Appendices).

Table 1: Firewater ring main size and fire water pumps discharge header pressure based on PIPENET calculation without any blocked pipe section in fire water network

Fire Scenario Description	Required Flow Rate (lpm) Note 1	Minimum Required Pressure at users (barg)- Note 2	Calculated Maximum ring size (inch)	Calculated Pressure at Fire Water Pump Discharge Header (barg)
Fire in Most Remote Point of Fire Water Network, without any blocked pipe section in fire water network	6496	10	10	10.33

1. Based on Calculation Note For Fire Water Demand, BK-GCS-PEDCO-120-SA-CN-0002
2. At the inlet flange of firefighting equipment (hydrant valve) – based on IPS-E-SF-220

As per NFPA-20, the suction and discharge size of each firewater pump with capacity of 454.2

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D02</td><td>0003</td><td>CN</td><td>SA</td><td>120</td><td>PEDCO</td><td>GCS</td><td>BK</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D02	0003	CN	SA	120	PEDCO	GCS	BK	شماره صفحه: ۸ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
D02	0003	CN	SA	120	PEDCO	GCS	BK																			

m3/hr is 10".

Hydrant is 4" and hydrant/monitor is 6" based on standards and also NISOC recommendations.

Based on the above calculated sizes, pressure at discharge of firewater pumps will be as the result of scenario 2.

6.2 SCENARIO 2 – CALCULATE THE FIRE WATER PUMPS DISCHARGE PRESUURE BASED ON MAXIMUM FIREWATER DEMAND SCENARIOS WITH A STRATEGIC BLOCKED PIPE

The following table reflects the summary of firewater pump pressure based on PIPENET hydraulic calculation results (see attached Appendices).

Table 2: Firewater ring main size and fire water pumps discharge header pressure based on PIPENET calculation with a strategic blocked pipe

Fire Scenario Description	Required Flow Rate (lpm) Note 1	Minimum Required Pressure at users (barg)- Note 2	Strategic Blocked Pipe Label	Calculated Pressure at Fire Water Pump Discharge Header (barg)
Fire in Most Remote Point of Fire Water Network, with a strategic blocked pipe section in fire water network	2000	10	23	10.29

1. Based on firewater demand
2. At the inlet flange of firefighting equipment (hydrant valve) – based on IPS-E-SF-220

As per result, discharge pressure of firewater pump in case of maximum firewater demand at farthest point will be 10.29 barg.

6.3 SCENARIO 3 – CALCULATE THE SIZE OF EACH DELUGE LINE BASED ON CALCULATED MOST REMOTE NOZZLE CALCULATION

The following table reflects the sizes of deluge valve spray lines and required pressure in downstream of each deluge valve based on PIPENET hydraulic calculation results (see attached Appendices).

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادر کننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>SA</td><td>CN</td><td>0003</td><td>D02</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	SA	CN	0003	D02	شماره صفحه: ۹۰ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	SA	CN	0003	D02																			

Table 3: Deluge line sizes and pressure based on PIPENET calculation

Deluge Name	Pressure in inlet of DV (barg) Note 1	DV Size Note 2	Size of DV Lines (inch)	Required Pressure in DV down stream	Spray Nozzles K-factor
DV-2301	10.4 - 11.4	4	4	5.7	18 35 51
DV-2302	10.4 - 11.4	6	4	5.6	64 35 30
DV-2303	10.4 - 11.4	6	4	5.6	64 35 30
DV-2304	10.4 - 11.4	6	4	5	64 35 26

1. Based on Hydraulic calculation report
2. Based on Calculation Note For Fire Water Demand, BK-GCS-PEDCO-120-SA-CN-0002

7.0 CONCLUSION

Based on the result, firewater pumps should deliver flow of 6496 LPM @ 10.33 barg at the discharge tie-in of pumps to cater maximum firewater demand on the plant.

With considering of 10 barg pressure on farthest hydrant, minimum required pressure will be 10.33 barg at the firewater pump discharge to cater required firewater demand on the plant.

As per NFPA-20, the suction and discharge size of firewater pumps with capacity of 454.2 m³/hr is 10". In addition, based on standard and considering of the above calculation results, pump discharge header and ring main sizes will be considered 10".

Table 3 shows the Deluge Valve size and also Deluge line sizes and pressure. Deluge sprays should be provided with K factors according to table 3. (Data should be confirmed by deluge valve vendor)

Hydrant is 4" and hydrant/monitor is 6" based on standards and also NISOC recommendations.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">FIRE WATER HYDRAULIC CALCULATION NOTE</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D02</td><td>0003</td><td>CN</td><td>SA</td><td>120</td><td>PEDCO</td><td>GCS</td><td>BK</td></tr></table>	FIRE WATER HYDRAULIC CALCULATION NOTE								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D02	0003	CN	SA	120	PEDCO	GCS	BK	شماره صفحه : ۱۰ از ۱۰
FIRE WATER HYDRAULIC CALCULATION NOTE																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D02	0003	CN	SA	120	PEDCO	GCS	BK																			

8.0 ATTACHMENTS

Att.1: FIRE WATER NETWORK HYDRAULIC CALCULATION

Att. 1.1:

- FWHC-Most Remote Point-Normal, Calculation Report

Att. 1.2:

- FWHC-Most Remote Point-Block, Calculation Report

Att.2: DELUGE SYSTEMS HYDRAULIC CALCULATION

Att.2.1:

- DV-2301, Calculation Report

Att.2.2:

- DV-2302, Calculation Report

Att.2.3:


- DV-2303, Calculation Report

Att.2.4:


- DV-2304, Calculation Report

ATTACHMENTS

Att.1.1



Fire Water Hydraulic Calculation			
PIPENET Schematic		Wednesday, September 07, 2022	Page 1 of 1
Pipe bore (in) < 6.750000 < 7.500000 < 8.250000 < 9.000000 < 9.750000 > 9.750000			



Fire Water Hydraulic Calculation

PIPENET Schematic

Wednesday, September 07, 2022


Page 1 of 1

Pipe velocity
(m/sec)

< 0.400000
< 1.600000

< 0.800000
< 2.000000

< 1.200000
> 2.000000



Fire Water Hydraulic Calculation

PIPENET Schematic

Wednesday, September 07, 2022


Page 1 of 1

Pipe vol. flow
(l/min)

< 1200.000000
< 4800.000000

< 2400.000000
< 6000.000000

< 3600.000000
> 6000.000000



Fire Water Hydraulic Calculation

PIPENET Schematic

Wednesday, September 07, 2022

Page 1 of 1

Pressure
(Bar G)

Red < 10.050000
Cyan < 10.275000

Orange < 10.125000
Blue < 10.350000

Green < 10.200000
Magenta > 10.350000


```
=====
=====
                                PIPENET SPRAY/SPRINKLER MODULE
=====
=====
```

```
=====
=====
                                VERSION 1.8
=====
=====
```

```
Results for :  Fire Water Hydraulic Calculation
               Gas Compressor Station
               05/11/2022
```

```
Licence Owner from key:
```

```
Licence Type: UNKNOWN
```

```
Key number: Unavailable
```

```
MUS Date: Unavailable
=====
=====
```

```
09:14 on 7-Sep-2022
```

1

```
LIST OF CONTENTS
=====
```

	Page

Control Information.....	1
Fluid System.....	1
Design Information.....	2
Pipe Configuration.....	4
Designed Diameters & Flowrates.....	6
Flow in Pipes.....	7
Flow at Inlets.....	8

Flow at Outlets.....	9
Materials Take Off.....	10
Important Notice.....	12
Comments.....	13

1

TITLE : Fire Water Hydraulic Calculation
PAGE 1 OF 13

DATE : 7-Sep-2022

CONTROL INFORMATION

Convergence accuracy = 1.00E-03
Maximum no. of iterations = 50
Elevation Check Tolerance = 0.50 metres
Warnings Control Option = 0
***** Diagnostic level = 2

FLUID SYSTEM

Fluid Class = 1 (Liquid)
Density = 998.2 kg/cu.m
Viscosity = 1.0000E-03 Pa.s

1

TITLE : Fire Water Hydraulic Calculation
PAGE 2 OF 13

DATE : 7-Sep-2022

DESIGN INFORMATION

Waterspray System

Pipe Materials are :
Pipe Type Lining Type Thickness(inches)
3 -- ANSI B36.10 Sch.40 Not Lined

Design to NFPA 2013 Rules
Using the Hazen-Williams Equation

Velocity Pressure Model: Ignore velocity pressure

Pressure loss at entrance: Ignore

Pressure loss at exit: Ignore

1

TITLE : Fire Water Hydraulic Calculation
PAGE 3 OF 13

DATE : 7-Sep-2022

AVAILABLE PIPE SIZES AND MAXIMUM VELOCITIES USED FOR PIPE SIZING

ANSI B36.10 Sch.40
Not lined

Nom.Bore Act.Diam (inches) (inches)	Act.Diam Max.Vel. (inches) (m/sec)	Max.Vel. (m/sec)	Nom.Bore (inches)	Act.Diam (inches)	Max.Vel. (m/sec)	Nom.Bore (inches)
--	---	----------------------	-----------------------	-----------------------	----------------------	-----------------------

0.6250	0.6220	4.0000
0.7500	0.8240	4.0000
1.0000	1.0490	4.0000
1.2500	1.3800	4.0000
1.5000	1.6100	4.0000
2.0000	2.0670	4.0000
2.5000	2.4690	4.0000
3.0000	3.0680	4.0000
3.5000	3.5480	4.0000
4.0000	4.0260	4.0000
5.0000	5.0470	4.0000
6.0000	6.0650	4.0000
8.0000	7.9810	4.0000
10.0000	10.0200	4.0000
12.0000	11.9380	4.0000
14.0000	13.1240	4.0000
16.0000	15.0000	4.0000
18.0000	16.8760	4.0000
20.0000	18.8120	4.0000
24.0000	22.6240	4.0000

1

TITLE : Fire Water Hydraulic Calculation
PAGE 4 OF 13

DATE : 7-Sep-2022

PIPE CONFIGURATION

Pipe Label Fitt.eq.lnth (metres)	Input Node	Output Node	Nom.Bore (inches)	Length (metres)	Elevation (metres)	C Factor
---	------------	-------------	-----------------------	---------------------	------------------------	-------------

1	1	2	10.000	1.0000	0.000	120.0
0.000						
2	2	3	10.000	20.00	0.000	120.0
0.000						
3	3	4	10.000	44.00	0.000	120.0
0.000						
4	4	5	10.000	43.00	0.000	120.0
13.41						
5	5	6	10.000	32.50	0.000	120.0
1.524						
6	6	7	10.000	210.0	0.000	120.0
0.000						
7	7	8	10.000	55.50	0.000	120.0
8.230						
8	8	9	10.000	49.00	0.000	120.0
0.000						
9	9	10	10.000	51.00	0.000	120.0
1.524						

10	10	11	10.000	48.00	0.000	120.0
0.000						
11	11	12	10.000	65.50	0.000	120.0
8.230						
12	20	13	6.000	1.0000	1.0000	120.0
4.267						
13	12	14	10.000	91.00	0.000	120.0
8.230						
14	14	15	10.000	4.000	0.000	120.0
0.000						
15	15	16	10.000	18.00	0.000	120.0
0.000						
16	16	17	10.000	36.00	0.000	120.0
1.524						
17	17	18	10.000	16.50	0.000	120.0
0.000						
18	18	19	10.000	13.50	0.000	120.0
15.24						
19	19	20	10.000	24.50	0.000	120.0
16.76						
20	21	20	10.000	16.50	0.000	120.0
15.24						
21	23	21	10.000	41.00	0.000	120.0
0.000						
22	13	22	6.000	1.0000	0.000	120.0
0.000						
23	24	23	10.000	162.0	0.000	120.0
21.64						
24	2	24	10.000	22.00	0.000	120.0
13.41						
25	21	25	6.000	1.0000	0.000	120.0
4.267						
26	25	26	6.000	1.0000	1.0000	120.0
0.000						
27	19	27	6.000	1.0000	0.000	120.0
4.267						
28	27	28	6.000	1.0000	1.0000	120.0
0.000						

PIPE FITTINGS

Pipe Number x Type Equivalent Length
Label (metres)

4	2 x 2	6.706			
5	1 x 5	1.524			
7	1 x 2	6.706	1 x 5	1.524	
9	1 x 5	1.524			
11	1 x 2	6.706	1 x 5	1.524	
12	1 x 2	4.267			
13	1 x 2	6.706	1 x 5	1.524	
1					

TITLE : Fire Water Hydraulic Calculation
PAGE 5 OF 13

DATE : 7-Sep-2022

PIPE FITTINGS

Pipe Number x Type Equivalent Length
Label (metres)

```

---
16      1 x 5      1.524
18      1 x 4      15.24
19      1 x 4      15.24      1 x 5      1.524
20      1 x 4      15.24
23      3 x 2      6.706      1 x 5      1.524
24      2 x 2      6.706
25      1 x 2      4.267
27      1 x 2      4.267

```

Fitting types are :

- 1 -- 45 Deg Elbow
- 2 -- 90 Deg Standard Elbow
- 3 -- 90 Deg Long Radius Elbow
- 4 -- Tee or Cross (Flow Turned Thro 90 Deg)
- 5 -- Gate Valve
- 6 -- Swing Check Valve
- 7 -- Non-Return Valve
- 8 -- Ball Valve
- 9 -- Butterfly Valve

1

TITLE : Fire Water Hydraulic Calculation
PAGE 6 OF 13

DATE : 7-Sep-2022

DESIGNED DIAMETERS & FLOWRATES

Pipe Label	Input Node	Output Node	Flowrate (lit/min)	Pipe Type	Act. Bore (inches)	Nom. Size (inches)	Pipe Group
1	1	2	6496.0146	3	10.0200	10.0000	*
2	2	3	2266.3787	3	10.0200	10.0000	*
3	3	4	2266.3787	3	10.0200	10.0000	*
4	4	5	2266.3787	3	10.0200	10.0000	*
5	5	6	2266.3787	3	10.0200	10.0000	*
6	6	7	2266.3787	3	10.0200	10.0000	*
7	7	8	2266.3787	3	10.0200	10.0000	*
8	8	9	2266.3787	3	10.0200	10.0000	*
9	9	10	2266.3787	3	10.0200	10.0000	*
10	10	11	2266.3787	3	10.0200	10.0000	*
11	11	12	2266.3787	3	10.0200	10.0000	*
12	20	13	2496.0059	3	6.0650	6.0000	*
13	12	14	2266.3787	3	10.0200	10.0000	*
14	14	15	2266.3787	3	10.0200	10.0000	*
15	15	16	2266.3787	3	10.0200	10.0000	*
16	16	17	2266.3787	3	10.0200	10.0000	*
17	17	18	2266.3787	3	10.0200	10.0000	*
18	18	19	2266.3787	3	10.0200	10.0000	*
19	19	20	266.3742	3	10.0200	10.0000	*
20	21	20	2229.6316	3	10.0200	10.0000	*
21	23	21	4229.6362	3	10.0200	10.0000	*
22	13	22	2496.0059	3	6.0650	6.0000	*
23	24	23	4229.6362	3	10.0200	10.0000	*
24	2	24	4229.6362	3	10.0200	10.0000	*
25	21	25	2000.0045	3	6.0650	6.0000	*
26	25	26	2000.0045	3	6.0650	6.0000	*
27	19	27	2000.0045	3	6.0650	6.0000	*
28	27	28	2000.0045	3	6.0650	6.0000	*

A * indicates that this is a SET diameter

Pipe Materials are :

Pipe Type	Lining Type	Thickness(inches)
-----------	-------------	--------------------

3 -- ANSI B36.10 Sch.40 Not Lined
1

TITLE : Fire Water Hydraulic Calculation
PAGE 7 OF 13

DATE : 7-Sep-2022

FLOW IN PIPES

Pipe Flowrate Label (lit/min)	Input Velocity Node (m/sec)	Output Node	Nom.Bore (inches)	Inlet Pr. (bar G)	Outlet Pr. (bar G)	Drop in Pr. (bar)	Frict. Loss (bar)
-----	-----	-----	-----	-----	-----	-----	-----
1	1	2	10.00	10.34	10.33	1.8749E-03	1.8749E-03
6496.	2.128						
2	2	3	10.00	10.33	10.33	5.3425E-03	5.3425E-03
2266.	0.7425						
3	3	4	10.00	10.33	10.32	1.1752E-02	1.1752E-02
2266.	0.7425						
4	4	5	10.00	10.32	10.30	1.5068E-02	1.5068E-02
2266.	0.7425						
5	5	6	10.00	10.30	10.29	9.0876E-03	9.0876E-03
2266.	0.7425						
6	6	7	10.00	10.29	10.24	5.6089E-02	5.6089E-02
2266.	0.7425						
7	7	8	10.00	10.24	10.22	1.7023E-02	1.7023E-02
2266.	0.7425						
8	8	9	10.00	10.22	10.21	1.3087E-02	1.3087E-02
2266.	0.7425						
9	9	10	10.00	10.21	10.19	1.4030E-02	1.4030E-02
2266.	0.7425						
10	10	11	10.00	10.19	10.18	1.2819E-02	1.2819E-02
2266.	0.7425						
11	11	12	10.00	10.18	10.16	1.9692E-02	1.9692E-02
2266.	0.7425						
12	20	13	6.00	10.10	9.988	0.1173	1.9402E-02
2496.	2.232						
13	12	14	10.00	10.16	10.13	2.6505E-02	2.6505E-02
2266.	0.7425						
14	14	15	10.00	10.13	10.13	1.0672E-03	1.0672E-03
2266.	0.7425						
15	15	16	10.00	10.13	10.13	4.8075E-03	4.8075E-03
2266.	0.7425						
16	16	17	10.00	10.13	10.12	1.0025E-02	1.0025E-02
2266.	0.7425						
17	17	18	10.00	10.12	10.11	4.4050E-03	4.4050E-03
2266.	0.7425						
18	18	19	10.00	10.11	10.11	7.6780E-03	7.6780E-03
2266.	0.7425						
19	19	20	10.00	10.11	10.10	2.0981E-04	2.0981E-04
266.4	8.7266E-02						
20	21	20	10.00	10.11	10.10	8.2331E-03	8.2331E-03
2230.	0.7304						
21	23	21	10.00	10.15	10.11	3.4757E-02	3.4757E-02
4230.	1.386						
22	13	22	6.00	9.988	9.984	3.6821E-03	3.6821E-03
2496.	2.232						
23	24	23	10.00	10.30	10.15	0.1557	0.1557
4230.	1.386						
24	2	24	10.00	10.33	10.30	3.0020E-02	3.0020E-02
4230.	1.386						
25	21	25	6.00	10.11	10.10	1.2878E-02	1.2878E-02
2000.	1.788						

26	25	26	6.00	10.10	10.000	0.1003	2.4437E-03
2000.	1.788						
27	19	27	6.00	10.11	10.09	1.2877E-02	1.2877E-02
2000.	1.788						
28	27	28	6.00	10.09	9.992	0.1003	2.4437E-03
2000.	1.788						

1

TITLE : Fire Water Hydraulic Calculation
PAGE 8 OF 13

DATE : 7-Sep-2022

FLOW AT INLETS

Inlet Node	Pressure (bar G)	Flowrate (lit/min)	Equivalent K-factor (lit/min , bar G)
1	10.34	6496.	2020.6

Note: A * after a value indicates that this is a specification
1

TITLE : Fire Water Hydraulic Calculation
PAGE 9 OF 13

DATE : 7-Sep-2022

FLOW AT OUTLETS

Outlet Node	Pressure (bar G)	Flowrate (lit/min)	Equivalent K-factor (lit/min , bar G)
22	9.984	2496. *	789.94
26	10.000	* 2000. *	632.46
28	9.992	2000. *	632.71

Note: A * after a value indicates that this is a specification
1

TITLE : Fire Water Hydraulic Calculation
PAGE 10 OF 13

DATE : 7-Sep-2022

Materials Take-off

Pipe lengths

ANSI B36.10 Sch.40

Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length
(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)

6.000 6.000
10.000 1064.
1

TITLE : Fire Water Hydraulic Calculation
PAGE 11 OF 13

DATE : 7-Sep-2022

Materials Take Off

Fittings

Fitting Nominal Size (inches)	Fitting Type								
	1	2	3	4	5	6	7	8	9
6.000	0	3	0	0	0	0	0	0	0
10.000	0	10	0	3	8	0	0	0	0

Fitting Types are :

1 -- 45 Deg Elbow	4 -- Tee or Cross	7 -- Non-Return Valve
2 -- 90 Deg Standard Elbow	5 -- Gate Valve	8 -- Ball Valve
3 -- 90 Deg Long Radius Elbow	6 -- Swing Check Valve	9 -- Butterfly Valve

All fittings are as specified by user - no additional fittings have been generated automatically.

The supply demand graph is not available for the network without pump

1

TITLE : Fire Water Hydraulic Calculation
PAGE 12 OF 13

DATE : 7-Sep-2022

IMPORTANT NOTICE

Your attention is drawn to the need to maintain adequate standards. SUNRISE SYSTEMS Ltd has itself taken steps to ensure that this program produces valid results when properly used. Users are reminded of their responsibilities in the application of program results and, in particular, you should ensure that pertinent output documents are examined and approved by qualified staff prior to use.

1

TITLE : Fire Water Hydraulic Calculation
PAGE 13 OF 13

DATE : 7-Sep-2022

COMMENTS

Analysis Converged in 6 Iterations


1

=====


Fire Water Hydraulic Calculation
Gas Compressor Station
05/11/2022

=====

Att.1.2



Fire Water Hydraulic Calculation			
PIPENET Schematic		Wednesday, September 07, 2022	Page 1 of 1
Pipe bore (in)			
	< 6.750000 < 9.000000	< 7.500000 < 9.750000	< 8.250000 > 9.750000



Fire Water Hydraulic Calculation

PIPENET Schematic

Wednesday, September 07, 2022


Page 1 of 1

Pipe velocity
(m/sec)

< 0.300000
< 1.200000

< 0.600000
< 1.500000

< 0.900000
> 1.500000



Fire Water Hydraulic Calculation

PIPENET Schematic

Wednesday, September 07, 2022


Page 1 of 1

Pipe vol. flow
(l/min)

< 400.000000
< 1600.000000

< 800.000000
< 2000.000000

< 1200.000000
> 2000.000000



Fire Water Hydraulic Calculation

PIPENET Schematic

Wednesday, September 07, 2022

Page 1 of 1

Pressure
(Bar G)

■ < 10.050000
■ < 10.200000

■ < 10.100000
■ < 10.250000

■ < 10.150000
■ > 10.250000

```

=====
=====
                                PIPENET SPRAY/SPRINKLER MODULE
=====
=====

```

```

=====
=====
                                VERSION 1.8
=====
=====

```

```

Results for :  Fire Water Hydraulic Calculation
               Gas Compressor Station
               05/11/2022

```

```

Licence Owner from key:

```

```

Licence Type: UNKNOWN

```

```

Key number: Unavailable

```

```

MUS Date: Unavailable

```

```

=====
=====
                                09:26 on 7-Sep-2022

```

1

```

LIST OF CONTENTS
=====

```

	Page

Control Information.....	1
Fluid System.....	1
Design Information.....	2
Pipe Configuration.....	4
Designed Diameters & Flowrates.....	6
Flow in Pipes.....	7
Flow at Inlets.....	8

Flow at Outlets.....	9
Flows and Pressures at Breaks & Blocks.....	10
Materials Take Off.....	11
Important Notice.....	13
Comments.....	14

1

TITLE : Fire Water Hydraulic Calculation
PAGE 1 OF 14

DATE : 7-Sep-2022

CONTROL INFORMATION

Convergence accuracy = 1.00E-03
Maximum no. of iterations = 50
Elevation Check Tolerance = 0.50 metres
Warnings Control Option = 0
***** Diagnostic level = 2

FLUID SYSTEM

Fluid Class = 1 (Liquid)
Density = 998.2 kg/cu.m
Viscosity = 1.0000E-03 Pa.s

1

TITLE : Fire Water Hydraulic Calculation
PAGE 2 OF 14

DATE : 7-Sep-2022

DESIGN INFORMATION

Waterspray System

Pipe Materials are :
Pipe Type Lining Type Thickness(inches)
3 -- ANSI B36.10 Sch.40 Not Lined

Design to NFPA 2013 Rules
Using the Hazen-Williams Equation

Velocity Pressure Model: Ignore velocity pressure

Pressure loss at entrance: Ignore

Pressure loss at exit: Ignore

1

TITLE : Fire Water Hydraulic Calculation
PAGE 3 OF 14

DATE : 7-Sep-2022

AVAILABLE PIPE SIZES AND MAXIMUM VELOCITIES USED FOR PIPE SIZING

ANSI B36.10 Sch.40
Not lined

Nom.Bore	Act.Diam	Max.Vel.	Nom.Bore	Act.Diam	Max.Vel.	Nom.Bore
Act.Diam	Max.Vel.					
(inches)	(inches)	(m/sec)	(inches)	(inches)	(m/sec)	(inches)
(inches)	(m/sec)					

0.6250	0.6220	4.0000
0.7500	0.8240	4.0000
1.0000	1.0490	4.0000
1.2500	1.3800	4.0000
1.5000	1.6100	4.0000
2.0000	2.0670	4.0000
2.5000	2.4690	4.0000
3.0000	3.0680	4.0000
3.5000	3.5480	4.0000
4.0000	4.0260	4.0000
5.0000	5.0470	4.0000
6.0000	6.0650	4.0000
8.0000	7.9810	4.0000
10.0000	10.0200	4.0000
12.0000	11.9380	4.0000
14.0000	13.1240	4.0000
16.0000	15.0000	4.0000
18.0000	16.8760	4.0000
20.0000	18.8120	4.0000
24.0000	22.6240	4.0000

1

TITLE : Fire Water Hydraulic Calculation
PAGE 4 OF 14

DATE : 7-Sep-2022

PIPE CONFIGURATION

Pipe Label	Input Node	Output Node	Nom.Bore	Length	Elevation	C
Fitt.eq.lnth			(inches)	(metres)	(metres)	Factor
(metres)						

1	1	2	10.000	1.0000	0.000	120.0
0.000						
2	2	3	10.000	20.00	0.000	120.0
0.000						
3	3	4	10.000	44.00	0.000	120.0
0.000						
4	4	5	10.000	43.00	0.000	120.0
13.41						
5	5	6	10.000	32.50	0.000	120.0
1.524						
6	6	7	10.000	210.0	0.000	120.0
0.000						
7	7	8	10.000	55.50	0.000	120.0
8.230						
8	8	9	10.000	49.00	0.000	120.0
0.000						

9	9	10	10.000	51.00	0.000	120.0
1.524						
10	10	11	10.000	48.00	0.000	120.0
0.000						
11	11	12	10.000	65.50	0.000	120.0
8.230						
12	23	13	6.000	1.0000	0.000	120.0
0.000						
13	12	14	10.000	91.00	0.000	120.0
0.000						
14	14	15	10.000	4.000	0.000	120.0
0.000						
15	15	16	10.000	18.00	0.000	120.0
0.000						
16	16	17	10.000	36.00	0.000	120.0
1.524						
17	17	18	10.000	16.50	0.000	120.0
0.000						
18	18	19	10.000	13.50	0.000	120.0
0.000						
19	19	20	10.000	24.50	0.000	120.0
1.524						
20	20	21	10.000	16.50	0.000	120.0
0.000						
21	21	23	10.000	41.00	0.000	120.0
0.000						
22	13	22	6.000	1.0000	1.0000	120.0
0.000						
23	23	24	10.000	162.0	0.000	120.0
21.64	\$					
24	24	2	10.000	22.00	0.000	120.0
13.41						

NOTE: a \$ indicates a BLOCKED Pipe

PIPE FITTINGS

Pipe Label	Number x Type	Equivalent Length (metres)
------------	---------------	-----------------------------

4	2 x 2	6.706		
5	1 x 5	1.524		
7	1 x 2	6.706	1 x 5	1.524
9	1 x 5	1.524		
11	1 x 2	6.706	1 x 5	1.524
16	1 x 5	1.524		
19	1 x 5	1.524		
23	3 x 2	6.706	1 x 5	1.524
24	2 x 2	6.706		

1

TITLE : Fire Water Hydraulic Calculation
PAGE 5 OF 14

DATE : 7-Sep-2022

Fitting types are :

- 1 -- 45 Deg Elbow
- 2 -- 90 Deg Standard Elbow
- 3 -- 90 Deg Long Radius Elbow
- 4 -- Tee or Cross (Flow Turned Thro 90 Deg)
- 5 -- Gate Valve
- 6 -- Swing Check Valve
- 7 -- Non-Return Valve
- 8 -- Ball Valve
- 9 -- Butterfly Valve

DESIGNED DIAMETERS & FLOWRATES

Pipe Label	Input Node	Output Node	Flowrate (lit/min)	Pipe Type	Act. Bore (inches)	Nom. Size (inches)	Pipe Group
1	1	2	2000.0048	3	10.0200	10.0000	*
2	2	3	2000.0048	3	10.0200	10.0000	*
3	3	4	2000.0048	3	10.0200	10.0000	*
4	4	5	2000.0048	3	10.0200	10.0000	*
5	5	6	2000.0048	3	10.0200	10.0000	*
6	6	7	2000.0048	3	10.0200	10.0000	*
7	7	8	2000.0048	3	10.0200	10.0000	*
8	8	9	2000.0048	3	10.0200	10.0000	*
9	9	10	2000.0048	3	10.0200	10.0000	*
10	10	11	2000.0048	3	10.0200	10.0000	*
11	11	12	2000.0048	3	10.0200	10.0000	*
12	23	13	2000.0045	3	6.0650	6.0000	*
13	12	14	2000.0048	3	10.0200	10.0000	*
14	14	15	2000.0048	3	10.0200	10.0000	*
15	15	16	2000.0048	3	10.0200	10.0000	*
16	16	17	2000.0048	3	10.0200	10.0000	*
17	17	18	2000.0048	3	10.0200	10.0000	*
18	18	19	2000.0048	3	10.0200	10.0000	*
19	19	20	2000.0048	3	10.0200	10.0000	*
20	20	21	2000.0048	3	10.0200	10.0000	*
21	21	23	2000.0048	3	10.0200	10.0000	*
22	13	22	2000.0045	3	6.0650	6.0000	*
23	23	24	0.0000	3	10.0200	10.0000	*
24	24	2	0.0000	3	10.0200	10.0000	*

A * indicates that this is a SET diameter

Pipe Materials are :

Pipe Type	Lining Type	Thickness(inches)
3 -- ANSI B36.10 Sch.40	Not Lined	

FLOW IN PIPES

Pipe Flowrate Label (lit/min)	Input Velocity Node (m/sec)	Output Node	Nom.Bore (inches)	Inlet Pr. (bar G)	Outlet Pr. (bar G)	Drop in Pr. (bar)	Frict. Loss (bar)
1	1	2	10.00	10.30	10.30	2.1267E-04	2.1267E-04
2000.	0.6552						
2	2	3	10.00	10.30	10.29	4.2400E-03	4.2400E-03

2000.	0.6552						
3	3	4	10.00	10.29	10.28	9.3298E-03	9.3298E-03
2000.	0.6552						
4	4	5	10.00	10.28	10.27	1.1960E-02	1.1960E-02
2000.	0.6552						
5	5	6	10.00	10.27	10.26	7.2145E-03	7.2145E-03
2000.	0.6552						
6	6	7	10.00	10.26	10.22	4.4528E-02	4.4528E-02
2000.	0.6552						
7	7	8	10.00	10.22	10.21	1.3513E-02	1.3513E-02
2000.	0.6552						
8	8	9	10.00	10.21	10.20	1.0389E-02	1.0389E-02
2000.	0.6552						
9	9	10	10.00	10.20	10.18	1.1138E-02	1.1138E-02
2000.	0.6552						
10	10	11	10.00	10.18	10.17	1.0178E-02	1.0178E-02
2000.	0.6552						
11	11	12	10.00	10.17	10.16	1.5633E-02	1.5633E-02
2000.	0.6552						
12	23	13	6.00	10.10	10.10	2.4452E-03	2.4452E-03
2000.	1.788						
13	12	14	10.00	10.16	10.14	1.9295E-02	1.9295E-02
2000.	0.6552						
14	14	15	10.00	10.14	10.14	8.4782E-04	8.4782E-04
2000.	0.6552						
15	15	16	10.00	10.14	10.13	3.8166E-03	3.8166E-03
2000.	0.6552						
16	16	17	10.00	10.13	10.13	7.9556E-03	7.9556E-03
2000.	0.6552						
17	17	18	10.00	10.13	10.12	3.5000E-03	3.5000E-03
2000.	0.6552						
18	18	19	10.00	10.12	10.12	2.8620E-03	2.8620E-03
2000.	0.6552						
19	19	20	10.00	10.12	10.11	5.5180E-03	5.5180E-03
2000.	0.6552						
20	20	21	10.00	10.11	10.11	3.4971E-03	3.4971E-03
2000.	0.6552						
21	21	23	10.00	10.11	10.10	8.6956E-03	8.6956E-03
2000.	0.6552						
22	13	22	6.00	10.10	10.000	0.1003	2.4437E-03
2000.	1.788						
23	23	24	10.00	10.10	10.30	-0.1941	0.1941
0.000	0.000	\$					
24	24	2	10.00	10.30	10.30	0.000	0.000
0.000	0.000						

NOTE: A \$ indicates a Blocked Pipe - Pressures may not be meaningful.

1

TITLE : Fire Water Hydraulic Calculation
PAGE 8 OF 14

DATE : 7-Sep-2022

FLOW AT INLETS

Inlet Node	Pressure (bar G)	Flowrate (lit/min)	Equivalent K-factor (lit/min , bar G)
1	10.30	2000.	623.26

Note: A * after a value indicates that this is a specification

** WARNING : There are Broken or Blocked Pipes in the Network.

1

FLOW AT OUTLETS

Outlet Node	Pressure (bar G)	Flowrate (lit/min)	Equivalent K-factor (lit/min , bar G)
22	10.000	* 2000.	* 632.46

Note: A * after a value indicates that this is a specification

** WARNING : There are Broken or Blocked Pipes in the Network.

1

FLows AND PRESSURES AT BREAKS AND BLOCKS

Pipe Label	Status	Node	Flowrates (lit/min)	Flowrates (lit/min)	Pressures (bar G)	Pressures (bar G)
23	Blocked at node	24	0.00	* 0.00	* 10.3	10.1

NOTE: A * after a value indicates a program supplied Specification.
Negative flows are OUT of the network.

1

Materials Take-off

Pipe lengths

ANSI B36.10 Sch.40

Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length
(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)

6.000	2.000
10.000	1064.

1

Materials Take Off

Fittings

Fitting Nominal Size (inches)	Fitting Type								
	1	2	3	4	5	6	7	8	9
10.000	0	9	0	0	7	0	0	0	0

Fitting Types are :

1 -- 45 Deg Elbow	4 -- Tee or Cross	7 -- Non-Return Valve
2 -- 90 Deg Standard Elbow	5 -- Gate Valve	8 -- Ball Valve
3 -- 90 Deg Long Radius Elbow	6 -- Swing Check Valve	9 -- Butterfly Valve

All fittings are as specified by user - no additional fittings have been generated automatically.

The supply demand graph is not available for the network without pump
1

IMPORTANT NOTICE

Your attention is drawn to the need to maintain adequate standards. SUNRISE SYSTEMS Ltd has itself taken steps to ensure that this program produces valid results when properly used. Users are reminded of their responsibilities in the application of program results and, in particular, you should ensure that pertinent output documents are examined and approved by qualified staff prior to use.

1


COMMENTS

Analysis Converged in 3 Iterations
1


=====

=====


Att.2.1



PIPENET Schematic	Tuesday, September 06, 2022		Page 1 of 1
Pipe bore (in)	< 1.500000 < 3.000000	< 2.000000 < 3.500000	< 2.500000 > 3.500000



PIPENET Schematic	Tuesday, September 06, 2022		Page 1 of 1
Pipe velocity (m/sec)	< 1.000000	< 2.000000	< 3.000000
	< 4.000000	< 5.000000	> 5.000000



DV-2301


V-2105

V-2104


P-2101 B

P-2101 A

PIPENET Schematic	Tuesday, September 06, 2022		Page 1 of 1
Nozzle calc. flow (l/min)	< 36.000000 < 72.000000	< 48.000000 < 84.000000	< 60.000000 > 84.000000



PIPENET Schematic	Tuesday, September 06, 2022		Page 1 of 1
Pipe vol. flow (l/min)	< 500.000000 < 2000.000000	< 1000.000000 < 2500.000000	< 1500.000000 > 2500.000000



PIPENET Schematic			
Tuesday, September 06, 2022			
Page 1 of 1			
Pressure	< 3.200000	< 3.600000	< 4.000000
(Bar G)	< 4.400000	< 4.800000	> 4.800000

```

=====
=====
                                PIPENET SPRAY/SPRINKLER MODULE
=====
=====

```

```

=====
=====
                                VERSION 1.8
=====
=====

```

```

Results for :

```

```

Licence Owner from key:

```

```

        Licence Type: UNKNOWN

```

```

        Key number: Unavailable

```

```

        MUS Date: Unavailable

```

```

=====
=====
                                15:42 on 6-Sep-2022

```

1

```

LIST OF CONTENTS
=====

```

	Page

Control Information.....	1
Fluid System.....	1
Design Information.....	2
Pipe Configuration.....	4
Nozzle Configuration.....	7
Designed Diameters & Flowrates.....	9
Flow in Pipes.....	11

Flow through Nozzles.....	13
Flow at Inlets.....	14
Materials Take Off.....	15
Important Notice.....	18
Comments.....	19
Warnings.....	20

1

TITLE :
PAGE 1 OF 20

DATE : 6-Sep-2022

CONTROL INFORMATION

Convergence accuracy = 1.00E-03
Maximum no. of iterations = 50
Elevation Check Tolerance = 0.50 metres
Warnings Control Option = 0
***** Diagnostic level = 2

FLUID SYSTEM

Fluid Class = 1 (Liquid)
Density = 998.2 kg/cu.m
Viscosity = 1.0000E-03 Pa.s

1

TITLE :
PAGE 2 OF 20

DATE : 6-Sep-2022

DESIGN INFORMATION

Waterspray System

Pipe Materials are :
Pipe Type Lining Type Thickness(inches)
3 -- ANSI B36.10 Sch.40 Not Lined

Design to NFPA 2013 Rules
Using the Hazen-Williams Equation

Velocity Pressure Model: Ignore velocity pressure

Pressure loss at entrance: Ignore

Pressure loss at exit: Ignore

1

TITLE :
PAGE 3 OF 20

DATE : 6-Sep-2022

 AVAILABLE PIPE SIZES AND MAXIMUM VELOCITIES USED FOR PIPE SIZING

ANSI B36.10 Sch.40
 Not lined

Nom.Bore Act.Diam (inches) (inches)	Act.Diam Max.Vel. (inches) (m/sec)	Max.Vel. (m/sec)	Nom.Bore (inches)	Act.Diam (inches)	Max.Vel. (m/sec)	Nom.Bore (inches)
--	---	----------------------	-----------------------	-----------------------	----------------------	-----------------------

0.6250	0.6220	4.0000
0.7500	0.8240	4.0000
1.0000	1.0490	4.0000
1.2500	1.3800	4.0000
1.5000	1.6100	4.0000
2.0000	2.0670	4.0000
2.5000	2.4690	4.0000
3.0000	3.0680	4.0000
3.5000	3.5480	4.0000
4.0000	4.0260	4.0000
5.0000	5.0470	4.0000
6.0000	6.0650	4.0000
8.0000	7.9810	4.0000
10.0000	10.0200	4.0000
12.0000	11.9380	4.0000
14.0000	13.1240	4.0000
16.0000	15.0000	4.0000
18.0000	16.8760	4.0000
20.0000	18.8120	4.0000
24.0000	22.6240	4.0000

1

TITLE :
 PAGE 4 OF 20

DATE : 6-Sep-2022

 PIPE CONFIGURATION

Pipe Label Fitt.eq.lnth (metres)	Input Node	Output Node	Nom.Bore (inches)	Length (metres)	Elevation (metres)	C Factor
---	------------	-------------	-----------------------	---------------------	------------------------	-------------

1	1	2	4.000	20.00	0.000	120.0
6.096						
3	3	4	2.000	2.000	2.000	120.0
0.000						
4	4	5	1.500	2.000	0.000	120.0
0.000						
5	5	6	1.500	1.500	0.000	120.0
0.000						
6	6	7	1.500	1.500	0.000	120.0
0.000						
7	63	3	2.000	1.900	0.000	120.0
0.000						
8	4	9	1.500	2.000	0.000	120.0
0.000						

9	9	10	1.500	1.500	0.000	120.0
0.000						
10	2	65	1.500	11.50	0.000	120.0
0.000						
11	10	12	1.500	1.500	0.000	120.0
0.000						
12	3	13	2.000	3.500	0.000	120.0
0.000						
13	11	14	3.000	3.000	3.000	120.0
4.572						
14	13	15	2.000	2.000	2.000	120.0
0.000						
15	15	16	1.500	2.000	0.000	120.0
0.000						
16	14	17	1.500	2.000	0.000	120.0
1.219						
17	17	18	1.500	2.000	0.000	120.0
0.000						
18	18	19	1.500	2.000	0.000	120.0
0.000						
19	19	20	1.500	2.000	0.000	120.0
0.000						
20	20	21	1.500	2.000	0.000	120.0
0.000						
21	21	22	1.500	2.000	0.000	120.0
0.000						
22	22	23	1.500	2.000	0.000	120.0
0.000						
23	14	24	1.500	2.000	0.000	120.0
1.219						
24	24	25	1.500	2.000	0.000	120.0
0.000						
25	25	26	1.500	2.000	0.000	120.0
0.000						
26	26	27	1.500	2.000	0.000	120.0
0.000						
27	27	28	1.500	2.000	0.000	120.0
0.000						
28	28	29	1.500	2.000	0.000	120.0
0.000						
29	29	30	1.500	2.000	0.000	120.0
0.000						
30	14	31	3.000	2.000	2.000	120.0
4.572						
31	31	32	1.500	2.000	0.000	120.0
0.000						
32	32	33	1.500	2.000	0.000	120.0
0.000						
33	33	34	1.500	2.000	0.000	120.0
0.000						
34	34	35	1.500	2.000	0.000	120.0
0.000						
35	35	36	1.500	2.000	0.000	120.0
0.000						
36	36	37	1.500	2.000	0.000	120.0
0.000						
37	37	38	1.500	2.000	0.000	120.0
0.000						
38	31	39	1.500	2.000	0.000	120.0
0.000						
39	39	40	1.500	2.000	0.000	120.0
0.000						
40	40	41	1.500	2.000	0.000	120.0
0.000						
41	41	42	1.500	2.000	0.000	120.0
0.000						
42	42	43	1.500	2.000	0.000	120.0
0.000						
43	43	44	1.500	2.000	0.000	120.0
0.000						
44	44	45	1.500	2.000	0.000	120.0

0.000

1

TITLE :
PAGE 5 OF 20

DATE : 6-Sep-2022

PIPE CONFIGURATION

Pipe Label Fitt.eq.lnth (metres)	Input Node	Output Node	Nom.Bore (inches)	Length (metres)	Elevation (metres)	C Factor
---	------------	-------------	-----------------------	---------------------	------------------------	-------------

45	65	8	1.500	8.000	0.000	120.0
0.000						
46	8	47	1.500	1.500	0.000	120.0
0.000						
47	47	48	1.500	3.500	3.500	120.0
2.438						
48	48	49	1.0000	0.5000	0.000	120.0
0.6096						
49	49	50	1.0000	1.100	0.000	120.0
0.000						
50	50	51	1.0000	1.100	0.000	120.0
0.000						
51	51	52	1.0000	1.100	0.000	120.0
0.000						
52	48	53	1.0000	0.5000	0.000	120.0
0.6096						
53	53	54	1.0000	1.100	0.000	120.0
0.000						
54	54	55	1.0000	1.100	0.000	120.0
0.000						
55	55	56	1.0000	1.100	0.000	120.0
0.000						
56	16	57	1.500	1.500	0.000	120.0
0.000						
57	57	58	1.500	1.500	0.000	120.0
0.000						
58	15	59	1.500	2.000	0.000	120.0
0.000						
59	59	60	1.500	1.500	0.000	120.0
0.000						
60	60	61	1.500	1.500	0.000	120.0
0.000						
61	62	63	2.000	1.900	0.000	120.0
0.000						
62	2	62	2.000	7.000	0.000	120.0
0.000						
63	2	11	3.000	2.500	0.000	120.0
0.000						

PIPE FITTINGS

Pipe Label	Number x Type	Equivalent Length (metres)
---------------	---------------	--------------------------------

1	1 x 4	6.096
13	1 x 4	4.572
16	1 x 2	1.219

23	1 x 2	1.219
30	1 x 4	4.572
47	1 x 4	2.438
48	1 x 2	0.6096
52	1 x 2	0.6096

Fitting types are :

- 1 -- 45 Deg Elbow
- 2 -- 90 Deg Standard Elbow
- 3 -- 90 Deg Long Radius Elbow
- 4 -- Tee or Cross (Flow Turned Thro 90 Deg)
- 5 -- Gate Valve
- 6 -- Swing Check Valve

1

TITLE :
PAGE 6 OF 20

DATE : 6-Sep-2022

-
-
- 7 -- Non-Return Valve
 - 8 -- Ball Valve
 - 9 -- Butterfly Valve

1

TITLE :
PAGE 7 OF 20

DATE : 6-Sep-2022

NOZZLE CONFIGURATION

Nozzle Press Label	Input Node	Nozzle Type	K-Factor	Req Flow (lit/min)	Min Press (bar G)	Max (bar G
--						
1	6	4	51.0000	90.0000	0.25000E+01	
0.50000E+01						
2	7	4	51.0000	90.0000	0.25000E+01	
0.50000E+01						
3	18	2	35.0000	60.0000	0.25000E+01	
0.50000E+01						
4	19	2	35.0000	60.0000	0.25000E+01	
0.50000E+01						
5	10	4	51.0000	90.0000	0.25000E+01	
0.50000E+01						
6	12	4	51.0000	90.0000	0.25000E+01	
0.50000E+01						
7	57	4	51.0000	90.0000	0.25000E+01	
0.50000E+01						
8	58	4	51.0000	90.0000	0.25000E+01	
0.50000E+01						
9	20	2	35.0000	60.0000	0.25000E+01	
0.50000E+01						
10	21	2	35.0000	60.0000	0.25000E+01	
0.50000E+01						
11	60	4	51.0000	90.0000	0.25000E+01	
0.50000E+01						
12	61	4	51.0000	90.0000	0.25000E+01	
0.50000E+01						
13	22	2	35.0000	60.0000	0.25000E+01	
0.50000E+01						
14	23	2	35.0000	60.0000	0.25000E+01	
0.50000E+01						

15	25	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
16	26	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
17	27	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
18	28	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
19	29	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
20	30	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
21	40	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
22	41	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
23	42	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
24	43	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
25	44	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
26	45	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
27	33	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
28	34	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
29	35	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
30	36	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
31	37	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
32	38	2	35.0000	60.0000	0.25000E+01
0.50000E+01					
33	50	3	18.0000	30.0000	0.25000E+01
0.50000E+01					
34	51	3	18.0000	30.0000	0.25000E+01
0.50000E+01					
35	52	3	18.0000	30.0000	0.25000E+01
0.50000E+01					
36	54	3	18.0000	30.0000	0.25000E+01
0.50000E+01					
37	55	3	18.0000	30.0000	0.25000E+01
0.50000E+01					
38	56	3	18.0000	30.0000	0.25000E+01
0.50000E+01					
1					

TITLE :
PAGE 8 OF 20

DATE : 6-Sep-2022

Nozzle types are :
2 -- Nozzles for H1
3 -- nozzles for h2
4 -- Nozzle for P
1

TITLE :
PAGE 9 OF 20

DATE : 6-Sep-2022

DESIGNED DIAMETERS & FLOWRATES

Pipe Label	Input Node	Output Node	Flowrate (lit/min)	Pipe Type	Act. Bore (inches)	Nom. Size (inches)	Pipe Group
1	1	2	2407.5625	3	4.0260	4.0000	*
3	3	4	369.2936	3	2.0670	2.0000	*
4	4	5	184.6468	3	1.6100	1.5000	*
5	5	6	184.6468	3	1.6100	1.5000	*
6	6	7	92.2677	3	1.6100	1.5000	*
7	63	3	734.7587	3	2.0670	2.0000	*
8	4	9	184.6468	3	1.6100	1.5000	*
9	9	10	184.6468	3	1.6100	1.5000	*
10	2	65	196.8742	3	1.6100	1.5000	*
11	10	12	92.2677	3	1.6100	1.5000	*
12	3	13	365.4651	3	2.0670	2.0000	*
13	11	14	1475.9302	3	3.0680	3.0000	*
14	13	15	365.4651	3	2.0670	2.0000	*
15	15	16	182.7325	3	1.6100	1.5000	*
16	14	17	373.7258	3	1.6100	1.5000	*
17	17	18	373.7258	3	1.6100	1.5000	*
18	18	19	309.9557	3	1.6100	1.5000	*
19	19	20	247.1455	3	1.6100	1.5000	*
20	20	21	184.9745	3	1.6100	1.5000	*
21	21	22	123.1808	3	1.6100	1.5000	*
22	22	23	61.5656	3	1.6100	1.5000	*
23	14	24	373.7258	3	1.6100	1.5000	*
24	24	25	373.7258	3	1.6100	1.5000	*
25	25	26	309.9557	3	1.6100	1.5000	*
26	26	27	247.1455	3	1.6100	1.5000	*
27	27	28	184.9745	3	1.6100	1.5000	*
28	28	29	123.1808	3	1.6100	1.5000	*
29	29	30	61.5656	3	1.6100	1.5000	*
30	14	31	728.4784	3	3.0680	3.0000	*
31	31	32	364.2392	3	1.6100	1.5000	*
32	32	33	364.2392	3	1.6100	1.5000	*
33	33	34	302.0823	3	1.6100	1.5000	*
34	34	35	240.8645	3	1.6100	1.5000	*
35	35	36	180.2721	3	1.6100	1.5000	*
36	36	37	120.0488	3	1.6100	1.5000	*
37	37	38	60.0001	3	1.6100	1.5000	*
38	31	39	364.2392	3	1.6100	1.5000	*
39	39	40	364.2392	3	1.6100	1.5000	*
40	40	41	302.0823	3	1.6100	1.5000	*

1

TITLE :
PAGE 10 OF 20

DATE : 6-Sep-2022

DESIGNED DIAMETERS & FLOWRATES

Pipe Label	Input Node	Output Node	Flowrate (lit/min)	Pipe Type	Act. Bore (inches)	Nom. Size (inches)	Pipe Group
41	41	42	240.8645	3	1.6100	1.5000	*
42	42	43	180.2721	3	1.6100	1.5000	*
43	43	44	120.0488	3	1.6100	1.5000	*
44	44	45	60.0001	3	1.6100	1.5000	*
45	65	8	196.8742	3	1.6100	1.5000	*
46	8	47	196.8742	3	1.6100	1.5000	*
47	47	48	196.8742	3	1.6100	1.5000	*

1	1	2	4.00	5.028	4.367	0.6614	0.6614
2408.	4.886						
3	3	4	2.00	3.584	3.348	0.2364	4.0613E-02
369.3	2.843						
4	4	5	1.50	3.348	3.310	3.8040E-02	3.8040E-02
184.6	2.343						
5	5	6	1.50	3.310	3.281	2.8530E-02	2.8530E-02
184.6	2.343						
6	6	7	1.50	3.281	3.273	7.9048E-03	7.9048E-03
92.27	1.171						
7	63	3	2.00	3.722	3.584	0.1378	0.1378
734.8	5.657						
8	4	9	1.50	3.348	3.310	3.8040E-02	3.8040E-02
184.6	2.343						
9	9	10	1.50	3.310	3.281	2.8530E-02	2.8530E-02
184.6	2.343						
10	2	65	1.50	4.367	4.121	0.2463	0.2463
196.9	2.498						
11	10	12	1.50	3.281	3.273	7.9048E-03	7.9048E-03
92.27	1.171						
12	3	13	2.00	3.584	3.514	6.9715E-02	6.9715E-02
365.5	2.814						
13	11	14	3.00	4.271	3.686	0.5852	0.2916
1476.	5.158						
14	13	15	2.00	3.514	3.279	0.2356	3.9838E-02
365.5	2.814						
15	15	16	1.50	3.279	3.241	3.7315E-02	3.7315E-02
182.7	2.319						

16	14	17	1.50	3.686	3.460	0.2257	0.2257
373.7	4.742	18	1.50	3.460	3.320	0.1402	0.1402
17	17	19	1.50	3.320	3.220	9.9180E-02	9.9180E-02
373.7	4.742	20	1.50	3.220	3.155	6.5230E-02	6.5230E-02
18	18	21	1.50	3.155	3.117	3.8165E-02	3.8165E-02
310.0	3.933	22	1.50	3.117	3.099	1.7990E-02	1.7990E-02
19	19	23	1.50	3.099	3.094	4.9899E-03	4.9899E-03
247.1	3.136	24	1.50	3.686	3.460	0.2257	0.2257
20	20	25	1.50	3.460	3.320	0.1402	0.1402
185.0	2.347	26	1.50	3.320	3.220	9.9180E-02	9.9180E-02
21	21	27	1.50	3.220	3.155	6.5230E-02	6.5230E-02
123.2	1.563	28	1.50	3.155	3.117	3.8165E-02	3.8165E-02
22	22	29	1.50	3.117	3.099	1.7990E-02	1.7990E-02
61.57	0.7812	30	1.50	3.099	3.094	4.9899E-03	4.9899E-03
23	14	31	3.00	3.686	3.421	0.2643	6.8533E-02
373.7	4.742	32	1.50	3.421	3.288	0.1337	0.1337
24	24	33	1.50	3.288	3.154	0.1337	0.1337
373.7	4.742	34	1.50	3.154	3.059	9.4565E-02	9.4565E-02
25	25	35	1.50	3.059	2.997	6.2200E-02	6.2200E-02
310.0	3.933	36	1.50	2.997	2.961	3.6390E-02	3.6390E-02
26	26	37	1.50	2.961	2.944	1.7155E-02	1.7155E-02
247.1	3.136	38	1.50	2.944	2.939	4.7550E-03	4.7550E-03
27	27	39	1.50	3.421	3.288	0.1337	0.1337
185.0	2.347	40	1.50	3.288	3.154	0.1337	0.1337
28	28	41	1.50	3.154	3.059	9.4565E-02	9.4565E-02
123.2	1.563	42	1.50	3.059	2.997	6.2200E-02	6.2200E-02
29	29	43	1.50	2.997	2.961	3.6390E-02	3.6390E-02
61.57	0.7812						
30	14						
728.5	2.546						
31	31						
364.2	4.622						
32	32						
364.2	4.622						
33	33						
302.1	3.833						
34	34						
240.9	3.056						
35	35						
180.3	2.288						
36	36						
120.0	1.523						
37	37						
60.00	0.7614						
38	31						
364.2	4.622						
39	39						
364.2	4.622						
40	40						
302.1	3.833						
41	41						
240.9	3.056						
42	42						
180.3	2.288						
1							

TITLE :
PAGE 12 OF 20

DATE : 6-Sep-2022

FLOW IN PIPES

Pipe Flowrate Label (lit/min)	Input Velocity Node (m/sec)	Output Node	Nom.Bore (inches)	Inlet Pr. (bar G)	Outlet Pr. (bar G)	Drop in Pr. (bar)	Frict. Loss (bar)
---	---------------------------------------	----------------	-----------------------	-----------------------	------------------------	-----------------------	-----------------------

43	43	44	1.50	2.961	2.944	1.7155E-02	1.7155E-02
120.0	1.523						
44	44	45	1.50	2.944	2.939	4.7550E-03	4.7550E-03
60.00	0.7614						
45	65	8	1.50	4.121	3.949	0.1713	0.1713
196.9	2.498						
46	8	47	1.50	3.949	3.917	3.2125E-02	3.2125E-02
196.9	2.498						
47	47	48	1.50	3.917	3.448	0.4698	0.1272
196.9	2.498						
48	48	49	1.00	3.448	3.394	5.3085E-02	5.3085E-02
98.44	2.942						
49	49	50	1.00	3.394	3.342	5.2630E-02	5.2630E-02
98.44	2.942						
50	50	51	1.00	3.342	3.317	2.4795E-02	2.4795E-02
65.53	1.959						
51	51	52	1.00	3.317	3.310	6.8700E-03	6.8700E-03
32.75	0.9789						
52	48	53	1.00	3.448	3.394	5.3085E-02	5.3085E-02
98.44	2.942						
53	53	54	1.00	3.394	3.342	5.2630E-02	5.2630E-02
98.44	2.942						
54	54	55	1.00	3.342	3.317	2.4795E-02	2.4795E-02
65.53	1.959						
55	55	56	1.00	3.317	3.310	6.8700E-03	6.8700E-03
32.75	0.9789						
56	16	57	1.50	3.241	3.213	2.7985E-02	2.7985E-02
182.7	2.319						
57	57	58	1.50	3.213	3.206	7.7550E-03	7.7550E-03
91.31	1.159						
58	15	59	1.50	3.279	3.241	3.7315E-02	3.7315E-02
182.7	2.319						
59	59	60	1.50	3.241	3.213	2.7985E-02	2.7985E-02
182.7	2.319						
60	60	61	1.50	3.213	3.206	7.7550E-03	7.7550E-03
91.31	1.159						
61	62	63	2.00	3.859	3.722	0.1378	0.1378
734.8	5.657						
62	2	62	2.00	4.367	3.859	0.5075	0.5075
734.8	5.657						
63	2	11	3.00	4.367	4.271	9.6265E-02	9.6265E-02
1476.	5.158						
1							

TITLE :
PAGE 13 OF 20

DATE : 6-Sep-2022

FLOW THROUGH NOZZLES

Nozzle FlowDens Label /metres	Input FlowDens Label **2)	Inlet Press (bar G)	Req. Flow (lit/min)	Flowrate (lit/min)	% Deviation	Req. (lit/min

1	6	0.32810E+01	90.0000	92.3789	2.64	
2	7	0.32731E+01	90.0000	92.2675	2.52	
3	18	0.33197E+01	60.0000	63.7699	6.28	
4	19	0.32205E+01	60.0000	62.8101	4.68	
5	10	0.32810E+01	90.0000	92.3789	2.64	
6	12	0.32731E+01	90.0000	92.2675	2.52	

7	57	0.32133E+01	90.0000	91.4212	1.58
8	58	0.32056E+01	90.0000	91.3109	1.46
9	20	0.31553E+01	60.0000	62.1708	3.62
10	21	0.31171E+01	60.0000	61.7936	2.99
11	60	0.32133E+01	90.0000	91.4212	1.58
12	61	0.32056E+01	90.0000	91.3109	1.46
13	22	0.30991E+01	60.0000	61.6150	2.69
14	23	0.30941E+01	60.0000	61.5655	2.61
15	25	0.33197E+01	60.0000	63.7699	6.28
16	26	0.32205E+01	60.0000	62.8101	4.68
17	27	0.31553E+01	60.0000	62.1708	3.62
18	28	0.31171E+01	60.0000	61.7936	2.99
19	29	0.30991E+01	60.0000	61.6150	2.69
20	30	0.30941E+01	60.0000	61.5655	2.61
21	40	0.31538E+01	60.0000	62.1567	3.59
22	41	0.30593E+01	60.0000	61.2177	2.03
23	42	0.29971E+01	60.0000	60.5922	0.99
24	43	0.29607E+01	60.0000	60.2232	0.37
25	44	0.29435E+01	60.0000	60.0485	0.08
26	45	0.29388E+01	60.0000	60.0000 *	0.00
27	33	0.31538E+01	60.0000	62.1567	3.59
28	34	0.30593E+01	60.0000	61.2177	2.03
29	35	0.29971E+01	60.0000	60.5922	0.99
30	36	0.29607E+01	60.0000	60.2232	0.37
31	37	0.29435E+01	60.0000	60.0485	0.08
32	38	0.29388E+01	60.0000	60.0000	0.00
33	50	0.33418E+01	30.0000	32.9051	9.68
34	51	0.33170E+01	30.0000	32.7828	9.28
35	52	0.33101E+01	30.0000	32.7489	9.16
36	54	0.33418E+01	30.0000	32.9051	9.68
37	55	0.33170E+01	30.0000	32.7828	9.28
38	56	0.33101E+01	30.0000	32.7489	9.16

Note: A * after a value indicates that this is a specification

1

TITLE :
PAGE 14 OF 20

DATE : 6-Sep-2022

FLOW AT INLETS

Inlet Node	Pressure (bar G)	Flowrate (lit/min)	Equivalent K-factor (lit/min , bar G)
1	5.028	2408.	1073.6

Note: A * after a value indicates that this is a specification

1

TITLE :
PAGE 15 OF 20

DATE : 6-Sep-2022

Materials Take-off

Pipe lengths

ANSI B36.10 Sch.40

Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length
(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)

1.000	7.600
1.500	100.5
2.000	18.30
3.000	7.500
4.000	20.00

1

TITLE :
PAGE 16 OF 20

DATE : 6-Sep-2022

Materials Take-off

Nozzles

Type	K-Factor	Number
Nozzle for P	51.0000	8
Nozzles for H1	35.0000	24
nozzles for h2	18.0000	6

1

TITLE :
PAGE 17 OF 20

DATE : 6-Sep-2022

Materials Take Off

Fittings

Fitting Nominal Size (inches)	1	2	3	4	5	6	7	8	9
1.000	0	2	0	0	0	0	0	0	0
1.500	0	2	0	1	0	0	0	0	0
3.000	0	0	0	2	0	0	0	0	0
4.000	0	0	0	1	0	0	0	0	0

Fitting Types are :

1 -- 45 Deg Elbow	4 -- Tee or Cross	7 -- Non-Return Valve
2 -- 90 Deg Standard Elbow	5 -- Gate Valve	8 -- Ball Valve
3 -- 90 Deg Long Radius Elbow	6 -- Swing Check Valve	9 -- Butterfly Valve

All fittings are as specified by user - no additional fittings have been generated automatically.

The supply demand graph is not available for the network without pump

1

TITLE :
PAGE 18 OF 20

DATE : 6-Sep-2022

IMPORTANT NOTICE

Your attention is drawn to the need to maintain adequate standards. SUNRISE SYSTEMS Ltd has itself taken steps to ensure that this program produces valid results when properly used. Users are reminded of their responsibilities in the application of program results and, in particular, you should ensure that pertinent output documents are examined and approved by qualified staff prior to use.

1


TITLE :
PAGE 19 OF 20

DATE : 6-Sep-2022

COMMENTS

Analysis Converged in 3 Iterations
1

Att.2.2





C-2101 & 2102A

V-2102A

V-2101A

DV-2302






DV-2302

C-2101 & 2102A

V-2102A


V-2101A

PIPENET Schematic	Saturday, May 14, 2022		Page 1 of 1
Nozzle calc. flow (l/min)	< 60.000000 < 105.000000	< 75.000000 < 120.000000	< 90.000000 > 120.000000



DV-2302

PIPENET Schematic	Saturday, May 14, 2022		Page 1 of 1
Pipe vol. flow (l/min)	 < 500.000000	 < 1000.000000	 < 1500.000000
	 < 2000.000000	 < 2500.000000	 > 2500.000000



PIPETET Schematic			
Saturday, May 14, 2022		Page 1 of 1	
Pressure (Bar G)	< 3.600000	< 4.000000	< 4.400000
	< 4.800000	< 5.200000	> 5.200000

```

=====
=====
                                PIPENET SPRAY/SPRINKLER MODULE
=====
=====

```

```

=====
=====
                                VERSION 1.8
=====
=====

```

```

Results for :

```

```

Licence Owner from key:

```

```

        Licence Type: UNKNOWN

```

```

        Key number: Unavailable

```

```

        MUS Date: Unavailable

```

```

=====
=====
                                11:44 on 10-May-2022

```

1

```

LIST OF CONTENTS
=====

```

	Page

Control Information.....	1
Fluid System.....	1
Design Information.....	2
Pipe Configuration.....	4
Nozzle Configuration.....	6
Designed Diameters & Flowrates.....	7
Flow in Pipes.....	8

Flow through Nozzles.....	9
Flow at Inlets.....	10
Materials Take Off.....	11
Important Notice.....	14
Comments.....	15
Warnings.....	16

1

TITLE :
PAGE 1 OF 16

DATE : 10-May-2022

CONTROL INFORMATION

Convergence accuracy = 1.00E-03
Maximum no. of iterations = 50
Elevation Check Tolerance = 0.50 metres
Warnings Control Option = 0
***** Diagnostic level = 2

FLUID SYSTEM

Fluid Class = 1 (Liquid)
Density = 998.2 kg/cu.m
Viscosity = 1.0000E-03 Pa.s

1

TITLE :
PAGE 2 OF 16

DATE : 10-May-2022

DESIGN INFORMATION

Waterspray System

Pipe Materials are :
Pipe Type Lining Type Thickness(inches)
3 -- ANSI B36.10 Sch.40 Not Lined

Design to NFPA 2013 Rules
Using the Hazen-Williams Equation

Velocity Pressure Model: Ignore velocity pressure

Pressure loss at entrance: Ignore

Pressure loss at exit: Ignore

1

TITLE :
PAGE 3 OF 16

DATE : 10-May-2022

 AVAILABLE PIPE SIZES AND MAXIMUM VELOCITIES USED FOR PIPE SIZING

ANSI B36.10 Sch.40
 Not lined

Nom.Bore Act.Diam (inches) (inches)	Act.Diam Max.Vel. (inches) (m/sec)	Max.Vel. (m/sec)	Nom.Bore (inches)	Act.Diam (inches)	Max.Vel. (m/sec)	Nom.Bore (inches)
--	---	----------------------	-----------------------	-----------------------	----------------------	-----------------------

0.6250	0.6220	4.0000
0.7500	0.8240	4.0000
1.0000	1.0490	4.0000
1.2500	1.3800	4.0000
1.5000	1.6100	4.0000
2.0000	2.0670	4.0000
2.5000	2.4690	4.0000
3.0000	3.0680	4.0000
3.5000	3.5480	4.0000
4.0000	4.0260	4.0000
5.0000	5.0470	4.0000
6.0000	6.0650	4.0000
8.0000	7.9810	4.0000
10.0000	10.0200	4.0000
12.0000	11.9380	4.0000
14.0000	13.1240	4.0000
16.0000	15.0000	4.0000
18.0000	16.8760	4.0000
20.0000	18.8120	4.0000
24.0000	22.6240	4.0000

1

TITLE :
 PAGE 4 OF 16

DATE : 10-May-2022

 PIPE CONFIGURATION

Pipe Label Fitt.eq.lnth (metres)	Input Node	Output Node	Nom.Bore (inches)	Length (metres)	Elevation (metres)	C Factor
---	------------	-------------	-----------------------	---------------------	------------------------	-------------

1	1	2	4.000	11.50	0.000	120.0
6.096						
2	2	3	4.000	12.60	0.000	120.0
3.048						
3	3	4	4.000	4.500	4.500	120.0
6.096						
4	4	5	2.000	2.000	0.000	120.0
1.524						
5	5	6	2.000	1.600	0.000	120.0
0.000						
6	6	7	2.000	1.600	0.000	120.0
0.000						
7	7	8	2.000	1.600	0.000	120.0
0.000						

8	8	9	2.000	1.600	0.000	120.0
0.000						
9	9	10	2.000	1.600	0.000	120.0
0.000						
10	10	11	2.000	1.600	0.000	120.0
0.000						
12	4	13	2.000	1.600	0.000	120.0
0.000						
13	13	14	2.000	1.600	0.000	120.0
0.000						
14	14	15	2.000	1.600	0.000	120.0
0.000						
15	15	16	2.000	1.600	0.000	120.0
0.000						
16	16	17	2.000	1.600	0.000	120.0
0.000						
17	17	18	2.000	1.600	0.000	120.0
0.000						
18	4	19	2.000	1.0000	0.000	120.0
1.524						
19	19	20	2.000	1.600	0.000	120.0
0.000						
20	20	21	2.000	1.600	0.000	120.0
0.000						
21	21	22	2.000	1.600	0.000	120.0
0.000						
22	22	23	2.000	1.600	0.000	120.0
0.000						
23	23	24	2.000	1.600	0.000	120.0
0.000						
24	24	25	2.000	1.600	0.000	120.0
0.000						
25	2	26	1.500	18.00	0.000	120.0
1.219						
26	26	27	1.500	8.600	0.000	120.0
2.438						
27	27	28	1.0000	4.000	4.000	120.0
1.524						
28	27	29	1.0000	4.000	0.000	120.0
0.6096						
29	29	30	1.0000	4.000	4.000	120.0
1.524						
30	28	31	1.0000	3.000	0.000	120.0
0.000						
31	28	32	1.0000	3.000	0.000	120.0
0.000						
32	30	33	1.0000	3.000	0.000	120.0
0.000						
33	30	34	1.0000	3.000	0.000	120.0
0.000						

PIPE FITTINGS

Pipe Label	Number x Type	Equivalent Length (metres)
---------------	---------------	--------------------------------

1	1 x 4	6.096
2	1 x 2	3.048
3	1 x 4	6.096

1

TITLE :
PAGE 5 OF 16

DATE : 10-May-2022

PIPE FITTINGS

Pipe Label	Number x Type	Equivalent Length (metres)
---------------	---------------	--------------------------------

4	1 x 2	1.524
18	1 x 2	1.524
25	1 x 2	1.219
26	1 x 4	2.438
27	1 x 4	1.524
28	1 x 2	0.6096
29	1 x 4	1.524

Fitting types are :

- 1 -- 45 Deg Elbow
- 2 -- 90 Deg Standard Elbow
- 3 -- 90 Deg Long Radius Elbow
- 4 -- Tee or Cross (Flow Turned Thro 90 Deg)
- 5 -- Gate Valve
- 6 -- Swing Check Valve
- 7 -- Non-Return Valve
- 8 -- Ball Valve
- 9 -- Butterfly Valve

1

TITLE :
PAGE 6 OF 16

DATE : 10-May-2022

NOZZLE CONFIGURATION

Nozzle Press Label	Input Node	Nozzle Type	K-Factor	Req Flow (lit/min)	Min Press (bar G)	Max (bar G)

--						
1	11	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
2	10	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
3	9	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
4	8	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
5	7	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
6	6	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
7	18	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
8	17	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
9	16	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
10	15	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
11	14	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
12	13	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						

13	20	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
14	21	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
15	22	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
16	23	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
17	24	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
18	25	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
19	31	3	35.0000	64.0000	0.25000E+01
0.40000E+01					
20	32	3	35.0000	64.0000	0.25000E+01
0.40000E+01					
21	33	2	30.0000	48.9000	0.25000E+01
0.40000E+01					
22	34	2	30.0000	48.9000	0.25000E+01
0.40000E+01					

Nozzle types are :

- 1 -- Nozzles for GC
- 2 -- Nozzles for vessels
- 3 -- Nozzle for vessels 1

1

TITLE :
PAGE 7 OF 16

DATE : 10-May-2022

DESIGNED DIAMETERS & FLOWRATES

Pipe Label	Input Node	Output Node	Flowrate (lit/min)	Pipe Type	Act. Bore (inches)	Nom. Size (inches)	Pipe Group
1	1	2	2459.1860	3	4.0260	4.0000	*
2	2	3	2223.5366	3	4.0260	4.0000	*
3	3	4	2223.5366	3	4.0260	4.0000	*
4	4	5	731.1163	3	2.0670	2.0000	*
5	5	6	731.1163	3	2.0670	2.0000	*
6	6	7	607.1738	3	2.0670	2.0000	*
7	7	8	484.5858	3	2.0670	2.0000	*
8	8	9	362.8984	3	2.0670	2.0000	*
9	9	10	241.7417	3	2.0670	2.0000	*
10	10	11	120.8360	3	2.0670	2.0000	*
12	4	13	754.7920	3	2.0670	2.0000	*
13	13	14	626.8461	3	2.0670	2.0000	*
14	14	15	500.2919	3	2.0670	2.0000	*
15	15	16	374.6631	3	2.0670	2.0000	*
16	16	17	249.5796	3	2.0670	2.0000	*
17	17	18	124.7540	3	2.0670	2.0000	*
18	4	19	737.6288	3	2.0670	2.0000	*
19	19	20	737.6288	3	2.0670	2.0000	*
20	20	21	612.5851	3	2.0670	2.0000	*
21	21	22	488.9060	3	2.0670	2.0000	*
22	22	23	366.1346	3	2.0670	2.0000	*
23	23	24	243.8976	3	2.0670	2.0000	*
24	24	25	121.9137	3	2.0670	2.0000	*
25	2	26	235.6494	3	1.6100	1.5000	*
26	26	27	235.6494	3	1.6100	1.5000	*
27	27	28	128.0003	3	1.0490	1.0000	*
28	27	29	107.6491	3	1.0490	1.0000	*

29	29	30	107.6491	3	1.0490	1.0000	*
30	28	31	64.0001	3	1.0490	1.0000	*
31	28	32	64.0001	3	1.0490	1.0000	*
32	30	33	53.8245	3	1.0490	1.0000	*
33	30	34	53.8245	3	1.0490	1.0000	*

A * indicates that this is a SET diameter

Pipe Materials are :

Pipe Type	Lining Type	Thickness(inches)
-----------	-------------	--------------------

3	-- ANSI B36.10 Sch.40	Not Lined
---	-----------------------	-----------

1

TITLE :

DATE : 10-May-2022

PAGE 8 OF 16

FLOW IN PIPES

Pipe Flowrate Label (lit/min)	Input Velocity Node (m/sec)	Output Node	Nom.Bore (inches)	Inlet Pr. (bar G)	Outlet Pr. (bar G)	Drop in Pr. (bar)	Frict. Loss (bar)
1	1	2	4.00	5.597	5.133	0.4639	0.4639
2459.	4.990						
2	2	3	4.00	5.133	4.791	0.3424	0.3424
2224.	4.512						
3	3	4	4.00	4.791	4.119	0.6724	0.2318
2224.	4.512						
4	4	5	2.00	4.119	3.865	0.2532	0.2532
731.1	5.628						
5	5	6	2.00	3.865	3.750	0.1149	0.1149
731.1	5.628						
6	6	7	2.00	3.750	3.669	8.1520E-02	8.1520E-02
607.2	4.674						
7	7	8	2.00	3.669	3.615	5.3715E-02	5.3715E-02
484.6	3.731						
8	8	9	2.00	3.615	3.584	3.1455E-02	3.1455E-02
362.9	2.794						
9	9	10	2.00	3.584	3.569	1.4840E-02	1.4840E-02
241.7	1.861						
10	10	11	2.00	3.569	3.565	4.1101E-03	4.1101E-03
120.8	0.9303						
12	4	13	2.00	4.119	3.997	0.1219	0.1219
754.8	5.811						
13	13	14	2.00	3.997	3.910	8.6470E-02	8.6470E-02
626.8	4.826						
14	14	15	2.00	3.910	3.853	5.6980E-02	5.6980E-02
500.3	3.851						
15	15	16	2.00	3.853	3.820	3.3370E-02	3.3370E-02
374.7	2.884						
16	16	17	2.00	3.820	3.804	1.5740E-02	1.5740E-02
249.6	1.921						
17	17	18	2.00	3.804	3.800	4.3600E-03	4.3600E-03
124.8	0.9604						
18	4	19	2.00	4.119	3.934	0.1843	0.1843
737.6	5.679						
19	19	20	2.00	3.934	3.817	0.1169	0.1169
737.6	5.679						
20	20	21	2.00	3.817	3.734	8.2870E-02	8.2870E-02
612.6	4.716						
21	21	22	2.00	3.734	3.680	5.4605E-02	5.4605E-02

488.9	3.764						
22	22	23	2.00	3.680	3.648	3.1975E-02	3.1975E-02
366.1	2.819						
23	23	24	2.00	3.648	3.633	1.5085E-02	1.5085E-02
243.9	1.878						
24	24	25	2.00	3.633	3.629	4.1800E-03	4.1800E-03
121.9	0.9386						
25	2	26	1.50	5.133	4.559	0.5740	0.5740
235.6	2.990						
26	26	27	1.50	4.559	4.230	0.3297	0.3297
235.6	2.990						
27	27	28	1.00	4.230	3.408	0.8212	0.4296
128.0	3.826						
28	27	29	1.00	4.230	3.969	0.2602	0.2602
107.6	3.218						
29	29	30	1.00	3.969	3.266	0.7034	0.3119
107.6	3.218						
30	28	31	1.00	3.408	3.344	6.4725E-02	6.4725E-02
64.00	1.913						
31	28	32	1.00	3.408	3.344	6.4725E-02	6.4725E-02
64.00	1.913						
32	30	33	1.00	3.266	3.219	4.6980E-02	4.6980E-02
53.82	1.609						
33	30	34	1.00	3.266	3.219	4.6980E-02	4.6980E-02
53.82	1.609						
1							

TITLE :
PAGE 9 OF 16

DATE : 10-May-2022

FLOW THROUGH NOZZLES

Nozzle FlowDens Label /metres	Input FlowDens Label **2)	Inlet Press (bar G)	Req. Flow (lit/min)	Flowrate (lit/min)	% Deviation	Req. (lit/min
1	11	0.35648E+01	118.0000	120.8357	2.40	
2	10	0.35689E+01	118.0000	120.9054	2.46	
3	9	0.35837E+01	118.0000	121.1565	2.67	
4	8	0.36152E+01	118.0000	121.6871	3.12	
5	7	0.36689E+01	118.0000	122.5877	3.89	
6	6	0.37504E+01	118.0000	123.9421	5.04	
7	18	0.37997E+01	118.0000	124.7537	5.72	
8	17	0.38040E+01	118.0000	124.8253	5.78	
9	16	0.38198E+01	118.0000	125.0833	6.00	
10	15	0.38531E+01	118.0000	125.6284	6.46	
11	14	0.39101E+01	118.0000	126.5539	7.25	
12	13	0.39966E+01	118.0000	127.9456	8.43	
13	20	0.38173E+01	118.0000	125.0434	5.97	
14	21	0.37345E+01	118.0000	123.6787	4.81	
15	22	0.36799E+01	118.0000	122.7712	4.04	
16	23	0.36479E+01	118.0000	122.2366	3.59	
17	24	0.36328E+01	118.0000	121.9837	3.38	
18	25	0.36286E+01	118.0000	121.9134	3.32	
19	31	0.33437E+01	64.0000	64.0000 *	0.00	
20	32	0.33437E+01	64.0000	64.0000	0.00	
21	33	0.32190E+01	48.9000	53.8244	10.07	
22	34	0.32190E+01	48.9000	53.8244	10.07	

Note: A * after a value indicates that this is a specification

TITLE :
PAGE 10 OF 16

DATE : 10-May-2022

FLOW AT INLETS

Inlet Node	Pressure (bar G)	Flowrate (lit/min)	Equivalent K-factor (lit/min , bar G)
1	5.597	2459.	1039.5

Note: A * after a value indicates that this is a specification
1

TITLE :
PAGE 11 OF 16

DATE : 10-May-2022

Materials Take-off

Pipe lengths

ANSI B36.10 Sch.40

Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length
(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)

1.000	24.00
1.500	26.60
2.000	31.80
4.000	28.60

1

TITLE :
PAGE 12 OF 16

DATE : 10-May-2022

Materials Take-off

Nozzles

Type	K-Factor	Number
Nozzles for GC	64.0000	18
Nozzle for vessels 1	35.0000	2
Nozzles for vessels	30.0000	2

1

TITLE :
PAGE 13 OF 16

DATE : 10-May-2022

Materials Take Off

Fittings

Fitting Nominal Size (inches)	1	2	3	4	5	6	7	8	9
1.000	0	1	0	2	0	0	0	0	0
1.500	0	1	0	1	0	0	0	0	0
2.000	0	2	0	0	0	0	0	0	0
4.000	0	1	0	2	0	0	0	0	0

Fitting Types are :

1 -- 45 Deg Elbow 4 -- Tee or Cross 7 -- Non-Return Valve
 2 -- 90 Deg Standard Elbow 5 -- Gate Valve 8 -- Ball Valve
 3 -- 90 Deg Long Radius Elbow 6 -- Swing Check Valve 9 -- Butterfly Valve

All fittings are as specified by user - no additional fittings have been generated automatically.

The supply demand graph is not available for the network without pump

1

TITLE :
 PAGE 14 OF 16

DATE : 10-May-2022

IMPORTANT NOTICE

Your attention is drawn to the need to maintain adequate standards. SUNRISE SYSTEMS Ltd has itself taken steps to ensure that this program produces valid results when properly used. Users are reminded of their responsibilities in the application of program results and, in particular, you should ensure that pertinent output documents are examined and approved by qualified staff prior to use.

1

TITLE :
 PAGE 15 OF 16

DATE : 10-May-2022

COMMENTS

Analysis Converged in 3 Iterations

1

Att.2.3


C-2101 & 2102B

V-2101B


V-2102B

DV-2303

PIPENET Schematic		Saturday, May 14, 2022	Page 1 of 1
Pipe bore (in)	< 1.500000	< 2.000000	< 2.500000
	< 3.000000	< 3.500000	> 3.500000



PIPENET Schematic	Saturday, May 14, 2022		Page 1 of 1
Pipe velocity (m/sec)	 < 1.000000	 < 2.000000	 < 3.000000
	 < 4.000000	 < 5.000000	 > 5.000000



PIPENET Schematic		Saturday, May 14, 2022	Page 1 of 1
Nozzle calc. flow (l/min)			
	< 60.000000 < 105.000000	< 75.000000 < 120.000000	< 90.000000 > 120.000000


C-2101 & 2102B

V-2101B

V-2102B

DV-2303

PIPENET Schematic	Saturday, May 14, 2022		Page 1 of 1
Pipe vol. flow (l/min)	< 500.000000	< 1000.000000	< 1500.000000
	< 2000.000000	< 2500.000000	> 2500.000000



PIPENET Schematic			
Saturday, May 14, 2022			Page 1 of 1
Pressure	< 3.500000	< 4.000000	< 4.500000
(Bar G)	< 5.000000	< 5.500000	> 5.500000

```

=====
=====
                                PIPENET SPRAY/SPRINKLER MODULE
=====
=====

```

```

=====
=====
                                VERSION 1.8
=====
=====

```

```

Results for :

```

```

Licence Owner from key:

```

```

Licence Type: UNKNOWN

```

```

Key number: Unavailable

```

```

MUS Date: Unavailable

```

```

=====
=====
                                12:22 on 10-May-2022

```

1

```

LIST OF CONTENTS
=====

```

	Page

Control Information.....	1
Fluid System.....	1
Design Information.....	2
Pipe Configuration.....	4
Nozzle Configuration.....	6
Designed Diameters & Flowrates.....	7
Flow in Pipes.....	8

Flow through Nozzles.....	9
Flow at Inlets.....	10
Materials Take Off.....	11
Important Notice.....	14
Comments.....	15
Warnings.....	16

1

TITLE :
PAGE 1 OF 16

DATE : 10-May-2022

CONTROL INFORMATION

Convergence accuracy = 1.00E-03
Maximum no. of iterations = 50
Elevation Check Tolerance = 0.50 metres
Warnings Control Option = 0
***** Diagnostic level = 2

FLUID SYSTEM

Fluid Class = 1 (Liquid)
Density = 998.2 kg/cu.m
Viscosity = 1.0000E-03 Pa.s

1

TITLE :
PAGE 2 OF 16

DATE : 10-May-2022

DESIGN INFORMATION

Waterspray System

Pipe Materials are :
Pipe Type Lining Type Thickness(inches)
3 -- ANSI B36.10 Sch.40 Not Lined

Design to NFPA 2013 Rules
Using the Hazen-Williams Equation

Velocity Pressure Model: Ignore velocity pressure

Pressure loss at entrance: Ignore

Pressure loss at exit: Ignore

1

TITLE :
PAGE 3 OF 16

DATE : 10-May-2022

 AVAILABLE PIPE SIZES AND MAXIMUM VELOCITIES USED FOR PIPE SIZING

ANSI B36.10 Sch.40
 Not lined

Nom.Bore Act.Diam (inches) (inches)	Act.Diam Max.Vel. (inches) (m/sec)	Max.Vel. (m/sec)	Nom.Bore (inches)	Act.Diam (inches)	Max.Vel. (m/sec)	Nom.Bore (inches)
--	---	----------------------	-----------------------	-----------------------	----------------------	-----------------------

0.6250	0.6220	4.0000
0.7500	0.8240	4.0000
1.0000	1.0490	4.0000
1.2500	1.3800	4.0000
1.5000	1.6100	4.0000
2.0000	2.0670	4.0000
2.5000	2.4690	4.0000
3.0000	3.0680	4.0000
3.5000	3.5480	4.0000
4.0000	4.0260	4.0000
5.0000	5.0470	4.0000
6.0000	6.0650	4.0000
8.0000	7.9810	4.0000
10.0000	10.0200	4.0000
12.0000	11.9380	4.0000
14.0000	13.1240	4.0000
16.0000	15.0000	4.0000
18.0000	16.8760	4.0000
20.0000	18.8120	4.0000
24.0000	22.6240	4.0000

1

TITLE :
 PAGE 4 OF 16

DATE : 10-May-2022

 PIPE CONFIGURATION

Pipe Label Fitt.eq.lnth (metres)	Input Node	Output Node	Nom.Bore (inches)	Length (metres)	Elevation (metres)	C Factor
---	------------	-------------	-----------------------	---------------------	------------------------	-------------

1	1	2	4.000	11.50	0.000	120.0
6.096						
2	2	3	4.000	9.600	0.000	120.0
3.048						
3	3	4	4.000	4.500	4.500	120.0
6.096						
4	4	5	2.000	2.000	0.000	120.0
1.524						
5	5	6	2.000	1.600	0.000	120.0
0.000						
6	6	7	2.000	1.600	0.000	120.0
0.000						
7	7	8	2.000	1.600	0.000	120.0
0.000						

8	8	9	2.000	1.600	0.000	120.0
0.000						
9	9	10	2.000	1.600	0.000	120.0
0.000						
10	10	11	2.000	1.600	0.000	120.0
0.000						
12	4	13	2.000	1.600	0.000	120.0
0.000						
13	13	14	2.000	1.600	0.000	120.0
0.000						
14	14	15	2.000	1.600	0.000	120.0
0.000						
15	15	16	2.000	1.600	0.000	120.0
0.000						
16	16	17	2.000	1.600	0.000	120.0
0.000						
17	17	18	2.000	1.600	0.000	120.0
0.000						
18	4	19	2.000	1.0000	0.000	120.0
1.524						
19	19	20	2.000	1.600	0.000	120.0
0.000						
20	20	21	2.000	1.600	0.000	120.0
0.000						
21	21	22	2.000	1.600	0.000	120.0
0.000						
22	22	23	2.000	1.600	0.000	120.0
0.000						
23	23	24	2.000	1.600	0.000	120.0
0.000						
24	24	25	2.000	1.600	0.000	120.0
0.000						
25	2	26	1.500	18.00	0.000	120.0
1.219						
26	26	27	1.500	9.600	0.000	120.0
2.438						
27	27	28	1.0000	4.000	4.000	120.0
1.524						
28	27	29	1.0000	4.000	0.000	120.0
0.6096						
29	29	30	1.0000	4.000	4.000	120.0
1.524						
30	28	31	1.0000	3.000	0.000	120.0
0.000						
31	28	32	1.0000	3.000	0.000	120.0
0.000						
32	30	33	1.0000	3.000	0.000	120.0
0.000						
33	30	34	1.0000	3.000	0.000	120.0
0.000						

PIPE FITTINGS

Pipe Label	Number x Type	Equivalent Length (metres)
---------------	---------------	--------------------------------

1	1 x 4	6.096
2	1 x 2	3.048
3	1 x 4	6.096

1

TITLE :
PAGE 5 OF 16

DATE : 10-May-2022

PIPE FITTINGS

Pipe Label	Number x Type	Equivalent Length (metres)
---------------	---------------	--------------------------------

4	1 x 2	1.524
18	1 x 2	1.524
25	1 x 2	1.219
26	1 x 4	2.438
27	1 x 4	1.524
28	1 x 2	0.6096
29	1 x 4	1.524

Fitting types are :

- 1 -- 45 Deg Elbow
- 2 -- 90 Deg Standard Elbow
- 3 -- 90 Deg Long Radius Elbow
- 4 -- Tee or Cross (Flow Turned Thro 90 Deg)
- 5 -- Gate Valve
- 6 -- Swing Check Valve
- 7 -- Non-Return Valve
- 8 -- Ball Valve
- 9 -- Butterfly Valve

1

TITLE :
PAGE 6 OF 16

DATE : 10-May-2022

NOZZLE CONFIGURATION

Nozzle Press Label	Input Node	Nozzle Type	K-Factor	Req Flow (lit/min)	Min Press (bar G)	Max (bar G
--------------------------	---------------	----------------	----------	------------------------	-----------------------	---------------

--						
1	11	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
2	10	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
3	9	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
4	8	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
5	7	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
6	6	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
7	18	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
8	17	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
9	16	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
10	15	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
11	14	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
12	13	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						

13	20	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
14	21	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
15	22	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
16	23	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
17	24	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
18	25	1	64.0000	118.0000	0.25000E+01
0.40000E+01					
19	31	3	35.0000	64.0000	0.25000E+01
0.40000E+01					
20	32	3	35.0000	64.0000	0.25000E+01
0.40000E+01					
21	33	2	30.0000	48.9000	0.25000E+01
0.40000E+01					
22	34	2	30.0000	48.9000	0.25000E+01
0.40000E+01					

Nozzle types are :

- 1 -- Nozzles for GC
- 2 -- Nozzles for vessels
- 3 -- Nozzles for vessels 1

1

TITLE :
PAGE 7 OF 16

DATE : 10-May-2022

DESIGNED DIAMETERS & FLOWRATES

Pipe Label	Input Node	Output Node	Flowrate (lit/min)	Pipe Type	Act. Bore (inches)	Nom. Size (inches)	Pipe Group
1	1	2	2482.3562	3	4.0260	4.0000	*
2	2	3	2246.7070	3	4.0260	4.0000	*
3	3	4	2246.7070	3	4.0260	4.0000	*
4	4	5	738.7493	3	2.0670	2.0000	*
5	5	6	738.7493	3	2.0670	2.0000	*
6	6	7	613.5161	3	2.0670	2.0000	*
7	7	8	489.6494	3	2.0670	2.0000	*
8	8	9	366.6913	3	2.0670	2.0000	*
9	9	10	244.2686	3	2.0670	2.0000	*
10	10	11	122.0992	3	2.0670	2.0000	*
12	4	13	762.6375	3	2.0670	2.0000	*
13	13	14	633.3650	3	2.0670	2.0000	*
14	14	15	505.4966	3	2.0670	2.0000	*
15	15	16	378.5617	3	2.0670	2.0000	*
16	16	17	252.1769	3	2.0670	2.0000	*
17	17	18	126.0523	3	2.0670	2.0000	*
18	4	19	745.3206	3	2.0670	2.0000	*
19	19	20	745.3206	3	2.0670	2.0000	*
20	20	21	618.9761	3	2.0670	2.0000	*
21	21	22	494.0086	3	2.0670	2.0000	*
22	22	23	369.9567	3	2.0670	2.0000	*
23	23	24	246.4440	3	2.0670	2.0000	*
24	24	25	123.1866	3	2.0670	2.0000	*
25	2	26	235.6494	3	1.6100	1.5000	*
26	26	27	235.6494	3	1.6100	1.5000	*
27	27	28	128.0003	3	1.0490	1.0000	*
28	27	29	107.6491	3	1.0490	1.0000	*

29	29	30	107.6491	3	1.0490	1.0000	*
30	28	31	64.0001	3	1.0490	1.0000	*
31	28	32	64.0001	3	1.0490	1.0000	*
32	30	33	53.8245	3	1.0490	1.0000	*
33	30	34	53.8245	3	1.0490	1.0000	*

A * indicates that this is a SET diameter

Pipe Materials are :

Pipe Type	Lining Type	Thickness(inches)
-----------	-------------	--------------------

3	-- ANSI B36.10 Sch.40	Not Lined
---	-----------------------	-----------

1

TITLE :

DATE : 10-May-2022

PAGE 8 OF 16

FLOW IN PIPES

Pipe Flowrate Label (lit/min)	Input Velocity Node (m/sec)	Output Node	Nom.Bore (inches)	Inlet Pr. (bar G)	Outlet Pr. (bar G)	Drop in Pr. (bar)	Frict. Loss (bar)
1	1	2	4.00	5.635	5.163	0.4720	0.4720
2482.	5.037						
2	2	3	4.00	5.163	4.881	0.2821	0.2821
2247.	4.559						
3	3	4	4.00	4.881	4.204	0.6768	0.2363
2247.	4.559						
4	4	5	2.00	4.204	3.946	0.2581	0.2581
738.7	5.687						
5	5	6	2.00	3.946	3.829	0.1172	0.1172
738.7	5.687						
6	6	7	2.00	3.829	3.746	8.3100E-02	8.3100E-02
613.5	4.723						
7	7	8	2.00	3.746	3.691	5.4755E-02	5.4755E-02
489.6	3.770						
8	8	9	2.00	3.691	3.659	3.2070E-02	3.2070E-02
366.7	2.823						
9	9	10	2.00	3.659	3.644	1.5125E-02	1.5125E-02
244.3	1.881						
10	10	11	2.00	3.644	3.640	4.1950E-03	4.1950E-03
122.1	0.9400						
12	4	13	2.00	4.204	4.080	0.1243	0.1243
762.6	5.871						
13	13	14	2.00	4.080	3.992	8.8140E-02	8.8140E-02
633.4	4.876						
14	14	15	2.00	3.992	3.934	5.8080E-02	5.8080E-02
505.5	3.892						
15	15	16	2.00	3.934	3.900	3.4015E-02	3.4015E-02
378.6	2.914						
16	16	17	2.00	3.900	3.884	1.6045E-02	1.6045E-02
252.2	1.941						
17	17	18	2.00	3.884	3.879	4.4451E-03	4.4451E-03
126.1	0.9704						
18	4	19	2.00	4.204	4.016	0.1879	0.1879
745.3	5.738						
19	19	20	2.00	4.016	3.897	0.1191	0.1191
745.3	5.738						
20	20	21	2.00	3.897	3.813	8.4475E-02	8.4475E-02
619.0	4.765						
21	21	22	2.00	3.813	3.757	5.5660E-02	5.5660E-02

494.0	3.803						
22	22	23	2.00	3.757	3.724	3.2600E-02	3.2600E-02
370.0	2.848						
23	23	24	2.00	3.724	3.709	1.5375E-02	1.5375E-02
246.4	1.897						
24	24	25	2.00	3.709	3.705	4.2651E-03	4.2651E-03
123.2	0.9484						
25	2	26	1.50	5.163	4.589	0.5740	0.5740
235.6	2.990						
26	26	27	1.50	4.589	4.230	0.3595	0.3595
235.6	2.990						
27	27	28	1.00	4.230	3.408	0.8212	0.4296
128.0	3.826						
28	27	29	1.00	4.230	3.969	0.2602	0.2602
107.6	3.218						
29	29	30	1.00	3.969	3.266	0.7034	0.3119
107.6	3.218						
30	28	31	1.00	3.408	3.344	6.4725E-02	6.4725E-02
64.00	1.913						
31	28	32	1.00	3.408	3.344	6.4725E-02	6.4725E-02
64.00	1.913						
32	30	33	1.00	3.266	3.219	4.6980E-02	4.6980E-02
53.82	1.609						
33	30	34	1.00	3.266	3.219	4.6980E-02	4.6980E-02
53.82	1.609						
1							

TITLE :
PAGE 9 OF 16

DATE : 10-May-2022

FLOW THROUGH NOZZLES

Nozzle FlowDens Label /metres **2)	Input FlowDens Label	Inlet Press (bar G)	Req. Flow (lit/min)	Flowrate (lit/min)	% Deviation	Req. (lit/min
1	11	0.36397E+01	118.0000	122.0989	3.47	
2	10	0.36439E+01	118.0000	122.1692	3.53	
3	9	0.36590E+01	118.0000	122.4225	3.75	
4	8	0.36911E+01	118.0000	122.9578	4.20	
5	7	0.37458E+01	118.0000	123.8664	4.97	
6	6	0.38289E+01	118.0000	125.2329	6.13	
7	18	0.38792E+01	118.0000	126.0520	6.82	
8	17	0.38836E+01	118.0000	126.1243	6.88	
9	16	0.38997E+01	118.0000	126.3845	7.11	
10	15	0.39337E+01	118.0000	126.9345	7.57	
11	14	0.39918E+01	118.0000	127.8681	8.36	
12	13	0.40799E+01	118.0000	129.2722	9.55	
13	20	0.38972E+01	118.0000	126.3441	7.07	
14	21	0.38127E+01	118.0000	124.9672	5.90	
15	22	0.37570E+01	118.0000	124.0517	5.13	
16	23	0.37244E+01	118.0000	123.5123	4.67	
17	24	0.37091E+01	118.0000	123.2571	4.46	
18	25	0.37048E+01	118.0000	123.1863	4.40	
19	31	0.33437E+01	64.0000	64.0000 *	0.00	
20	32	0.33437E+01	64.0000	64.0000	0.00	
21	33	0.32190E+01	48.9000	53.8244	10.07	
22	34	0.32190E+01	48.9000	53.8244	10.07	

Note: A * after a value indicates that this is a specification
1

TITLE :
PAGE 10 OF 16

DATE : 10-May-2022

FLOW AT INLETS

Inlet Node	Pressure (bar G)	Flowrate (lit/min)	Equivalent K-factor (lit/min , bar G)
1	5.635	2482.	1045.7

Note: A * after a value indicates that this is a specification
1

TITLE :
PAGE 11 OF 16

DATE : 10-May-2022

Materials Take-off

Pipe lengths

ANSI B36.10 Sch.40

Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length
(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)

1.000 24.00
1.500 27.60
2.000 31.80
4.000 25.60

1

TITLE :
PAGE 12 OF 16

DATE : 10-May-2022

Materials Take-off

Nozzles

Type	K-Factor	Number
Nozzles for GC	64.0000	18
Nozzles for vessels 1	35.0000	2
Nozzles for vessels	30.0000	2

1

TITLE :
PAGE 13 OF 16

DATE : 10-May-2022

Materials Take Off

Fittings

Fitting Nominal Size (inches)	1	2	3	4	5	6	7	8	9
1.000	0	1	0	2	0	0	0	0	0
1.500	0	1	0	1	0	0	0	0	0
2.000	0	2	0	0	0	0	0	0	0
4.000	0	1	0	2	0	0	0	0	0

Fitting Types are :

1 -- 45 Deg Elbow 4 -- Tee or Cross 7 -- Non-Return Valve
 2 -- 90 Deg Standard Elbow 5 -- Gate Valve 8 -- Ball Valve
 3 -- 90 Deg Long Radius Elbow 6 -- Swing Check Valve 9 -- Butterfly Valve

All fittings are as specified by user - no additional fittings have been generated automatically.

The supply demand graph is not available for the network without pump

1

TITLE :
PAGE 14 OF 16

DATE : 10-May-2022

IMPORTANT NOTICE

Your attention is drawn to the need to maintain adequate standards. SUNRISE SYSTEMS Ltd has itself taken steps to ensure that this program produces valid results when properly used. Users are reminded of their responsibilities in the application of program results and, in particular, you should ensure that pertinent output documents are examined and approved by qualified staff prior to use.

1

TITLE :
PAGE 15 OF 16


DATE : 10-May-2022

COMMENTS


Analysis Converged in 3 Iterations


1

Att.2.4




PIPENET Schematic	Saturday, May 14, 2022		Page 1 of 1
Pipe bore (in)	< 1.500000 < 3.000000	< 2.000000 < 3.500000	< 2.500000 > 3.500000






PIPENET Schematic		Saturday, May 14, 2022	Page 1 of 1
Nozzle calc. flow (l/min)			



PIPENET Schematic	Saturday, May 14, 2022		Page 1 of 1
Pipe vol. flow (l/min)	< 500.000000	< 1000.000000	< 1500.000000
	< 2000.000000	< 2500.000000	> 2500.000000



```

=====
=====
                                PIPENET SPRAY/SPRINKLER MODULE
=====
=====

```

```

=====
=====
                                VERSION 1.8
=====
=====

```

```

Results for :

```

```

Licence Owner from key:

```

```

Licence Type: UNKNOWN

```

```

Key number: Unavailable

```

```

MUS Date: Unavailable

```

```

=====
=====
                                13:35 on 10-May-2022

```

1

```

LIST OF CONTENTS
=====

```

	Page

Control Information.....	1
Fluid System.....	1
Design Information.....	2
Pipe Configuration.....	4
Nozzle Configuration.....	6
Designed Diameters & Flowrates.....	7
Flow in Pipes.....	9

Flow through Nozzles.....	10
Flow at Inlets.....	11
Materials Take Off.....	12
Important Notice.....	15
Comments.....	16
Warnings.....	17

1

TITLE :
PAGE 1 OF 17

DATE : 10-May-2022

CONTROL INFORMATION

Convergence accuracy = 1.00E-03
Maximum no. of iterations = 50
Elevation Check Tolerance = 0.50 metres
Warnings Control Option = 0
***** Diagnostic level = 2

FLUID SYSTEM

Fluid Class = 1 (Liquid)
Density = 998.2 kg/cu.m
Viscosity = 1.0000E-03 Pa.s

1

TITLE :
PAGE 2 OF 17

DATE : 10-May-2022

DESIGN INFORMATION

Waterspray System

Pipe Materials are :		
Pipe Type	Lining Type	Thickness(inches)
3 -- ANSI B36.10 Sch.40	Not Lined	

Design to NFPA 2013 Rules
Using the Hazen-Williams Equation

Velocity Pressure Model: Ignore velocity pressure

Pressure loss at entrance: Ignore

Pressure loss at exit: Ignore

1

TITLE :
PAGE 3 OF 17

DATE : 10-May-2022

 AVAILABLE PIPE SIZES AND MAXIMUM VELOCITIES USED FOR PIPE SIZING

ANSI B36.10 Sch.40
 Not lined

Nom.Bore	Act.Diam	Max.Vel.	Nom.Bore	Act.Diam	Max.Vel.	Nom.Bore
Act.Diam	Max.Vel.					
(inches)	(inches)	(m/sec)	(inches)	(inches)	(m/sec)	(inches)
(inches)	(m/sec)					

0.6250	0.6220	4.0000
0.7500	0.8240	4.0000
1.0000	1.0490	4.0000
1.2500	1.3800	4.0000
1.5000	1.6100	4.0000
2.0000	2.0670	4.0000
2.5000	2.4690	4.0000
3.0000	3.0680	4.0000
3.5000	3.5480	4.0000
4.0000	4.0260	4.0000
5.0000	5.0470	4.0000
6.0000	6.0650	4.0000
8.0000	7.9810	4.0000
10.0000	10.0200	4.0000
12.0000	11.9380	4.0000
14.0000	13.1240	4.0000
16.0000	15.0000	4.0000
18.0000	16.8760	4.0000
20.0000	18.8120	4.0000
24.0000	22.6240	4.0000

1

TITLE :
 PAGE 4 OF 17

DATE : 10-May-2022

 PIPE CONFIGURATION

Pipe Label	Input Node	Output Node	Nom.Bore	Length	Elevation	C
Fitt.eq.lnth			(inches)	(metres)	(metres)	Factor
(metres)						

1	1	2	4.000	11.50	0.000	120.0
0.000						
2	2	3	4.000	17.00	0.000	120.0
0.000						
3	3	12	4.000	4.500	4.500	120.0
0.000						
4	12	5	2.000	2.000	0.000	120.0
0.000						
5	5	6	2.000	1.600	0.000	120.0
0.000						
6	6	7	2.000	1.600	0.000	120.0
0.000						
7	7	8	2.000	1.600	0.000	120.0
0.000						

8	8	9	2.000	1.600	0.000	120.0
0.000						
9	9	10	2.000	1.600	0.000	120.0
0.000						
10	10	11	2.000	1.600	0.000	120.0
0.000						
12	12	13	2.000	1.600	0.000	120.0
0.000						
13	13	14	2.000	1.600	0.000	120.0
0.000						
14	14	15	2.000	1.600	0.000	120.0
0.000						
15	15	16	2.000	1.600	0.000	120.0
0.000						
16	16	17	2.000	1.600	0.000	120.0
0.000						
17	17	18	2.000	1.600	0.000	120.0
0.000						
18	12	19	2.000	1.0000	0.000	120.0
0.000						
19	19	20	2.000	1.600	0.000	120.0
0.000						
20	20	21	2.000	1.600	0.000	120.0
0.000						
21	21	22	2.000	1.600	0.000	120.0
0.000						
22	22	23	2.000	1.600	0.000	120.0
0.000						
23	23	24	2.000	1.600	0.000	120.0
0.000						
24	24	25	2.000	1.600	0.000	120.0
0.000						
25	2	26	2.000	18.00	0.000	120.0
0.000						
26	26	35	2.000	5.000	0.000	120.0
0.000						
27	27	28	1.0000	4.000	4.000	120.0
0.000						
28	27	29	1.500	4.000	0.000	120.0
0.000						
29	29	30	1.0000	4.000	4.000	120.0
0.000						
30	28	31	1.0000	3.000	0.000	120.0
0.000						
31	28	32	1.0000	3.000	0.000	120.0
0.000						
32	30	33	1.0000	3.000	0.000	120.0
0.000						
33	30	34	1.0000	3.000	0.000	120.0
0.000						
34	35	27	2.000	12.00	0.000	120.0
0.000						
35	35	36	1.500	4.000	4.000	120.0
0.000						
36	36	37	1.0000	3.000	0.000	120.0
0.000						
37	36	38	1.0000	3.000	0.000	120.0
0.000						
1						

TITLE :
PAGE 5 OF 17

DATE : 10-May-2022

PIPE FITTINGS

Pipe Number x Type Equivalent Length

Label (metres)

Fitting types are :

- 1 -- 45 Deg Elbow
- 2 -- 90 Deg Standard Elbow
- 3 -- 90 Deg Long Radius Elbow
- 4 -- Tee or Cross (Flow Turned Thro 90 Deg)
- 5 -- Gate Valve
- 6 -- Swing Check Valve
- 7 -- Non-Return Valve
- 8 -- Ball Valve
- 9 -- Butterfly Valve

1

TITLE :
PAGE 6 OF 17

DATE : 10-May-2022

NOZZLE CONFIGURATION

Nozzle Press Label	Input Node	Nozzle Type	K-Factor	Req Flow (lit/min)	Min Press (bar G)	Max (bar G
1	11	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
2	10	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
3	9	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
4	8	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
5	7	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
6	6	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
7	18	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
8	17	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
9	16	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
10	15	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
11	14	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
12	13	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
13	20	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
14	21	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
15	22	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
16	23	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
17	24	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						
18	25	1	64.0000	118.0000	0.25000E+01	
0.40000E+01						

19	31	2	26.0000	48.9000	0.25000E+01
0.40000E+01					
20	32	2	26.0000	48.9000	0.25000E+01
0.40000E+01					
21	33	2	26.0000	48.9000	0.25000E+01
0.40000E+01					
22	34	2	26.0000	48.9000	0.25000E+01
0.40000E+01					
23	37	3	35.0000	64.0000	0.25000E+01
0.40000E+01					
24	38	3	35.0000	64.0000	0.25000E+01
0.40000E+01					

Nozzle types are :

- 1 -- Nozzles for GC
- 2 -- Nozzles for vessels
- 3 -- Nozzles for vessels 1

1

TITLE :
PAGE 7 OF 17

DATE : 10-May-2022

DESIGNED DIAMETERS & FLOWRATES

Pipe Label	Input Node	Output Node	Flowrate (lit/min)	Pipe Type	Act. Bore (inches)	Nom. Size (inches)	Pipe Group
1	1	2	2496.0637	3	4.0260	4.0000	*
2	2	3	2161.7388	3	4.0260	4.0000	*
3	3	12	2161.7388	3	4.0260	4.0000	*
4	12	5	713.9799	3	2.0670	2.0000	*
5	5	6	713.9799	3	2.0670	2.0000	*
6	6	7	592.9354	3	2.0670	2.0000	*
7	7	8	473.2181	3	2.0670	2.0000	*
8	8	9	354.3835	3	2.0670	2.0000	*
9	9	10	236.0689	3	2.0670	2.0000	*
10	10	11	118.0003	3	2.0670	2.0000	*
12	12	13	727.2349	3	2.0670	2.0000	*
13	13	14	603.9489	3	2.0670	2.0000	*
14	14	15	482.0111	3	2.0670	2.0000	*
15	15	16	360.9699	3	2.0670	2.0000	*
16	16	17	240.4568	3	2.0670	2.0000	*
17	17	18	120.1937	3	2.0670	2.0000	*
18	12	19	720.5248	3	2.0670	2.0000	*
19	19	20	720.5248	3	2.0670	2.0000	*
20	20	21	598.3735	3	2.0670	2.0000	*
21	21	22	477.5597	3	2.0670	2.0000	*
22	22	23	357.6356	3	2.0670	2.0000	*
23	23	24	238.2355	3	2.0670	2.0000	*
24	24	25	119.0833	3	2.0670	2.0000	*
25	2	26	334.3244	3	2.0670	2.0000	*
26	26	35	334.3244	3	2.0670	2.0000	*
27	27	28	98.9562	3	1.0490	1.0000	*
28	27	29	98.6481	3	1.6100	1.5000	*
29	29	30	98.6481	3	1.0490	1.0000	*
30	28	31	49.4781	3	1.0490	1.0000	*
31	28	32	49.4781	3	1.0490	1.0000	*
32	30	33	49.3241	3	1.0490	1.0000	*
33	30	34	49.3241	3	1.0490	1.0000	*
34	35	27	197.6043	3	2.0670	2.0000	*
35	35	36	136.7201	3	1.6100	1.5000	*
36	36	37	68.3600	3	1.0490	1.0000	*

1	1	2	4.00	5.023	4.712	0.3116	0.3116
2496.	5.065						
2	2	3	4.00	4.712	4.359	0.3530	0.3530
2162.	4.387						
3	3	12	4.00	4.359	3.825	0.5340	9.3450E-02
2162.	4.387						
4	12	5	2.00	3.825	3.687	0.1375	0.1375
714.0	5.497						
5	5	6	2.00	3.687	3.577	0.1100	0.1100
714.0	5.497						
6	6	7	2.00	3.577	3.499	7.8015E-02	7.8015E-02
592.9	4.565						
7	7	8	2.00	3.499	3.448	5.1405E-02	5.1405E-02
473.2	3.643						
8	8	9	2.00	3.448	3.418	3.0105E-02	3.0105E-02
354.4	2.728						
9	9	10	2.00	3.418	3.403	1.4200E-02	1.4200E-02
236.1	1.817						
10	10	11	2.00	3.403	3.399	3.9351E-03	3.9351E-03
118.0	0.9084						
12	12	13	2.00	3.825	3.711	0.1138	0.1138
727.2	5.599						
13	13	14	2.00	3.711	3.630	8.0720E-02	8.0720E-02
603.9	4.650						
14	14	15	2.00	3.630	3.577	5.3185E-02	5.3185E-02
482.0	3.711						
15	15	16	2.00	3.577	3.546	3.1145E-02	3.1145E-02
361.0	2.779						
16	16	17	2.00	3.546	3.531	1.4695E-02	1.4695E-02
240.5	1.851						

17	17	18	2.00	3.531	3.527	4.0700E-03	4.0700E-03
120.2	0.9253						
18	12	19	2.00	3.825	3.755	6.9930E-02	6.9930E-02
720.5	5.547						
19	19	20	2.00	3.755	3.643	0.1119	0.1119
720.5	5.547						
20	20	21	2.00	3.643	3.563	7.9345E-02	7.9345E-02
598.4	4.607						
21	21	22	2.00	3.563	3.511	5.2280E-02	5.2280E-02
477.6	3.676						
22	22	23	2.00	3.511	3.481	3.0620E-02	3.0620E-02
357.6	2.753						
23	23	24	2.00	3.481	3.466	1.4440E-02	1.4440E-02
238.2	1.834						
24	24	25	2.00	3.466	3.462	3.9999E-03	3.9999E-03
119.1	0.9168						
25	2	26	2.00	4.712	4.408	0.3041	0.3041
334.3	2.574						
26	26	35	2.00	4.408	4.323	8.4465E-02	8.4465E-02
334.3	2.574						
27	27	28	1.00	4.246	3.662	0.5848	0.1933
98.96	2.958						
28	27	29	1.50	4.246	4.223	2.3860E-02	2.3860E-02
98.65	1.252						
29	29	30	1.00	4.223	3.639	0.5837	0.1921
98.65	2.949						
30	28	31	1.00	3.662	3.621	4.0210E-02	4.0210E-02
49.48	1.479						
31	28	32	1.00	3.662	3.621	4.0210E-02	4.0210E-02
49.48	1.479						
32	30	33	1.00	3.639	3.599	3.9975E-02	3.9975E-02
49.32	1.474						
33	30	34	1.00	3.639	3.599	3.9975E-02	3.9975E-02
49.32	1.474						
34	35	27	2.00	4.323	4.246	7.6630E-02	7.6630E-02
197.6	1.521						
35	35	36	1.50	4.323	3.888	0.4352	4.3637E-02
136.7	1.735						
36	36	37	1.00	3.888	3.815	7.3115E-02	7.3115E-02
68.36	2.043						
37	36	38	1.00	3.888	3.815	7.3115E-02	7.3115E-02
68.36	2.043						
1							

TITLE :
PAGE 10 OF 17

DATE : 10-May-2022

FLOW THROUGH NOZZLES

Nozzle FlowDens Label /metres	Input FlowDens Label **2)	Inlet Press (bar G)	Req. Flow (lit/min)	Flowrate (lit/min)	% Deviation	Req. (lit/min
1	11	0.33994E+01	118.0000	118.0000 *	0.00	
2	10	0.34034E+01	118.0000	118.0683	0.06	
3	9	0.34176E+01	118.0000	118.3143	0.27	
4	8	0.34477E+01	118.0000	118.8343	0.71	
5	7	0.34991E+01	118.0000	119.7169	1.46	
6	6	0.35771E+01	118.0000	121.0442	2.58	
7	18	0.35270E+01	118.0000	120.1934	1.86	
8	17	0.35310E+01	118.0000	120.2628	1.92	
9	16	0.35457E+01	118.0000	120.5127	2.13	

10	15	0.35769E+01	118.0000	121.0409	2.58
11	14	0.36301E+01	118.0000	121.9375	3.34
12	13	0.37108E+01	118.0000	123.2858	4.48
13	20	0.36428E+01	118.0000	122.1510	3.52
14	21	0.35634E+01	118.0000	120.8134	2.38
15	22	0.35112E+01	118.0000	119.9239	1.63
16	23	0.34805E+01	118.0000	119.3998	1.19
17	24	0.34661E+01	118.0000	119.1519	0.98
18	25	0.34621E+01	118.0000	119.0831	0.92
19	31	0.36214E+01	48.9000	49.4780	1.18
20	32	0.36214E+01	48.9000	49.4780	1.18
21	33	0.35989E+01	48.9000	49.3240	0.87
22	34	0.35989E+01	48.9000	49.3240	0.87
23	37	0.38148E+01	64.0000	68.3599	6.81
24	38	0.38148E+01	64.0000	68.3599	6.81

Note: A * after a value indicates that this is a specification
1

TITLE :
PAGE 11 OF 17

DATE : 10-May-2022

FLOW AT INLETS

Inlet Node	Pressure (bar G)	Flowrate (lit/min)	Equivalent K-factor (lit/min , bar G)
1	5.023	2496.	1113.7

Note: A * after a value indicates that this is a specification
1

TITLE :
PAGE 12 OF 17

DATE : 10-May-2022

Materials Take-off

Pipe lengths

ANSI B36.10 Sch.40

Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length	Nom. Size	Tot. Length
(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)	(inches)	(metres)

1.000	26.00
1.500	8.000
2.000	66.80
4.000	33.00

1

TITLE :
PAGE 13 OF 17

DATE : 10-May-2022

Materials Take-off

Nozzles

Type	K-Factor	Number
----	-----	-----
Nozzles for GC	64.0000	18
Nozzles for vessels	26.0000	4
Nozzles for vessels 1	35.0000	2

1

TITLE :
PAGE 14 OF 17

DATE : 10-May-2022

Materials Take Off

Fittings

Fitting Nominal Size (inches)	1	2	3	Fitting Type	4	5	6	7	8	9
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Fitting Types are :

1 -- 45 Deg Elbow	4 -- Tee or Cross	7 -- Non-Return Valve
2 -- 90 Deg Standard Elbow	5 -- Gate Valve	8 -- Ball Valve
3 -- 90 Deg Long Radius Elbow	6 -- Swing Check Valve	9 -- Butterfly Valve

All fittings are as specified by user - no additional fittings have been generated automatically.

The supply demand graph is not available for the network without pump

1

TITLE :
PAGE 15 OF 17

DATE : 10-May-2022

IMPORTANT NOTICE

Your attention is drawn to the need to maintain adequate standards. SUNRISE SYSTEMS Ltd has itself taken steps to ensure that this program produces valid results when properly used. Users are reminded of their responsibilities in the application of program results and, in particular, you should ensure that pertinent output documents are examined and approved by qualified staff prior to use.

1

TITLE :
PAGE 16 OF 17

DATE : 10-May-2022

COMMENTS

Analysis Converged in 3 Iterations
1