

تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

· ۵۳ - · ۷۳ - 9 1 1 4

PMR FOR EMERGENCY DIESEL GENERATOR - BK15	5
---	---

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 BK15
 PEDCO
 110
 EL
 MR
 0003
 D01

شماره صفحه: ۱ از ۱۵

طرح نگهداشت و افزایش تولید ۲۷ مخزن

PMR FOR EMERGENCY DIESEL GENERATOR - BK15

نگهداشت و افزایش تولید میدان نفتی بینک

D01 D00 Rev.	May.2023 Aug.2022 Date	FI IFI Purpose of Issue/Status	H.Shakiba H.Shakiba Prepared by:	M.Fakharian M.Fakharian Checked by:	A.M.Mohseni M.Mehrshad Approved by:	Client Approval
D01	May.2023	FI	H.Shakiba	M.Faknarian	A.M.Monseni	
			110111	AA Fallonia	A B A B A - L '	

Class: 3 Client Doc. Number: F0Z-708403

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for Client Review
AB-A: As-Built –Approved



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



٠.	1		شما
- ()	يىما	0 1	سمار

· 27 - · 77 - 9114

,	PMR FOR EMERGENCY DIESEL GENERATOR - BK15							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK15	PEDCO	110	EL	MR	0003	D01	

شماره صفحه: ۲ از ۱۵

REVISION RECORD SHEET

				ľ	REVISI
PAGE	D00	D01	D02	D03	D04
1	Х	Χ			
2	X	X			
3	X				
4	Х				
5	Х	Х			
6	X				
7	Х				
8	Х				
9	Х				
10	Х	Х			
11	Х				
12	X				
13	Х				
14	X	Х			
15	X				
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33 34					
35					
36				-	
37				-	
38 39				-	
				 	
40				-	
41				 	
42				<u> </u>	
43				-	
44					
45					
46					
47				ļ	
48				ļ	
49					
50					

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
100	l	l	l		l .



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

· 27 - · 77 - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK15	PEDCO	110	EL	MR	0003	D01	

شماره صفحه: ۳ از ۱۵

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	REFERENCE / ATTACHED DOCUMENTS	5
4.0	SUBJECT OF THE SUPPLY	6
5.0	LIMITS OF SUPPLY	6
5.1	SCOPE OF SUPPLY	6
5.1.1	MAIN DESCRIPTION	6
5.1.2	SPARE PARTS	7
5.1.3	OTHER ITEMS	7
5.2	EXCLUSIONS	7
5.3	BATTERY LIMITS	7
6.0	INSPECTION AND TESTS	7
7.0	VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE	
8.0	UNIT RESPONSIBILITY	
9.0	GUARANTEE AND WARRANTY	
10.0	DEVIATION	9
11.0	PRICE BREAKDOWN	9
	LIST OF REFERENCE / APPLICABLE DOCUMENTS	
ATTAC	HMENT 2	10
11.2	VENDOR DOCUMENTS MIN. REQUIREMENT	10
ATTAC	CHMENT 3	14
11.3		
ATTAC	HMENT 4	15
11.4	ALTERNATIVES TO JOB SPECIFICATION	15



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

· ۵۳ - · ۷۳ - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	BK15	PEDCO	110	EL	MR	0003	D01

شماره صفحه: ۴ از ۱۵

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, required modifications on BK15 work over well (with electric power supply) shall be done.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development –Modifications on BK15

Work over Well & Electrification Facilities

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy - Design &

Inspection(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

· 24 - · 74 - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	BK15	PEDCO	110	EL	MR	0003	D01

شماره صفحه: ۵ از ۱۵

supplier or VENDOR.

MAY:

Is used where a provision is completely discretionary.

2.0 GENERAL

- This document presents the item material requisitions for Contractor's use as appropriate.
- This material requisition covers the requirements for the design, manufacturing, testing and supply of Diesel Generator in well pads 15 as listed below. All equipment/devices/items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.



The vendor's supply shall include:

No.	Item	Description	Tag No.	Total QTY.
1	Diesel Generator	0.4 KV, 190.3KW prime (at ISO cond.)	Well 15-DG-001	1 Set

3.0 REFERENCE / ATTACHED DOCUMENTS

- **a.** Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- **b.** All codes and standards which have been referenced in above mentioned specs shall be considered.
- c. In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.

d. Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



پیمان:	شماره

· 24 - · 74 - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه		
BK	BK15	PEDCO	110	EL	MR	0003	D01		

شماره صفحه: ۶ از ۱۵

If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, the supplier shall be considered to be in full compliance with the relevant document.

The supplier may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY

The supplier shall supply 190.3KW Diesel Generator. The scope of supply is detailed at para. 5. The supplier shall include in the supply, all other equipment/devices/items not listed in the following, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.

5.0 LIMITS OF SUPPLY

5.1 SCOPE OF SUPPLY

5.1.1 MAIN DESCRIPTION

Diesel Generator shall be according to "Data Sheets for Diesel Generator of Well Pads (BK-SSGRL-PEDCO-110-EL-DT-0004)" & "Calculation Note for Diesel Generator Sizing of Well Pads (BK-SSGRL-PEDCO-110-EL-CN-0008)"

The supplier shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.
- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.
- · Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



پیمان:	شماره

· 24 - · 74 - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK15	PEDCO	110	EL	MR	0003	D01	

شماره صفحه: ۷ از ۱۵

- QA/QC Organization Chart and procedures that shall be submitted for approval.
- Plan for HOLD points in the production process proposed to PURCHASER for witness or approval particular activities.
- Production schedule indicating main quality manufacturing processes, inspection and tests.
- Qualification of all personnel performing tests to be reviewed by the inspector
- Supplier shall also provide the description of the following quality activities:
 - Sub suppliers products quality
 - Quality check and identification of the materials and equipment entering in their manufacturing shop.
- · Calibration of test instruments and equipment
- Provide detailed specifications and data sheets.

5.1.2 SPARE PARTS

Following items shall be considered (supplied) and included in the bid documentation:

- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Capital spare parts (as option / if any)

5.1.3 OTHER ITEMS

Special tools required for installation and maintenance

5.2 EXCLUSIONS

Not Applicable

5.3 BATTERY LIMITS

Not Applicable

6.0 INSPECTION AND TESTS

The equipment shall be inspected and tested in accordance with the quality control plan issued by the supplier and approved by the PURCHASER before the award of the order. The QC plan shall at least be according to the PROJECT ITP PROCEDURE (Doc. No. ICE-EID-MI-SP01-Rev01 & ICE-EID-MI-SP02-REV-01) and data sheets (if any).



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



پیمان:	شماره

· 24 - · 74 - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	BK15	PEDCO	110	EL	MR	0003	D01		

شماره صفحه: ۸ از ۱۵

The supplier shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE

- Vendor document shall be according to attachment 2 of this document.
- All documents, preliminary or final, are to be stamped and signed by the supplier.
- Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.
- PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.
- All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 "GENERAL DEFINITION"

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, testing, final check-out and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.

Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-suppliers.

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.

The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/packages at site

VENDOR shall guarantee the performance of supplied items (if any).

VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



۰۵۳	- • ٧٣	– ۹۱ ۸۴

PMR FOR EMERGENCY DIESEL GENERATOR - BK15									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	BK15	PEDCO	110	EL	MR	0003	D01		

شماره صفحه: ۹ از ۱۵

services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period.

Vendor shall ensure a correct and safe operation of the unit, providing all safety protection Devices. Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION

VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.

VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for PURCHASER's approval.

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (END-QC-SP-1)
- 3) 2 years operational spare parts (END-QC-SP-1)
- 4) Packing & transportation
- 5) Other fee (if any)



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

۰۵۳ – ۷۷۳ – ۹۱۸۴

PMR FOR EMERGENCY DIESEL GENERATOR - BK15									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	BK15	PEDCO	110	EL	MR	0003	D01		

شماره صفحه : ۱۰ از ۱۵



ATTACHMENT 1

11.1 <u>LIST OF REFERENCE / APPLICABLE DOCUMENTS</u>

No.	Document No.	Document Title	
Proces	SS		
1.	BK-GNRAL-PEDCO-000-PR-DB-0001	Process Basis of Design	D08
Electri	cal		
2.	BK-GNRAL-PEDCO-000-EL-DC-0001	Electrical System Design Criteria	D02
3.	BK-GCS-PEDCO-120-ME-SP-0012	Specification for Diesel Engines	D03
4.	BK-SSGRL-PEDCO-110-EL-CN-0008	Calculation Note for Diesel Generator Sizing of Well Pads	D03
5.	BK-SSGRL-PEDCO-110-EL-DT-0004	Data Sheets for Diesel Generator of Well Pads	D04
6.	BK-SSGRL-PEDCO-110-EL-SL-0002	Single Line Diagram for LV Switchgear of Well Pads	D03
7.	BK-SSGRL-PEDCO-110-EL-LD-0001	Control Logic Diagram for LV Incomers of Well Pads	D03
8.	BK-SSGRL-PEDCO-110-EL-DG-0001	Electrical Typical Schematic Diagrams for LV Panels of Well Pads	D05
Gener	al		
9.	BK-BK15-PEDCO-110-PI-PY-0001	Plot Plan Drawing – BK15	D00
10.	IPS-M-EL-138(1)	Material and Equipment Standard for Synchronous Generator	-
11.	IPS-M-PM-290(1)	Material and equipment standard for reciprocating internal combustion engines	-
12.	BK-GNRAL-PEDCO-000-QC-PR-0022	Specification for Final Data Book (FDB) Requirements	D00
13.	BK-GNRAL-PEDCO-000-QC-PR-0045	Packing , Marking , Transportation Procedure	D00
14.	ICE-EID-MI-SP01-Rev01	دستورالعمل بازرسی، خرید و ساخت کالا	-
15.	ICE-EID-MI-SP02-Rev01	سطح بازرسی کالا و تجهیزات	-
16.	E&C-QC-SP-1	دستورالعمل تامین قطعات یدکی راه اندازی و راهبری دو سالانه	-
17.	BK-GNRAL-PEDCO-000-PI-SP-0006	Specification for Painting	D04
18.	BK-GNRAL-HD-000-PM-PR-0003	Document Numbering Procedure	G04

ATTACHMENT 2

11.2 <u>VENDOR DOCUMENTS MIN. REQUIREMENT</u>

		With Bid	TIME SCHEDULE					
o S		with bia	For Review		Final Issue			
Item N	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)		
MANAGEMENT								
1	Vendor Document Index and Schedule	4N	6C+E		6C+E			



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

+ DT - + YT - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	BK15	PEDCO	110	EL	MR	0003	D01		

شماره صفحه: ۱۱ از ۱۵

		Wat Bill	TIME SCHEDULE				
<u>o</u>		With Bid	For Review		Final Issue		
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)	
2	Organization Brief	3N	6C+E				
3	Schedule Level 1, 2, 3 & 4 showing Engineering, Procurement, Fabrication, Inspection, Testing, and Delivery Plan.	4N	6C+E		6C+E		
4	Physically Progress Report (Every 2 Weeks))		6C+E				
5	Project Organization Chart	3N	6C+E				
6	Reference List	3N					
7	Vendor Catalogue	3N					
QUALI	τΥ						
8	Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO)	4N			6C+E		
9	Preliminary Inspection & Test Plan	4N					
10	Inspection & Test Plan		6C+E		6C+E		
HSE							
11	HSE Procedure		6C+E		6C+E		
INTER	FACE						
12	Electrical & Control Cable Schedule (for all systems)		6C+E		6C+E		
13	Electrical & Control Wiring Drawings (for all systems)		6C+E		6C+E		
14	Interface Block Diagrams	3N	6C+E		6C+E		
15	Utility Consumption List	3N	6C+E		6C+E		
16	Power Supply Requirements	3N	6C+E		6C+E		
17	Weight / Centre of Gravity Drawings & Data's		6C+E		6C+E		
18	P & ID of Package		6C+E		6C+E		
ENGIN	EERING						
19	Package Data Sheets						
20	General Arrangements Drawings						
21	Mechanical Equipment List	3N	6C+E		6C+E		
22	Electrical Equipment List	3N	6C+E		6C+E		



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

111P - 774 - 711F

PMR FOR EMERGENCY DIESEL GENERATOR - BK15								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK15	PEDCO	110	EL	MR	0003	D01	

شماره صفحه: ۱۲ از ۱۵

		With Did	TIME SCHEDULE				
ġ.		With Bid	For Review		Final Issue		
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)	
23	Single Line Diagram	3N	6C+E		6C+E		
24	Junction Box, Local Panels & Cabinets: wiring diagrams & termination drawings		6C+E		6C+E		
25	Earthing Details		6C+E		6C+E		
26	Fuel Tank Sizing		6C+E		6C+E		
27	Electrical Cables Routing (incl. cable trays & junction boxes)		6C+E		6C+E		
28	I/O List Document		6C+E		6C+E		
29	Electrical Equipment Location Drawings (incl. provisions for operational and maintenance access)		6C+E		6C+E		
30	Protection Device Operating Curves		6C+E		6C+E		
31	Electrical Control Schematics		6C+E		6C+E		
32	Instrument & Control Detailed Specifications (one per component)		6C+E		6C+E		
33	Instrument cables routing (incl. cable trays & junction boxes)		6C+E		6C+E		
34	Instrument Equipment Location Drawings (incl. provisions for operational and maintenance access)		6C+E		6C+E		
35	Power Distribution & Consumption		6C+E		6C+E		
36	Shipping Detail Drawing		6C+E		6C+E		
37	Final Data Book		6C+E		6C+E		
38	Completed Equipment Datasheets	4N	6C+E		6C+E		
39	Electrical Equipment Catalogue	3N	6C+E		6C+E		
40	Electrical Interface Block Diagrams		6C+E		6C+E		
PROC	JREMENT						
41	List of Sub-Suppliers (table giving: part of equipment, tag no., sub-supplier reference)(5.1.3)	4N			6C+E		
42	Unpriced copy of sub-orders		6C+E				
MANU	FACTURING						
43	Heat Treatment Procedures		6C+E		6C+E		



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

· 27 - · 77 - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	BK15	PEDCO	110	EL	MR	0003	D01		

شماره صفحه: ۱۳ از ۱۵

		With Bid	TIME SCHEDULE				
ġ		with Bia	For Review		Final Issue		
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)	
TESTIN	IG						
44	Factory Acceptance Test (FAT) Procedure		6C+E		6C+E		
45	Site Acceptance Test (SAT) Procedure		6C+E		6C+E		
RECOR	RDS, REPORTS & CERTIFICATES						
46	Material Conformity Certificate		6C+E		6C+E		
47	Testing Authority Approval Certificate (if any)		6C+E		6C+E		
48	Ingress Protection Certificate		6C+E		6C+E		
49	Dimensional Control Reports		6C+E		6C+E		
50	FAT Test Report / Certificates		6C+E		6C+E		
INSTAL	LATION						
51	Sub-Assembly Documentation		6C+E		6C+E		
52	Sub-Assembly Drawings		6C+E		6C+E		
53	Erection/Installation Manual (if required)		6C+E		6C+E		
54	Name Plate Documents		6C+E		6C+E		
55	Handling, Transportation & Storage Instructions		6C+E		6C+E		
56	Unpacking & Inspection Instructions		6C+E				
57	Preliminary Packing List	4N					
58	Packing List		6C+E		6C+E		
OPERA	TION & MAINTENANCE						
59	Operating Instructions		6C+E		6C+E		
60	Maintenance Instructions (if required)		6C+E		6C+E		
61	Commissioning & Start-up Manual		6C+E		6C+E		
62	List of Spare Parts Commissioning & Start-up	4N	6C+E		6C+E		
63	List of Spare Parts 2 Years Operation	4N	6C+E		6C+E		
64	List of Special Tools	4N	6C+E		6C+E		
65	Software Manual (incl. Troubleshooting)		6C+E		6C+E		
OTHER	S						
66	All others documents (if required) will be listed in the order		6C+E				



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

· 27 - · 77 - 9114

PMR FOR EMERGENCY DIESEL GENERATOR - BK15									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	BK15	PEDCO	110	EL	MR	0003	D01		

شماره صفحه: ۱۴ از ۱۵

	ġ	With Bid	TIME SCHEDULE			
Item No.		With Bia	For Review		Final Issue	
	Document	Copies	Copies	Solar	Copies	Calendar
		No./Type	No./Type	days	No./Type	days
		(7)	(1)	(2)	(1)	(3)

NOTES:

- (1) N= Number of document, C=Copy, E=Electronic Copy
- (2) Starting from date of order placement
- (3) Starting from reception of documentation without comments
- (4) First issue of the document is subjected to the release of payment milestone as per purchase order
- (5) Calendar days after reception of drive data
- (6) Prior to testing
- (7) One copy each bid copy
- (8) List of Documents Will be Finalized in Vendor Document index and Schedule

ATTACHMENT 3

Requisition No.:

Equipment No.:

Description:

11.3 <u>DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION</u>

Item No.	Description of proposed exception	Recommended revision to job specification	Reason for proposed exception	Effect on base proposal if CONTRACTOR rejects exception



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK15



شماره پیمان:

 $\cdot \Delta T - \cdot VT - 91 \Lambda F$

PMR FOR EMERGENCY DIESEL GENERATOR - BK15									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	BK15	PEDCO	110	EL	MR	0003	D01		

شماره صفحه: ۱۵ از ۱۵

ATTACHMENT 4

Requisition No.:

Description:

11.4 ALTERNATIVES TO JOB SPECIFICATION

Equipment No.:							
Item No.	Job Specification No. & Paragraph No.	Requirements of Job Specification	Description of Proposed Alternative	Reason for Proposed Alternative			