



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



DATA SHEETS FOR DIFF. PRESSURE FLOW TRANSMITTER

شماره پیمان:

053 - 073 - 9184

پروژه

BK

بسته کاری

GCS

صادر کننده

PEDCO

تسهیلات

120

رشته

IN

نوع مدرک

DT

سریال

0012

نسخه

D03

شماره صفحه: 1 از 6

طرح نگهداشت و افزایش تولید 27 مخزن

DATA SHEETS FOR DIFF. PRESSURE FLOW TRANSMITTER

نگهداشت و افزایش تولید میدان نفتی بینک

D03	JUL.2023	AFC	P.Hajisadeghi	M.Fakharian	A.M.Mohseni	
D02	MAY.2023	AFC	P.Hajisadeghi	M.Fakharian	A.M.Mohseni	
D01	DEC.2022	IFA	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
D00	APR.2022	IFC	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 1

CLIENT Doc. Number: F9Z-708933

status:

IDC: Inter-Discipline Check

IFC: Issued For Comment

IFA: Issued For Approval

AFD: Approved For Design

AFC: Approved For Construction

AFP: Approved For Purchase

AFQ: Approved For Quotation

IFI: Issued For Information

AB-R: As-Built for CLIENT Review

AB-A: As-Built -Approved



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



DATA SHEETS FOR DIFF. PRESSURE FLOW TRANSMITTER

شماره پیمان:

053 - 073 - 9184

پروژه

BK

بسته کاری

GCS

صادرکننده

PEDCO

تسهیلات

120

رشته

IN

نوع مدرک

DT

سریال

0012

نسخه

D03

شماره صفحه: 2 از 6

REVISION RECORD SHEET

Page	D00	D01	D02	D03	D04
1	X	X	X	X	
2	X	X	X	X	
3	X	X			
4	X	X			
5	X	X			
6	X	X	X	X	
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					

Page	D00	D01	D02	D03	D04
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



DATA SHEETS FOR DIFF. PRESSURE FLOW TRANSMITTER

شماره پیمان:

053 - 073 - 9184

پروژه

BK

بسته کاری

GCS

صادرکننده

PEDCO

تسهيلات

120

رشته

IN

نوع مدرک

DT

سریال

0012

نسخه

D03

شماره صفحه: 3 از 6

REFERENCE DOCUMENTS :

Specification For Instrumentation	BK-GNRAL-PEDCO-000-IN-SP-0001
Process Basis Of Design	BK-GNRAL-PEDCO-000-PR-DB-0001
Piping Material Specification	BK-GCS-PEDCO-120-PI-SP-0001
Hazardous Area Classification Layout	BK-GCS-PEDCO-120-SA-PY-0002
Instrument & Control System Design Criteria	BK-GCS-PEDCO-120-IN-DC-0002
Symbol & Legend For PFD and P&ID	BK-GCS-PEDCO-120-PR-PI-0001
P&ID - Gas Compression Inlet Gas Pipeline (Binak)	BK-GCS-PEDCO-120-PR-PI-0002
P&ID - Gas Compression Inlet Gas Pipeline (Golkhari)	BK-GCS-PEDCO-120-PR-PI-0003
P&ID - Slug Catcher System	BK-GCS-PEDCO-120-PR-PI-0004
P&ID - Gas Compression Inlet Knock Out Drum	BK-GCS-PEDCO-120-PR-PI-0005
P&ID - 1st Stage Gas Compression Suction Drums	BK-GCS-PEDCO-120-PR-PI-0006
P&ID - 1st Stage Gas Compression Compressors	BK-GCS-PEDCO-120-PR-PI-0007
P&ID - 1st Stage Gas Compression Air Coolers	BK-GCS-PEDCO-120-PR-PI-0008
P&ID - 2nd Stage Gas Compression Suction Drums	BK-GCS-PEDCO-120-PR-PI-0009
P&ID - 2nd Stage Gas Compression Compressors	BK-GCS-PEDCO-120-PR-PI-0010
P&ID - 2nd Stage Gas Compression Air Coolers	BK-GCS-PEDCO-120-PR-PI-0011
P&ID - 2nd Stage Gas Compression Discharge Drum	BK-GCS-PEDCO-120-PR-PI-0012
P&ID - Gas Compression Dehydration Package	BK-GCS-PEDCO-120-PR-PI-0013
P&ID - Lean Glycol Storage Tank	BK-GCS-PEDCO-120-PR-PI-0014
P&ID - Instrument & Plant Air System	BK-GCS-PEDCO-120-PR-PI-0015
P&ID - Nitrogen Generation System	BK-GCS-PEDCO-120-PR-PI-0016
P&ID - Close Drain System	BK-GCS-PEDCO-120-PR-PI-0017
P&ID - Corrosion Inhibitor Package	BK-GCS-PEDCO-120-PR-PI-0018
P&ID - Methanol Injection Package	BK-GCS-PEDCO-120-PR-PI-0019
P&ID - LP Flare System	BK-GCS-PEDCO-120-PR-PI-0020
P&ID - Oily Water Sewer	BK-GCS-PEDCO-120-PR-PI-0021
P&ID - Fuel Gas System	BK-GCS-PEDCO-120-PR-PI-0022
P&ID - Diesel Oil System	BK-GCS-PEDCO-120-PR-PI-0023
P&ID - Potable Water System	BK-GCS-PEDCO-120-PR-PI-0024
P&ID - Glycol Sump Drum	BK-GCS-PEDCO-120-PR-PI-0025
P&ID - Fire Water Network	BK-GCS-PEDCO-120-SA-PI-0001
P&ID - Total Flooding System For Extension of Existing Elect. Building	BK-GCS-PEDCO-120-SA-PI-0002

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								
	DATA SHEETS FOR DIFF. PRESSURE FLOW TRANSMITTER								
شماره پیمان: 053 - 073 - 9184	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 4 از 6
	BK	GCS	PEDCO	120	IN	DT	0012	D03	

GENERAL NOTES:

1 - Zero and span adjustment shall be included and be accessible from outside in addition to HHC.

2 - Over range protection (at least 30% full scale) shall be considered.

3 - Tag plate as per Specification for Instrumentation, shall be stainless steel 304 SS (VTC). Following details shall be engraved on them:

- Tag Number
- Range Limit
- Service
- Manufacture Model

4 - Painting shall be in accordance with manufacturer standard.

5 - VTA : Vendor To Advise

6 - N/A : Not Applicable

7 - Environmental condition for field instrumentation of Binak oilfield shall be considered as per the following (According to "BK-GNRL-PEDCO-000-PR-DB-0001: Process Basis Of Design"):

Maximum ambient temperature: 50 (°C)

Minimum ambient temperature: 5 (°C)

Maximum steel surface exposed to sun: 85 (°C)

Maximum summer dry bulb: 50 (°C)

DB/RH for Summer HVAC Design: 41 °C / 61 %

DB FOR Winter HVAC Design: 6 °C

Relative Humidity:

- Maximum Design relative humidity (%): 100
- Minimum Design relative humidity (%): 0

8 - Material Test Certificate and calibration Certificate for all transmitters to be submitted by Vendor.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								
	DATA SHEETS FOR DIFF. PRESSURE FLOW TRANSMITTER								
	شماره پیمان:	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
053 - 073 - 9184	BK	GCS	PEDCO	120	IN	DT	0012	D03	شماره صفحه: 5 از 6

DIFF. PRESSURE TYPE FLOW TRANSMITTER				
GENERAL DATA	1	Tag No.	SEE NEXT PAGE	
	2	P&ID No.	SEE NEXT PAGE	
	3	Equipment No. / Line No.	SEE NEXT PAGE	
	4	Area Classification	ZONE 2, IIB T4	
	5	Piping Class	SEE NEXT PAGE	
	6	RFI Protection	Tropicalisation	NEEDED Needed
OPERATING CONDITIONS	7	Fluid	SEE NEXT PAGE	
	8	Phase	SEE NEXT PAGE	
	9	Operating Pressure	(Barg)	SEE NEXT PAGE
	10	Design Pressure	(Barg)	SEE NEXT PAGE
	11	Operating Temperature	(°C)	SEE NEXT PAGE
	12	Design Temperature	(°C)	SEE NEXT PAGE
	13	Min./Normal/Max Flow Rate	(Kg/h)	SEE NEXT PAGE
TRANSMITTER	14	Element Type	SEE NEXT PAGE	
	15	Size of Process Connection	SEE NEXT PAGE	
	16	Rating of Process Connection	-	
	17	Element Material	SEE NEXT PAGE	
	18	Enclosure Material	Die cast aluminium	
	19	Instrument Range	SEE NEXT PAGE	
	20	Power Supply	24 VDC-Loop powered	
	21	Output Signal	4-20 mA	
	22	Communication Protocol	SMART HART (4-20mA)	
	23	Electrical Connection	ISO M20 x 1.5	
	24	Electrical Certification	Ex "ia"	
	25	Ingress Protection	IP-65 as minimum	
	26	Accuracy	Write Protection	0.1% of F.S Not Needed (Note 1)
	27	Repeatability	+/- 0.1% or better	
	28	Span and Zero Adjustment	Required	
	29	Over Range Protection	SEE NEXT PAGE (1.3 of F.S)	
DIAPHRAGM SEAL	30	Type	N/A	
	31	Size (In)	N/A	
	32	Fill Fluid	N/A	
	33	Diaphragm Material	N/A	
	34	Capillary Material	N/A	
	35	Capillary Length	N/A	
OPTIONS	36	Integral Indicator	Display Unit	Required Barg
	37	Mounting Brackets	Required, 2" Support Pipe	
	38	Manifold	Body Material	SEE NEXT PAGE 316 S.S.L
	39	Connection	1/2 " NPT	
	40	Manifold Model	Manifold Manufacturer	-
	41	Integral Indicator Style	LCD TYPE	
	42	NACE Requirements	SEE NEXT PAGE	
PURCHASING DATA	43	Model	Manufacturer	Will be finalized later Will be finalized later
	44	Supplier	Order	Will be finalized later Will be finalized later

Notes:

(1) According to Specification For Instrumentation, If smart type transmitters are selected for **ESD application** they shall be configured as "write protected". There is no Flow Transmitter for ESD.

 NISOC			تجهیزات و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک										  												
شماره پیمان:			DATA SHEETS FOR DIFF. PRESSURE FLOW TRANSMITTER										شماره سند: 6 از 6												
			بروزده	رشته کاری	مکانر کننده	انجهادات	رشته	نوع مدرک	میراث	سابعه															
053 - 073 - 9184			BK	GCS	PEDCO	120	IN	DT	D03			0012	D03												
DIFF. PRESSURE TYPE FLOW TRANSMITTER LIST																									
Rev.	Item No.	Tag No.	P&ID No.	Equipment No. / Line No.	Service	Fluid	Connection Rating	Phase	Design Pressure (Bar-g)	Operating Pressure (Bar-g)	Design Temp. (°C)	Operating Temp. (°C)	Calibration Range (mBarg)	Instrument Range (mBarg)	Flow Rate (Kg/h)			Element Type	Element Material	Size of Process Connection (Orifice Flange Tapping)	Over Range Protection	5-Way Valve (1/2"NPTF x 1/4"NPTF)	NACE	Model	Remark
															Min.	Normal	Max.								
D03 MODIFIED	1	FIT-2101	BK-GCS-PEDCO-120-PR-PI-0002-D06	GAS-111-0101-AN07-6"-PT	Gas Compression Inlet Gas Pipeline (Binak)	GAS	300#	Vapour	18.2	7.5	85	46.11/26.67	0-250 (VTC)	0-250 (VTC)	2297.4	6564	7220.4	Diaphragm	SS 316L	2 x 1/2" NPTF	X 1.3 Full Scale	Yes	Yes	VTA	
D03 MODIFIED	2	FIT-2102	BK-GCS-PEDCO-120-PR-PI-0003-D06	GAS-111-0001-FN07-8"-PT	Gas Compression Inlet Gas Pipeline (Golshari)	GAS	600#	Vapour	90	7.5	85	32/15.5	0-250 (VTC)	0-250 (VTC)	3944.15	11269	12395.9	Diaphragm	SS 316L	2 x 1/2" NPTF	X 1.3 Full Scale	Yes	Yes	VTA	
D03 MODIFIED	3	FIT-2111	BK-GCS-PEDCO-120-PR-PI-0004-D06 (2 of 2)	CDH-112-0014-CN05-4"-PT	Slug Catcher System	CONDENSATE	300#	LIQUID	47.7	19.5	85	23.22/8.82	0-250 (VTC)	0-250 (VTC)	3 (m3/h)	10 (m3/h)	11 (m3/h)	Diaphragm	SS 316L	2 x 1/2" NPTF	X 1.3 Full Scale	Yes	Yes	VTA	
D03 MODIFIED	4	FIT-2211	BK-GCS-PEDCO-120-PR-PI-0016-D06	NIT-112-0024-AN01-2"-PT	Nitrogen Package Outlet	GAS	300#	GAS	18.2	8	85	60	0-250 (VTC)	0-250 (VTC)	-	41.37	42.49	Diaphragm	SS 316L	2 x 1/2" NPTF	X 1.3 Full Scale	Yes	No	VTA	
D03 MODIFIED	5	FIT-2271	BK-GCS-PEDCO-120-PR-PI-0022-D06	FLG-112-0110-AN07-2"-PT	Fuel Gas System	Fuel Gas	300#	GAS	18.2	4.9	85	48	0-250 (VTC)	0-250 (VTC)	-	-	505.8	Diaphragm	SS 316L	2 x 1/2" NPTF	X 1.3 Full Scale	Yes	Yes	VTA	