

# المرادات ومروادات المرادات ال

## عمومی و مشترک

شماره پیمان:

 $\textbf{.} \Delta \textbf{..} - \textbf{..} V \textbf{..} - \textbf{..} 1 \Lambda \textbf{..}$ 

		MECHANI	CAL DES	GN CR	ITERIA			
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GNRAL	PEDCO	000	ME	DC	0001	D04	

شماره صفحه: ۱ از ۲۰

## طرح نگهداشت و افزایش تولید ۲۷ مخزن

## **MECHANICAL DESIGN CRITERIA**

نگهداشت و افزایش تولید میدان نفتی بینک

Class:2		CLIENT Doc. Number: FO	)Z-707120			
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
D00	JUL.2021	IFC	M.Asgharnejad	M.Fakharian	Sh.Ghalikar	
D01	JUN.2022	IFA	H.Adineh	M.Fakharian	M.Mehrshad	
D02	SEP.2022	IFA	H.Adineh	M.Fakharian	M.Mehrshad	
D03	NOV.2022	IFA	H.Adineh	M.Fakharian	M.Mehrshad	
D04	JAN.2023	AFD	H.Adineh	M.Fakharian	M.Mehrshad	

#### Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for CLIENT Review

AB-A: As-Built -Approved



# مرکت قب تروایان HIRGAN ENERGY

## عمومی و مشترک

**MECHANICAL DESIGN CRITERIA** شماره پیمان: بسته کاری صادر کننده نوع مدرک رشته تسهیلات نسخه پروژه سر يال  $\textbf{.} \Delta \textbf{m} - \textbf{.} \textbf{V} \textbf{m} - \textbf{9} \textbf{1} \Delta \textbf{f}$ BK GNRAL PEDCO 000 ME DC 0001 D04

شماره صفحه: ۲ از ۲۰

## REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	Х	Х	Χ	X	X
2	X	X X X	Χ	Χ	Х
3	X	Χ			
4	X X X X	Χ			
5	X	Χ			
6	X				
7	X	X			
8		Х			
9	X X X X X X X X X				
10	X	X X X			
	X	X			
12		X			
13	\ \ \ \ \	X			
14	· ·	^	X		
15	Ŷ		Х		
16	Y	Y			
17	V V	X	Х		
18	\ \frac{\( \)}{\( \)}				
19	X	X			
20	^	^			
21 22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41 42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65				<b></b>	

PAGE	D00	D01	D02	D03	D04
66					
67					
68					
69 70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80 81					
82					
83					
84					
85					
86					
87			ļ		ļ
88					
89			<u> </u>		
90					
91 92					
93					
94					
95					
96					
97					
98					
99					
100					
101 102					
103					
104					
105					
106					
107					
108			-		
109			<del>                                     </del>		<del>                                     </del>
110			1		$\vdash$
111 112			<b>-</b>		
113					
114					
115					
116					
117					
118			ļ		ļ
119			-		
120			<del>                                     </del>		<del>                                     </del>
121 122			<b>-</b>		
122			<del>                                     </del>		
123					
125			1		
126					
127					
128					
129					
130			L		





## عمومی و مشترک

پیمان:	شماره
•۵۳ - •۷۳ - 9184	

		MECHANI	CAL DES	IGN CR	ITERIA		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GNRAL	PEDCO	000	ME	DC	0001	D04

شماره صفحه: ۳ از ۲۰

## **CONTENTS**

1.0	INTRODUCTION	4
2.0	SCOPE	4
	NORMATIVE REFERENCES	
4.0	ORDER OF PRECEDENCE	.13
5.0	GENERAL CRITERIA	.13
6.0	EQUIPMENT DESIGN CRITERIA	.17
7.0	MISCELLANEOUS	.19





## عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۷۷۳ – ۵۳۰

		MECHANI	CAL DESI	GN CR	ITERIA		
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GNRAL	PEDCO	000	ME	DC	0001	D04

شماره صفحه: ٤ از ٢٠

#### 1.0 INTRODUCTION

Binak oilfield in Bushehr province, a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

#### **GENERAL DEFINITION**

The following terms shall be used in this document.

COMPANY: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development – General Facilities

EPD/EPC CONTRACTOR: Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy - Design &

Inspection(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR(GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.

#### 2.0 SCOPE

The purpose of this document is to provide the contractors with the design and selection criteria for the new equipment to be provided during the project.

It shall be used in conjunction with data/requisition sheets for present document subject.





## عمومی و مشترک

MECHANICAL DESIGN CRITERIA

نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه


شماره صفحه: ٥ از ٢٠

نسخه

D04

سريال

0001



#### 3.0 NORMATIVE REFERENCES

شماره پیمان:

If the revision of a standard or code is note specified, latest revision should be assumed.

000

ME

DC

#### 3.1 LOCAL CODES AND STANDARDS (LATEST REVISION)

GNRAL PEDCO

• IPS-G-ME-100	General Standard for Atmospheric Above Ground Welded Steel Storage Tanks.
• IPS-G-ME-110	General Standard for Large Welded Low Pressure Storage Tanks.
• IPS-G-ME-150	General Standard for Towers, Reactors, Pressure Vessels and Internals.
<ul> <li>IPS-G-ME-200</li> </ul>	Engineering and Material Standard for Fired Heaters.
• IPS-G-ME-210	General Standard for Flare Details for General Refinery and Petrochemical Service.
• IPS-C-PM-216	Construction Standard for Machinery Installation and Installation Design.
• IPS-E-PM-100	Engineering Standard for General Standard Requirements of Process Machineries.
• IPS-E-PM-385	Engineering Standard for Process Machinery Piping.
• IPS-G-PM-105	General Standard for Centrifugal Pumps for Petroleum, Petrochemical and Natural Gas Industries.
• IPS-G-PM-120	General Standard for Accessibility and Safety of Machineries.
• IPS-M-PM-115	Material and Equipment Standard for Centrifugal Pumps for General Services.
• IPS-M-PM-125	Material and Equipment Standard for Centrifugal Fire Water Pumps.
• IPS-M-PM-140	Material and Equipment Standard for Positive Displacement Pumps-Rotary.
• IPS-M-PM-150	Material and Equipment Standard for Positive Displacement Pumps-Controlled Volume.
• IPS-M-PM-180	Material and Equipment Standard for Packaged, Integrally Geared Centrifugal Compressors for Utility and Instruments.
• IPS-G-PM-200	Reciprocating Compressors For Petroleum, Chemical, And Gas Industry Services.
• IPS-M-PM-211	Material and Equipment Standard for Reciprocating Compressors for Instrument Air Services.





## عمومی و مشترک

;	شماره پیمان:			MECHANI	CAL DES	IGN CR	ITERIA				
.04 14 - 114		پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	شماره صفحه : ٦ از ٢٠	
	BK GNRAL PEDCO 000 ME DC 0001						0001	D04			
	• IPS-I	M-PM-2	20			erial olacer	and E			tandard for Positive ary.	
	• IPS-I	M-PM-2	90			Material and Equipment Standard for Reciprocating Internal Combustion Engines.					
	• IPS-I	PS-M-PM-300				erial a ar Uni		oment S	Standa	ard for Special Purpose	
	• IPS-I	S-M-PM-310				erial a		oment S	Standa	ard for Special Purpose	
	• IPS-I	S-M-PM-320				iling a				rd for Lubrication, Shaft ms and Auxiliaries for	
,	• IPS-I	M-PM-3	30		Mat	erial a	and Equip	ment S	tanda	rd for Mixers.	
	• IPS-I	E-PR-25	50		Eng	jineeri	ng Stand	ard for	Perfor	mance Guarantee.	
,	• IPS-I	E-PR-33	30			Engineering Standard for Process Design of Compressed Air Systems.					
,	• IPS-I	E-PR-46	60		Engineering Standard for Process Design of Flare and Blowdown Systems.						
,	• IPS-I	E-PR-7(	00		Engineering Standard for Process Design of Crude Oil Electrostatic Desalters.					ss Design of Crude Oil	
,	• IPS-I	E-PR-75	50		_	jineeri npres	•	ndard	for	Process Design of	
,	• IPS-I	E-PR-77	71		_	Engineering Standard for Process Requirements of Heat Exchanging Equipment.					
	• IPS-I	E-PR-85	50		Engineering Standard for Process Requirements of Vessels and Separators.						
1	• IPS-I	E-PR-90	)5		Eng	jineeri	ng Stand	ard for	Proces	ss Design of Dryers.	
	• IPS-(	C-SF-24	12		Qua	ality C		commis		ery, Testing, Inspection, g and Maintenance of	
	• IPS-I	E-SF-50	)4		Eng	jineeri	ng Stand	ard for	Fire Fi	ghting Vessels.	
	• IPS-I	E-SF-86	60		Engineering Standard for Air Pollution Control.						
	• IPS-0	G-SF-90	00		Ger	neral S	Standard t	for Nois	e Con	trol and Vibration.	
	• IPS-I	M-SF-50	04			erial	and Equ	ipment	Stan	dard for Fire Fighting	

Vessels.

Gantry Cranes.

IPS-G-GN-210

IPS-M-GN-350

General Standard for Packing & Packages.

Material and Equipment Standard for Overhead and





#### عمومي و مشترك

شماره پیمان:		MECHANICAL DESIGN CRITERIA							
· ۵۳ - · V۳ — 9 ۱	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	شماره صفحه: ۷ از ۲۰
· <b>6</b> 1 · <b>7</b> 1 · <b>7</b> 1/71	BK	GNRAL	PEDCO	000	ME	DC	0001	D04	
	DIV	GINKAL	PEDCO	000	IVIL	DC	0001	D04	

•	IPS-C-TP-101	Construction Standard for Surface preparation.
•	IPS-C-TP-102	Construction Standard for Painting.
•	IPS-C-TP-352	Construction Standard for Lining.
•	IPS-C-TP-701	Construction Standard for Application of Thermal Insulation.
•	IPS-E-TP-100	Engineering Standards for Paints.
•	IPS-E-TP-350	Engineering Standards for Linings.
•	IPS-E-TP-700	Engineering Standards for Thermal Insulations.
•	IPS-E-IN-100	Engineering Standards for General Instrumentation.
•	IPS-E-EL-100	Engineering Standards for Electrical System Design.
•	IPS-E-CE-210	Construction Standards for Steel Structure.
•	IPS-M-PI-130	Material and Equipment Standard for Pig Launching and Receiving Traps

#### 3.2 INTERNATIONAL CODES AND STANDARDS

#### American Society of Mechanical Engineers (ASME)

## **Boiler and Pressure Vessel Codes**

Section II Material Specifications

Section V Non-destructive Examination

Section VIII-Division 1 & 2 Design

Section IX Welding and Brazing Qualification

## American Society of Mechanical Engineers/American National Standard Institute (ASME/ANSI)

A 12.1	Safety Requirements for Floor and Openings, Railings and Toe Boards
A 14.3	Safety Requirements for Fixed Ladders
B 16.1	Cast Iron Pipe Flanges and Flanged Fittings
B 16.11	Forged Fittings Socket Welding and Fitting
B 16.25	Butt Welding Ends
B 16.47	Large Diameter Steel Flanges , NPS 26 Through NPS 60 , Metric / Inch Standard
B 16.5	Pipe Flanges and Flanged Fittings , NPS 1/2 Through NPS 24 , Metric / Inch Standard
B 16.9	Factory Made Wrought Steel Butt Welding Fittings
B 30.11	Monorails and Under Hung Cranes





## عمومی و مشترک

شماره پیمان:			MECHANI	CAL DES	IGN CR	ITERIA	
· ۵۳ - · ۷۳ - 9 ۱ ۸ ۴	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	
- 41 (1/1)	BK	GNRAL	PEDCO	000	ME	DC	

شماره صفحه: ۸ از ۲۰

B 30.17	Overhead and Gantry Cranes (Top-Running Bridge, Single Girder, Under Hung Hoist)
B 30.2	Overhead & Gantry Cranes
B 31.3	Process Piping
B 31.4	Pipeline Transportation Systems for Liquids Hydrocarbons & Other Liquids
B 31.8	Gas Transmission and Distribution Piping System
B 73.1	Specification for End Suction Centrifugal Pumps
PTC 10	Power Test Code – Compressors & Exhausters
PTC 17	Power Test Code – Diesel Engines
STS-1	Steel Stacks

سريال

0001

نسخه

D04

## • American Petroleum Institute (API)

SPEC. 7B-11C	Specification for Internal-Combustion Reciprocating Engines for Oil-Field Service
530	Calculation of Heater Tube Thickness in Petroleum Refineries Petroleum and natural gas industries
PUBL. 535	Burners for Fired Heaters in General Refinery Services
537	Flare Details for General Refinery and Petrochemical Service
610	Centrifugal Pumps for Petroleum, Petrochemical and Natural Gas Industries
613	Special Purpose Gear Units For Petroleum, Chemical, And Gas Industry Services
614	Lubrication, Shaft-Sealing And Control-Oil Systems For Special Purpose Applications
618	Reciprocating Compressors For Petroleum, Chemical And Gas Industry Services
619	Rotary Type Positive Displacement Compressors For General Refinery Services
620	Design And Construction Of Large, Welded, Low- Pressure Storage Tanks
650	Welded Carbon Steel Tanks for Oil Storage
662	Plate Heat Exchangers for General Refinery Services
670	Vibration, Axial Position, And Bearing Temperature Monitoring Systems





## عمومی و مشترک

									)
شماره پیمان:			MECHANI	CAL DES	IGN CR	ITERIA			
· DT = · VT — 9 1 A F	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	شماره صفحه: ۹ از ۲۰
	BK	GNRAL	PEDCO	000	ME	DC	0001	D04	

Special-Purpose Couplings For Refinery Services
Packaged, Integrally Geared, Centrifugal Plant And Inst. Air Compressors
Positive Displacement Pumps – Controlled Volume
Positive Displacement Pumps-Rotary
General Purpose Gear Units
Packaged Reciprocating Plant and Instrument Air Compressors for General Refinery Services
Shaft Sealing Systems For Centrifugal And Rotary Pumps
Dry Gas Sealing Systems for Axial, Centrifugal, Rotary Screw Compressors and Expanders
Recommended Practice for Classification For Locations For Electrical Installations At Petroleum Facilities
Recommended Practice for Sizing, Selection And Installation Of Pressure Relieving Devices in Refineries
Guide for Pressure-Relieving and Depressurizing System
Recommended Practice for Machinery Installation and Installation Design
Venting Atmospheric and Low-pressure Storage Tanks

## National Association of Corrosion Engineers (NACE)/ International Standard Organization (ISO)

MR 0175 / ISO 15156	Petroleum and Natural Gas Industries – Material for Use in H2S-Containing Environments in Oil & Gas Production
MR 0103	Materials resistant to Sulfide Stress Cracking in Corrosive Petroleum Refining Environments
TM 0177	Laboratory Testing of Metals for Resistance to Sulphide Stress Cracking and Stress Corrosion in H2S Environments
TM 0284	Evaluation of Pipeline and Pressure Vessel Steels for Resistance to Hydrogen-Induced Cracking





## عمومی و مشترک

شماره پیمان: ۱۸۴ – ۷۷۳ – ۵۳۰

MECHANICAL DESIGN CRITERIA							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GNRAL	PEDCO	000	ME	DC	0001	D04
							•

شماره صفحه: ۱۰ از ۲۰

- American Society of Testing and Materials (ASTM)
- American Welding Society (AWS)

D 1.1 Structural Steel Welding Code

- American Institute of Steel Construction (AISC)
- American Society of Civil Engineers (ASCE 7-10)
- Welding Research Council (WRC)

107 Local Stresses in Spherical & Cylindrical Shells

Due to External Loadings

297 Local Stresses in Cylindrical Shells Due to

External Loadings on Nozzles - Supplement to

WRC Bulletin No. 107

#### • International Standard Organization (ISO)

10440-2	Packaged Air Compressors (Oil-free)
1328-1	Cylindrical Gears – ISO System of Accuracy – Part 1: Definitions and Allowable Valves of Deviations Relevant to Corresponding Flanks of Gear Teeth
1461	Hot-dip Galvanized Coating on Fabrication Iron and Steel Articles Specification and Test Methods
5199	Technical Specification for Centrifugal pumps – Class II
9001-2008	Quality Systems- Requirements
15608	Welding- Guidelines for a Metallic Materials Grouping System
ISO 1940-1/2	Mechanical Vibration - Balance Quality Requirements of Rigid
	requirements of regio
ISO 10440-2	Petroleum and Natural Gas Industries – Rotary- Type Positive-Displacement Compressors – Part 2: Packaged Air Compressors (Oil-Free)
ISO 10440-2 ISO 1217	Petroleum and Natural Gas Industries – Rotary- Type Positive-Displacement Compressors – Part
	Petroleum and Natural Gas Industries – Rotary- Type Positive-Displacement Compressors – Part 2: Packaged Air Compressors (Oil-Free)
ISO 1217	Petroleum and Natural Gas Industries – Rotary- Type Positive-Displacement Compressors – Part 2: Packaged Air Compressors (Oil-Free) Displacement Compressors – Acceptance Tests





## عمومی و مشترک

شماره پیمان: ۱۸۴ – ۱۷۳ – ۵۳۰

MECHANICAL DESIGN CRITERIA							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GNRAL	PEDCO	000	ME	DC	0001	D04

شماره صفحه: ۱۱ از ۲۰

#### Non-Rotating Parts

#### British Standards Institution (BSI)

466	Specification for Power Driven Overhead Traveling Cranes for General Use
477	Inspection, Access and Entry Openings for Pressure Vessels
2573 Parts 1 & 2	Rules for the Design of Cranes – Specification for Classification, Stress Calculation & Design of Structures/Mechanism
2594	Carbon Steel Welded Horizontal Cylindrical Tanks
4592	Specification for Open Bar Grating
5276-2	Pressure Vessel Details (Dimensions). Specification for Saddle Supports for Horizontal Cylindrical Pressure Vessels
5304	Safe Use of Machinery
5514	Reciprocating Internal Combustion engines: Performance
6399-2	Loading for Buildings. Code of Practice for Wind Loads
EN 10204	Metallic Products. Types of Inspection Documents
EN 13184	Non-Destructive Testing. Leak Testing. Pressure Change Method
EN 13185	Non-Destructive Testing. Leak Testing. Tracer Gas Method
5500	Specification for Unfired Fusion welded Pressure

#### National Fire Protection Association (NFPA)

20 Centrifugal fire Pumps

#### AWWA American Water Works Association

D 100 Welded Steel Tanks for Water Storage

Vessels

#### • International Electrotechnical Commission (IEC)

79 Electrical Apparatus for Explosive Gas

Atmospheres

Degree of Protection Provided by Enclosures

#### NEMA SM 23 Nozzle Loads

HI Hydraulic Institute

PD





## عمومی و مشترک

شماره پیمان: ۱۸۴ – ۰۷۳ – ۰۵۳

MECHANICAL DESIGN CRITERIA							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GNRAL	PEDCO	000	ME	DC	0001	D04

شماره صفحه: ۱۲ از ۲۰

- DIN Institute for Normung Deutsches
- EEMUA 140 Noise Procedure Specification
- Environmental Codes, Standards & Regulations
- EFRC Guide Lines

#### 3.3 THE PROJECT DOCUMENTS

•	BK-GNRAL-PEDCO-000-PR-DB-0001	Process Basis of Design
•	BK-GNRAL-PEDCO-000-PR-DC-0001	Process Design Criteria
•	BK-GNRAL-PEDCO-000-ST-DC-0001	Structural Design Criteria
•	BK-GNRAL-PEDCO-000-CV-DC-0001	Civil Design Criteria
•	BK-GNRAL-PEDCO-000-ST-DC-0001	Design Criteria For Steel Structure
•	BK-GNRAL-PEDCO-000-ME-SP-0001	Specification For Pressure Vessels
•	BK-GNRAL-PEDCO-000-ME-SP-0002	Specification for Atmospheric Above Ground
		Welded Steel Tanks
•	BK-GCS-PEDCO-120-ME-SP-0010	Specification for Large Welded Low Pressure
		Storage Tanks
•	BK-GCS-PEDCO-120-ME-SP-0001	Specification for Air Cooled Heat Exchangers
•	BK-GCS-PEDCO-120-ME-SP-0002	Specification for Reciprocating Compressors
		(API 618)
•	BK-GCS-PEDCO-120-ME-SP-0003	Specification for Centrifugal Pumps For
		Process Services
•	BK-GCS-PEDCO-120-ME-SP-0004	Specification For Centrifugal Pumps For
		General Services
•	BK-GCS-PEDCO-120-ME-SP-0005	Specification For Fire Water Pumps
•	BK-GCS-PEDCO-120-ME-SP-0006	Specification For Air Compressor Package





## عمومی و مشترک

شماره پیمان:	MECHANICAL DESIGN CRITERIA								
· ۵۳ - · ۷۳ — ٩ ١٨۴	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	از ۲۰
	BK	GNRAL	PEDCO	000	ME	DC	0001	D04	

شماره صفحه: ۱۳ از ۲۰

•	BK-GCS-PEDCO-120-ME-SP-0007	Specification For Air Dryer Package
•	BK-GCS-PEDCO-120-ME-SP-0008	Specification For Chemical Injection Package
•	BK-GCS-PEDCO-120-ME-SP-0009	Specification for Overhead Travelling Cranes
•	BK-GCS-PEDCO-120-ME-SP-0011	Specification For Control Volume Pump (API
		675)
•	BK-GCS-PEDCO-120-ME-SP-0012	Specification For Diesel Engine
•	BK-GCS-PEDCO-120-ME-SP-0013	Specification For Flare Package
•	BK-GCS-PEDCO-120-ME-SP-0014	Specification For Nitrogen Package
•	BK-GNRAL-PEDCO-000-PI-SP-0006	Specification For Painting
•	BK-GNRALPEDCO-000-PI-DC-0001	Piping Design Criteria
•	BK-GNRAL-PEDCO-000-PI-SP-0008	Specification For Material Requirements in
		Sour Service
•	BK-GNRAL-PEDCO-000-IN-SP-0001	Specification For Instrumentation
•	BK-GNRAL-PEDCO-000-EL-DC-0001	Electrical System Design Criteria
•	BK-GNRAL-PEDCO-000-EL-SP-0009	Specification For Diesel Generator
•	Piping and Instrumentation Diagrams	

#### 3.4 ENVIRONMENTAL DATA

Refer to "Process Basis of Design; Doc. No. BK-GNRAL-PEDCO-000-PR-DB-0001".

#### 4.0 ORDER OF PRECEDENCE

In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.

#### 5.0 GENERAL CRITERIA

The following general principles and objectives shall be adopted during the selection and design of mechanical equipment:





## عمومی و مشترک

پیمان:	شماره
• ۵۳ - • ۷۳ - ۹ ۱۸۴	

MECHANICAL DESIGN CRITERIA									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	GNRAL	PEDCO	000	ME	DC	0001	D04		

شماره صفحه: ۱۶ از ۲۰

#### 5.1 EMISSION LIMITS

Emission levels for the design and operation of equipment used on the Project must be established on the basis of Iranian legislation and regulations, as defined by the Environmental Protection Agency of Iran and specified in IPS-E-SF-860, Air Pollution Control.

#### 5.2 DESIGN LIFE

Equipment and its auxiliaries shall be conceived, configured, designed, and manufactured to achieve a minimum design life of 20 years.

#### **5.3 PERFORMANCE**

Equipment shall be designed and selected so as to meet the specified performance requirements, including any specified design margins, and to function safely and satisfactorily under all conditions of operation. Performance guarantees shall be provided by the equipment supplier where required.

#### 5.4 FIT FOR PURPOSE

Equipment shall be fit for purpose, designed and manufactured so as to be a cost-effective solution that meets the specified requirements.

#### 5.5 CONSTRUCTABILITY

Equipment shall be designed so as to enable safe and easy installation. Equipment shall be supplied with any special tools that are required for installation.

#### 5.6 OPERABILITY

Equipment shall be designed ergonomically, so as to be simple and safe to operate. All local instrumentation, controls and associate equipment required for full operation shall be provided. Equipment shall be supplied with any special tools that are required for operation.

#### 5.7 MAINTAINABILITY

Equipment shall be designed so as to minimize routine maintenance requirements. Where maintenance activities are required, equipment design and layout shall permit safe, unobstructed and easy access. Equipment shall be supplied with any special tools that are required for maintenance activities.

#### 5.8 RELIABILITY AND AVAILABILITY

Equipment design and selection shall aim to maximize reliability and availability (and to achieve any specified availability targets).



## عمومی و مشترک



پیمان:	شماره

- ۵۳ –	۰۷۳ –	9114
		, .,

MECHANICAL DESIGN CRITERIA									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	GNRAL	PEDCO	000	ME	DC	0001	D04		

شماره صفحه: ۱۵ از ۲۰

#### 5.9 AREA CLASSIFICATION

All equipment shall be designed to suit electrical hazardous area classification as determined during the basic engineering design phase layout.

#### 5.10 UTILITIES

During the selection and design of equipment, consideration shall be given to the availability of utilities. Chemicals and lubricants requirements to be advised by equipment VENDOR.

#### **5.11 LOCAL STATUTORY REQUIREMENTS**

Any applicable local statutory rules and regulations concerning the design, fabrication, assembly, inspection and/or testing of mechanical equipment shall be adhered to.

#### **5.12 EQUIPMENT STANDARDIZATION**

Effort shall be made to standardize the spares stocking by minimizing the variety of makes and types of driven equipment, drivers and auxiliary equipment and systems. This standardization shall be applied so far as if does not interfere with the selection of an optimal solution for the specified operating conditions.

#### 5.13 EQUIPMENT PACKAGING

In order to have single source responsibility for the functioning of each complete machine train and equipment package, each shall be supplied as a packaged unit to the maximum extent possible. Whenever practical, both the main and auxiliary equipment in each package shall be mounted and delivered on a common skid/baseplate to the maximum possible extent, for ease of handling and to minimize site installation, hook-up and commissioning. Each package skid shall include all interconnecting piping, valves pipe supports, cables and cable trays, with flanged piping connections and junction boxes located at the skid edge.

#### **5.14 MATERIALS OF CONSTRUCTION**

Materials of construction shall be shown on the equipment data sheets.

#### 5.15 DISCIPLINE INTERFACE DOCUMENTS

The following documents are required for interfacing with other engineering disciplines (as may be applicable to specific mechanical equipment items):

- Process flow diagrams
- · Piping and instrument diagrams
- Process data sheets
- Motor data sheets
- Instrument data sheets
- Electrical layout/location drawings



## المن تبدية وارات HIRGAN ENERGY

## عمومی و مشترک

	پیمان:	شماره
- ۵۳ –	•٧٣ — 911	:

MECHANICAL DESIGN CRITERIA									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	GNRAL	PEDCO	000	ME	DC	0001	D04		
								_	

شماره صفحه: ۱٦ از ۲۰

- Electrical area classification drawings
- Piping material specifications
- Piping layout/location drawings
- Civil/structural drawings
- Job specifications for packaged units by other disciplines
- Material selection diagrams

#### **5.16 SAFETY MEASURES**

In addition to the above, safety standards and features that are inherent in the specific mechanical equipment design codes, standards and regulations are also applicable.

Safety features to be incorporated into the design include, but are not limited to the following:

- Ladders and platforms for equipment:
  - Ladder cages
  - o Safety chains across platform accesses
  - o Step-off platforms, where necessary
  - o Platform grating
  - o Toe plates.
  - Hand rails
- Enclosed guards over rotating components (e.g., couplings and V-belts).
- Protection of personnel from hot surfaces through the use of thermal insulation or expanded metal covers and guards.

#### 5.17 EQUIPMENT FABRICATION

Equipment design shall be based on maximizing shop fabrication and assembly where practical.

All external surfaces for shop fabricated equipment shall be painted in VENDOR's shop.

#### **5.18 TRANSPORTATION LIMITATIONS**

Equipment packaging, preparation for shipment and delivery shall be in accordance with the project Packing, Marking, Transportation Procedure Doc. No. "BK-GNRAL-PEDCO-000-QC-PR-0045".



## عمومي و مشترك



	پیمان:	شماره
. ^~ ~ _	_ 4114	

MECHANICAL DESIGN CRITERIA									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه		
BK	GNRAL	PEDCO	000	ME	DC	0001	D04		

شماره صفحه: ۱۷ از ۲۰

#### 5.19 VENDOR AND MANUFACTURER DATA & RESPONSIBILITY

- 5.19.1 The equipment shall be performance, mechanical, electrical and instrumentation guaranteed by vendor/manufacturer.
- 5.19.2 The vendors/manufacturers shall submit the equipment itp (inspection & test plan), spare part list with their technical offers. All of the tests & inspections shall be carried out after client approval.
- 5.19.3 The vendors/manufacturers shall submit the filled data sheets of the equipment which are prepared in detail design engineering phase.
- 5.19.4 The vendors/manufacturers to prepare the required items of the equipment according to NISOC vendor list (latest edition).
- 5.19.5 The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/packages at site.

#### 6.0 EQUIPMENT DESIGN CRITERIA

The design basis for the following equipment shall be as specified below:

- Pressure vessels
- Storage Tanks
- Air Cooled Heat Exchangers
- Gas Dehydration Package
- Instrument and Plant Air/Nitrogen Generation Package
- Rotating Equipment
- Packaged Equipment and Miscellaneous Items.

#### 6.1 PRESSURE VESSELS

Design and fabrication of pressure vessels shall be in accordance with "Specification for Pressure Vessels, No. BK-GNRAL-PEDCO-000-ME-SP-0001" and "Iranian Petroleum Standard No. IPS-G-ME-150(1)".

Materials used for pressure components of pressure vessels shall conform to ASME, Section II (applicable parts).

Non-destructive examination for pressure vessels shall conform to ASME, Section V. Welding for pressure vessels shall conform to the requirement of ASME, Section IX.

The used material for construction of pressure vessels shall be noted in the relevant data sheets.



## عمومی و مشترک



اره پیم <b>ا</b> ن:	شما
---------------------	-----

.04 - .74 - 9176

MECHANICAL DESIGN CRITERIA							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GNRAL	PEDCO	000	ME	DC	0001	D04

شماره صفحه: ۱۸ از ۲۰

#### 6.2 STORAGE TANKS

Design and fabrication of storage tanks shall be in accordance with "Specification for Atmospheric Above Ground Welded Steel Tanks, No. BK-GNRAL-PEDCO-000-ME-SP-0002" as well as "Specification for Large Welded Low Pressure Storage Tanks, No. BK-GCS-PEDCO-120-ME-SP-0010" and "Iranian Petroleum Standard No. IPS-G-ME-100 (1) for Atmospheric Above Ground Welded Steel Tanks for Oil Storage" and "Iranian Petroleum Standard No. IPS-G-ME-110 (1) for Large Welded Low Pressure Storage Tanks".

Tanks which exceed transportation limitations shall be field fabricated. All plates shall be cut, formed and nozzles welded in shop or factory prior to shipping field fabricated tanks. Smaller tanks shall be shop fabricated.

The used material for construction of storage tanks shall be noted in the relevant data sheets.

#### 6.3 AIR COOLED HEAT EXCHANGERS

Design and fabrication of air cooled heat exchangers shall be in accordance with "Specification for Air Cooled Heat Exchangers, No. BK-GCS-PEDCO-120-ME-SP-0001" and "Iranian Petroleum Standard No. IPS- G-ME-245(1)"

#### 6.4 GAS DEHYDRATION PACKAGE

Dehydration packages shall be in accordance with "Duty Specification for Gas Dehydration Package No. BK-GCS-PEDCO-120-PR-SP-0001" or VENDOR's standard, whichever is more stringent.

#### 6.5 AIR COMPRESSOR PACKAGE

Design and fabrication of air compressor package shall be in accordance with "Specification for Air Compressor Package, No. BK-GCS-PEDCO-120-ME-SP-0006" or VENDOR's standard, whichever is more stringent.

#### 6.6 ROTATING EQUIPMENT

#### 6.6.1 General

Rotating equipment drivers shall be electric motors unless otherwise specified on equipment data sheets.

#### 6.6.2 Centrifugal Pumps

For general service, pumps shall be provided in accordance with "Specification for Centrifugal Pumps for General Services, No. BK-GCS-PEDCO-120-ME-SP-0004".



## عمومی و مشترک



	شماره پیمان:
۰۵۳ – ۲۵۰ -	- 9114

MECHANICAL DESIGN CRITERIA							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GNRAL	PEDCO	000	ME	DC	0001	D04

شماره صفحه: ۱۹ از ۲۰

For process service applications, pumps shall conform to "Specification for Centrifugal Pumps For Process Services (API 610), No. BK-GCS-PEDCO-120-ME-SP-0003". For high-head applications, multistage ring section pumps shall be used. In all services (even water) BB4 type pumps are not allowed to use.

The metallurgy of pump components shall be suitable for the intended application. For sour service applications, materials meeting the NACE MR0175/ISO 16156 standard requirements shall be used.

Pumps and motors with speed increasing gears (if required) shall be mounted on a common baseplate.

Spare pumps in critical services shall be equipped with automatic start facilities.

All pumps shall be directly coupled to their drivers. All pumps and their drive train shall be mounted on common bases of rigid construction.

#### 6.6.3 Reciprocating and Rotary Screw Compressors

Rotary Screw-type compressors may be considered for applications involving relatively low flows and differential pressures. CLIENT approval is required for the application of this compressor type. The design and manufacture of reciprocating compressors shall be in accordance with the "Specification for Reciprocating Compressor (API 618), No. BK-GCS-PEDCO-120-ME-SP-002 ".

#### 6.6.4 Packaged Equipment and Miscellaneous Items

Packaged units shall be VENDOR's standard process design and in compliance with the data sheets for the packaged units. Mechanical design and fabrication for the equipment involved shall be as per the corresponding specifications for those types of equipment.

Miscellaneous items (such as flare packages, chemical injection systems, utility units, diesel engines, handling equipment) shall be VENDOR's standard design and in compliance with the corresponding specifications & data sheets.

#### 7.0 MISCELLANEOUS

#### 7.1 PAINTING

Above ground facilities (e.g., equipment, piping, and structural steel) shall be protected by using external paint for appearance and corrosion prevention in accordance with the project "Specification For Painting, No BK-GNRAL-PEDCO-000-PI-SP-0006".





## عمومي و مشترك

شماره پیمان: ۹۱۸۴ – ۰۷۳ – ۰۵۳

MECHANICAL DESIGN CRITERIA							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GNRAL	PEDCO	000	ME	DC	0001	D04

شماره صفحه: ۲۰ از ۲۰

#### 7.2 COATINGS AND LININGS

Internal coatings or linings for mechanical equipment shall be as specified on the equipment data sheets.

#### 7.3 INSULATION

Above ground equipment and piping shall be insulated for the conservation of heat and protection of personnel as indicated on the line list and/or the equipment data sheets or P&IDs.

#### 7.4 FIELD ASSEMBLY, FABRICATION AND INSTALLATION

Items that require field assembly and/or fabrication shall be identified on the equipment data sheets.