

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">SPECIFICATION FOR POWER & CONTROL CABLES</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D03</td><td>0014</td><td>SP</td><td>EL</td><td>000</td><td>PEDCO</td><td>GNRAL</td><td>BK</td></tr></table>	SPECIFICATION FOR POWER & CONTROL CABLES								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D03	0014	SP	EL	000	PEDCO	GNRAL	BK	شماره صفحه : ۲ از ۶
SPECIFICATION FOR POWER & CONTROL CABLES																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D03	0014	SP	EL	000	PEDCO	GNRAL	BK																			

REVISION RECORD SHEET



PAGE	D00	D01	D02	D03	D04
1	X	X	X	X	
2	X	X	X	X	
3	X		X		
4	X		X		
5	X		X		
6	X	X	X		
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض و ابنیه تحت الارض</p> <p>عمومی و مشترک</p>																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">SPECIFICATION FOR POWER & CONTROL CABLES</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D03</td><td>0014</td><td>SP</td><td>EL</td><td>000</td><td>PEDCO</td><td>GNRAL</td><td>BK</td></tr></table>	SPECIFICATION FOR POWER & CONTROL CABLES								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D03	0014	SP	EL	000	PEDCO	GNRAL	BK	شماره صفحه : ۳ از ۶
SPECIFICATION FOR POWER & CONTROL CABLES																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D03	0014	SP	EL	000	PEDCO	GNRAL	BK																			

CONTENTS

1.0	INTRODUCTION	4
2.0	SCOPE	5
3.0	ENVIRONMENTAL DATA	5
4.0	GUIDANCE FOR USE OF THIS DOCUMENT.....	5
5.0	ORDER OF PRECEDENCE	5
6.0	MODIFICATION TO IPS	6
6.1	COLOUR INDICATION FOR PHASES	6
6.2	CABLES INSULATION	6
6.3	OUTER SHEATH	6

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض و ابنیه تحت الارض</p> <p>عمومی و مشترک</p>								
شماره پیمان:	SPECIFICATION FOR POWER & CONTROL CABLES							شماره صفحه : ۴ از ۶	
۰۵۳ - ۰۷۳ - ۹۱۸۴	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GNRAL	PEDCO	000	EL	SP	0014		D03

1.0 INTRODUCTION



Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields CLIENT (NISOC)
PROJECT:	Binak Oilfield Development – General Facilities
EPD/EPC CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of : Hirgan Energy – Design & Inspection(D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC CONTRACTOR(GC) and approved by COMPANY (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by COMPANY rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR.
MAY:	Is used where a provision is completely discretionary.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	SPECIFICATION FOR POWER & CONTROL CABLES							شماره صفحه : ۵ از ۶	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GNRAL	PEDCO	000	EL	SP	0014		D03

2.0 SCOPE

This document gives amendment and supplement to IPS-M-EL-271 (2) "Material & Equipment for Low Voltage Cables & Wire" & IPS-M-EL-272(2) "Material & Equipment for Medium & High Voltage Power Cables" used in "Binak Oilfield Development".

3.0 ENVIRONMENTAL DATA

The installation site is in south of Iran with corrosive, hot and high humid atmosphere. Therefore, all equipment shall be designed to fully comply with the performance specification in the environmental conditions. For more information refer to "Process Basis Design; section 11".

4.0 GUIDANCE FOR USE OF THIS DOCUMENT

The amendments/supplement to the related IPS Standard(s) given in this document are directly related to the equivalent sections or clauses in the IPS Standard(s). For clarity, the section and paragraph numbering of the IPS Standard(s) has been used as long as possible. Where clauses in IPS are referenced within this document, it shall mean those clauses are amended by this document. Clauses in "IPS" that are not amended by this document shall remain valid as written.

For ease of reference, the clause or section numbering of the related IPS Standard(s) has been used throughout this specification. For the purpose of this specification, the following definitions shall hold:

Sub. (Substitution): The IPS Std. clause is deleted and replaced by a new clause.

Del. (Deletion): The IPS Std. clause is deleted without any replacement.


Add. (Addition): A new clause with a new number is added.

Mod. (Modification): Part of the IPS Std. clause is modified, and/or a new description and/or condition are added to that Clause.

5.0 ORDER OF PRECEDENCE

In case of conflict between requirements specified herein & the requirements of any other referenced document, the most approved stringent requirements of below listed items shall be considered based on the approval given by the owner's representative:

- Purchase order
- Material Requisition

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک																									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	<table><tr><th colspan="8">SPECIFICATION FOR POWER & CONTROL CABLES</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>D03</td><td>0014</td><td>SP</td><td>EL</td><td>000</td><td>PEDCO</td><td>GNRAL</td><td>BK</td></tr></table>	SPECIFICATION FOR POWER & CONTROL CABLES								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	D03	0014	SP	EL	000	PEDCO	GNRAL	BK	شماره صفحه : ۶ از ۶
SPECIFICATION FOR POWER & CONTROL CABLES																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
D03	0014	SP	EL	000	PEDCO	GNRAL	BK																			

- MTO & Data Sheet
- This Specification
- Drawing & Other Specification
- Reference Project Specification
- Iranian Petroleum Standard (IPS)
- Reference international Code & Standards

When the term “Authorized”, Authorization”, “Approval”, or “Approved” are used in this specification, it shall mean authorization or Approval from OWNER.

In case of any conflict between the project documents, the most stringent one shall be considered.

6.0 MODIFICATION TO IPS

6.1 Colour Indication for Phases

AC System	Dc System	Grounding
R-Phase: Red	P: Red	G: Green/Yellow
S-Phase: Yellow	N: Black	
T-Phase: Blue		
N: Black		

6.2 Cables Insulation

- LV Cables: XLPE insulation and PVC jacketed
- MV Cables: XLPE insulation and PVC jacketed
- For lighting equipment's located in hazardous area Fire Resistance cable shall be used.

6.3 Outer Sheath

- The colour of the outer sheath of all medium voltage & high power cables shall be red.
- The colour of the outer sheath of all low voltage power & control cables shall be black.
- The insulation colour of earthing cables shall be green/yellow.