

## احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

· 27 - · 77 - 9114

	CALCULATION NOTE FOR CAPACITOR BANKS							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	PEDCO	120	EL	CN	0011	D03	

شماره صفحه : ۱ از ۸

# طرح نگهداشت و افزایش تولید ۲۷ مخزن

## CALCULATION NOTE FOR CAPACITOR BANKS

نگهداشت و افزایش تولید میدان نفتی بینک

A						
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	Client Approval
D00	Nov. 2021	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	
D01	Feb. 2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D02	Jul. 2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D03	Aug. 2023	AFD	H.Shakiba	M.Fakharian	A.M.Mohseni	

Class:2 Client Doc. Number: F0Z-709017

#### Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for Client Review

AB-A: As-Built -Approved



## احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:
--------------

۰۵۳ - ۰۷۳ - ۹۱۸۴

CALCULATION NOTE FOR CAPACITOR BANKS							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	CN	0011	D03


شماره صفحه: ۲ از ۸

# REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	Х	Χ	Х	Х	
2	X	Χ	Χ	Χ	
3	Х				
4	X				
5	Х				
6	Х	Χ	Χ		
7	Х	Χ	Χ	Х	
8				Х	
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33	1				
34					
35					
36	1				
37	<u> </u>				
38	-				
39	1				
40	<u> </u>				
41	-				
42	<u> </u>				
43	<u> </u>				
44					
45	1				
46					
47					
48	1				
49					

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85			ļ		
86					
87					
88					
89					
90					
91			ļ		ļ
92			ļ		<u> </u>
93			ļ		ļ
94			ļ		ļ
95			ļ		<u> </u>
96			ļ		
97			ļ		ļ
98			ļ		<u> </u>
99			ļ		
100					1







شماره پیمان:

• 24 - • 44 - • 47 - 47 - 47

CALCULATION NOTE FOR CAPACITOR BANKS							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	CN	0011	D03

شماره صفحه: ۳ از ۸

## **CONTENTS**

1.0	INTRODUCTION	4
2.0	SCOPE	5
3.0	NORMATIVE REFERENCES	5
3.1	Local Codes & Standards	5
3.2		5
3.3	ENVIRONMENTAL DATA	5
3.4	Order of Precedence	5
4.0	CALCULATION	6
4.1	CALCULATION FOR LV CAPACITOR BANK	
4.2	CALCULATION FOR MV CAPACITOR BANK	6



## احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



·
شماره پیمان:

· 24 - · 74 - 9114

CALCULATION NOTE FOR CAPACITOR BANKS							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	CN	0011	D03

شماره صفحه: ۴ از ۸

#### 1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

#### **GENERAL DEFINITION**

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields CLIENT (NISOC)

PROJECT: Binak Oilfield Development – Surface Fcilities; New

Gas Compressor Station

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy – Design & Inspection

(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.



## احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

. 24 - . 12 - 417

	CALC	CULATION N	OTE FOR	CAPA	CITOR BANK	<b>KS</b>	
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	CN	0011	D03

شماره صفحه: ۵ از ۸

#### 2.0 SCOPE

This document covers minimum necessary requirements for the design, selection, manufacture, inspection, testing and delivery of Capacitor bank.

It shall be used in conjunction with data/requisition sheets for present document subject.

#### 3.0 NORMATIVE REFERENCES

#### 3.1 Local Codes & Standards

• IPS-E-EL-100 (1) Engineering Standard for Electrical System Design

• IPS-M-EL-181 (2) Material & Equipment Standard for Power Factor Improvement Capacitor

#### 3.2 The Project Documents

#### 3.3 Environmental Data

Refer to "Process Basis of Design; Doc. No. BK-GNRAL-PEDCO-000-PR-DB-0001"

#### 3.4 Order of Precedence

In case of conflict between requirements specified herein & the requirements of any other referenced document, the most approved stringent requirements of below listed items shall be considered based on the approval given by the owner's representative:

- Purchase order
- Material Requisition
- MTO & Data Sheet
- This Specification
- Drawing & Other Specification
- Reference Project Specification
- Iranian Petroleum Standard (IPS)
- Reference international Code & Standards

When the term "Authorized", Authorization", "Approval", or "Approved" are used in this specification, it shall mean authorization or Approval from OWNER.

In case of any conflict between the project documents, the most stringent one shall be considered.



## احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



ن:	ييما	ار ه	شما

CALCULATION NOTE FOR CAPACITOR BANKS							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	CN	0011	D03

شماره صفحه: ۶ از ۸

#### 4.0 CALCULATION

#### 4.1 Calculation for LV Capacitor Bank

According to load list (BK-GCS-PEDCO-120-EL-LI-0001-D04):

Total Active Peak Load Power for LV switchgear is = 242.97+217.93+343.49=804.39 Kw

Total Reactive Peak Load Power for LV switchgear is = 137.83+118.78+213.61=470.23 Kvar

Therefore:

Tan 
$$(\Psi_1) = \frac{Q}{P} = \frac{470.23}{804.39} = 0.58$$
 while Cos  $(\Psi_1) = 0.863$ 

According to IPS-M-EL-181 power factor shall improve to 0.95

So 
$$Cos(\Psi_2) = 0.95$$
 then  $Tan(\Psi_2) = 0.33$ 

$$Q = P \times (Tan(\Psi_1) - Tan(\Psi_2))$$
 formula(1)

According to formula (1) we calculate:

$$Q_L = 804.39 \times (0.58 - 0.33) \sim 201.09 \, Kvar$$

According to basic document a coefficient 0.6 is required. So the capacitor will be 201.09x0.6 =120.654

According to above calculation, We choose two sets of 120 KVAR capacitor bank.

Also current of capacitor bank will be calculated from following formula:

$$I = Q/(\sqrt{3} \times 0.4)$$
 formula (2)

According to formula (2):

$$I = \frac{120}{\sqrt{3} \times 0.4} \cong 173.20 A$$

We consider upstream breaker bigger that 1.5 I:

$$I_b = 1.5 \times 173.20 = 259.8$$

Then we select 315A MCCB circuit breaker.

#### 4.2 Calculation for MV Capacitor Bank

#### **Gas Compressor Power Factor Compensation**

According to basic design, each gas compressor shall have separate capacitor bank. Based on Load List, (BK-GCS-PEDCO-120-EL-LI-0001-D04):

Total Active Peak Load Power for C-2101A is 981.05 Kw.

Total Reactive Peak Load Power for C-2101A is 812.928 Kvar



## احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:
--------------

• ۵۳ – • ۷۳ –	٩	١	λ۴
---------------	---	---	----

CALCULATION NOTE FOR CAPACITOR BANKS								ĺ
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	PEDCO	120	EL	CN	0011	D03	

شماره صفحه: ۷ از ۸

#### Therefore:

Tan 
$$(\Psi_1) = \frac{Q}{P} = \frac{812.928}{981.05} = 0.828$$
 while Cos  $(\Psi_1) = 0.77$ 

According to IPS-M-EL-181 power factor shall improve to 0.95

So 
$$Cos(\Psi_2) = 0.95$$
 then  $Tan(\Psi_2) = 0.33$ 

According to formula (1) we calculate:


$$Q_L = 981.05 \times (0.828 - 0.33) \sim 488.56 = 500 \, Kvar$$

Therefore each capacitor bank shall be 500 KVAR for each Compressor.

According to ABB Manual Handbook (Attachment), Single Power Factor Correction is as follow: Single or individual power factor connection is carried out by connecting a capacitor of the correct value directly to the terminals of the device which absorbs reactive power. This type of power factor correction is advisable in the case of large users with constant load & power factor & long connection times.

Individual PFC is usually applied to motors. The capacitor unit capacitors are connected directly to loads.

The usual connection diagrams are shown in the following figure:



In the case of direct connection (diagrams 1 & 2), there is a risk of that after disconnection of the supply, the motor will continue to rotate (residual kinetic energy) & self-excite with the reactive energy supplied by the capacitor bank, acting as an asynchronous generator. In this case, the voltage is maintained on the load side of switching & control device, with the risk of dangerous overvoltage of up to twice the rated voltage value. Therefore total capacity should not be more





# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



و ماد :	شماره
ىسىن.	سسارت

· 24 - · 74 - 9114

CALCULATION NOTE FOR CAPACITOR BANKS								ĺ
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	PEDCO	120	EL	CN	0011	D03	

شماره صفحه: ۸ از ۸

than reactive power of motors at no load condition, because this may cause over voltages in the system.

However in the case of diagram 3, to avoid the risk detailed above, the normal procedure is to connect the PFC bank to the motor only when it is running & to disconnect it before the disconnection of the motor supply.

As a general rule, for a motor with power P, it is advisable to use a PFC with reactive power Q below 90% of the reactive power absorbed by the no load motor Q, at rated voltage U to avoid a leading power factor.

Considering that under no load condition, the current absorbed  $I_0$  is solely reactive, if the voltage is expressed in volts, it results

$$Q_L = 0.9 \times Q = 0.9 \times \frac{\sqrt{3} \times U \times I_0}{1000} [Kvar]$$
 formula(3)

Generally, no load current of motor is about 30% of full current & accordingly,

$$I_{Full\ Load} = \frac{P}{\sqrt{3} \times V \times Cos(\emptyset) \times \eta} = \frac{981}{\sqrt{3} \times 11 \times 0.77 \times 0.95} = 70.4$$

Based on

$$Q_L = 0.9 \times Q = 0.9 \times \frac{\sqrt{3} \times 11000 \times 0.3 \times 70.4}{1000} = 362 [Kvar]$$

3 Sets of 360KVAR capacitor banks shall be designed for C2101A/B/C.

According to above calculation:

 $Q_1 = 812.9 \text{ Kvar}$ 

 $Q_L = 360 \text{ Kvar}$ 

Therefore  $Q_2 = 812.9 - 360 = 453$  KVAR

After Power Factor Correction of Compressor, the active power is 981 Kw while reactive power is 451 Kvar, then power factor is Cos(Atan (453/981))=0.9

Power factor will improve from 0.77 to 0.9.