

تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:

111P - 77. - 7A.

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۱ از ۱۵

طرح نگهداشت و افزایش تولید ۲۷ مخزن

PMR FOR TRANSMISSION OVER HEAD LINE - BK14

نگهداشت و افزایش تولید میدان نفتی بینک

Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	Client Approval
D00	Nov. 2022	IFI	H.Shakiba	M.Fakharian	M.Mehrshad	
D01	Aug. 2023	IFI	H.Shakiba	M.Fakharian	A.M.Mohseni	

Class: 3 Client Doc. Number: F0Z-708255

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for Client Review
AB-A: As-Built –Approved



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری **BK14**



4	
_	

	ماره پیمان:
• ۵۳ - • ۷۳ -	- 9114

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۲ از ۱۵

REVISION RECORD SHEET

AGE	D00	D01	D02	D03	D04
1	Χ	Χ			
2	Х	Х			
3	Х				
4	Χ				
5	Χ				
6	Χ				
7	Χ				
8	Χ				
9	Χ				
10	Χ	Х			
11	Х				
12	Х				
13	Х	Χ			
14	Х				
15	Х				
16					
17					
18					1
19					1
20					1
21					
22					
23					<u> </u>
24					
25					
26					
27					
28					-
			1		1
29					<u> </u>
30					ļ
31					
32					
33					
34					
35					
36					
37					
38					
39					1
40					1
41					
42					<u> </u>
43					
44					
45					-
				-	-
46					
47					1
48					1
49					
50					



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:

1118 - 77. - 7A.

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۳ از ۱۵

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	REFERENCE / ATTACHED DOCUMENTS	5
4.0	SUBJECT OF THE SUPPLY	6
5.0	LIMITS OF SUPPLY	6
5.1	SCOPE OF SUPPLY	6
5.1.1	MAIN DESCRIPTION	6
5.1.2	Spare parts	7
5.1.3	OTHER ITEMS	7
5.2	EXCLUSIONS	7
5.3	BATTERY LIMITS	7
6.0	INSPECTION AND TESTS	7
7.0	VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE	8
8.0	UNIT RESPONSIBILITY	8
9.0	GUARANTEE AND WARRANTY	8
10.0	DEVIATION	9
11.0	PRICE BREAKDOWN	
ATTAC	CHMENT 1	10
11.1	,	
ATTAC	CHMENT 2	11
11.2	VENDOR DOCUMENTS MIN. REQUIREMENT	11
ATTAC	CHMENT 3	14
11.3	,	
ATTAC	CHMENT 4	14
11.4	ALTERNATIVES TO JOB SPECIFICATION	14



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:

· 24 - · 74 - 9114

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۴ از ۱۵

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, required modifications on BK14 work over well (with electric power supply) shall be done.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development -Modifications on BK14

Work over Well & Electrification Facilities

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy - Design &

Inspection(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:

. 24 - . 14 - 9114

PMR FOR TRANSMISSION OVER HEAD LINE - BK14							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	BK14	PEDCO	110	EL	MR	0013	D01

شماره صفحه: ۵ از ۱۵

2.0 GENERAL

- This document presents the item material requisitions for Contractor's use as appropriate.
- This material requisition covers the requirements for the design, manufacturing, testing and supply of 33kV Transmission Over Head Line to BK-14 as listed below. All equipment/devices/items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.
- The vendor's supply shall include:

No.	Item	Description	Total QTY.
1	Electrification to BK-14 Via 33kV Over Head Line Transmission	 33 KV Transmission Over Head Line for BK-14 33 KV Substation Including Gantry in T-off for BK-14/GOREH/BINAK & Gantry in Well BK-14 with all Necessary Equipment. 	1

3.0 REFERENCE / ATTACHED DOCUMENTS

- a. Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- **b.** All codes and standards which have been referenced in above mentioned specs shall be considered.
- c. In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.

d. Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.

If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, the supplier shall be considered to be in full compliance with the relevant document.



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



پیمان:	شماره
--------	-------

- ۵۳ –	۰ ۲۳ –	9114

	PMR FOR TRANSMISSION OVER HEAD LINE - BK14							
پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۶ از ۱۵

The supplier may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY

The supplier shall supply Requirement of 33 KV Transmission Over Head Line for Electrification of BK-14. The scope of supply is detailed at para. 5. The supplier shall include in the supply, all other equipment/devices/items not listed in the following, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.

5.0 LIMITS OF SUPPLY

5.1 SCOPE OF SUPPLY



5.1.1 MAIN DESCRIPTION

33 KV Transmission Over Head Line Acc. to "MTO for Transmission Over Head Line - BK14", "BK-BK14-PEDCO-110-EL-MT-0001".

The supplier shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.
- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.
- Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:
 - QA/QC organization chart and procedures that shall be submitted for approval.
 - Plan for HOLD points in the production process proposed to PURCHASER for witness or approval particular activities.



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



ن:	پيما	شماره	٥
----	------	-------	---

• 24 - • 44 - 914 -

PMR FOR TRANSMISSION OVER HEAD LINE - BK14							
پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	BK14	PEDCO	110	EL	MR	0013	D01

شماره صفحه: ۷ از ۱۵

- Production schedule indicating main quality manufacturing processes, inspection and tests.
- Qualification of all personnel performing tests to be reviewed by the inspector
- Supplier shall also provide the description of the following quality activities:
 - Sub suppliers products quality
 - Quality check and identification of the materials and equipment entering in their manufacturing shop.
- Calibration of test instruments and equipment
- Provide detailed specifications and data sheets.

5.1.2 SPARE PARTS

Following items shall be considered (supplied) and included in the bid documentation:

- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&D-QC-SP-1).
- Capital spare parts (as option / if any)

5.1.3 OTHER ITEMS

Special tools required for installation and maintenance

5.2 EXCLUSIONS

The following items are excluded by the supplier scope of supply and will be provided by purchaser:

Not Applicable.

5.3 BATTERY LIMITS

The battery limits are summarized as follows:

Not Applicable.

6.0 INSPECTION AND TESTS

The equipment shall be inspected and tested in accordance with the quality control plan issued by the supplier and approved by the PURCHASER before the award of the order. The QC plan shall



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



پیمان:	شماره

۰۵۳	- * V\mathcal{V}\mathcal{U} =	- 9114

	PMR FOR TRANSMISSION OVER HEAD LINE - BK14							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۸ از ۱۵

at least be according to the PROJECT ITP PROCEDURE (Doc. No. ICE-EID-MI-SP01-Rev01 & ICE-EID-MI-SP02-Rev01) and data sheets (if any).

The supplier shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE

- Vendor document shall be according to attachment 2 of this document.
- All documents, preliminary or final, are to be stamped and signed by the supplier.
- Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.
- PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.
- All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 "GENERAL DEFINITION"

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, testing, final check-out and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.

Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-suppliers.

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.

The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/packages at site

VENDOR shall guarantee the performance of supplied items (if any).

VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:	,
--------------	---

. 22 - . 12 - . 174

	PMR FOR TRANSMISSION OVER HEAD LINE - BK14							
پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۹ از ۱۵

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period.

Vendor shall ensure a correct and safe operation of the unit, providing all safety protection.

Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION

VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.

VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for PURCHASER's approval.

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (END-QC-SP-1)
- 3) 2 years operational spare parts (END-QC-SP-1)
- 4) Packing & transportation
- 5) Other fee (if any)



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:

 \cdot Δ T - \cdot \cdot \cdot \cdot \cdot \cdot 1 λ F

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۱۰ از ۱۵

ATTACHMENT 1



11.1 LIST OF REFERENCE / APPLICABLE DOCUMENTS

No.	Document No.	Document Title		
Proc	ess			
1	BK-GNRAL-PEDCO-000-PR-DB-0001	Process Basis of Design	D08	
Elec	trical			
2	BK-GNRAL-PEDCO-000-EL-SP-0019	Specification for Overhead Transmission Lines	D03	
3	BK-SSGRL-PEDCO-110-EL-DW-0001	Typical Installation Details for Over Head Line Equipment	D03	
4	BK-GNRAL-PEDCO-000-EL-DW-0002	Typical Installation Details & Notes for Earthing and Lightning Protection System	D04	
5	BK-SSGRL-PEDCO-110-EL-DT-0013	Data Sheets for 33 KV Over Head Line Equipment	D04	
6	BK-BK14-PEDCO-110-SU-DW-0001	Over Head Line Plan and Profile - BK14	D04	
7	BK-SSGRL-PEDCO-110-EL-RT-0005	33KV Over Head Line Study Report	D02	
8	BK-SSGRL-PEDCO-110-EL-SL-0001	Overall Single Line Diagram of Well Pads	D03	
9	BK-BK14-PEDCO-110-EL-MT-0001	MTO For Transmission Over Head Line - BK14	D02	
10	BK-SSGRL-PEDCO-110-EL-PY-0001	Earthing Layout For Electrical Tower (Gantry) of Well Pads	D01	
Gene	eral			
11	BK-GNRAL-PEDCO-000-QC-PR-0022	Specification for Final Data Book (FDB) Requirements	D00	
12	BK-GNRAL-PEDCO-000-QC-PR-0045	Packing , Marking , Transportation Procedure	D00	
13	ICE-EID-MI-SP01-Rev01	دستورالعمل بازرسی، خرید و ساخت کالا	-	
14	ICE-EID-MI-SP02-Rev01	سطح بازرسی کالا و تجهیزات	-	
15	E&C-QC-SP-1	دستورالعمل تامین قطعات یدکی راه اندازی و راهبری دو سالانه	1	
16	BK-GNRAL-PEDCO-000-PI-SP-0006	Specification For Painting	D04	
17	BK-GNRAL-HD-000-PM-PR-0003	Document Numbering Procedure	G04	



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:

· 27 - · 77 - 9114

PMR FOR TRANSMISSION OVER HEAD LINE - BK14							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	BK14	PEDCO	110	EL	MR	0013	D01

شماره صفحه: ۱۱ از ۱۵

ATTACHMENT 2

11.2 <u>VENDOR DOCUMENTS MIN. REQUIREMENT</u>

			TIMES	SCHEDULE		
o Z		With Bid	For Review		Fina	Issue
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)
MANA	GEMENT					
001	Vendor Document Index and Schedule (See attachment 2)	4N	6C+E		6C+E	
002	Organization Brief	3N	6C+E			
003	Schedule Level 1, 2, 3 & 4 showing Engineering, Procurement, Fabrication, Inspection, Testing, and Delivery Plan.	4N	6C+E		6C+E	
004	Physically Progress Report (Every 2 Weeks))		6C+E			
005	Project Organization Chart	3N	6C+E			
006	Reference List	3N				
007	Vendor Catalogue	3N				
QUALI	тү					
008	Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO)	4N			6C+E	
009	Preliminary Inspection and Test Plan	4N				
010	Inspection and Test Plan		6C+E		6C+E	
HSE						
011	HSE Procedure		6C+E		6C+E	
ENGIN	EERING					
012	Item List Including Code, Material, Description, Size, QTY, etc.		6C+E		6C+E	
013	Preliminary Packing List		6C+E		6C+E	
014	Packing List		6C+E		6C+E	
015	Catalog for all equipment of 33kV OHL and Substations.		6C+E		6C+E	



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:

 \cdot Δ T - \cdot \vee T - 9 1 λ F

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۱۲ از ۱۵

			TIME SCHEDULE				
9		With Bid	For Review		Fina	Issue	
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)	
016	Technical data sheet & drawing for all equipment of 33kv OHL and substations.		6C+E		6C+E		
017	Vendor final data book for all equipment of 33kv OHL and substations.		6C+E		6C+E		
PROC	UREMENT						
018	List of Sub-Suppliers (table giving: part of equipment, tag no., sub-supplier reference)(5.1.3)	4N			6C+E		
019	Unpriced copy of sub-orders		6C+E				
MANU	FACTURING						
020	All 33 kV Outdoor Substation equipment (main)		6C+E		6C+E		
021	All 33 kV OHL equipment		6C+E		6C+E		
TESTII	NG						
022	Type test certificate for all equipment of 33kV OHL and Substations.		6C+E		6C+E		
023	Routine test report for all equipment of 33kV OHL and Substations.		6C+E		6C+E		
RECO	RDS, REPORTS & CERTIFICATES						
024	Material Conformity Certificate		6C+E		6C+E		
025	Testing Authority Approval Certificate (if any)		6C+E		6C+E		
026	Inspection and Test Reports(if any)		6C+E		6C+E		
027	Non-Conformities Report		6C+E		6C+E		
INSTA	LLATION						
028	Inspection and Test Reports (if any)		6C+E		6C+E		
029	Non-Conformities Report						
030	Final VENDOR QC & Data Books		6C+E		6C+E		
OPER	ATION & MAINTENANCE	1	1		ı		
031	Operating Instructions		6C+E		6C+E		
032	Maintenance Instructions (if required)		6C+E		6C+E		



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



شماره پیمان:

· 24 - · 14 - 4114

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۱۳ از ۱۵

	With Bid		TIME SCHEDULE				
ė.		with bid	For Re	view	Final Issue		
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Type (1)	Calendar days (3)	
033	Commissioning & Start-up Manual		6C+E		6C+E		
034	List of Spare Parts Commissioning & Start-up	4N	6C+E		6C+E		
035	List of Spare Parts 2 Years Operation	4N	6C+E		6C+E		
036	List of Special Tools	4N	6C+E		6C+E		
037	Function Test Procedure		6C+E		6C+E		
OTHER	RS						
038	All others documents (if required) will be listed in the order		6C+E				

NOTES:

- (1) N= Number of document, C=Copy, E=Electronic Copy
- (2) Starting from date of order placement
- (3) Starting from reception of documentation without comments
- (4) First issue of the document is subjected to the release of payment milestone as per purchase order
- (5) Calendar days after reception of drive data
- (6) Prior to testing
- (7) One copy each bid copy
- (8) List of Documents Will be Finalized in Vendor Document index and Schedule



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری **BK14**



ِه پيمان:	شمار
-----------	------

· 24 - · 74 - 9114

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۱۴ از ۱۵

ATTACHMENT 3

Requisition No.:

Description:

11.3 <u>DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION</u>

Equipm	quipment No.:								
Item No.	Description of proposed exception	Recommended revision to job specification	Reason for proposed exception	Effect on base proposal if CONTRACTOR rejects exception					

ATTACHMENT 4

11.4 <u>ALTERNATIVES TO JOB SPECIFICATION</u>

Requisition	No.:

Description:

Equipment No.:

	Job Specification No. & Paragraph No.	Requirements of Job Specification	Description of Proposed Alternative	Reason for Proposed Alternative
--	---------------------------------------	-----------------------------------	---	------------------------------------



تسهیلات برق رسانی و انجام اصلاحات مربوط به چاه تعمیری BK14



ىىمان:	ت ماه م
	- Jum

 $\bullet \Delta \tau - \bullet V \tau - 91 \Lambda \tau$

PMR FOR TRANSMISSION OVER HEAD LINE - BK14								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	BK14	PEDCO	110	EL	MR	0013	D01	

شماره صفحه: ۱۵ از ۱۵