
















[illegible]



THIS DRAWING


[illegible]



NOTES				
1) ALL ELEVATIONS AND COORDINATES ARE IN "m" AND DIMENSIONS ARE IN "mm" UNLESS OTHERWISE NOTED.				
2) ALL DIMENSIONS AND ELEVATIONS SHALL BE CHECKED BY THE CONTRACTOR PRIOR TO CONSTRUCTION.				
3) ACCORDING TO THE SPECIFICATION OF CONCRETE WORKS: "BK-GNRL-PEDCO-000-ST-SP-0001", 28 DAYS CHARACTERISTIC COMPRESSIVE STRENGTH OF MAIN CONCRETE IS 30 MPa				
4) ACCORDING TO THE SPECIFICATION OF CONCRETE WORKS: "BK-GNRL-PEDCO-000-ST-SP-0001", 28 DAYS CHARACTERISTIC COMPRESSIVE STRENGTH OF LEAN CONCRETE IS 15 MPa				
5) REINFORCING BARS SHALL BE S400 ACCORDING TO: ISIRI3132 AND INBC9 WITH MINIMUM TENSILE YIELD STRENGTH 400 N/mm ²				
6) CONCRETE COVER OVER BARS SHALL BE 75mm FOR FOUNDATION AND 50mm FOR BEAMS & COLUMNS.				
7) UNDERGROUND CONCRETE SHALL BE PROTECTED AND COATED ACCORDING TO RELEVANT SPECIFICATION.				
8) CEMENT TYPE 2 SHALL BE USED ACCORDING TO GEOTECHNICAL REPORT SUGGESTION.				
±0.00 = +186.05 MSL				

LEGEND	
F.G.L.	: FINISH GROUND LEVEL
T.O.F.	: TOP OF FOUNDATION
B.O.B.	: BOTTOM OF BASEPLATE
T.O.B.	: TOP OF BEAM
	REINFORCED CONCRETE
	LEAN CONCRETE
	GROUND

REFERENCE DRAWING	DRG. No.
ARCHITECTURAL DRAWING FOR SWITCHGEAR BUILDING OF WELLPADS-BK-14	BK-BK14-PEDCO-110-AR-DW-0002
STRUCTURAL DRAWING FOR SWITCHGEAR BUILDING FOR WELLPADS-BK-14	BK-BK14-PEDCO-110-ST-DW-0005
GENERAL NOTES-REINFORCED CONCRETE STRUCTURES	BK-GNRL-PEDCO-000-ST-DW-0012
STANDARD DRAWING FOR INSERT PLATES IN CONCRETE	BK-GNRL-PEDCO-000-ST-DW-0007
PLOT PLAN DRAWING -BK14	BK-BK14-PEDCO-110-PI-PY-0001
GENERAL CIVIL LAYOUT- BK14	BK-BK14-PEDCO-110-CV-PY-0001



***						***					
REV.						DESCRIPTION					
REV.						DATE					
PROJECT NAME:						BINA K OILFIELD DEVELOPMENT/SUB-SURFACE WORK PACKAGES BK14 WHF MODIFICATIONS					
PROJECT NO.:						971020					
EPC CONTRACTOR:						EPD/EPC CONTRACTOR (GC):					
DRAWING TITLE:						STRUCTURAL DRAWING FOR SWITCHGEAR BUILDING FOR WELL PADS - BK-14					
SCALE						DRAWING NO.					
AS SHOWN						SHEET NO.					
REV.						REV.					
BUDGET REF.						LOCATION					
053-073-9184						SIZE					
F						CLASS					
4						SERIAL NO.					
708218						SHEET					
3						REVISION					
D00						NO CONSTRUCTION PERMITTED UNLESS DRAWING APPROVED					
APPROVED FOR CONSTRUCTION						BY:					
DATE:						DATE:					