

NOTES

- 1- ONE PORTABLE METER FOR CORROSION PROBES TO BE PROVIDE PER SITE TO RECOVERY MONITOR CORROSION DATA.
- 2- ESD LEVEL 3 FOR HH & LL ALARM LIQUID LEVEL.
- 3- CONTROL VALVE SIZING WILL BE FINALIZED BY VENDOR.
- 4- PARTIAL STROKE DEVICE TO BE CONSIDERED FOR ALL ESD'S ACTIVATED BY ESD 1.0.
- 5- LINE SHALL BE EXPANDED TO MINIMUM 4" FOE CO INSTALLATION.
- 6- 2*100K PSV'S ONE DUTY AND ONE STANDBY.

GENERAL NOTE

LEGEND

REFERENCE DRAWING	DRG. No.
Utility Flow Diagram	BK-GCS-FRDO-120-PR-PI-001
Symbol & Legend For PFD & P&ID	BK-GCS-FRDO-120-PR-PI-001

KEY PLAN

REV.	DESCRIPTION	CHECKED		REV. APPR.	
		BY	DATE	BY	DATE
000	0000000000	00.00	000.0000	00.00	000.0000