

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								  
	ELECTRICAL LOAD LIST								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	پروژه BK	بسته کاری GCS	صادر کننده PEDCO	تسهیلات 120	رشته EL	نوع مدرک LI	سریال 0001	نسخه D06	شماره صفحه: ۱ از ۷

طرح نگهداشت و افزایش تولید ۲۷ مخزن

ELECTRICAL LOAD LIST

نگهداشت و افزایش تولید میدان نفتی بینک

D06	Jan.2024	IFA	H.Shakiba	M.Fakharian	S.Faramarzpour	
D05	Feb.2023	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D04	Jul.2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D03	May.2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D02	Mar.2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D01	Jan.2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D00	Nov.2021	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	Client Approval

Class: 1

Client Doc. Number: F0Z-709066

status:

IDC: Inter-Discipline Check

IFC: Issued For Comment

IFA: Issued For Approval

AFD: Approved For Design

AFC: Approved For Construction

AFP: Approved For Purchase

AFQ: Approved For Quotation

IFI: Issued For Information

AB-R: As-Built for CLIENT Review

AB-A: As-Built –Approved

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض							 	
	احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								
	ELECTRICAL LOAD LIST								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	پروژه BK	بسته کاری GCS	صادرکننده PEDCO	تسهیلات 120	رشته EL	نوع مدرک LI	سریال 0001	نسخه D06	شماره صفحه: ۷ از ۲

REVISION RECORD SHEET

Page	D02	D03	D04	D05	D06	Page	D02	D03	D04	D05	D06
1	X	X	X	X	X	51					
2	X	X	X	X	X	52					
3	X	X	X			53					
4	X	X	X			54					
5	X	X	X	X	X	55					
6	X	X	X	X	X	56					
7	X	X	X	X		57					
8						58					
9						59					
10						60					
11						61					
12						62					
13						63					
14						64					
15						65					
16						66					
17						67					
18						68					
19						69					
20						70					
21						71					
22						72					
23						73					
24						74					
25						75					
26						76					
27						77					
28						78					
29						79					
30						80					
31						81					
32						82					
33						83					
34						84					
35						85					
36						86					
37						87					
38						88					
39						89					
40						90					
41						91					
42						92					
43						93					
44						94					
45						95					
46						96					
47						97					
48						98					
49						99					
50						100					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض							 
	احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک							
	ELECTRICAL LOAD LIST							
شماره پیمان: ۰۵۳-۰۷۳-۹۱۸۴	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
	BK	GCS	PEDCO	120	EL	LI	0001	D06
								شماره صفحه: ۳ از ۷

Service Type:

N : Normal Load

E : Emergency Load

Load Duty:

C : Continuous Load

I : Intermitant Load

S : Stand By Load

LR/FL: Loacked Rotor / Full Load Current

Load Type:

M: Motor

F: Non-Motor

Definition of API Factor

1.25 for Motor Power < 22kW,

1.15 for Motor Power between, 22kW and 55kW

1.1 for Motor Power > 55kW

Height derating factor can be determined as follows if no manufacturer data is available:

Height Above Sea Level	Height Factor
< 1000 m	1
1000 < Height < 1500 m	0.97
1500 m >	0.94

Coolant (Cooling) Factor is 0.88 according to basic document for motor feeder type.

LV Feeder Type:

F1: Simple 4-Pole MCCB Feeder with Thermal/Magnetic Trips, for I<63A Feeders

F2: Simple 4-Pole MCCB Feeder with Thermal/Magnetic Trips, for 63A=<I<100A Feeders

F3: Simple 4-Pole MCCB Feeder with Thermal/Magnetic Trips, for 100A=<I Feeders

F4: Simple 3-Pole MCCB Feeder with Thermal/Magnetic Trips, for I<63A Feeders

F5: Simple 3-Pole MCCB Feeder with Thermal/Magnetic Trips, for 63A=<I<100A Feeders

F6: Simple 3-Pole MCCB Feeder with Thermal/Magnetic Trips, for 100A=<I Feeders

F7: Simple 2-Pole MCCB Feeder for Feeding Single Phase Loads (Ph+N or 2-Ph)

F8: Simple 2-Pole MCCB Feeder for Feeding Single Phase Loads (Ph+N or 2-Ph) with Contactor

F9: Simple 3-Pole MCCB Feeder for Feeding Three Phase Loads (3PH+N) with Contactor

M1: Direct on Line Motor Starter Feeders for $0.4 \leq P < 4kW$ (Switch Fuse + Contactor + Bimetal + R/L Signaling)

M2: Direct on Line Motor Starter Feeders for $4kW \leq P < 18.5kW$ (Switch Fuse + Contactor + Bimetal + R/L Signaling + R/L Ammeter)

M3: Direct on Line Motor Starter Feeders for $18.5kW \leq P < 30$ (Switch Fuse + Contactor + Bimetal + R/L Signaling + R/L Ammeter (49, 50G, Phase Control))

M4: Direct on Line Motor Starter Feeders for $30kW \leq P$ (Switch Fuse + Contactor + Overload CT + R/L Signaling + R/L Ammeter + Motor Protection Relay (49, 50G, Phase Control))

M5: Direct on Line Motor Starter Feeders for $0.55 kW \leq P < 18.5kW$ (Switch Fuse + Contactor + Bimetal + R/L Signaling + R/L Ammeter) for Package

MV Feeder Type:

C1: 11 KV Incoming Feeder

C2: Outgoing Transformer 2000 KVA

C3: Outgoing Motor Starter <1000 KW

C4: Bus Coupler 11 KV

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								  							
	ELECTRICAL LOAD LIST								شماره صفحه: ۴ از ۷							
شماره پیمان: ۰۵۳-۰۷۳-۹۱۸۴	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	BK	GCS	PEDCO	120	EL	LI	0001	D06

Item NO	Rev	Bus	Equipment Number	Load Description	Service Type	Load Duty	Diversity Factor for Demand Load	NO Phases	Rated Voltage (V)	Load Type	Starting Method	BHP (Kw)	API Factor	Coolant Factor	Height Factor	Mechanical Power (Kw)	Rated Power (Kw)	Eff. (%)	Power Factor	Load Factor (%)	LR/FL	Current Normal Operation(A)	Starting Conditions Current (A)	Absorbed Peak Active Power (Kw)	Absorbed Peak Reactive Power (Kvar)	Absorbed Peak Apparent Power (Kva)	Feeder Type
1	D02	GCS-11-SWG-001A	C-2101A	First & Second Stage Gas Compressor A	N	C	1	3	11	M	DOL	932	1.1	0.88	1	1165	1250	95	77	74.6	6	89.7	538.1	981.05	812.928	1274.09	C3
2	D02	GCS-11-SWG-001B	C-2101B	First & Second Stage Gas Compressor B	N	C	1	3	11	M	DOL	932	1.1	0.88	1	1165	1250	95	77	74.6	6	89.7	538.1	981.05	812.928	1274.09	C3
3	D02	GCS-11-SWG-001A	C-2101C	First & Second Stage Gas Compressor C	N	S	0.1	3	11	M	DOL	932	1.1	0.88	1	1165	1250	95	77	74.6	6	89.7	538.1	98.11	81.293	127.41	C3
4	D00	GCS-11-SWG-001B	P-2301A	Fire Water Electric Pump	N	I	0.75	3	3.3	M	DOL	220	1.1	0.88	1	275.00	300	92	82	73.3	6	69.57	417.44	179.35	125.19	218.72	C3
5	D03	GCS-11-SWG-001A	GCS-TR-001	Transformer-001 11/42 KV	N	C	1	3	11	F	-	-	-	-	-	-	1000	100	80	100.0	1	65.61	-	1000.00	750.00	1250.00	C2
6	D03	GCS-11-SWG-001B	GCS-TR-002	Transformer-002 11/42 KV	N	C	1	3	11	F	-	-	-	-	-	-	1000	100	80	100.0	1	65.61	-	1000.00	750.00	1250.00	C2

GCS-11-SWG-001A					
Continuous		Intermittent		Standby	
Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)
1981.05	1562.93	0.00	0.00	98.11	81.29
Power Calculation		Avtive Power (Kw)	Reactive Power (Kvar)	Apparent power (KVA)	Power Factor
Maximum Normal Running Load		1981.05	1562.93	2523.35	0.79
Peak Load		2079.158	1644.221	2650.73	0.78
Peak Load				2650.728	

GCS-11-SWG-001B					
Continuous		Intermittent		Standby	
Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)
1981.05	1562.93	179.35	125.19	0.00	0.00
Power Calculation		Avtive Power (Kw)	Reactive Power (Kvar)	Apparent power (KVA)	Power Factor
Maximum Normal Running Load		2160.40	1688.11	2741.73	0.79
Peak Load		2160.40	1688.11	2741.73	0.79
Peak Load				2741.725	

The **Peak** load on 11 Kv switchgear "GCS-11-SWG-001A" is 2650 KVA while demand load on "GCS-11-SWG-001B" is aboat 2742 KVA.

Fire water Pump will fed from 800 kVA tmsformer 11/3.3 KV, which will be finalized after power flow calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک									
	ELECTRICAL LOAD LIST								شماره صفحه: ۵ از ۷	
	شماره پیمان:	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
۰۵۳-۰۷۲-۹۱۸۴		BK	GCS	PEDCO	120	EL	LI	0001	D06	

Item NO	Rev	Bus	Equipment Number	Load Description	Service Type	Load Duty	Diversity Factor for Demand Load	NO Phases	Rated Voltage (V)	Load Type	Starting Method	BHP (Kw)	API Factor	Coolant Factor	Height Factor	Mechanical Power (Kw)	Rated Power (Kw)	Eff. (%)	Power Factor	Load Factor (%)	LR/FL	Current Normal Operation(A)	Absorbed Peak Active Power (Kw)	Absorbed Peak Reactive Power (Kvar)	Feeder Type
1	D06	GCS-400-NSWG-001A	AC-2121A	First Stage Air Cooler 21A	N	C	1	3	0.4	M	DOL	2.3	1.25	0.88	1	3.27	5.5	84	79	41.8	6.5	12.0	2.74	2.12	M2
2	D06	GCS-400-NSWG-001A	AC-2122A	Second Stage Air Cooler 22A	N	C	1	3	0.4	M	DOL	4	1.25	0.88	1	5.68	5.5	84	79	72.7	6.5	12.0	4.76	3.70	M2
3	D06	GCS-400-NSWG-001B	AC-2121B	First Stage Air Cooler 21B	N	C	1	3	0.4	M	DOL	2.3	1.25	0.88	1	3.27	5.5	84	79	41.8	6.5	12.0	2.74	2.12	M2
4	D06	GCS-400-NSWG-001B	AC-2122B	Second Stage Air Cooler 22B	N	C	1	3	0.4	M	DOL	4	1.25	0.88	1	5.68	5.5	84	79	72.7	6.5	12.0	4.76	3.70	M2
5	D06	GCS-400-NSWG-001A	AC-2121C	First Stage Air Cooler 21C	N	S	0.1	3	0.4	M	DOL	2.3	1.25	0.88	1	3.27	5.5	84	79	41.8	6.5	12.0	0.27	0.21	M2
6	D06	GCS-400-NSWG-001A	AC-2122C	Second Stage Air Cooler 22C	N	S	0.1	3	0.4	M	DOL	4	1.25	0.88	1	5.68	5.5	84	79	72.7	6.5	12.0	0.48	0.37	M2
7	D06	GCS-400-NSWG-001A	AC-2131A	First Stage Air Cooler 31A	N	C	1	3	0.4	M	DOL	2.3	1.25	0.88	1	3.27	5.5	84	79	41.8	6.5	12.0	2.74	2.12	M2
8	D06	GCS-400-NSWG-001A	AC-2132A	Second Stage Air Cooler 32A	N	C	1	3	0.4	M	DOL	4	1.25	0.88	1	5.68	5.5	84	79	72.7	6.5	12.0	4.76	3.70	M2
9	D06	GCS-400-NSWG-001B	AC-2131B	First Stage Air Cooler 31B	N	C	1	3	0.4	M	DOL	2.3	1.25	0.88	1	3.27	5.5	84	79	41.8	6.5	12.0	2.74	2.12	M2
10	D06	GCS-400-NSWG-001B	.	Second Stage Air Cooler 32B	N	C	1	3	0.4	M	DOL	4	1.25	0.88	1	5.68	5.5	84	79	72.7	6.5	12.0	4.76	3.70	M2
11	D06	GCS-400-NSWG-001A	AC-2131C	First Stage Air Cooler 31C	N	S	0.1	3	0.4	M	DOL	2.3	1.25	0.88	1	3.27	5.5	84	79	41.8	6.5	12.0	0.27	0.21	M2
12	D06	GCS-400-NSWG-001A	AC-2132C	Second Stage Air Cooler 32C	N	S	0.1	3	0.4	M	DOL	4	1.25	0.88	1	5.68	5.5	84	79	72.7	6.5	12.0	0.48	0.37	M2
13	D06	GCS-400-NSWG-001E	PK-C-2203A	Instrument & Plant Air Package A	E	C	1	3	0.4	F	-	-	-	-	-	-	75	92	82	100.0	1	143.5	81.52	56.90	F3
14	D06	GCS-400-NSWG-001E	PK-C-2203B	Instrument & Plant Air Package B	E	S	0.1	3	0.4	F	-	-	-	-	-	-	75	92	82	100.0	1	143.5	8.15	5.69	F3
15	D06	GCS-400-NSWG-001A	PK-Dr-2203A	Air Dryer Package A	N	G	1	3	0.4	F	-	-	-	-	-	-	0	78	75	100.0	1	0.0	0.00	0.00	F1
16	D06	GCS-400-NSWG-001B	PK-Dr-2203B	Air Dryer Package B	N	S	0.1	3	0.4	F	-	-	-	-	-	-	0	78	75	100.0	1	0.0	0.00	0.00	F1
17	D06	GCS-400-NSWG-001A	PK-C-2204	Air Compressor for N2 Package	N	C	1	3	0.4	F	-	-	-	-	-	-	75	91	82	100.0	1	145.1	82.42	57.53	F3
18	D06	GCS-400-NSWG-001A	PK-2204	Nitrogen Package	N	G	1	3	0.4	F	-	-	-	-	-	-	2.2	78	75	100.0	1	5.4	2.82	2.49	F1
19	D06	GCS-400-NSWG-001A	PK-2201	LP Flare Package	N	C	1	3	0.4	F	-	-	-	-	-	-	30	90	80	100.0	1	60.1	33.33	25.00	F1
20	D06	GCS-400-NSWG-001E	IG-2201	LP Flare Ignition Package	E	I	0.75	3	0.4	F	-	-	-	-	-	-	2	90	85	100.0	1	3.77	1.67	1.03	F1
21	D06	GCS-400-NSWG-001B	PK-2207	Corrosion Inhibitor Package	N	C	1	3	0.4	F	-	-	-	-	-	-	2	90	85	100.0	1	3.77	2.22	1.38	F1
22	D06	GCS-400-NSWG-001B	PK-2101	Dehydration Package	N	C	1	3	0.4	F	-	-	-	-	-	-	65.2	90	85	100.0	1	123.02	72.44	44.90	F1
23	D06	GCS-400-NSWG-001E	P-2203A	Sump Pump A	E	I	0.75	3	0.4	M	DOL	1	1.25	0.88	1	1.42	1.5	78	75	66.67	5	3.70	0.96	0.85	M1
24	D06	GCS-400-NSWG-001E	P-2203B	Sump Pump B	E	I	0.75	3	0.4	M	DOL	1	1.25	0.88	1	1.42	1.5	78	75	66.67	5	3.70	0.96	0.85	M1
25	D04	GCS-400-NSWG-001E	P-2202A	Closed Drain Pump A	E	I	0.75	3	0.4	M	DOL	2.9	1.25	0.88	1	4.12	5.5	84	79	52.7	6.5	11.96	2.59	2.01	M2
26	D04	GCS-400-NSWG-001E	P-2202B	Closed Drain Pump B	E	I	0.75	3	0.4	M	DOL	2.9	1.25	0.88	1	4.12	5.5	84	79	52.7	6.5	11.96	2.59	2.01	M2
27	D06	GCS-400-NSWG-001E	P-2101A	Slug Pump A	E	I	0.75	3	0.4	M	DOL	7	1.25	0.88	1	9.94	11	88	79	63.6	6.5	22.84	5.97	4.63	M2
28	D06	GCS-400-NSWG-001E	P-2101B	Slug Pump B	E	I	0.75	3	0.4	M	DOL	7	1.25	0.88	1	9.94	11	88	79	63.6	6.5	22.84	5.97	4.63	M2
29	D06	GCS-400-NSWG-001E	P-2302A	Fire Water Jockey Pump A	E	I	0.75	3	0.4	F	-	-	-	0.88	1	-	18.5	90	79	0.0	1	37.56	15.42	11.96	F1
30	D06	GCS-400-NSWG-001E	P-2302B	Fire Water Jockey Pump B	E	I	0.75	3	0.4	F	-	-	-	0.88	1	-	18.5	90	79	0.0	1	37.56	15.42	11.96	F1
31	D06	GCS-400-NSWG-001B	P-2209	Potable Water Pump	N	I	0.75	3	0.4	M	DOL	1.5	1.25	0.88	1	2.13	2.2	78	75	68.2	5.2	5.43	1.44	1.27	M1
32	D06	GCS-400-NSWG-001E	P-2206	Diesel Oil Pump	E	I	0.75	3	0.4	M	DOL	0.6	1.25	0.88	1	0.85	1.1	73	75	54.5	4.7	2.90	0.62	0.54	M1
33	D04	GCS-400-NSWG-001E	P-2201A	LP Flare K.O. Drum Pump A	E	I	0.75	3	0.4	M	DOL	0.6	1.25	0.88	1	0.85	1.1	73	75	54.5	4.7	2.90	0.62	0.54	M1
34	D04	GCS-400-NSWG-001E	P-2201B	LP Flare K.O. Drum Pump B	E	I	0.75	3	0.4	M	DOL	0.6	1.25	0.88	1	0.85	1.1	73	75	54.5	4.7	2.90	0.62	0.54	M1
35	D04	GCS-400-NSWG-001A	P-2103A	Glycol Transfer Pump A	N	I	0.75	3	0.4	M	DOL	1	1.25	0.88	1	1.42	1.5	78	75	66.7	5	3.70	0.96	0.85	M1
36	D04	GCS-400-NSWG-001B	P-2103B	Glycol Transfer Pump B	N	I	0.75	3	0.4	M	DOL	1	1.25	0.88	1	1.42	1.5	78	75	66.7	5	3.70	0.96	0.85	M1
37	D06	GCS-400-NSWG-001B	P-2102	Glycol Manual Pump	N	I	0.75	3	0.4	M	DOL	0.4	1.25	0.88	1	0.57	1.1	73	75	36.4	4.7	2.90	0.41	0.36	M1
38	D04	GCS-400-NSWG-001B	P-2104	Glycol Drain Pump	N	I	0.75	3	0.4	M	DOL	0.8	1.25	0.88	1	1.14	1.1	73	75	72.7	4.7	2.90	0.82	0.72	M1
39	D06	GCS-400-NSWG-001B	GCS-400-CR-01	Main Compressor Crane	N	I	0.75	3	0.4	F	-	-	-	-	-	-	10	90	85	100.0	1	18.87	8.33	5.16	F1
40	D06	GCS-400-NSWG-001A	GCS-400-CR-02	Fire Water Pumps Crane	N	I	0.75	3	0.4	F	-	-	-	-	-	-	5	90	85	100.0	1	9.43	4.17	2.58	F1
41	D06	GCS-400-NSWG-001B	GCS-400-NDP-01	Process Area Normal Distribution Panel	N	C	1	3	0.4	F	-	-	-	-	-	-	13.6	90	85	100.0	1	25.66	15.11	9.37	F1
42	D06	GCS-400-NSWG-001E	GCS-400-EDP-01	Process Area Emergency Distribution Panel	E	C	1	3	0.4	F	-	-	-	-	-	-	4.7	90	85	100.0	1	8.87	5.22	3.24	F1
43	D06	GCS-400-NSWG-001A	GCS-400-NDP-02	Utility Area Normal Distribution Panel	N	C	1	3	0.4	F	-	-	-	-	-	-	6.6	90	85	100.0	1	12.45	7.33	4.54	F1
44	D06	GCS-400-NSWG-001E	GCS-400-EDP-02	Utility Area Emergency Distribution Panel	E	C	1	3	0.4	F	-	-	-	-	-	-	3.2	90	85	100.0	1	6.04	3.56	2.20	F1
45	D06	GCS-400-NSWG-001B	WS-PR-01	First Welding Receptacle (Process Area)	N	I	0.75	3	0.4	F	-	-	-	-	-	-	35	90	75	100.0	1	74.84	29.17	25.72	F2
46	D06	GCS-400-NSWG-001A	WS-PR-03	Third Welding Receptacle (Process Area)	N	S	0.1	3	0.4	F	-	-	-	-	-	-	35	90	75	100.0	1	74.84	3.89	3.43	F2
47	D06	GCS-400-NSWG-001B	WS-UT-01	First Welding Receptacle (Utility Area)	N	I	0.75	3	0.4	F	-	-	-	-	-	-	35	90	75	100.0	1	74.84	29.17	25.72	F2
48	D06	GCS-400-NSWG-001A	WS-UT-02	Second Welding Receptacle (Utility Area)	N	S	0.1	3	0.4	F	-	-	-	-	-	-	35	90	75	100.0	1	74.84	3.89	3.43	F2
49	D06	GCS-400-NSWG-001A	GCS-400-CP01	Cathodic Protection Transformer Rectifier1	N	C	1	3	0.4	F	-	-	-	-	-	-	5	90	90	100.0	1	8.91	5.56	2.69	F1
50	D06	GCS-400-NSWG-001A	GCS-110-CHG-001	110VDC Charger 1	N	S	0.1	3	0.4	F	-	-	-	-	-	-	20	90	85	100.0	1	37.74	2.22	1.38	F1
51	D06	GCS-400-NSWG-001E	GCS-110-CHG-002	110VDC Charger 2	E	C	1	3	0.4	F	-	-	-	-	-	-	20	90	85	100.0	1	37.74	22.22	13.77	F1
52	D06	GCS-400-NSWG-001A	GCS-24-CHG-001	24VDC Charger 1	N	S	0.1	3	0.4	F	-	-	-	-	-	-	23	90	85	100.0	1	43.40	2.56	1.58	F1
53	D06	GCS-400-NSWG-001E	GCS-24-CHG-002	24VDC Charger 2	E	C	1	3	0.4	F	-	-	-	-	-	-	23	90	85	100.0	1	43.40	25.56	15.84	F1
54	D06	GCS-400-NSWG-001B	GCS-110-UPS-001	110VAC UPS 1	N	S	0.1	3	0.4	F	-	-	-	-	-	-	50.8	90	85	100.0	1	95.85	5.64	3.50	F2
55	D06	GCS-400-NSWG-001E	GCS-110-UPS-002	110VAC UPS 2	E	C	1	3	0.4	F	-	-	-	-	-	-	50.8	90	85	100.0	1	95.85	56.44	34.98	F2

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک											
	ELECTRICAL LOAD LIST								شماره صفحه: ۶ از ۷			
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	پسته کاری	پروژه				
۰۵۳-۰۷۳-۹۱۸۴	D06	0001	LI	EL	120	PEDCO	GCS	BK	شماره پیمان:			

Item NO	Rev	Bus	Equipment Number	Load Description	Service Type	Load Duty	Diversity Factor for Demand Load	NO Phases	Rated Voltage (V)	Load Type	Starting Method	BHP (Kw)	API Factor	Coolant Factor	Height Factor	Mechanical Power (Kw)	Rated Power (Kw)	Eff. (%)	Power Factor	Load Factor (%)	LR/FL	Current Normal Operation(A)	Absorbed Peak Active Power (Kw)	Absorbed Peak Reactive Power (Kvar)	Feeder Type
56	D06	GCS-400-NSWG-001E	GCS-110-UPS-Bypass	110VAC UPS By Pass	E	S	0.1	3	0.4	F	-	-	-	-	-	-	23.46	90	85	100.0	1	44.26	2.61	1.62	F1
57	D04	GCS-400-NSWG-001A		MOV 1	N	C	1	3	0.4	F	-	-	-	-	-	-	2	90	85	100.0	1	3.77	2.22	1.38	F1
58	D04	GCS-400-NSWG-001B		MOV 2	N	S	0.1	3	0.4	F	-	-	-	-	-	-	2	90	85	100.0	1	3.77	0.22	0.14	F1
59	D04	GCS-400-NSWG-001E	GCS-230-FDP 01	Fire Diesel Panel 01 (Electrical Main Motor)	E	C	1	1	0.23	F	-	-	-	-	-	-	1	90	85	100.0	1	3.28	1.11	0.69	F7
60	D04	GCS-400-NSWG-001E	GCS-230-FDP 02	Fire Diesel Panel 02 (Diesel Engine)	E	C	1	1	0.23	F	-	-	-	-	-	-	1	90	85	100.0	1	3.28	1.11	0.69	F7
61	D06	GCS-400-NSWG-001A	MCC-2101A	Auxiliary Panel for Gas Compressor C-2101A	N	C	1	3	0.4	F	-	-	-	-	-	-	41.1	90	85	100.0	1	77.55	45.67	28.30	F2
62	D06	GCS-400-NSWG-001B	MCC-2101B	Auxiliary Panel for Gas Compressor C-2101B	N	C	1	3	0.4	F	-	-	-	-	-	-	41.1	90	85	100.0	1	77.55	45.67	28.30	F2
63	D06	GCS-400-NSWG-001B	MCC-2101C	Auxiliary Panel for Gas Compressor C-2101C	N	S	0.1	3	0.4	F	-	-	-	-	-	-	41.1	90	85	100.0	1	77.55	4.57	2.83	F2
64	D01	GCS-400-NSWG-001E	SPH-01	Space Heater & Lighting for New LV Switchgear	E	C	1	1	0.23	F	-	-	-	-	-	-	2	90	85	100.0	1	6.56	2.22	1.38	F7
65	D01	GCS-400-NSWG-001E	SPH-02	Space Heater & Lighting for MV Switchgear	E	C	1	1	0.23	F	-	-	-	-	-	-	2	90	85	100.0	1	6.56	2.22	1.38	F7
66	D06	GCS-400-NSWG-001E	GCS-400-EDP-CRM	Control Room Emergency Distribution Panel & HVAC	E	C	1	3	0.4	F	-	-	-	-	-	-	30.3	95	85	100.0	1	54.16	31.89	19.77	F1
67	D06	GCS-400-NSWG-001A	GCS-400-NDP-SWHVAC	Switchgear Distribution Panel & HVAC	N	C	1	3	0.4	F	-	-	-	-	-	-	30	90	85	100.0	1	56.60	33.33	20.66	F1
68	D06	GCS-400-NSWG-001E	GCS-400-EDP-CCTV	CCTV Distribution Panel & HVAC	E	C	1	3	0.4	F	-	-	-	-	-	-	15	90	85	100.0	1	28.30	16.67	10.33	F1
69	D06	GCS-400-NSWG-001B	GCS-400-EDP-WARE	Warehouse Distribution Panel & HVAC	N	C	1	3	0.4	F	-	-	-	-	-	-	10	90	85	100.0	1	18.87	11.11	6.89	F1
70	D06	GCS-400-NSWG-001E	EHTG	Electrical Heat-Tracing Panel	E	C	1	3	0.4	F	-	-	-	-	-	-	10	100	90	100.0	1	16.04	10.00	4.84	F1
71	D03	GCS-400-NSWG-001A	CAP-01	Capacitor Bank 1	N	C	1	3	0.4	F	-	-	-	-	-	-	-	100	100	100	1	173.21	-	120	F3
72	D03	GCS-400-NSWG-001B	CAP-02	Capacitor Bank 2	N	C	1	3	0.4	F	-	-	-	-	-	-	-	100	100	100	1	173.21	-	120	F3

GCS-400-NSWG-001A			
Max Intermittent		Max Standby (KW)	
(KW)	(KVAR)	(KW)	(KVAR)
4.17	2.58	3.89	3.43
5.56	3.44	38.89	34.30

GCS-400-NSWG-001B			
Max Intermittent		Max Standby (KW)	
(KW)	(KVAR)	(KW)	(KVAR)
29.17	25.72	5.64	3.50
38.89	34.30	56.44	34.98

GCS-400-NSWG-001E			
Max Intermittent		Max Standby (KW)	
(KW)	(KVAR)	(KW)	(KVAR)
15.42	11.96	8.15	5.69
20.56	15.95	81.52	56.90

1. For each LV switchgear A & B, a separate transformer is needed to supply normal & emergency power. So the sum of apparent power will be about 1189KVA, which 2 transformers 1250 KVA are required.
2. Size of transformers shall be finalized in load flow and motor starting study.
3. Power factor has been calculated while all capacitor banks are out of service.

GCS-400-NSWG-001A					
Continuous		Intermittent		Standby	
Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)
227.68	154.23	5.13	3.43	14.06	10.98
Power Calculation		Avtive Power (Kw)	Reactive Power (Kvar)	Apparent power (KVA)	Power Factor
Maximum Normal Running Load (Demand)		232.81	157.66	281.17	0.83
Peak Load		246.866	168.644	298.97	0.83
Peak Load With 20% Spare (KVA)				358.765	
GCS-400-NSWG-001B					
Continuous		Intermittent		Standby	
Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)
161.56	102.47	70.30	59.82	10.43	6.47
Power Calculation		Avtive Power (Kw)	Reactive Power (Kvar)	Apparent power (KVA)	Power Factor
Maximum Normal Running Load (Demand)		231.86	162.29	283.01	0.82
Peak Load		242.292	168.751	295.27	0.82
Peak Load With 20% Spare (KVA)				354.320	
GCS-400-NSWG-001E					
Continuous		Intermittent		Standby	
Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)	Avtive Power (Kw)	Reactive Power (Kvar)
259.75	166.00	53.38	41.57	10.76	7.31
Power Calculation		Avtive Power (Kw)	Reactive Power (Kvar)	Apparent power (KVA)	Power Factor
Maximum Normal Running Load		313.13	207.57	375.68	0.83
Peak Load		323.891	214.878	388.69	0.83
Peak Load With 20% Spare (KVA)				466.425	
Total Peak Load on LV Switchgear					
Peak Load		Avtive Power (Kw)	Reactive Power (Kvar)	Apparent power (KVA)	Power Factor
		813.05	552.27	982.88	0.8272
Peak Load With 20% Spare (KVA)				1179.458	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								
	ELECTRICAL LOAD LIST								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	پروژه BK	بسته کاری GCS	صادر کننده PEDCO	تسهیلات 120	رشته EL	نوع مدرک LI	سریال 0001	نسخه D06	شماره صفحه: ۷ از ۷

1. Mechanical Power (KW): Mechanical Power for Motors = BHP(KW) x API Factor / (Cooling Factor x Height Factor)

2. Rated Power(KW): Rated Power = The Nearest Size of The Equipment to Mechanical Power of Motors

3. Load Factor(%): Load Factor = (BHP/Rated Power) x 100

4. Normal Operation(A): Normal Operation (A) = Rated Power / (Sqrt(3) x Nominal Voltage x cosØ)

5. Starting Current(A): Starting Current(A) = (LR/LF) x Normal Current

6. Electrical Power Demand (KW):

Electrical Absorbed Power Demand (KW) = BHP(KW) x Diversity Factor / Efficiency

Electrical Absorbed Power Demand (KW) = Rated Power(KW) x Diversity Factor / Efficiency

7. Electrical Reactive Power Demand (KVAR):

Electrical Reactive Power Demand (KVAR) = Electrical Absorbed Power Demand (KW) x Tangent(Ø)

For "Electrical Demand" calculation, following "Diversity Factors" has been considered (based on peak loads):

Continuous: 100% Diversity factor.

Intermittent: Normally less than 12 hours/day, As generally 75%

Standby: Spare/Backup drives or systems, As generally 10% or biggest standby load (which is bigger)

Note

1- Electrical heat tracing for compressor will be supplied from Auxiliary MCC of each one