



ينك

شماره پیمان:

053 - 073 - 9184

	PMR FOR INSTRUMENT JUNCTION BOX AND GLAND							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	
BK	PPL	PEDCO	320	IN	MR	0016	D00	

شماره صفحه: 1 از 17

طرح نگهداشت و افزایش تولید 27 مخزن

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND

نگهداشت و افزایش تولید میدان نفتی بینک

	T			T		
D00	FEB. 2024	IFI	P.Hajisadeghi	M.Fakharian	S.Faramarzpour	
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
Class:3		CLIENT Doc. Number: F0	Z-709285			

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for CLIENT Review
AB-A: As-Built –Approved





شماره پیمان:

053 - 073 - 9184

	PMR FOR INSTRUMENT JUNCTION BOX AND GLAND							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	
BK	PPL	PEDCO	320	IN	MR	0016	D00	

شماره صفحه: 2 از 17

REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	Х				
2	X				
3	X				
4	X				
5 6	X				
7	X				
8	X				
9	Χ				
10	X				
11	X				
12 13	X				
14	X				
15	x				
16	X				
17	Χ				
18					
19					
20	+				
21					
22 23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33 34					
35					
36					
37					
38					
39					
40					
41					
42 43					
43 44					
45					
46					
47					
48	1				
49	1				
50					
51 52					
52					
54					
55					
56					
57					
58					
59	1				
60					
61	1				
62 63					
64					
65	1				

PAGE	D00	D01	D02	D03	D04
66					
67					
68					
69 70					
70 71					
72					
73					
74					
75					
<u> 76</u>					
77					
78 79					
80					
81					
82					
83					
84					
85	-		-		
86	-		-		
87 88			-		
88 89	t		t		
90					
91					
92					
93					
94					
95					
96	-				
97 98					
99					
100					
101					
102					
103					
104	-				
105					
106 107					
107					
109					
110					
111					
112	-		-		
113	-		<u> </u>		
114 115	 		 		
115	†		†		
117					
118					
119					
120					
121	-		-		
122	-		<u> </u>		
123	 		 		
124 125	†		†		
125					
127					
128					
129					
130	L				





بينك

شماره پیمان:

053 - 073 - 9184

	PMR FOR INSTRUMENT JUNCTION BOX AND GLAND							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	
BK	PPL	PEDCO	320	IN	MR	0016	D00	

شماره صفحه: 3 از 17

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	REFERENCE / ATTACHED DOCUMENTS	5
4.0	SUBJECT OF THE SUPPLY	5
5.0	LIMITS OF SUPPLY	6
5.1 5.2 5.3	Scope of Supply Exclusions Battery Limits	7
6.0	INSPECTION AND TESTS	
7.0	VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE	8
8.0	UNIT RESPONSIBILITY	8
9.0	GUARANTEE AND WARRANTY	8
10.0	DEVIATION	
11.0	PRICE BREAKDOWN	9
ATTAC	CHMENT 1	11
11.1	LIST OF REFRENCE / APPLICABLE DOCUMENTS	11
ATTAC	CHMENT 2	12
11.2	VENDOR DOCUMENTS MIN. REQUIREMENT	12
ATTAC	CHMENT 3	16
11.3	DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION	16
ATTAC	CHMENT 4	17
11.4	ALTERNATIVES TO JOB SPECIFICATION	17





ينك

شماره پیمان:

053 - 073 - 9184

	PMR FOR INSTRUMENT JUNCTION BOX AND GLAND							
پروژه	نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه							
BK	PPL	PEDCO	320	IN	MR	0016	D00	

شماره صفحه: 4 از 17

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, New Gas/Condensate Pipelines (from Binak New GCS to Siahmakan GIS/Binak PU) shall be constructed.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PURCHASER: Means the "Company" where this document is a part

of direct purchaser order by the "Company", and the "Contractor" where this document is a part of contract

document.

PROJECT: Binak Oilfield Development - Construction of Well

Location, Wellhead Facilities, Electrification Facilities, Flowlines for W007S and Extension of Binak B/C

Manifold

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR/PURCHSER: Joint Venture of: Hirgan Energy - Design &

Inspection(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

supply material.

SUB VENDOR: The firm or person who will have a direct contract

with the Vendor or another Subvendor to perform a

part or parts of the Work

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR

(GC) and approved by CLIENT (in writing) for the

inspection of goods.

SHALL: Is used where a provision is mandatory. SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR

or VENDOR.





شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	PPL	PEDCO	320	IN	MR	0016	D00	

شماره صفحه: 5 از 17

MAY:

Is used where a provision is completely discretionary.

2.0 GENERAL

This document presents the item material requisitions for Contractor's use as appropriate.

This material requisition covers the requirements for the design, manufacturing, testing and supply of Instrument Junction box and gland as listed in section 5. All equipment/devices/items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.

3.0 REFERENCE / ATTACHED DOCUMENTS

- a. Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- **b.** All codes and standards which have been referenced in above mentioned specs shall be considered.
- **c.** In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.
- d. Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.

If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, VENDOR shall be considered to be in full compliance with the relevant document.

VENDOR may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY

VENDOR shall supply Instrument Junction box and gland. The scope of supply is detailed at part 5. VENDOR shall include in the supply, all other equipment/devices/items not listed in part 5, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.





تك

شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	
BK	PPL	PEDCO	320	IN	MR	0016	D00	

شماره صفحه: 6 از 17

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.

5.0 LIMITS OF SUPPLY

5.1 SCOPE OF SUPPLY

5.1.1 MAIN DESCRIPTION

The scope of supply includes Instrument Junction box and gland Main feature are as below:

- Junction box and gland & plug
- · All other necessary components not called for here
- Painting and coating

Detail of supply is listed below:

No.	Item	Description		
1	Instrument Junction box and gland (Complete	As per MTO For Instrument Junction box and Gland		
	with plastic plug for all cable entries)	Doc. No.:" BK-PPL-PEDCO-320-IN-MT-0003"		
2	Cable aland	As per MTO For Instrument Junction box and Gland		
2	Cable gland	Doc. No.:" BK-PPL-PEDCO-320-IN-MT-0003"		
2	Cable Plug	As per MTO For Instrument Junction box and Gland		
3		Doc. No.:" BK-PPL-PEDCO-320-IN-MT-0003"		

VENDOR shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.
- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.
- Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:
 - QA/QC Organization Chart and procedures that shall be submitted for approval.
 - Plan for HOLD points in the production process proposed to CLIENT/EPC CONTRACTOR for witness or approval particular activities.





شماره پیمان:

053 - 073 - 9184

	PMR FOR INSTRUMENT JUNCTION BOX AND GLAND								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه		
BK	PPL	PEDCO	320	IN	MR	0016	D00		

شماره صفحه: 7 از 17

- Production schedule indicating main quality manufacturing processes, inspection and tests
- Qualification of all personnel performing tests to be reviewed by the inspector
- Vendor shall also provide the description of the following quality activities:
 - Sub vendor products quality
 - Quality check and identification of the materials and equipment entering in their manufacturing shop.
- · Calibration of test instruments and equipment
- · Provide detailed specifications and data sheets.

5.1.2 SPARE PARTS

- The Vendor shall provide certain quantities of consumable for the installation, precommissioning, commissioning, start-up and up to the end of the guarantee period.
- The quantities shall be estimated by Vendor and shall be based upon the Vendor's experience. The following two periods shall be taken into account:
 - Pre-commissioning and commissioning period where the consumption of consumable is greater
 - Normal use of the System
- The VENDOR shall provide lists of recommended spare parts, which shall include the original part numbers with prices for commissioning, start-up and two years operation. All spare parts shall be identified individually.
- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&C-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&C-QC-SP-1).
- The VENDOR shall be able to provide spares back up and support for the plant life of at least 20 years.
- SPIR form shall be approved by CLIENT prior to procurement.

5.1.3 OTHER ITEMS

Name plate

5.2 EXCLUSIONS

No exclusion is applicable.

5.3 BATTERY LIMITS

No battery limit is applicable.





شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND								
پروژه	نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه							
BK PPL PEDCO 320 IN MR 0016 D00								

شماره صفحه: 8 از 17

6.0 INSPECTION AND TESTS

The equipment shall be inspected and tested in accordance with the Inspection &Test plan (ITP) issued by the vendor and approved by the CLIENT/EPC CONTRACTOR before the award of the order. The Inspection & Test plan (ITP) shall be at least according to the Commodity Procurement and Manufacturing Inspection Instruction (Docs .Nos. ICE-EID-MI-SP01-Rev01), Inspection Level of Commodity and Equipment (Docs .Nos. ICE-EID-MI-SP02-Rev01) and Data Sheets. The vendor shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation. All required manufacturing and function test/inspection also Factory Acceptance Test /Site Acceptance Test and Quality Assurance requirements shall be considered in vendor responsibility as per project specification.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE

Vendor document shall be according to attachment 2 of this document.

All documents, preliminary or final, are to be stamped and signed by VENDOR.

Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.

PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.

All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 "GENERAL DEFINITION"

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, and testing, final check-out, training and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.

Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-vendors.

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.





شماره پیمان:

053 - 073 - 9184

	PMR FOR INSTRUMENT JUNCTION BOX AND GLAND								
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه								
BK PPL PEDCO 320 IN MR 0016 D00									

شماره صفحه: 9 از 17

The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/packages at site

VENDOR shall guarantee the performance of supplied items.

VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period.

Vendor shall ensure a correct and safe operation of the unit, providing all safety protection Devices.

Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION

VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.

VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for CLIENT/EPC CONTRACTOR's approval.

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.





ينك

	شماره پیمان:
053 - 073	_9184

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه								
BK PPL PEDCO 320 IN MR 0016 D00									

شماره صفحه: 10 از 17

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (E&C-QC-SP-1)
- 3) 2 years' operational spare parts (E&C-QC-SP-1)
- 4) Packing & transportation





053 - 073 - 9184

شماره پیمان:

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه								
BK PPL PEDCO 320 IN MR 0016 D00									

شماره صفحه: 11 از 17

ATTACHMENT 1

11.1 LIST OF REFRENCE / APPLICABLE DOCUMENTS

No.	Document No.	Document Title	REV.	
	Instru	ument		
1.	BK-GNRAL-PEDCO-000-IN-SP-0010	Specification For Instrument/F&G Cables	D02	
2.	BK-PPL-PEDCO-320-IN-LI-0007	Instrument Cable List	D00	
3.	BK-PPL-PEDCO-320-IN-LI-0004	Panels & Junction Box List	D01	
4.	BK-PPL-PEDCO-320-IN-DG-0007	Instrument Junction Box Termination Diagram	D03	
5.	BK-PPL-PEDCO-320-IN-MT-0003	MTO For Instrument Junction box and Gland	D00	
6.	BK-PPL-PEDCO-320-IN-DC-0001	DCO-320-IN-DC-0001 Instrument & Control System Design Criteria		
	Pro	cess		
7.	BK-GNRAL-PEDCO-000-PR-DB-0001	Process Basis Of Design	D08	
	Gen	neral		
8.	ICE-EID-MI-SP01-Rev01	دستورالعمل بازرسی خرید و ساخت کالا	D01	
9.	ICE-EID-MI-SP02-Rev01	دستورالعمل سطح بازرسي كالا و تجهيزات	D01	
10.	E&C-QC-SP-1	دستورالعمل تامین قطعات یدکی راه اندازی و راهبردی دوساله	D00	
11.	BK-GNRAL-PEDCO-000-QC-PR-0022	Specification For Final Data Book (FDB) Requirements	D00	
12.	BK-GNRAL-PEDCO-000-QC-PR-0045	Packing, Marking, Transportation Procedure	D00	

^{**}NOTE: THE LATEST REVISION OF PROJECT DOCUMENT IN ATTACHMENT 1 TO BE CONSIDERED AS REFERENCE BY VENDOR.





شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه								
BK PPL PEDCO 320 IN MR 0016 D0									

شماره صفحه: 12 از 17

ATTACHMENT 2

11.2 VENDOR DOCUMENTS MIN. REQUIREMENT

		With Bid	TIME SCHEDULE				
ġ		With Bid	For R	eview	Final	Issue	
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Typ e (1)	Calenda r days (3)	
MANA	GEMENT						
01	Vendor Document Index and Schedule (See attachment 2)	4N	6C+E		6C+E		
02	Organization Brief	3N	6C+E				
03	Schedule Level 1, 2, 3 & 4 showing Engineering, Procurement, Fabrication, Inspection, Testing, and Delivery Plan.	4N	6C+E		6C+E		
04	Physically Progress Report (Every 2 Weeks))		6C+E				
05	Project Organization Chart	3N	6C+E				
06	Reference List	3N					
07	Vendor Catalogue	3N	6C+E				
QUAL	TY						
08	Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO)	4N			6C+E		
09	Preliminary Inspection and Test Plan	4N					
10	Inspection and Test Plan		6C+E		6C+E		
HSE							
11	HSE Procedure		6C+E		6C+E		
ENGIN	EERING						
12	Specifications/Data Sheets (Completed)	3N	6C+E		6C+E		
13	Dimensional Outlines	3N	6C+E		6C+E		
14	Mounting Details		6C+E		6C+E		
15	General Arrangement	3N	6C+E		6C+E		





شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه								
BK PPL PEDCO 320 IN MR 0016 D00									

شماره صفحه: 13 از 17

		Wid Bil	TIME SCHEDULE				
ġ.		With Bid	For Review		Final Issue		
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Typ e (1)	Calenda r days (3)	
16	Detailed Dimensions of Cut- Outs		6C+E		6C+E		
17	Termination details		6C+E		6C+E		
18	Parts/Material List	3N	6C+E		6C+E		
19	Technical Description and Relevant Catalogues	3N	6C+E		6C+E		
20	List of Deviations from the Specification and Data Sheets	3N	6C+E		6C+E		
PROCI	JREMENT						
21	List of Sub-Suppliers (table giving: part of equipment, tag no., sub-supplier reference)(5.1.3)	4N			6C+E		
22	Unpriced copy of sub-orders		6C+E				
23	Packing Spec. / Shipping Schedule	3N	6C+E		6C+E		
24	Weight List/ Shipping List	3N	6C+E		6C+E		
25	Mechanical & Performance Guarantees	3N	6C+E		6C+E		
TESTIN	NG						
26	Manufacturing, Test & Inspection Procedures	3N	6C+E		6C+E		
27	Performance & Functional Test Procedure		6C+E		6C+E		
28	Factory Acceptance Test (FAT) Procedure		6C+E		6C+E		
RECO	RDS, REPORTS & CERTIFICATES						
29	Material Conformity Certificate		6C+E		6C+E		
30	Testing Authority Approval Certificate (if any)		6C+E		6C+E		
31	Hazardous Area Certificates.		6C+E		6C+E		
32	Ingress Protection Certificate		6C+E		6C+E		
33	Conformity Certificates (subsupplier/equipment)		6C+E		6C+E		
33	Material Certificates Identification Diagram. (cross-reference material		6C+E		6C+E		





شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه								
BK PPL PEDCO 320 IN MR 0016 D00									

شماره صفحه: 14 از 17

			TIME SCHEDULE				
<u>.</u>		With Bid	For R	eview	Final	Issue	
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Typ e (1)	Calenda r days (3)	
	location ; certificates for critical components)						
34	Dimensional Control Reports		6C+E		6C+E		
35	Hardness Test Reports		6C+E		6C+E		
36	FAT Test Report / Certificates		6C+E		6C+E		
37	Performance Test Report / Certificates		6C+E		6C+E		
38	Calibration Curves of Control Equipment		6C+E		6C+E		
39	Calibration Test Certificates		6C+E		6C+E		
40	Test & Inspection Reports		6C+E		6C+E		
41	IP Certificate		6C+E		6C+E		
42	EX Certificate		6C+E		6C+E		
43	Non-Conformities Report		6C+E		6C+E		
INSTA	LLATION						
44	Sub-Assembly Documentation		6C+E		6C+E		
45	Sub-Assembly Drawings		6C+E		6C+E		
46	Erection/Installation Manual (if required)		6C+E		6C+E		
47	Name Plate Documents		6C+E		6C+E		
48	Handling, Transportation & Storage Instructions		6C+E		6C+E		
49	Unpacking & Inspection Instructions		6C+E				
50	Preliminary Packing List	4N					
51	Packing List		6C+E		6C+E		
OPERA	ATION & MAINTENANCE						
52	Operating Instructions		6C+E		6C+E		
53	Maintenance Instructions		6C+E		6C+E		
54	Commissioning & Start-up Manual		6C+E		6C+E		
55	List of Spare Parts Commissioning & Start-up	4N	6C+E		6C+E		
56	List of Spare Parts 2 Years Operation	4N	6C+E		6C+E		





شماره صفحه: 15 از 17

شماره پیمان:

053 - 073 - 9184

	PMR FOR INSTRUMENT JUNCTION BOX AND GLAND						
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
BK	PPL	PEDCO	320	IN	MR	0016	D00

		With Bid	TIME SCHEDULE			
<u>o</u>		with bid	For R	eview	Final	Issue
Item No.	Document	Copies No./Type (7)	Copies No./Type (1)	Solar days (2)	Copies No./Typ e (1)	Calenda r days (3)
57	List of Special Tools	4N	6C+E		6C+E	
58	Function Test Procedure		6C+E		6C+E	
OTHERS						
59	Vendor Final Book				6C+E	1 Week After Delivery
60	All others documents (if required) will be listed in the order		6C+E			•

NOTES:

- (1) N= Number of document, C=Copy, E=Electronic Copy
- (2) Starting from date of order placement
- (3) Starting from reception of documentation without comments
- (4) First issue of the document is subjected to the release of payment milestone as per purchase order
- (5) Calendar days after reception of drive data
- (6) Prior to testing
- (7) One copy each bid copy
- (8) List of documents will be finalized in VDIS.





بينك

شماره پیمان: 9184 – 073 – 053

 PMR FOR INSTRUMENT JUNCTION BOX AND GLAND

 نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه

 BK
 PPL
 PEDCO
 320
 IN
 MR
 0016
 D00

شماره صفحه: 16 از 17

ATTACHMENT 3

11.3 DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION

Requisition	No.:
-------------	------

Description:

Equipment No.:

Item No.	Description of Proposed Exception	Recommended Revision to JOB SPECIFICATION	Reason for Proposed Exception	Effect on Base PROPOSAL if CONTRACTOR Rejects Exception





بينك

شماره پیمان:

053 - 073 - 9184

PMR FOR INSTRUMENT JUNCTION BOX AND GLAND							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
BK	PPL	PEDCO	320	IN	MR	0016	D00

شماره صفحه : 17 از 17

ATTACHMENT 4

11.4 ALTERNATIVES TO JOB SPECIFICATION

Requisition No.:	
------------------	--

Description:

Equipment No.:

Item No.	Job Specification No. & Paragraph No.	Requirements of Job Specification	Description of Proposed Alternative	Reason for Proposed Alternative