

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک							 
	MTO FOR HVAC & PLUMBING FOR EXTENSION OF EXISTING ELECT. BUILDING							
شماره پیمان:	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
۰۵۳ - ۰۷۳ - ۹۱۸۴	BK	GCS	PEDCO	120	HV	MT	0002	D00
شماره صفحه: ۱ از ۴								

طرح نگهداشت و افزایش تولید ۲۷ مخزن

MTO FOR HVAC & PLUMBING FOR EXTENSION OF EXISTING ELECT. BUILDING

نگهداشت و افزایش تولید میدان نفتی بینک

D00	APR.2024	IFI	K.Ahmadi	M.Fakharian	S.Faramarzpour	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 3	CLIENT Doc. Number: F8Z-708882
----------	--------------------------------

status:	IDC: Inter-Discipline Check IFC: Issued For Comment IFA: Issued For Approval AFD: Approved For Design AFC: Approved For Construction AFP: Approved For Purchase AFQ: Approved For Quotation IFI: Issued For Information AB-R: As-Built for CLIENT Review AB-A: As-Built –Approved
---------	---

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک							 	
	MTO FOR HVAC & PLUMBING FOR EXTENSION OF EXISTING ELECT. BUILDING								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	پروژه BK	بسته کاری GCS	صادر کننده PEDCO	تسهیلات 120	رشته HV	نوع مدرک MT	سریال 0002	نسخه D00	شماره صفحه: ۲ از ۴

REVISION RECORD SHEET

Page	D00	D01	D02	D03	D04
1	X				
2	X				
3	X				
4	X				
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					

Page	D00	D01	D02	D03	D04
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								
	MTO FOR HVAC & PLUMBING FOR EXTENSION OF EXISTING ELECT. BUILDING								
شماره پیمان:	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۴ از ۳
۰۵۳ - ۰۷۳ - ۹۱۸۴	BK	GCS	PEDCO	120	HV	MT	0002	D00	

NON PAINTABLE GALVANIZED SHEET					
Item	Description	Unit	Size	Qty.	Remark
1	Noun paintable Galvanized sheet with 0.5 mm thickness.	M ²	-	15	-
2	Noun paintable Galvanized sheet with 0.6 mm thickness.	M ²	-	12	-
SUPPLY AIR DIFFUSER					
Item	Description	Unit	Size	Qty.	Remark
1	Square four-way ceiling diffuser from extruded aluminum profile with 1.25mm thickness and anodized finish.	Piece	150*150 MM	1	-
2	Square four-way ceiling diffuser from extruded aluminum profile with 1.25mm thickness and anodized finish.	Piece	300*300 MM	1	-
EXHAUST AIR GRILL					
Item	Description	Unit	Size	Qty.	Remark
1	Square egg crate grill from extruded aluminum profile with 1.25mm thickness and anodized finish.	Piece	150*150 MM	1	-
2	Square egg crate grill from extruded aluminum profile with 1.25mm thickness and anodized finish.	Piece	400*400 MM	1	-
OPPOSED BLADE MANUAL VOLUME DAMPER					
Item	Description	Unit	Size	Qty.	Remark
1	Duct mounted opposed blade volume damper with 1.5mm thikness galvanized steel sheet for frames and blades.	Piece	150*100 MM	1	-
2	Duct mounted opposed blade volume damper with 1.5mm thikness galvanized steel sheet for frames and blades.	Piece	150*150 MM	1	-
3	Duct mounted opposed blade volume damper with 1.5mm thikness galvanized steel sheet for frames and blades.	Piece	300*200 MM	1	-
4	Duct mounted opposed blade volume damper with 1.5mm thikness galvanized steel sheet for frames and blades.	Piece	400*150 MM	1	-
BLAST PROTECTION DAMPER					
Item	Description	Unit	Size	Qty.	Remark
1	Blast protection damper with 2mm thikness galvanized steel sheet for frames and blades.	Piece	300*250 MM	1	-
2	Blast protection damper with 2mm thikness galvanized steel sheet for frames and blades.	Piece	400*150 MM	1	-
FIRE DAMPER					
Item	Description	Unit	Size	Qty.	Remark
1	Fusible link fire damper with 2mm thikness galvanized steel sheet for frames and blades.	Piece	300*250 MM	1	-
2	Fusible link fire damper with 2mm thikness galvanized steel sheet for frames and blades.	Piece	400*150 MM	2	-

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								
	MTO FOR HVAC & PLUMBING FOR EXTENSION OF EXISTING ELECT. BUILDING								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۱۸۴	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۴ از ۴
	BK	GCS	PEDCO	120	HV	MT	0002	D00	

POLYPROPYLENE (PP) PIPE ACCORDING TO ASTM F2389 OR ISIRI 6314-1,2 AND FITTINGS FOR CONDENSATE PIPES					
Item	Description	Unit	Size	Qty.	Remark
1	Polypropylene (pp) pipe.	M (length)	25 MM	40	-
2	Polypropylene (pp) pipe.	M (length)	20 MM	16	-
3	Polypropylene (pp) elbow 90°.	Piece	25 MM	7	
4	Polypropylene (pp) equal Tee 90°.	Piece	25 MM	3	
5	Polypropylene (pp) unequal Tee 90°.	Piece	25*20*25 MM	2	
6	Polypropylene (pp) concentric reducer	Piece	25*20 MM	3	
7	Polypropylene (pp) elbow 90°.	Piece	20 MM	2	
8	Polypropylene (pp) equal Tee 90°.	Piece	20 MM	1	