

	<p>نگهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان:	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 1 از 24
053 – 073 – 9184	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	IN	MR	0011	D02

طرح نگهداشت و افزایش تولید 27 مخزن

PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER

نگهداشت و افزایش تولید میدان نفتی بینک

D02	APR. 2024	IFI	P.Hajisadeghi	M.Fakharian	S.Faramarzpour	
D01	AUG. 2023	IFI	P.Hajisadeghi	M.Fakharian	A.M.Mohseni	
D00	AUG. 2022	IFI	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class:3

CLIENT Doc. Number: F0Z-709287

Status:

IDC: Inter-Discipline Check
 IFC: Issued For Comment
 IFA: Issued For Approval
 AFD: Approved For Design
 AFC: Approved For Construction
 AFP: Approved For Purchase
 AFQ: Approved For Quotation
 IFI: Issued For Information
 AB-R: As-Built for CLIENT Review
 AB-A: As-Built –Approved

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							 شماره صفحه : 2 از 24
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02

REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	X	X	X		
2	X	X	X		
3	X				
4	X		X		
5	X	X	X		
6	X	X	X		
7	X	X	X		
8	X	X	X		
9	X	X	X		
10	X	X	X		
11	X	X	X		
12	X	X			
13	X	X	X		
14	X	X			
15	X				
16	X		X		
17	X		X		
18	X	X			
19	X	X			
20	X	X			
21	X				
22			X		
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					

PAGE	D00	D01	D02	D03	D04
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					
129					
130					

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادر کننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>IN</td><td>MR</td><td>0011</td><td>D02</td></tr></table>	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	IN	MR	0011	D02	شماره صفحه : 3 از 24
PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	IN	MR	0011	D02																			

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	REFERENCE / ATTACHED DOCUMENTS	5
4.0	SUBJECT OF THE SUPPLY	5
5.0	LIMITS OF SUPPLY	11
5.1	SCOPE OF SUPPLY	11
5.1.1	Main Description.....	11
5.1.2	Spare parts.....	12
5.1.3	Other Items	12
5.2	EXCLUSIONS	12
5.3	BATTERY LIMITS	13
6.0	INSPECTION AND TESTS	13
7.0	VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE.....	13
8.0	UNIT RESPONSIBILITY	13
9.0	GUARANTEE AND WARRANTY	14
10.0	DEVIATION	14
11.0	PRICE BREAKDOWN.....	15
ATTACHMENT 1	16	
11.1	LIST OF REFERENCE / APPLICABLE DOCUMENTS.....	16
ATTACHMENT 2	18	
11.2	VENDOR DOCUMENTS MIN. REQUIREMENT	18
ATTACHMENT 3	23	
11.3	DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION	23
ATTACHMENT 4	24	
11.4	ALTERNATIVES TO JOB SPECIFICATION	24

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک							 شرکت توسعه و پارس HIRGAN ENERGY TE	
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 4 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02	

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

GENERAL DEFINITION

The following terms shall be used in this document.



CLIENT:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – Surface Facilities; New Gas Compressor Station
EPD/EPC CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR/ PURCHSER:	Joint Venture of : Hirgan Energy – Design & Inspection (D&I) Companies
VENDOR:	The Firm or Person Who Will Fabricate or supply The Equipment or Material.
SUB VENDOR:	The firm or person who will have a direct contract with the Vendor or another Subvendor to perform a part or parts of the Work
EXECUTOR:	Executor is The Party Which Carries Out All or Part of Construction and/or Commissioning for The Project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC CONTRACTOR (GC) and approved by CLIENT (in writing) for the inspection of goods.
SHALL:	Is Used Where a Provision Is Mandatory.
SHOULD:	Is Used Where a Provision Is Advisory Only.
WILL:	Is normally used in connection with the action by CLIENT rather than by an EPC/EPD CONTRACTOR or VENDOR.
MAY:	Is used Where a Provision Is Completely Discretionary.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادر کننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>IN</td><td>MR</td><td>0011</td><td>D02</td></tr></table>	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	IN	MR	0011	D02	شماره صفحه : 5 از 24
PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	IN	MR	0011	D02																			



2.0 GENERAL

This document presents the item material requisitions for Contractor's use as appropriate.

This material requisition covers the requirements for the design, manufacturing, testing and supply of Pressure /Differential Pressure/ Flow (DP)/ level (DP) Transmitter. All equipment/ devices/ items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.

3.0 REFERENCE / ATTACHED DOCUMENTS

- Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- All codes and standards which have been referenced in above mentioned specs shall be considered.
- In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.
- Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.

If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, ~~the supplier~~ **VENDOR** shall be considered to be in full compliance with the relevant document.

~~the supplier~~ **VENDOR** may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY

~~the supplier~~ **VENDOR** shall supply Pressure/ Differential Pressure/ Flow (DP)/ Level (DP) Transmitter. The scope of supply is detailed at part 5. ~~the supplier~~ **VENDOR** shall include in the supply, all other equipment/devices/items not listed in part 5, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 6 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011		D02

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.

The vendor's supply shall include:

D02

No.	Item	Description	Total QTY.
1	PDIT 2111	Connection: 1/2" NPT, 150# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
2	PDIT 2112	Connection: 1/2" NPT, 150# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
3	PDIT 2121A	Connection: 1/2" NPT, 150# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
4	PDIT 2121B	Connection: 1/2" NPT, 150# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
5	PDIT 2121C	Connection: 1/2" NPT, 150# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
6	PDIT 2131A	Connection: 1/2" NPT, 300# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
7	PDIT 2131B	Connection: 1/2" NPT, 300# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
8	PDIT 2131C	Connection: 1/2" NPT, 300# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
9	PDIT-2143	Connection: 1/2" NPT, 300# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
10	PDIT 2141	Connection: 1/2" NPT, 300# RF side, Range: 0-1000mbar As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
11	PIT-2102	Connection: 1/2" NPT, 150# RF side, Range: 0-11 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
12	PIT 2104	Connection: 1/2" NPT, 150# RF side, Range: 0-11 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
13	PIT 2111	Connection: 1/2" NPT, 150# RF side, Range: 0-11 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
14	PIT 2112	Connection: 1/2" NPT, 150# RF side, Range: 0-11 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK-GCS-PEDCO-120-IN-DT-0004"	1
15	PIT 2113	Connection: 1/2" NPT, 150# RF side, Range: 0-1 barg	1

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							 شماره صفحه : 7 از 24
شماره پیمان: 053 - 073 - 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02

No.	Item	Description	Total QTY.
		As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	
16	PIT 2113A	Connection: 1/2" NPT, 150# RF side, Range: 0 3 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
17	PIT 2114	Connection: 1/2" NPT, 300# RF side, Range: 0 25 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
18	PIT 2214A	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
19	PIT 2216A	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
20	PIT 2214B	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
21	PIT 2216B	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
22	PIT 2115	Connection: 1/2" NPT, 300# RF side, Range: 0 25 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
23	PIT 2113B	Connection: 1/2" NPT, 150# RF side, Cal. Range: 0 3 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
24	PIT 2116	Connection: 1/2" NPT, 150# RF side, Range: 0 11 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
25	PIT 2117	Connection: 1/2" NPT, 150# RF side, Range: 0 11 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
26	PIT 2121A	Connection: 1/2" NPT, 150# RF side, Range: 0 10 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
27	PIT 2121B	Connection: 1/2" NPT, 150# RF side, Range: 0 10 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
28	PIT 2121C	Connection: 1/2" NPT, 150# RF side, Range: 0 10 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
29	PIT 2122A	Connection: 1/2" NPT, 150# RF side, Range: 0 10 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
30	PIT 2125A	Connection: 1/2" NPT, 300# RF side, Range: 0 25 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
31	PIT 2122B	Connection: 1/2" NPT, 150# RF side, Range: 0 10 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
32	PIT 2125B	Connection: 1/2" NPT, 300# RF side, Range: 0 25 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 8 از 24	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011		D02

No.	Item	Description	Total QTY.
33	PIT 2122C	Connection: 1/2" NPT, 150# RF side, Range: 0-10 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
34	PIT 2125C	Connection: 1/2" NPT, 300# RF side, Range: 0-25 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
35	PIT 2131A	Connection: 1/2" NPT, 300# RF side, Range: 0-25 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
36	PIT 2134A	Connection: 1/2" NPT, 600# RF side, Range: 0-100 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
37	PIT 2131B	Connection: 1/2" NPT, 300# RF side, Range: 0-25 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
38	PIT 2134B	Connection: 1/2" NPT, 600# RF side, Range: 0-100 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
39	PIT 2131C	Connection: 1/2" NPT, 300# RF side, Range: 0-25 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
40	PIT 2134C	Connection: 1/2" NPT, 600# RF side, Range: 0-100 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
41	PIT 2135A	Connection: 1/2" NPT, 600# RF side, Range: 0-100 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
42	PIT 2135B	Connection: 1/2" NPT, 600# RF side, Range: 0-100 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
43	PIT 2135C	Connection: 1/2" NPT, 600# RF side, Range: 0-100 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
44	PIT 2151	Connection: 1/2" NPT, 150# RF side, Range: 0-11 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
45	PIT 2161	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
46	PIT 2202	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
47	PIT 2201	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
48	PIT 2203	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1
49	PIT 2201A	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: BK GCS PEDCO 120 IN DT 0004"	1

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 9 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02	

No.	Item	Description	Total QTY.
50	PIT 2201B	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
51	PIT 2201C	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
52	PIT 2213	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
53	PIT 2214	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
54	PIT 2211A	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
55	PIT 2211B	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg	1
56	PIT 2211C	Connection: 1/2" NPT, 150# RF side, Range: 0-15 barg	1
57	PIT 2272	Connection: 1/2" NPT, 150# RF side, Range: 0-10 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
58	PIT 2271	Connection: 1/2" NPT, 150# RF side, Range: 0-10 barg As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
59	PIT 2281	Connection: 1/2" NPT, 150# RF side, Range: 0-0.5 barg	1
60	PIT 2222A	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
61	PIT 2222B	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
62	PIT 2252	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
63	PIT 2251A	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
64	PIT 2251B	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
65	PIT 2191	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0004"	1
66	FT 2101	DP Type, Connection: 1/2" NPTM, 300# RF side, Range: 0-250 mBar As per Data Sheets For Diff. Pressure Flow Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0012"	1
67	FT 2102	DP Type, Connection: 1/2" NPTM, 300# RF side, Range: 0-250 mBar As per Data Sheets For Diff. Pressure Flow Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0012"	1
68	FT 2111	DP Type, Connection: 1/2" NPTM, 300# RF side, Range: 0-250 mBar As per Data Sheets For Diff. Pressure Flow Transmitter Doc. No.: "BK GCS PEDCO 120 IN DT 0012"	1
69	FT 2271	DP Type, Connection: 1/2" NPTM, 300# RF side, Range: 0-250 mBar	1

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادر کننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>IN</td><td>MR</td><td>0011</td><td>D02</td></tr></table>	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	IN	MR	0011	D02	شماره صفحه : 10 از 24
PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	IN	MR	0011	D02																			

No.	Item	Description	Total QTY.
		As per Data Sheets For Diff. Pressure Flow Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0012"	
70	FT 2211	DP Type, Connection: 1/2" NPTM, 300# RF side, Range: 0-250 mBar As per Data Sheets For Diff. Pressure Flow Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0012"	1
71	LT 2113	DP Type, Connection: 2x2", 300# RF side, C To C: 3100 mm	1
72	LT 2114	DP Type, Connection: 2x2", 300# RF side, C To C: 11000 mm	1
73	LT 2115	DP Type, Connection: 2x2", 300# RF side, C To C: 800 mm	1
74	LT 2161	DP Type, Connection: 2x2", 300# RF side, C To C: 600 mm As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
75	LT 2162	DP Type, Connection: 2x2", 300# RF side, C To C: 3500 mm As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
76	LT 2291	DP Type, Connection: 1x2", 300# RF side, C To C: 2100 mm As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
77	LT 2301	DP Type, Connection: 1x2", 300# RF side, C To C: 11500 mm As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
78	LT 2302	DP Type, Connection: 1x2", 300# RF side, C To C: 11500 mm As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
79	LT 2112	As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
80	LT 2111	As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
81	LT 2119	As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
82	LT 2221	As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
83	LT 2251	As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
84	LT 2281	As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1
85	LT 2293	As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.: "BK-GCS PEDCO 120 IN DT 0019"	1

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 11 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02	

5.0 LIMITS OF SUPPLY

5.1 SCOPE OF SUPPLY

5.1.1 MAIN DESCRIPTION



The scope of supply includes 67 Nos. Pressure /Differential Pressure/ Flow (DP)/ Level (DP) Transmitter Main feature are as below:

- Pressure/ Differential Pressure Transmitter/ DP Flow transmitter / DP level transmitter
- Local Indicator
- Sunshade
- 2 or 5 valve manifold
- Painting and coating

Detail of supply is as per below:

No.	Item	Description(*)
1	Pressure /Differential Pressure Transmitter	As per Data Sheets For Pressure/Diff. Pressure Transmitter Doc. No.:" BK-GCS-PEDCO-120-IN-DT-0004"
2	Diff. Pressure Flow Transmitter	As per Data Sheets For Diff. Pressure Flow Transmitter Doc. No.:" BK-GCS-PEDCO-120-IN-DT-0012"
3	Diff. Pressure Type Level Transmitter	As per Data Sheets For Diff. Pressure Type Level Transmitter Doc. No.:" BK-GCS-PEDCO-120-IN-DT-0019"

(*) : Latest revision of data sheet shall be considered as reference.

the supplier **VENDOR** shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.
- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.
- Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 12 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02	

- QA/QC Organization Chart and procedures that shall be submitted for approval.
- Plan for HOLD points in the production process proposed to CLIENT/EPC CONTRACTOR for witness or approval particular activities.
- Production schedule indicating main quality manufacturing processes, inspection and tests.
- Qualification of all personnel performing tests to be reviewed by the inspector
- Vendor shall also provide the description of the following quality activities:
 - o Sub vendors' products quality
 - o Quality check and identification of the materials and equipment entering in their manufacturing shop.
- Calibration of test instruments and equipment
- Provide detailed specifications and data sheets.

5.1.2 SPARE PARTS

- The Vendor shall provide certain quantities of consumable for the installation, pre-commissioning, commissioning, start-up and up to the end of the guarantee period.
- The quantities shall be estimated by Vendor and shall be based upon the Vendor's experience. The following two periods shall be taken into account:
 - Pre-commissioning and commissioning period where the consumption of consumable is greater
 - Normal use of the System
- The VENDOR shall provide lists of recommended spare parts, which shall include the original part numbers with prices for commissioning, start-up and two years operation. All spare parts shall be identified individually.
- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&C-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&C-QC-SP-1).
- The VENDOR shall be able to provide spares back up and support for the plant life of at least 20 years.
- SPIR form shall be approved by CLIENT prior to procurement.

5.1.3 OTHER ITEMS

- Name plate

5.2 EXCLUSIONS

No exclusion is applicable.

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER</th></tr><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>PEDCO</td><td>120</td><td>IN</td><td>MR</td><td>0011</td><td>D02</td></tr></table>	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	PEDCO	120	IN	MR	0011	D02	شماره صفحه : 13 از 24
PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	PEDCO	120	IN	MR	0011	D02																			

5.3 BATTERY LIMITS

No battery limit is applicable.

6.0 INSPECTION AND TESTS

The equipment shall be inspected and tested in accordance with the Inspection & Test plan (ITP) issued by the vendor and approved by the CLIENT or EPC/EPD (GC) CONTRACTOR before the award of the order . The Inspection & Test plan (ITP) shall be at least according to the Commodity Procurement and Manufacturing Inspection Instruction (Docs .Nos. ICE-EID-MI-SP01-Rev01), Inspection Level of Commodity and Equipment (Docs .Nos. ICE-EID-MI-SP02-Rev01) and Data Sheets. The vendor shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation. All required manufacturing and function test/inspection also Factory Acceptance Test /Site Acceptance Test and Quality Assurance requirements shall be considered in vendor responsibility as per project specification.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE

Vendor document shall be according to attachment 2 of this document.

D02

All documents, preliminary or final, are to be stamped and signed by ~~the supplier~~ VENDOR.

Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.

PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.

All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 **"GENERAL DEFINITION"**

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, and testing, final check-out, training and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.

Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-vendors.

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 14 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011		D02

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.

The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/packages at site

VENDOR shall guarantee the performance of supplied items

VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period.

Vendor shall ensure a correct and safe operation of the unit, providing all safety protection Devices.

Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION

VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.

VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for CLIENT/EPC CONTRACTOR's approval.

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 15 از 24
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	IN	MR	0011	D02

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (E&C-QC-SP-1)
- 3) 2 years' operational spare parts (E&C-QC-SP-1)
- 4) Packing & transportation
- 5) Other fee

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک							 شرکت توسعه و پارس 	
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER								شماره صفحه : 16 از 24
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	PEDCO	120	IN	MR	0011	D02	

ATTACHMENT 1

11.1 LIST OF REFERENCE / APPLICABLE DOCUMENTS

D02

No.	Document No.	Document Title	REV.
Instrument			
1	BK-GNRAL-PEDCO-000-IN-SP-0001	Specification For Instrumentation	D04
2	BK-GCS-PEDCO-120-IN-DT-0013	Data sheet for Orifice Plate / Restriction Orifice	D02
3	BK-GCS-PEDCO-120-IN-DT-0004	Data Sheets For Pressure/Diff. Pressure Transmitter	D03
4	BK-GCS-PEDCO-120-IN-DT-0019	Data Sheets For Diff. Pressure Type Level Transmitter	D03
5	BK-GCS-PEDCO-120-IN-DG-0002	Instrument Hook-up Diagram	D04
6	BK-GCS-PEDCO-120-IN-DC-0002	Instrument & Control System Design Criteria	D02
7	BK-GCS-PEDCO-120-IN-DT-0012	Data Sheets For Diff. Pressure Flow Transmitter	D03
Safety			
8	BK-GCS-PEDCO-120-SA-PI-0001	P&ID - Fire Water Network	D05
Piping			
9	BK-GCS-PEDCO-120-PI-SP-0001	Piping Material Specification	D06
Process			
10	BK-GCS-PEDCO-120-PR-PI-0001	Symbol & Legend For PFD and P&ID	D04
11	BK-GCS-PEDCO-120-PR-PI-0002	P&ID - Gas Compression Inlet Gas Pipeline (Binak)	D08
12	BK-GCS-PEDCO-120-PR-PI-0003	P&ID - Gas Compression Inlet Gas Pipeline (Golkhari)	D08
13	BK-GCS-PEDCO-120-PR-PI-0004	P&ID - Slug Catcher System	D08
14	BK-GCS-PEDCO-120-PR-PI-0005	P&ID - Gas Compression Inlet Knock Out Drum	D08
15	BK-GCS-PEDCO-120-PR-PI-0006	P&ID - 1st Stage Gas Compression Suction Drums	D08
16	BK-GCS-PEDCO-120-PR-PI-0007	P&ID - 1st Stage Gas Compression Compressors	D08
17	BK-GCS-PEDCO-120-PR-PI-0008	P&ID - 1st Stage Gas Compression Air Coolers	D08
18	BK-GCS-PEDCO-120-PR-PI-0009	P&ID - 2nd Stage Gas Compression Suction Drums	D08
19	BK-GCS-PEDCO-120-PR-PI-0010	P&ID - 2nd Stage Gas Compression Compressors	D07
20	BK-GCS-PEDCO-120-PR-PI-0011	P&ID - 2nd Stage Gas Compression Air Coolers	D08
21	BK-GCS-PEDCO-120-PR-PI-0012	P&ID - 2nd Stage Gas Compression Discharge Drum	D08
22	BK-GCS-PEDCO-120-PR-PI-0013	P&ID - Gas Compression Dehydration Package	D08
23	BK-GCS-PEDCO-120-PR-PI-0014	P&ID - Lean Glycol Storage Tank	D08
24	BK-GCS-PEDCO-120-PR-PI-0015	P&ID - Instrument & Plant Air System	D08
25	BK-GCS-PEDCO-120-PR-PI-0016	P&ID - Nitrogen Generation System	D08
26	BK-GCS-PEDCO-120-PR-PI-0017	P&ID - Close Drain System	D08
27	BK-GCS-PEDCO-120-PR-PI-0018	P&ID - Corrosion Inhibitor Package	D07
28	BK-GCS-PEDCO-120-PR-PI-0019	P&ID - Methanol Injection Package	D07
29	BK-GCS-PEDCO-120-PR-PI-0020	P&ID - LP Flare System	D08
30	BK-GCS-PEDCO-120-PR-PI-0021	P&ID - Oily Water Sewer	D05
31	BK-GCS-PEDCO-120-PR-PI-0022	P&ID - Fuel Gas System	D08

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک							
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 17 از 24
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	IN	MR	0011	D02

No.	Document No.	Document Title	REV.
32	BK-GCS-PEDCO-120-PR-PI-0023	P&ID - Diesel Oil System	D08
33	BK-GCS-PEDCO-120-PR-PI-0024	P&ID - Potable Water System	D07
34	BK-GCS-PEDCO-120-PR-PI-0025	P&ID - Glycol Sump Drum	D08
35	BK-GNRAL-PEDCO-000-PR-DC-0001	Process Design Criteria	D02
36	BK-GNRAL-PEDCO-000-PR-DB-0001	Process Basis Of Design	D08
General			
37	ICE-EID-MI-SP01-Rev01	دستورالعمل بازرسی خرید و ساخت کالا	-
38	ICE-EID-MI-SP02-Rev01	سطح بازرسی کالا و تجهیزات	-
39	E&C-QC-SP-1	دستورالعمل تامین قطعات یدکی راه اندازی و راهبردی دوساله	-
40	BK-GNRAL-PEDCO-000-QC-PR-0022	Specification For Final Data Book (FDB) Requirements	D00
41	BK-GNRAL-PEDCO-000-QC-PR-0045	Packing, Marking, Transportation Procedure	

****NOTE:** The Latest Revision Of Project Document In Attachment 1 To Be Considered As Reference By Vendor.

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							 HIRGAN ENERGY	
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 19 از 24	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02	

NO.	DESCRIPTION	WITH BID	AFTER ORDERING				AT THE FINAL INSPECTION (4)
		Q./TYPE (1)	Q./TYPE (1)	DELIVERY DATE (2)	PURPOSE (3)	FINAL ISSUE	
17	List of Sub-Vendors (table giving: part of equipment, tag no., sub-vendor reference)(5.1.3)	4N	(5)	4W	A	(5)	
18	Unpriced copy of sub-orders	4N	(5)	4W	I	-	
19	Packing Spec. / Shipping Schedule	4N	(5)	4W	I	-	
20	Weight List/ Shipping List	4N	(5)	4W	I	(5)	
21	Mechanical & Performance Guarantees	4N	(5)	4W	I	-	
QUALITY , MANUFACTURING, TESTING							
22	Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO)		(5)	3W	A	(5)	
23	Preliminary Project Schedule		(5)	4W	I	-	
24	Weld and NDT Map		(5)	4W	I	(5)	X
25	Surface Preparation and Painting Procedures		(5)	4W	I	(5)	X
26	Welding Procedure Specification (including repair procedures).		(5)	4W	I	(5)	X
27	Welder Qualification Procedure		(5)	4W	I	(5)	X
28	Fabrication Degree		(5)	4W	I	(5)	X
29	Manufacturing, Test & Inspection Procedures	4N	(5)	4W	A	(5)	X
30	Performance & Functional Test Procedure		(5)	4W	A	(5)	X
31	Factory Acceptance Test (FAT) Procedure		(5)	4W	A	(5)	X
RECORDS, REPORTS & CERTIFICATES							
32	Material Conformity Certificate		(5)	4W	I	(5)	X
33	Testing Authority Approval Certificate		(5)	4W	I	(5)	X
34	Hazardous Area Certificates.		(5)	4W	I	(5)	X
35	Ingress Protection Certificate		(5)	4W	I	(5)	X
36	Conformity Certificates (sub-vendor/equipment)		(5)	4W	I	(5)	X
37	Material Certificates Identification Diagram. (cross-reference material location ; certificates for critical components)		(5)	4W	I	(5)	X

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 20 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011		D02

NO.	DESCRIPTION	WITH BID	AFTER ORDERING				AT THE FINAL INSPECTION (4)
		Q./TYPE (1)	Q./TYPE (1)	DELIVERY DATE (2)	PURPOSE (3)	FINAL ISSUE	
38	Welding Procedure Qualification Record.		(5)	4W	I	(5)	
39	Welder Qualification Records.		(5)	4W	I	(5)	
40	NDT Operator Qualifications		(5)	4W	I	(5)	X
41	Detailed NDT Reports		(5)	4W	A	(5)	
42	Weld/ NDT Identification Diagram. (Cross-reference weld locations, WPS, welders, NDT reports).		(5)	4W	A	(5)	X
43	Dimensional Control Reports		(5)	4W	A	(5)	
44	PWHT Charts & Reports, including calibration records of recorders (for each heat treatment)		(5)	4W	I	(5)	X
45	Pressure Test Reports / Certificates		(5)	4W	A	(5)	X
46	FAT Test Report / Certificates		(5)	4W	A	(5)	
47	Performance Test Report / Certificates		(5)	4W	A	(5)	X
48	Material Test Certificates		(5)	4W	I	(5)	X
49	Calibration Curves of Control Equipment		(5)	4W	I	(5)	X
50	Calibration Test Certificates		(5)	4W	I	(5)	X
51	Surface Preparation & Coating Reports		(5)	4W	A	(5)	
52	Hydrostatic / Pneumatic Testing Certificates		(5)	4W	I	(5)	X
53	Welding Consumable Certificate		(5)	4W	I	(5)	X
54	Test & Inspection Reports		(5)	4W	A	(5)	
55	Rust Prevention Report		(5)	4W	A	(5)	
56	Non-Conformities Report		(5)	4W	A	(5)	
57	Letter of Conformity		(5)	4W	A	(5)	
INSTALLATION							
58	Sub-Assembly Documentation		(5)	4W	A	(5)	
59	Sub-Assembly Drawings		(5)	4W	A	(5)	
60	Erection/Installation Manual		(5)	4W	A	(5)	

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							 شماره صفحه : 21 از 24
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02

NO.	DESCRIPTION	WITH BID	AFTER ORDERING				AT THE FINAL INSPECTION (4)
		Q./TYPE (1)	Q./TYPE (1)	DELIVERY DATE (2)	PURPOSE (3)	FINAL ISSUE	
61	Name Plate Documents	4N	(5)	4W	A	(5)	
62	Handling, Transportation & Storage Instructions	4N	(5)	4W	A	(5)	
63	Unpacking & Inspection Instructions		(5)	4W	A	(5)	
64	Preliminary Packing List		(5)	4W	A	(5)	
65	Packing List		(5)	4W	A	(5)	
OPERATION & MAINTENANCE							
66	Operating Instructions		(5)	4W	A	(5)	
67	Maintenance Instructions		(5)	4W	A	(5)	
68	Commissioning & Start-up Manual		(5)	4W	A	(5)	
69	List of Spare Parts Commissioning & Start-up	4N	(5)	4W	A	(5)	
70	List of Spare Parts 2 Years Operation	4N	(5)	4W	A	(5)	
71	List of Special Tools	4N	(5)	4W	A	(5)	
72	Lube Oil Schedule		(5)	4W	A	(5)	
73	Software Manual (incl. Troubleshooting)		(5)	4W	A	(5)	
74	Consumables List		(5)	4W	A	(5)	
75	Function Test Procedure		(5)	4W	A	(5)	X
OTHERS							
76	Vendor Final Book		(5)	4W	A	(5)	X
77	All others documents will be listed in the order						
78							
79							

NOTES :

*** The electronic file (Native/PDF) and Hardcopy version shall be provided in all stages by vendor.

 NISOC	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 22 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02	

NO.	DESCRIPTION	WITH BID	AFTER ORDERING				AT THE FINAL INSPECTION (4)
		Q./TYPE (1)	Q./TY PE (1)	DELIVERY DATE (2)	PURPO SE (3)	FINAL ISSUE	
<p>(1) Q : QUANTITY ; TYPE : C = COPY,R = REPRODUCIBLE, P = POLYESTER, M = MICROFILM, E = ELECTRONIC, N=NUMBER OF DOCUMENT</p> <p>(2) W = CONSECUTIVE CALENDAR WEEK, M = CONSECUTIVE CALENDAR MONTH</p> <p>(3) A = FOR APPROVAL - I = FOR INFORMATION</p> <p>(4) X = DOCUMENTS TO BE SUBMITTED AT THE FINAL INSPECTION</p> <p>(5) "6 C+E" COPY OF DOCUMENT.</p> <p>(6) MECHANICAL CATALOGUE INCLUDING FINAL DRAWINGS/DOCUMENTS, UNPRICED PURCHASE ORDER & SUB- PURCHASE ORDER, MAINTENANCE DOSSIER ETC.</p> <p>(7) ALL DOCUMENTS AND/OR DRAWINGS FOR THIS PROJECT SHALL ALSO BE SUBMITTED IN THE ELECTRONIC FILES BY USING THE FOLLOWING SOFTWARE. MS OFFICE WORD 2013 OR UPPER VERSION (ENGLISH) FOR WORD PROCESSING MS OFFICE EXCEL 2013 OR UPPER VERSION (ENGLISH) FOR SPREAD SHEET AUTO CAD 2005 (ENGLISH) FOR DRAWING</p> <p>(8) IN ORDER TO DESIGN AND MANUFACTURE THE INSTRUMENTS, VENDOR SHALL CONSIDER THE SEISMIC FACTOR, SUITABLE FOR SEISMIC UBC 97 zone 4, AND THE RESULTS SHALL BE PROVIDED BY VENDOR.</p> <p>(9) List of Documents will be Finalized in VPIS.</p>							

D02

D02

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>							
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 23 از 24
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	IN	MR	0011	D02

ATTACHMENT 3

11.3 DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION

Requisition No.:

Description:

Equipment No.:

Item No.	Description of Proposed Exception	Recommended Revision to JOB SPECIFICATION	Reason for Proposed Exception	Effect on Base PROPOSAL if CONTRACTOR Rejects Exception

	<p>نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض</p> <p>احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک</p>								
شماره پیمان: 053 – 073 – 9184	PMR FOR DP FLOW /DP LEVEL /PRESSURE/DIFF. PRESSURE TRANSMITTER							شماره صفحه : 24 از 24	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	IN	MR	0011	D02	

ATTACHMENT 4

11.4 ALTERNATIVES TO JOB SPECIFICATION

Requisition No.:

Description:

Equipment No.:

Item No.	Job Specification No. & Paragraph No.	Requirements of Job Specification	Description of Proposed Alternative	Reason for Proposed Alternative