

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 1 : از 30
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

طرح نگهداشت و افزایش تولید 27 مخزن

HVAC CALCULATION NOTE FOR EXTENSION OF EXISTING ELECT. BUILDING

نگهداشت و افزایش تولید میدان نفتی بینک

Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
D03	MAR. 2024	IFA	K.Ahmadi	M.Fakharian	S.Faramarzpour	
D02	JAN. 2023	IFA	H.Adineh	M.Fakharian	M.Mehrshad	
D01	SEP. 2022	IFA	H.Adineh	M.Fakharian	M.Mehrshad	
D00	JUN. 2022	IFC	H.Adineh	M.Fakharian	M.Mehrshad	

Class: 2

CLIENT Doc. Number: F0Z-708866

Status:

IDC: Inter-Discipline Check
 IFC: Issued For Comment
 IFA: Issued For Approval
 AFD: Approved For Design
 AFC: Approved For Construction
 AFP: Approved For Purchase
 AFQ: Approved For Quotation
 IFI: Issued For Information
 AB-R: As-Built for CLIENT Review
 AB-A: As-Built –Approved

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک																	
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building <table border="1"> <tr> <td>نسخه</td> <td>سریال</td> <td>نوع مدرک</td> <td>رشته</td> <td>تسهیلات</td> <td>صادر کننده</td> <td>بسته کاری</td> <td>پروژه</td> </tr> <tr> <td>D03</td> <td>0002</td> <td>CN</td> <td>HV</td> <td>120</td> <td>PEDCO</td> <td>GCS</td> <td>BK</td> </tr> </table>	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	D03	0002	CN	HV	120	PEDCO	GCS	BK	شماره صفحه 2 : از 30
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه											
D03	0002	CN	HV	120	PEDCO	GCS	BK											

REVISION RECORD SHEET

PAGE	D00	D01	D02	D03	D04
1	X	X	X	X	
2	X	X	X	X	
3	X	X		X	
4	X	X		X	
5	X	X		X	
6	X	X		X	
7	X	X		X	
8	X	X		X	
9	X	X		X	
10	X	X		X	
11	X	X		X	
12	X	X		X	
13	X	X		X	
14	X	X		X	
15	X	X		X	
16	X	X		X	
17	X	X		X	
18	X	X		X	
19	X	X		X	
20	X	X		X	
21	X	X		X	
22	X	X		X	
23	X	X	X	X	
24	X	X		X	
25		X		X	
26		X		X	
27		X	X	X	
28				X	
29				X	
30				X	
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					

PAGE	D00	D01	D02	D03	D04
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073 – 9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 3 : از 30
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

CONTENTS

1.0	INTRODUCTION.....	4
2.0	SCOPE.....	4
3.0	NORMATIVE REFERENCES	5
3.1	LOCAL CODES AND STANDARDS.....	5
3.2	INTERNATIONAL CODES AND STANDARDS	5
3.3	ENVIRONMENTAL DATA	6
4.0	HVAC CALCULATION	6
4.1	DESIGN WEATHER PARAMETERS:	6
4.2	CONSTRUCTIONS U-VALUE:	10
4.3	SPACE INPUT DATA:	12
4.4	SYSTEM INPUT DATA:	15
4.5	AIR SYSTEM SIZING SUMMARAIR.....	18
4.6	VENTILATION SIZING SUMMARY	20
4.7	AIR SYSTEM DESIGN LOAD SUMMARY:	21
4.8	ZONE DESIGN LOAD SUMMARY:	23
4.9	SPACE DESIGN LOAD SUMMARY:	24
5.0	EQUIPMENT SELECTION	27
5.1	AIR CONDITIONING UNIT (SPLIT UNIT)	27
5.2	FAN FILTER UNIT SELECTION	29
5.3	EXHAUST FAN SELECTION	30

GENERAL COMMENT: all revised parts shall be highlighted and marked.

HE Reply:

The details of the external wall were modified.(Page 10)

Corrected results of calculations were presented.(Page 18–26)

Split air conditioner selection tables were updated based on corrected result.(Page 27–28)

Component pressure drop (external p.d.) of the fan filter unit and exhaust fan were corrected.(Page 29–30)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 4 : از 30
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – General Facilities
GENERAL CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of :Hirgan Energy – Design & Inspection(D&I) Companies
VENDOR:	The firm or person who will fabricate the equipment or material.
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	The firm appointed by EPD/EPC CONTRACTOR (GC) and approved by CLIENT (in writing) for the inspection of goods.
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by CLIENT rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR
MAY:	Is used where a provision is completely discretionary.

2.0 SCOPE

The main purpose of this document is to define the HVAC system load calculation has been carried out by computer program (HAP software) as per ASHRAE method in order to evaluate cooling load (summer) and heating load (winter) and also to select HVAC equipment for the calculated cooling and heating load.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 - 073- 9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 5 : از 30	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

3.0 NORMATIVE REFERENCES

3.1 LOCAL CODES AND STANDARDS

- IPS Iranian petroleum standards
- INBC Iranian National Building Code

3.2 INTERNATIONAL CODES AND STANDARDS

- ASTM American Society for Testing Materials Relevant Parts
- API 610 Centrifugal Pumps for General Refinery Service, 10th Edition
- ISO 15156 Petroleum and Natural Gas Industries. Materials for use in H2S Containing Environments in Oil and Gas Production
- AMCA Air Movement and Control Association
- ANSI American National Standards Institute.
- ASHRAE American Society of Heating, Refrigeration and Air-conditioning Engineer
- ASTM American Society for Testing and Material
- BOCA Building Officials and Code Administrators international
- BS British Standards
- CIBSE Chartered Institute of Building Services Engineers.
- NFPA National fire protection association
- SBCCI Southern Building Code Congress International
- SMACNA Sheet Metal and Air Conditioning Contractors' National Association
- AWWA American Water Works Association
- ASME The American Society of Mechanical Engineers

Note: The latest issued or revised edition of all above mentioned codes and standards shall be considered as reference.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 6 : از 30
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

3.3 ENVIRONMENTAL DATA

- ▶ Latitude 29° 73' N
- ▶ Longitude 50° 35' E
- ▶ Elevation 10 m
- ▶ Summer dry bulb temperature : 41° C
- ▶ Summer wet bulb temperature : 30.5° C
- ▶ Summer daily range temperature : 15.0° C
- ▶ Winter dry bulb temperature : 6° C
- ▶ Winter relative humidity : 78%

Refer to "Process Basis of Design; Doc. No BK-GNRAL-PEDCO-000-PR-DB-0001.

4.0 HVAC CALCULATION

4.1 DESIGN WEATHER PARAMETERS:

Design Parameters:

City Name	Binak
Location	IRAN
Latitude	29.7 Deg.
Longitude	-50.4 Deg.
Elevation	10.0 m
Summer Design Dry-Bulb	41.0 °C
Summer Coincident Wet-Bulb	30.5 °C
Summer Daily Range	15.0 °K
Winter Design Dry-Bulb	6.0 °C
Winter Design Wet-Bulb	4.4 °C
Atmospheric Clearness Number	1.00
Average Ground Reflectance	0.20
Soil Conductivity	1.385 W/(m-°K)
Local Time Zone (GMT +/- N hours)	-3.5 hours
Consider Daylight Savings Time	No
Simulation Weather Data	noneN/A
Current Data is	User Modified
Design Cooling Months	January to December

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 7 : از 30	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

Design Day Maximum Solar Heat Gains

(The MSHG values are expressed in W/m²)

Month	N	NNE	NE	ENE	E	ESE	SE	SSE	S
January	77.5	77.5	95.1	360.4	561.2	730.9	794.1	786.3	762.3
February	89.1	89.1	206.7	484.1	668.9	760.8	782.0	718.9	671.9
March	101.4	120.5	367.4	576.2	723.5	759.6	702.5	590.8	520.1
April	113.0	252.7	487.2	636.6	705.1	688.3	568.6	408.7	322.0
May	124.3	351.1	551.9	666.3	679.9	619.4	469.6	279.8	199.5
June	161.0	389.1	570.0	664.8	662.8	586.8	421.4	228.9	165.7
July	128.9	355.9	541.6	644.7	671.3	606.9	452.1	270.2	196.1
August	118.3	256.1	470.7	606.2	686.0	663.8	546.8	395.4	311.9
September	104.3	109.2	354.3	538.8	681.8	728.9	670.0	569.4	503.5
October	91.2	91.2	226.5	441.2	642.7	746.9	748.8	692.4	650.8
November	78.1	78.1	103.7	341.8	572.3	707.9	785.7	774.1	747.8
December	71.9	71.9	71.9	306.4	524.4	699.0	788.1	799.2	780.7
Month	SSW	SW	WSW	W	WNW	NW	NNW	HOR	Mult
January	779.8	791.7	733.2	577.4	337.4	108.2	77.5	591.4	1.00
February	716.3	777.2	772.2	650.4	482.8	225.6	89.1	714.5	1.00
March	590.5	703.8	755.6	713.7	589.1	369.6	114.3	816.8	1.00
April	413.5	574.6	682.6	707.6	645.8	485.9	241.4	863.3	1.00
May	282.1	471.6	614.4	688.4	669.7	550.4	343.5	875.1	1.00
June	233.1	424.2	577.0	674.2	670.6	567.0	376.4	872.9	1.00
July	274.2	458.7	596.0	677.5	657.5	539.9	345.0	865.3	1.00
August	398.9	554.0	657.3	682.8	624.7	473.1	240.3	846.4	1.00
September	569.0	669.3	728.9	681.0	540.4	354.6	108.6	783.8	1.00
October	697.0	755.4	737.2	647.9	457.7	216.5	91.2	696.8	1.00
November	775.6	786.0	708.0	568.2	351.0	91.0	78.1	582.8	1.00
December	798.2	790.7	685.6	536.9	295.2	71.9	71.9	533.5	1.00

Mult. = User-defined solar multiplier factor.

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
شماره پیمان: 053 – 073– 9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 8 : از 30
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	
	D03	0002	CN	HV	120	PEDCO	GCS	BK

Cooling Design Temperature Profile

Location: Binak, IRAN

(Dry and Wet Bulb temperatures are expressed in °C)


Hr	January		February		March		April		May		June	
	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB
0000	19.4	19.1	20.5	20.2	23.0	22.8	24.5	24.2	26.7	26.4	28.1	27.8
0100	18.6	18.3	19.7	19.5	22.3	22.0	23.7	23.5	26.0	25.7	27.4	27.1
0200	17.9	17.6	19.0	18.7	21.5	21.3	23.0	22.7	25.2	24.9	26.6	26.4
0300	17.3	17.0	18.4	18.1	20.9	20.7	22.4	22.1	24.6	24.3	26.0	25.8
0400	16.8	16.5	17.9	17.7	20.5	20.2	21.9	21.7	24.2	23.9	25.6	25.3
0500	16.7	16.4	17.8	17.5	20.3	20.1	21.8	21.5	24.0	23.7	25.4	25.2
0600	17.0	16.7	18.1	17.8	20.6	20.4	22.1	21.8	24.3	24.0	25.7	25.5
0700	17.7	17.4	18.8	18.6	21.4	21.1	22.8	22.6	25.1	24.8	26.5	26.2
0800	19.1	18.8	20.2	19.9	22.7	22.5	24.2	23.9	26.4	26.1	27.8	27.6
0900	21.0	20.7	22.1	21.9	24.7	24.4	26.1	25.9	28.4	27.0	29.8	28.2
1000	23.3	22.2	24.4	23.2	26.9	25.6	28.4	26.6	30.6	27.5	32.0	28.7
1100	25.8	22.9	26.9	23.9	29.5	26.2	30.9	27.2	33.2	28.1	34.6	29.3
1200	28.2	23.6	29.3	24.5	31.9	26.8	33.3	27.7	35.6	28.6	37.0	29.8
1300	30.0	24.1	31.1	25.0	33.7	27.2	35.1	28.1	37.4	29.0	38.8	30.2
1400	31.2	24.4	32.3	25.3	34.9	27.5	36.3	28.4	38.6	29.3	40.0	30.4
1500	31.7	24.5	32.8	25.4	35.3	27.6	36.8	28.5	39.0	29.4	40.4	30.5
1600	31.2	24.4	32.3	25.3	34.9	27.5	36.3	28.4	38.6	29.3	40.0	30.4
1700	30.2	24.1	31.3	25.0	33.8	27.3	35.3	28.2	37.5	29.1	38.9	30.2
1800	28.5	23.7	29.6	24.6	32.2	26.9	33.6	27.8	35.9	28.7	37.3	29.8
1900	26.6	23.1	27.7	24.1	30.2	26.4	31.7	27.3	33.9	28.3	35.3	29.4
2000	24.6	22.6	25.7	23.5	28.3	25.9	29.7	26.9	32.0	27.8	33.4	29.0
2100	23.0	22.1	24.1	23.1	26.6	25.5	28.1	26.5	30.3	27.4	31.7	28.6
2200	21.5	21.2	22.6	22.3	25.1	24.9	26.6	26.1	28.8	27.1	30.2	28.3
2300	20.3	20.0	21.4	21.1	23.9	23.7	25.4	25.1	27.6	26.8	29.0	28.0

Hr	July		August		September		October		November		December	
	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB
0000	28.7	27.8	28.7	27.8	27.6	27.2	25.6	25.3	22.5	22.2	19.9	19.6
0100	28.0	27.7	28.0	27.7	26.8	26.6	24.8	24.6	21.7	21.5	19.2	18.9
0200	27.2	26.9	27.2	26.9	26.1	25.8	24.1	23.8	21.0	20.7	18.4	18.1
0300	26.6	26.3	26.6	26.3	25.5	25.2	23.5	23.2	20.4	20.1	17.8	17.5
0400	26.2	25.9	26.2	25.9	25.0	24.8	23.0	22.8	19.9	19.7	17.4	17.1
0500	26.0	25.7	26.0	25.7	24.9	24.6	22.9	22.6	19.8	19.5	17.2	16.9
0600	26.3	26.0	26.3	26.0	25.2	24.9	23.2	22.9	20.1	19.8	17.5	17.2
0700	27.1	26.8	27.1	26.8	25.9	25.7	23.9	23.7	20.8	20.6	18.3	18.0
0800	28.4	27.8	28.4	27.8	27.3	27.0	25.3	25.0	22.2	21.9	19.6	19.3
0900	30.4	28.2	30.4	28.2	29.2	27.6	27.2	26.4	24.1	23.9	21.6	21.3
1000	32.6	28.7	32.6	28.7	31.5	28.1	29.5	26.9	26.4	25.4	23.8	23.4
1100	35.2	29.3	35.2	29.3	34.0	28.7	32.0	27.5	28.9	26.0	26.4	24.1
1200	37.6	29.8	37.6	29.8	36.4	29.2	34.4	28.1	31.3	26.6	28.8	24.7
1300	39.4	30.2	39.4	30.2	38.2	29.6	36.2	28.5	33.1	27.0	30.6	25.2
1400	40.6	30.4	40.6	30.4	39.4	29.8	37.4	28.7	34.3	27.3	31.8	25.5
1500	41.0	30.5	41.0	30.5	39.9	29.9	37.9	28.8	34.8	27.4	32.2	25.6
1600	40.6	30.4	40.6	30.4	39.4	29.8	37.4	28.7	34.3	27.3	31.8	25.5
1700	39.5	30.2	39.5	30.2	38.4	29.6	36.4	28.5	33.3	27.0	30.7	25.2
1800	37.9	29.9	37.9	29.9	36.7	29.3	34.7	28.1	31.6	26.6	29.1	24.8
1900	35.9	29.4	35.9	29.4	34.8	28.9	32.8	27.7	29.7	26.2	27.1	24.3
2000	34.0	29.0	34.0	29.0	32.8	28.4	30.8	27.2	27.7	25.7	25.2	23.8
2100	32.3	28.7	32.3	28.7	31.2	28.0	29.2	26.8	26.1	25.3	23.5	23.2
2200	30.8	28.3	30.8	28.3	29.7	27.7	27.7	26.5	24.6	24.3	22.0	21.7
2300	29.6	28.0	29.6	28.0	28.5	27.4	26.5	26.2	23.4	23.1	20.8	20.5

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 9 : از 30
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

Design Temperature Profile

Design Temperature Profiles for July



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							
	HVAC Calculation Note For Extension of Existing Elect. Building							
شماره پیمان: 053 - 073 - 9184	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
	BK	GCS	PEDCO	120	HV	CN	0002	D03

4.2 CONSTRUCTIONS U-VALUE:

Wall

Wall Details

Outside Surface Color Medium
 Absorptivity 0.675
 Overall U-Value 0.291 W/(m²-°K)

it is not correct

insulation layer shall be added

Wall Layers Details (Inside to Outside)

Layers	Thickness mm	Density kg/m ³	Specific Ht. kJ / (kg - °K)	R-Value (m ² -°K)/W	Weight kg/m ²
Inside surface resistance	0.000	0.0	0.00	0.12064	0.0
Gypsum plaster	5.000	800.9	1.09	0.03106	4.0
Cement plaster	20.000	1600.0	0.80	0.02500	32.0
HW concrete	300.000	2242.6	0.84	0.17334	672.8
Cement plaster	30.000	1600.0	0.80	0.03750	48.0
Face brick	90.000	2000.0	0.03	2.99571	180.0
Outside surface resistance	0.000	0.0	0.00	0.05864	0.0
Totals	445.000	-	-	3.44189	936.8

R=0.03 For face brick

Roof

Roof Details

Outside Surface Color Medium
 Absorptivity 0.675
 Overall U-Value 0.948 W/(m²-°K)

it is not correct

Roof Layers Details (Inside to Outside)

Layers	Thickness mm	Density kg/m ³	Specific Ht. kJ / (kg - °K)	R-Value (m ² -°K)/W	Weight kg/m ²
Inside surface resistance	0.000	0.0	0.00	0.12064	0.0
HW concrete	300.000	2242.6	0.84	0.17334	672.8
Poly Urtan	50.000	25.0	0.84	0.20000	1.3
HW concrete	300.000	977.1	0.84	0.28889	293.1
Waterproofing/isogume or similar	4.000	1000.0	1.67	0.17390	4.0
Cement plaster	25.000	1600.0	0.80	0.03750	40.0
Terrazzo tile	25.000	2000.0	0.84	0.00185	50.0
Outside surface resistance	0.000	0.0	0.00	0.05864	0.0
Totals	704.000	-	-	1.05476	1061.2

it is not correct

λ = 0.041 for polyurethane

B.P.D./T-1

Door Details:

Gross Area 2.6 m²
 Door U-Value 3.000 W/(m²-°K)

Glass Details:

Glass Area 0.0 m²
 Glass U-Value 3.293 W/(m²-°K)
 Glass Shade Coefficient 0.880
 Glass Shaded All Day? No

HE Reply:
 The details of the external wall were modified.(Page 10)

Ext. Dor W=1

Door Details:

Gross Area 2.2 m²
 Door U-Value 3.000 W/(m²-°K)

Glass Details:

Glass Area 0.0 m²
 Glass U-Value 3.293 W/(m²-°K)
 Glass Shade Coefficient 0.880
 Glass Shaded All Day? No

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073 – 9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 11 : از 30
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	
	D03	0002	CN	HV	120	PEDCO	GCS	BK	

Ext. Dor W=2

Door Details:

Gross Area 4.4 m²
Door U-Value 3.000 W/(m²-°K)

Glass Details:

Glass Area 0.0 m²
Glass U-Value 3.293 W/(m²-°K)
Glass Shade Coefficient 0.880
Glass Shaded All Day? No

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							 شماره صفحه 12 : از 30
شماره پیمان: 053 - 073 - 9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 12 : از 30
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	
	BK	GCS	PEDCO	120	HV	CN	0002	D03

4.3 SPACE INPUT DATA:

01-Capacitor Bank

1. General Details:

Floor Area 24.7 m²
Avg. Ceiling Height 4.1 m
Building Weight 341.8 kg/m²

1.1. OA Ventilation Requirements:

Space Usage User-Defined
OA Requirement 1 0.0 L/s/person
OA Requirement 2 0.00 L/(s-m²)
Space Usage Defaults . ASHRAE Standard 62.1-2010

2. Internals:

2.1. Overhead Lighting:

Fixture Type Recessed (Unvented)
Wattage 20.00 W/m²
Ballast Multiplier 1.00
Schedule Lighting

Occupancy 0.0 Person
Activity Level Office Work
Sensible 71.8 W/person
Latent 60.1 W/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 W
Schedule None
Latent 0 W
Schedule None

2.2. Task Lighting:

Wattage 0.00 W/m²
Schedule None

2.3. Electrical Equipment:

Wattage 4920.0 Watts
Schedule Electrical Eq.

2.4. People:

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (m ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
NNW	26.2	0	0	0
ENE	15.6	0	0	1

3.1. Construction Types for Exposure NNW

Wall Type Wall

3.2. Construction Types for Exposure ENE

Wall Type Wall
Door Type B.P.D./T-1

4. Roofs, Skylights:

Exp.	Roof Gross Area (m ²)	Roof Slope (deg.)	Skylight Qty.
H	24.7	0	0

4.1. Construction Types for Exposure H

Roof Type Roof

5. Infiltration:

Design Cooling 1.00 ACH
Design Heating 1.00 ACH
Energy Analysis 1.00 ACH

Infiltration occurs at all hours.

6. Floors:

Type Slab Floor On Grade
Floor Area 24.7 m²
Total Floor U-Value 0.568 W/(m²-°K)
Exposed Perimeter 10.3 m
Edge Insulation R-Value 0.00 (m²-°K)/W

7. Partitions:

7.1. 1st Partition Details:

Partition Type Wall Partition
Area 41.8 m²
U-Value 1.260 W/(m²-°K)
Uncondit. Space Max Temp 35.0 °C
Ambient at Space Max Temp 41.0 °C
Uncondit. Space Min Temp 12.8 °C
Ambient at Space Min Temp 6.0 °C

7.2. 2nd Partition Details:

(No partition data).

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							 شماره صفحه 13 : از 30
شماره پیمان: 053 - 073 - 9184	HVAC Calculation Note For Extension of Existing Elect. Building							
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	HV	CN	0002	D03

02-High Voltage Room

1. General Details:

Floor Area 129.8 m²
Avg. Ceiling Height 4.1 m
Building Weight 341.8 kg/m²

1.1. OA Ventilation Requirements:

Space Usage User-Defined
OA Requirement 1 332.7 L/s
OA Requirement 2 0.00 L/(s-m²)
Space Usage Defaults . ASHRAE Standard 62.1-2010

2. Internals:

2.1. Overhead Lighting:

Fixture Type Recessed (Unvented)
Wattage 20.00 W/m²
Ballast Multiplier 1.00
Schedule Lighting

2.2. Task Lighting:

Wattage 0.00 W/m²
Schedule None

2.3. Electrical Equipment:

Wattage 20960.0 Watts
Schedule Electrical Eq.

2.4. People:

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (m ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
NNW	51.1	0	0	0
ENE	21.4	0	0	1

3.1. Construction Types for Exposure NNW

Wall Type Wall

3.2. Construction Types for Exposure ENE

Wall Type Wall
Door Type Ext. Dor W=2

4. Roofs, Skylights:

Exp.	Roof Gross Area (m ²)	Roof Slope (deg.)	Skylight Qty.
H	129.8	0	0

4.1. Construction Types for Exposure H

Roof Type Roof

5. Infiltration:

Design Cooling 0.00 ACH
Design Heating 0.00 ACH
Energy Analysis 0.00 ACH

Infiltration occurs at all hours.

6. Floors:

Type Floor Above Unconditioned Space
Floor Area 129.8 m²
Total Floor U-Value 0.568 W/(m²-°K)
Unconditioned Space Max Temp. 35.0 °C
Ambient at Space Max Temp. 41.0 °C
Unconditioned Space Min Temp. 12.8 °C
Ambient at Space Min Temp. 6.0 °C

7. Partitions:

7.1. 1st Partition Details:

Partition Type Wall Partition
Area 43.4 m²
U-Value 1.260 W/(m²-°K)
Uncondit. Space Max Temp. 35.0 °C
Ambient at Space Max Temp. 41.0 °C
Uncondit. Space Min Temp. 12.8 °C
Ambient at Space Min Temp. 6.0 °C

7.2. 2nd Partion Details:

(No partition data).

Occupancy 0.0 Person
Activity Level Office Work
Sensible 71.8 W/person
Latent 60.1 W/person
Schedule None

2.5. Miscellaneous Loads:

Sensible 0 W
Schedule None
Latent 0 W
Schedule None

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							 شماره صفحه 14 : از 30
شماره پیمان: 053 - 073 - 9184	HVAC Calculation Note For Extension of Existing Elect. Building							
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	HV	CN	0002	D03

03-Low Voltage Room

1. General Details:

Floor Area 156.6 m²
Avg. Ceiling Height 4.1 m
Building Weight 341.8 kg/m²

1.1. OA Ventilation Requirements:

Space Usage User-Defined
OA Requirement 1 389.4 L/s
OA Requirement 2 0.00 L/(s-m²)
Space Usage Defaults . ASHRAE Standard 62.1-2010

2. Internals:

2.1. Overhead Lighting:

Fixture Type Recessed (Unvented)
Wattage 20.00 W/m²
Ballast Multiplier 1.00
Schedule Lighting

2.2. Task Lighting:

Wattage 0.00 W/m²
Schedule None

2.3. Electrical Equipment:

Wattage 37361.0 Watts
Schedule Electrical Eq.

3. Walls, Windows, Doors:

Exp.	Wall Gross Area (m ²)	Window 1 Qty.	Window 2 Qty.	Door 1 Qty.
WSW	21.4	0	0	1
SSE	13.6	0	0	0
ENE	21.4	0	0	1

3.1. Construction Types for Exposure WSW

Wall Type Wall
Door Type Ext. Dor W=1

3.2. Construction Types for Exposure SSE

Wall Type Wall

3.3. Construction Types for Exposure ENE

Wall Type Wall
Door Type Ext. Dor W=2

4. Roofs, Skylights:

Exp.	Roof Gross Area (m ²)	Roof Slope (deg.)	Skylight Qty.
H	156.6	0	0

4.1. Construction Types for Exposure H

Roof Type Roof

5. Infiltration:

Design Cooling 0.00 ACH
Design Heating 0.00 ACH
Energy Analysis 0.00 ACH
Infiltration occurs at all hours.

6. Floors:

Type Floor Above Unconditioned Space
Floor Area 156.6 m²
Total Floor U-Value 0.568 W/(m²-°K)
Unconditioned Space Max Temp. 35.0 °C
Ambient at Space Max Temp. 41.0 °C
Unconditioned Space Min Temp. 12.8 °C
Ambient at Space Min Temp. 6.0 °C

7. Partitions:

7.1. 1st Partition Details:

Partition Type Wall Partition
Area 128.4 m²
U-Value 1.260 W/(m²-°K)
Uncondit. Space Max Temp 35.0 °C
Ambient at Space Max Temp 41.0 °C
Uncondit. Space Min Temp 12.8 °C
Ambient at Space Min Temp 6.0 °C

7.2. 2nd Partition Details:

(No partition data).

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک																	
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building <table border="1"> <tr> <td>پروژه</td> <td>بسته کاری</td> <td>صادر کننده</td> <td>تسهيلات</td> <td>رشته</td> <td>نوع مدرک</td> <td>سريال</td> <td>نسخه</td> </tr> <tr> <td>BK</td> <td>GCS</td> <td>PEDCO</td> <td>120</td> <td>HV</td> <td>CN</td> <td>0002</td> <td>D03</td> </tr> </table>	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه	BK	GCS	PEDCO	120	HV	CN	0002	D03	شماره صفحه 15 : از 30
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه											
BK	GCS	PEDCO	120	HV	CN	0002	D03											

4.4 SYSTEM INPUT DATA:

Capacitor Bank System

1. General Details:

Air System Name Capacitor Bank System
 Equipment Type Terminal Units
 Air System Type Split DX Fan Coil
 Number of zones 1
 Ventilation Direct Ventilation

2. Ventilation System Components:

(Common Ventilation System not used: no inputs)

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
01-Capacitor Bank	x1

Thermostats and Zone Data:

Zone	Cooling T-Stat Occ. (°C)	Cooling T-Stat Unocc. (°C)	Heating T-Stat Occ. (°C)	Heating T-Stat Unocc. (°C)	T-Stat Throttling Range (°C)
1	30.0	31.0	10.0	8.0	0.83

Thermostat Schedule Fan
 Unoccupied Cooling is Available

Common Terminal Unit Data:

Cooling Coil:
 Design Supply Temperature 18.0 °C
 Coil Bypass Factor 0.100
 Cooling Source Air-Cooled DX
 Schedule JFMAMJJASOND

Heating Coil:
 Design Supply Temperature 35.0 °C
 Heating Source Electric Resistance
 Schedule JFMAMJJASOND
 Fan Control Fan On
 Ventilation Sizing Method ASHRAE Std 62.1-2010

Terminal Units Data:

Zone All
 Terminal Type Fan Coil
 Minimum Airflow 0.00 L/s/person
 Fan Performance 0 Pa
 Fan Overall Efficiency 50 %

4. Sizing Data (Computer-Generated):

System Sizing Data:

Sizing Data:
Hydronic Sizing Specifications:
 Chilled Water Delta-T 5.6 °K
 Hot Water Delta-T 11.1 °K
Safety Factors:
 Cooling Sensible 10 %
 Cooling Latent 10 %
 Heating 10 %

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							 شماره صفحه 16 : از 30
شماره پیمان: 053 - 073 - 9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 16 : از 30
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	HV	CN	0002	D03

Elec. Building System

1. General Details:

Air System Name Elec. Building
 Equipment Type Packaged Rooftop Units
 Air System Type Single Zone CAV
 Number of zones 1

2. Ventilation System Components:

Ventilation Air Data:

Airflow Control Constant Ventilation Airflow
 Ventilation Sizing Method Sum of Space OA Airflows
 Unocc. Damper Position Closed
 Damper Leak Rate 0 %
 Outdoor Air CO2 Level 400 ppm

Central Cooling Data:

Supply Air Temperature 14.4 °C
 Coil Bypass Factor 0.100
 Cooling Source Air-Cooled DX
 Schedule JFMAMJJASOND
 Capacity Control Cycled or Staged Capacity - Fan On

Central Heating Data:

Supply Temperature 35.0 °C
 Heating Source Electric Resistance
 Schedule JFMAMJJASOND
 Capacity Control Cycled or Staged Capacity - Fan On

Supply Fan Data:

Fan Type Forward Curved
 Configuration Draw-thru
 Fan Performance 0 Pa
 Overall Efficiency 54 %
 Fan Control 1-speed fan, cooling and heating

Duct System Data:

Supply Duct Data:

Duct Heat Gain 0 %
 Duct Leakage 0 %

Return Duct or Plenum Data:

Return Air Via Ducted Return

3. Zone Components:

Space Assignments:

Zone 1: Zone 1	
02-High Voltage Room	x1
03-Low Voltage Room	x1

Thermostats and Zone Data:

Zone All
 Cooling T-stat: Occ. 30.0 °C
 Cooling T-stat: Unocc. 31.0 °C
 Heating T-stat: Occ. 10.0 °C
 Heating T-stat: Unocc. 8.0 °C
 T-stat Throttling Range 0.83 °K
 Diversity Factor 100 %
 Direct Exhaust Airflow 0.0 L/s
 Direct Exhaust Fan kW 0.0 kW
 Thermostat Schedule Fan
 Unoccupied Cooling is Available

Supply Terminals Data:

Zone All
 Terminal Type Diffuser
 Minimum Airflow 0.00 L/s/person

Zone Heating Units:

Zone All
 Zone Heating Unit Type None
 Zone Unit Heat Source Electric Resistance
 Zone Heating Unit Schedule JFMAMJJASOND

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073 – 9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 17 : از 30
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	
	D03	0002	CN	HV	120	PEDCO	GCS	BK	

4. Sizing Data (Computer-Generated):

System Sizing Data:

Sizing Data:

Hydronic Sizing Specifications:

Chilled Water Delta-T 5.6 °K
Hot Water Delta-T 11.1 °K

Safety Factors:

Cooling Sensible 10 %
Cooling Latent 10 %
Heating 10 %

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 18 : از 30	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

4.5 AIR SYSTEM SIZING SUMMARAIR

Capacitor Bank System

Air System Information

Air System Name Capacitor Bank System
Equipment Class TERM
Air System Type SPLT-FC

Number of zones 1
Floor Area 24.7 m²
Location Binak, IRAN

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (kW)	Design Airflow (L/s)	Minimum Airflow (L/s)	Time of Peak Load	Maximum Heating Load (kW)	Zone Floor Area (m ²)	Zone L/(s-m ²)
Zone 1	6.5	448	448	Jul 1500	0.4	24.7	18.15

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 5.6 °K (L/s)	Time of Peak Load
Zone 1	7.4	6.4	30.6 / 22.1	18.7 / 17.9	-	Jul 1600

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 °K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.4	10.1 / 10.7	-	448	0.000	0.000	0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s-m ²)
Zone 1							
01-Capacitor Bank	1	6.5	Jul 1500	448	0.4	24.7	18.15

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک							 شماره صفحه 19 : از 30
شماره پیمان: 053 - 073 - 9184	HVAC Calculation Note For Extension of Existing Elect. Building							
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	PEDCO	120	HV	CN	0002	D03

Elec. Building System

Air System Information

Air System Name Elec. Building
Equipment Class PKG ROOF
Air System Type SZCAV

Number of zones 1
Floor Area 286.4 m²
Location Binak, IRAN

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Central Cooling Coil Sizing Data

Total coil load 107.7 kW
Sensible coil load 78.6 kW
Coil L/s at Aug 1500 3768 L/s
Max block L/s 3768 L/s
Sum of peak zone L/s 3768 L/s
Sensible heat ratio 0.730
m²/kW 2.7
W/m² 375.9
Water flow @ 5.6 °K rise N/A

Load occurs at Aug 1500
OA DB / WB 41.0 / 30.5 °C
Entering DB / WB 32.6 / 22.2 °C
Leaving DB / WB 15.3 / 14.4 °C
Coil ADP 13.3 °C
Bypass Factor 0.100
Resulting RH 36 %
Design supply temp. 14.4 °C
Zone T-stat Check 1 of 1 OK
Max zone temperature deviation 0.0 °K

Central Heating Coil Sizing Data

Max coil load 4.5 kW
Coil L/s at Des Htg 3768 L/s
Max coil L/s 3768 L/s
Water flow @ 11.1 °K drop N/A

Load occurs at Des Htg
W/m² 15.9
Ent. DB / Lvg DB 9.1 / 10.1 °C

Supply Fan Sizing Data

Actual max L/s 3768 L/s
Standard L/s 3764 L/s
Actual max L/(s-m²) 13.16 L/(s-m²)

Fan motor BHP 0.00 BHP
Fan motor kW 0.00 kW
Fan static 0 Pa

Outdoor Ventilation Air Data

Design airflow L/s 722 L/s
L/(s-m²) 2.52 L/(s-m²)
L/s/person 0.00 L/s/person

Zone Sizing Data

Zone Name	Maximum Cooling Sensible (kW)	Design Airflow (L/s)	Minimum Airflow (L/s)	Time of Peak Load	Maximum Heating Load (kW)	Zone Floor Area (m ²)	Zone L/(s-m ²)
Zone 1	70.7	3768	3768	Jul 0800	1.5	286.4	13.16

Zone Terminal Sizing Data

No Zone Terminal Sizing Data required for this system.

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s-m ²)
Zone 1							
02-High Voltage Room	1	26.2	Jul 0800	1395	0.7	129.8	10.75
03-Low Voltage Room	1	44.5	Jul 0800	2374	0.8	156.6	15.16

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 20 : از 30	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

4.6 VENTILATION SIZING SUMMARY

Capacitor Bank System

1. Summary

Ventilation Sizing Method ASHRAE Std 62.1-2010

Design Condition Cooling operation

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Supply Air (L/s) (Vpz)	Space Floor Area (m²) (Az)	Area Outdoor Air Rate (L/(s-m²)) (Ra)	Time Averaged Occupancy (Occupants) (Pz)	People Outdoor Air Rate (L/s/person) (Rp)	Air Distribution Effectiveness (Ez)	Space Outdoor Air (L/s) (Voz)	Breathing Zone Outdoor Air (L/s) (Vbz)	Space Ventilation Efficiency (Evz)
Zone 1										
01-Capacitor Bank	1	448	24.7	0.00	0.0	0.00	1.00	0	0	1.000
Totals (incl. Space Multipliers)		448							0	1.000

Elec. Building System

1. Summary

Ventilation Sizing Method Sum of Space OA Airflows

Design Ventilation Airflow Rate 722 L/s

2. Space Ventilation Analysis Table

Zone Name / Space Name	Mult.	Floor Area (m²)	Maximum Occupants	Maximum Supply Air (L/s)	Required Outdoor Air (L/s/person)	Required Outdoor Air (L/(s-m²))	Required Outdoor Air (L/s)	Required Outdoor Air (% of supply)	Uncorrected Outdoor Air (L/s)
Zone 1									
02-High Voltage Room	1	129.8	0.0	1394.9	0.00	0.00	332.7	0.0	332.7
03-Low Voltage Room	1	156.6	0.0	2373.5	0.00	0.00	389.4	0.0	389.4
Totals (incl. Space Multipliers)				3768.4					722.1

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 - 073 - 9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 21 : از 30	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

4.7 AIR SYSTEM DESIGN LOAD SUMMARY:

Capacitor Bank System

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1600			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 40.6 °C / 30.4 °C			HEATING OA DB / WB 6.0 °C / 4.4 °C		
ZONE LOADS	Details	Sensible (W)	Latent (W)	Details	Sensible (W)	Latent (W)
Window & Skylight Solar Loads	0 m²	0	-	0 m²	-	-
Wall Transmission	39 m²	82	-	39 m²	46	-
Roof Transmission	25 m²	268	-	25 m²	94	-
Window Transmission	0 m²	0	-	0 m²	0	-
Skylight Transmission	0 m²	0	-	0 m²	0	-
Door Loads	3 m²	64	-	3 m²	31	-
Floor Transmission	25 m²	0	-	25 m²	23	-
Partitions	42 m²	169	-	42 m²	0	-
Ceiling	0 m²	0	-	0 m²	0	-
Overhead Lighting	0 W	11	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	4920 W	4920	-	0	0	-
People	0	0	0	0	0	0
Infiltration	-	358	853	-	136	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 10%	587	85	10%	33	0
>> Total Zone Loads	-	6459	938	-	362	0
Zone Conditioning	-	6417	938	-	371	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Exhaust Fan Load	0 L/s	0	-	0 L/s	0	-
Ventilation Load	0 L/s	0	0	0 L/s	0	0
Ventilation Fan Load	0 L/s	0	-	0 L/s	0	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	6417	938	-	371	0
Terminal Unit Cooling	-	6417	950	-	0	0
Terminal Unit Heating	-	0	-	-	371	-
>> Total Conditioning	-	6417	950	-	371	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 22 : از 30	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

Elec. Building System

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Aug 1500 COOLING OA DB / WB 41.0 °C / 30.5 °C			HEATING DATA AT DES HTG HEATING OA DB / WB 6.0 °C / 4.4 °C		
ZONE LOADS	Details	Sensible (W)	Latent (W)	Details	Sensible (W)	Latent (W)
Window & Skylight Solar Loads	0 m²	0	-	0 m²	-	-
Wall Transmission	118 m²	236	-	118 m²	137	-
Roof Transmission	286 m²	2907	-	286 m²	1086	-
Window Transmission	0 m²	0	-	0 m²	0	-
Skylight Transmission	0 m²	0	-	0 m²	0	-
Door Loads	11 m²	274	-	11 m²	132	-
Floor Transmission	286 m²	536	-	286 m²	0	-
Partitions	172 m²	713	-	172 m²	0	-
Ceiling	0 m²	0	-	0 m²	0	-
Overhead Lighting	0 W	140	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	58321 W	58318	-	0	0	-
People	0	0	0	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 10%	6312	0	10%	136	0
>> Total Zone Loads	-	69437	0	-	1491	0
Zone Conditioning	-	69529	0	-	1189	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	3768 L/s	0	-	3768 L/s	0	-
Ventilation Load	722 L/s	9079	29054	722 L/s	3360	0
Supply Fan Load	3768 L/s	0	-	3768 L/s	0	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	78608	29054	-	4548	0
Central Cooling Coil	-	78608	29055	-	0	0
Central Heating Coil	-	0	-	-	4548	-
>> Total Conditioning	-	78608	29055	-	4548	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 23 : از 30	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

4.8 ZONE DESIGN LOAD SUMMARY:

Capacitor Bank System

Zone 1	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1500 COOLING OA DB / WB 41.0 °C / 30.5 °C			HEATING DATA AT DES HTG HEATING OA DB / WB 6.0 °C / 4.4 °C		
	OCCUPIED T-STAT 30.0 °C			OCCUPIED T-STAT 10.0 °C		
ZONE LOADS	Details	Sensible (W)	Latent (W)	Details	Sensible (W)	Latent (W)
Window & Skylight Solar Loads	0 m ²	0	-	0 m ²	-	-
Wall Transmission	39 m ²	81	-	39 m ²	46	-
Roof Transmission	25 m ²	272	-	25 m ²	94	-
Window Transmission	0 m ²	0	-	0 m ²	0	-
Skylight Transmission	0 m ²	0	-	0 m ²	0	-
Door Loads	3 m ²	65	-	3 m ²	31	-
Floor Transmission	25 m ²	0	-	25 m ²	23	-
Partitions	42 m ²	174	-	42 m ²	0	-
Ceiling	0 m ²	0	-	0 m ²	0	-
Overhead Lighting	0 W	12	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	4920 W	4920	-	0	0	-
People	0	0	0	0	0	0
Infiltration	-	373	843	-	136	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 10%	590	84	10%	33	0
>> Total Zone Loads	-	6486	928	-	362	0

Elec. Building System

Zone 1	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 0800 COOLING OA DB / WB 28.4 °C / 27.8 °C			HEATING DATA AT DES HTG HEATING OA DB / WB 6.0 °C / 4.4 °C		
	OCCUPIED T-STAT 30.0 °C			OCCUPIED T-STAT 10.0 °C		
ZONE LOADS	Details	Sensible (W)	Latent (W)	Details	Sensible (W)	Latent (W)
Window & Skylight Solar Loads	0 m ²	0	-	0 m ²	-	-
Wall Transmission	118 m ²	270	-	118 m ²	137	-
Roof Transmission	286 m ²	3448	-	286 m ²	1086	-
Window Transmission	0 m ²	0	-	0 m ²	0	-
Skylight Transmission	0 m ²	0	-	0 m ²	0	-
Door Loads	11 m ²	-27	-	11 m ²	132	-
Floor Transmission	286 m ²	-406	-	286 m ²	0	-
Partitions	172 m ²	-541	-	172 m ²	0	-
Ceiling	0 m ²	0	-	0 m ²	0	-
Overhead Lighting	5728 W	3194	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	58321 W	58318	-	0	0	-
People	0	0	0	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 10%	6426	0	10%	136	0
>> Total Zone Loads	-	70681	0	-	1491	0

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 24 : از 30	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

4.9 SPACE DESIGN LOAD SUMMARY:

Capacitor Bank System

TABLE 1.1.A. COMPONENT LOADS FOR SPACE " 01-Capacitor Bank " IN ZONE " Zone 1 "						
	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1500 COOLING OA DB / WB 41.0 °C / 30.5 °C OCCUPIED T-STAT 30.0 °C			HEATING DATA AT DES HTG HEATING OA DB / WB 6.0 °C / 4.4 °C OCCUPIED T-STAT 10.0 °C		
		Sensible	Latent		Sensible	Latent
SPACE LOADS	Details	(W)	(W)	Details	(W)	(W)
Window & Skylight Solar Loads	0 m ²	0	-	0 m ²	-	-
Wall Transmission	39 m ²	81	-	39 m ²	46	-
Roof Transmission	25 m ²	272	-	25 m ²	94	-
Window Transmission	0 m ²	0	-	0 m ²	0	-
Skylight Transmission	0 m ²	0	-	0 m ²	0	-
Door Loads	3 m ²	65	-	3 m ²	31	-
Floor Transmission	25 m ²	0	-	25 m ²	23	-
Partitions	42 m ²	174	-	42 m ²	0	-
Ceiling	0 m ²	0	-	0 m ²	0	-
Overhead Lighting	0 W	12	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	4920 W	4920	-	0	0	-
People	0	0	0	0	0	0
Infiltration	-	373	843	-	136	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 10%	590	84	10%	33	0
>> Total Zone Loads	-	6486	928	-	362	0

TABLE 1.1.B. ENVELOPE LOADS FOR SPACE " 01-Capacitor Bank " IN ZONE " Zone 1 "						
	Area	U-Value	Shade	COOLING TRANS	COOLING SOLAR	HEATING TRANS
	(m ²)	(W/(m ² ·°K))	Coeff.	(W)	(W)	(W)
NNW EXPOSURE						
WALL	26	0.291	-	47	-	30
ENE EXPOSURE						
WALL	13	0.291	-	34	-	15
DOOR	3	3.000	-	65	-	31
H EXPOSURE						
ROOF	25	0.948	-	272	-	94

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 25 : از 30	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

Elec. Building System

TABLE 1.1.A. COMPONENT LOADS FOR SPACE " 02-High Voltage Room " IN ZONE " Zone 1 "						
	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 0800 COOLING OA DB / WB 28.4 °C / 27.8 °C OCCUPIED T-STAT 30.0 °C			HEATING DATA AT DES HTG HEATING OA DB / WB 6.0 °C / 4.4 °C OCCUPIED T-STAT 10.0 °C		
		Sensible (W)	Latent (W)		Sensible (W)	Latent (W)
SPACE LOADS	Details			Details		
Window & Skylight Solar Loads	0 m ²	0	-	0 m ²	-	-
Wall Transmission	68 m ²	146	-	68 m ²	79	-
Roof Transmission	130 m ²	1562	-	130 m ²	492	-
Window Transmission	0 m ²	0	-	0 m ²	0	-
Skylight Transmission	0 m ²	0	-	0 m ²	0	-
Door Loads	4 m ²	-11	-	4 m ²	53	-
Floor Transmission	130 m ²	-184	-	130 m ²	0	-
Partitions	43 m ²	-137	-	43 m ²	0	-
Ceiling	0 m ²	0	-	0 m ²	0	-
Overhead Lighting	2596 W	1448	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	20960 W	20959	-	0	0	-
People	0	0	0	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 10%	2378	0	10%	62	0
>> Total Zone Loads	-	26162	0	-	687	0

TABLE 1.1.B. ENVELOPE LOADS FOR SPACE " 02-High Voltage Room " IN ZONE " Zone 1 "						
	Area	U-Value	Shade	COOLING	COOLING	HEATING
	(m ²)	(W/(m ² -°K))	Coeff.	TRANS (W)	SOLAR (W)	TRANS (W)
NNW EXPOSURE						
WALL	51	0.291	-	103	-	59
ENE EXPOSURE						
WALL	17	0.291	-	44	-	20
DOOR	4	3.000	-	-11	-	53
H EXPOSURE						
ROOF	130	0.948	-	1562	-	492

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 - 073 - 9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 26 : از 30	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002		D03

TABLE 1.2.A. COMPONENT LOADS FOR SPACE " 03-Low Voltage Room " IN ZONE " Zone 1 "						
DESIGN COOLING			DESIGN HEATING			
COOLING DATA AT Jul 0800 COOLING OA DB / WB 28.4 °C / 27.8 °C OCCUPIED T-STAT 30.0 °C			HEATING DATA AT DES HTG HEATING OA DB / WB 6.0 °C / 4.4 °C OCCUPIED T-STAT 10.0 °C			
		Sensible (W)	Latent (W)		Sensible (W)	Latent (W)
SPACE LOADS	Details			Details		
Window & Skylight Solar Loads	0 m ²	0	-	0 m ²	-	-
Wall Transmission	50 m ²	123	-	50 m ²	58	-
Roof Transmission	157 m ²	1885	-	157 m ²	594	-
Window Transmission	0 m ²	0	-	0 m ²	0	-
Skylight Transmission	0 m ²	0	-	0 m ²	0	-
Door Loads	7 m ²	-16	-	7 m ²	79	-
Floor Transmission	157 m ²	-222	-	157 m ²	0	-
Partitions	128 m ²	-404	-	128 m ²	0	-
Ceiling	0 m ²	0	-	0 m ²	0	-
Overhead Lighting	3132 W	1747	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	37361 W	37359	-	0	0	-
People	0	0	0	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	10% / 10%	4047	0	10%	73	0
>> Total Zone Loads	-	44519	0	-	804	0

TABLE 1.2.B. ENVELOPE LOADS FOR SPACE " 03-Low Voltage Room " IN ZONE " Zone 1 "						
	Area	U-Value	Shade	COOLING TRANS	COOLING SOLAR	HEATING TRANS
	(m ²)	(W/(m ² -°K))	Coeff.	(W)	(W)	(W)
WSW EXPOSURE						
WALL	19	0.291	-	53	-	22
DOOR	2	3.000	-	-5	-	26
SSE EXPOSURE						
WALL	14	0.291	-	27	-	16
ENE EXPOSURE						
WALL	17	0.291	-	44	-	20
DOOR	4	3.000	-	-11	-	53
H EXPOSURE						
ROOF	157	0.948	-	1885	-	594

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 - 073 - 9184	HVAC Calculation Note For Extension of Existing Elect. Building							شماره صفحه 27 : از 30	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

5.0 Equipment Selection

5.1 AIR CONDITIONING UNIT (SPLIT UNIT)

Capacitor Bank System

Item	Service Area Capacitor Bank
Calculated Sensible Cooling Load(w)	6486
Calculated Latent Cooling Load(w)	928
Calculated Total Cooling Load(w)	7414
Calculated Total Cooling Load (btu/hr)	25320
Calculated Sensible Heating Load(w)	362
Calculated Sensible Heating Load (btu/hr)	1236
Eq. ID (1202-SUI/SUO-GCSEB-XX)	01
Equipment QTY.	1 duty / 1 standby
Equipment Type	W.M.*
Eq. Calculated Cooling Load+ 10% Over Cap. (btu/hr)	27852
Eq. Calculated Heating Load+ 10% Over Cap. (btu/hr)	1360
Selected Eq. Nominal Cooling Cap. (btu/hr)	B.V.**
Selected Eq. Actual Cooling Cap. (btu/hr)	B.V.**
Selected Eq. Actual Heating Cap. (btu/hr)	B.V.**
Power Supply (V/PH/Hz)	230/1/50
Max. Power Consumption (w) Eq. (Cooling/Heating)	B.V.**
REMARKE ***	Cooling & Heating (Heat Pump)

*Wall Mounted Split unit

**By Vendor

***Indoor & Outdoor Unit-T3, With Thermostat and All Standard Accessory

Elec. Building System

Existing Package Unit:

PACKAGE UNIT SCHEDULE	
Performance	Tag No. : PU-02-01 , PU-02-02
	Cooling Capacity: 53400 KCAL/HR
	Nominal Tonnage: 25 TON
	Supply Air:12000 CMH – Fresh Air :2550 CMH
	SUMMER Air Inlet Temp. :80.5/68.8 °F Leaving Temp. :57.7/56.6 °F
Elec. Data	400-3-50
Physical Data	Dimensions:5200×2000×174 mm
	Operating Weight=1970 kg
Designation & Quantity	P.U-2 QTY=1
	MAX. Ambient Temp.= 125 °F
Com. Data	Elec. Power =25 HP 400-3-50
	Thermal =75450 Kcal/Hr
Condenser Data	QTY=2
	HP=3 HP
Fan Data	Elec.-400-3-50
	RPM=1450
Model	Similar to SARAN P.U. Model SPAR 25-1 Roof Top
Quantity	QTY.=2 One as Standby

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053 – 073– 9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 28 : از 30
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

High Voltage and Low Voltage Room:

Central Cooling Coil Sizing Data (From Hap 4.9)

Total coil load	107.7	kW
Sensible coil load	78.6	kW
Coil L/s at Aug 1500	3768	L/s
Max block L/s	3768	L/s
Sum of peak zone L/s	3768	L/s
Sensible heat ratio	0.730	
m ² /kW	2.7	
W/m ²	375.9	

Existing Package Unit Actual Total Cooling Capacity = 53400 kcal/hr = 17.8 ton = 62.6 kW

Total Cooling Load – Package Unit Cooling Capacity = 107.7 – 62.6 = 45.1 kW

LV & HV Rooms Split units new loads = 45.1 kW

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Cooling Latent (kW)	Heating (kW)
02-High Voltage Room	1	26.162	0	0.687
03-Low Voltage Room	1	44.519	0	0.804

$$\text{Low Voltage Room load Ratio} = \frac{44.5}{44.5 + 26.2} = \frac{44.5}{70.7} = 0.63$$

Low Voltage Room load = 0.63 × 45.1 kW = 28.413 kW

High Voltage Room load = 0.37 × 45.1 kW = 16.687 kW

Item	Service Area	
	High Voltage Room	Low Voltage Room
Calculated Sensible Cooling Load(w)	16687	28413
Calculated Latent Cooling Load(w)	0	0
Calculated Total Cooling Load(w)	16687	28413
Calculated Total Cooling Load (btu/hr)	56989	97035
Calculated Sensible Heating Load(w)	687	804
Calculated Sensible Heating Load (btu/hr)	2346	2746
Eq. ID (1202-SUI/SUO-GCSEB-XX)	02	03
Equipment QTY.	2 duty / 2 standby	2 duty / 2 standby
Equipment Type	C.T.	C.T.
Eq. Calculated Cooling Load+ 10% Over Cap. (btu/hr)	31344	53369
Eq. Calculated Heating Load+ 10% Over Cap. (btu/hr)	1290	1510
Selected Eq. Nominal Cooling Cap. (btu/hr)	B.V.**	B.V.**
Selected Eq. Actual Cooling Cap. (btu/hr)	B.V.**	B.V.**
Selected Eq. Actual Heating Cap. (btu/hr)	B.V.**	B.V.**
Power Supply (V/PH/Hz)	400/3/50	400/3/50
Max. Power Consumption (w) Eq. (Cooling/Heating)	B.V.**	B.V.**
REMARKE ***	Cooling & Heating (Heat Pump)	Cooling & Heating (Heat Pump)

* Ceiling Mounted Cassette Split unit

**By Vendor

***Indoor & Outdoor Unit-T3, With Thermostat, Control and All Standard Accessory

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 29 : از 30
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه	
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

5.2 FAN FILTER UNIT SELECTION

1202-FFU-GCSEB-01 (Capacitor Bank + CO2 Room)

Capacitor Bank

Air Flow = $24.73 \text{ (area, m}^2\text{)} \times 4.07 \text{ (height, m)} \times 1 \text{ ACH} \div 60 \text{ min} = 1.68 \text{ m}^3/\text{min} = 28 \text{ L/S}$
= 59.33 cfm

CO2 Room

Air Flow = $20.13 \text{ (area, m}^2\text{)} \times 4.57 \text{ (height, m)} \times 6 \text{ ACH} \div 60 \text{ min} = 9.2 \text{ m}^3/\text{min} = 153.3 \text{ L/S}$
= 324.9 cfm

Item		1202-FFU-GCSEB-01
Service Area		Capacitor Bank + CO2 Room
Equipment QTY.		1
Air Flow(L/S)		181.3
Air Flow(CFM)		384.23
Internal Pressure Drop (In.WG.)	Sand Tarp Louver	By Vendor
	V-Type Aluminium Filter	By Vendor
	Bag Filter (95% Efficiency)	By Vendor
Component Pressure Drop (External) (In.WG.)	Blast Proof Valve-01	0.200
	Fire Damper-01	0.150
	Intake Air Duct	0.050
	Intake Air Duct Volume Damper	0.040
	Intake Air Diffuser	0.026
Total External Pressure Drop * + 10% Over S.F.	(In.WG.)	0.466
	(Pa)	115.96
Fan type		Centrifugal
Power Supply (V/PH/Hz)		230/1/50
Power Consumption (w) Each Eq.		By Vendor
REMARKE		Equipped With Bird Mesh, Sand Tarp Louver, V-Type Aluminium Filter and Bag Filter (95% Efficiency).

* Total Pressure Drop (External + Internal) Shall Be Specified By Vendor.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض عمومی و مشترک								
شماره پیمان: 053-073-9184	HVAC Calculation Note For Extension of Existing Elect. Building								شماره صفحه 30 : از 30
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	PEDCO	120	HV	CN	0002	D03	

5.3 EXHAUST FAN SELECTION

1202-EF-GCSEB-01 (Capacitor Bank + CO2 Room)

Capacitor Bank

Air Flow = $24.73 \text{ (area, m}^2\text{)} \times 4.07 \text{ (height, m)} \times 1 \text{ ACH} \div 60 \text{ min} = 1.68 \text{ m}^3/\text{min} = 28 \text{ L/S}$
 $= 59.33 \text{ cfm}$

CO2 Room

Air Flow = $20.13 \text{ (area, m}^2\text{)} \times 4.57 \text{ (height, m)} \times 6 \text{ ACH} \div 60 \text{ min} = 9.2 \text{ m}^3/\text{min} = 153.3 \text{ L/S}$
 $= 324.9 \text{ cfm}$

Item		1202-EF-GCSEB-01
Service Area		Capacitor Bank + CO2 Room
Equipment QTY.		1
Air Flow(L/S)		181.3
Air Flow(CFM)		384.23
Component Pressure Drop (External) (In.WG.)	Exhaust Air Diffuser/Register	0.028
	Exhaust Air Duct Volume Damper	0.050
	Exhaust Air Duct	0.031
	Blast Proof Valve-02	0.200
	Fire Damper-02	0.150
Total Pressure Drop * + 10% Over S.F.	(In.WG.)	0.459
	(Pa)	114.22
Exhaust Fan type		Utility Ex. Fan (Centrifugal)
Power Supply (V/PH/Hz)		230/1/50
Power Consumption (w) Each Eq.		By Vendor
REMARKE		Equipped With Bird Mesh and Gravity Damper

* Total Pressure Drop (External + Internal) Shall Be Specified By Vendor.

Battery Room Exhaust Fan:

Air Flow = $25.64 \text{ (area, m}^2\text{)} \times 4.07 \text{ (height, m)} \times 10 \text{ ACH} \div 60 \text{ min} = 17.39 \text{ m}^3/\text{min} = 289.83 \text{ L/S}$
 $= 614.12 \text{ cfm} = 1043 \text{ m}^3/\text{hr}$

Wall Mounted Exhaust Fan Pressure Drop: 15 Pa

“This Fan is Existing and Battery Room Air Exhaust Directly from Inside Battery Room”