

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								  
	Data Sheets For ON/OFF & Shutdown Valves								
شماره پیمان: 053 - 073 - 9184	پروژه BK	بسته کاری GCS	صادرکننده PEDCO	تجهیزات 120	رشته IN	نوع مدارک DT	سریال 0010	نسخه D02	شماره صفحه: 1 از 44

طرح نگهداشت و افزایش تولید 27 مخزن

DATA SHEETS FOR ON/OFF & SHUTDOWN VALVES

نگهداشت و افزایش تولید میدان نفتی بینک

D02	AUG.2024	AFC	P.Hajisadeghi	M.Fakharian	M.Sadeghian	
D01	OCT.2022	IFA	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
D00	MAY.2022	IFC	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 1

CLIENT Doc. Number: F9Z-708931

status:

- IDC: Inter-Discipline Check
- IFC: Issued For Comment
- IFA: Issued For Approval
- AFD: Approved For Design
- AFC: Approved For Construction
- AFP: Approved For Purchase
- AFQ: Approved For Quotation
- IFI: Issued For Information
- AB-R: As-Built for CLIENT Review
- AB-A: As-Built - Approved



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



Data Sheets For ON/OFF & Shutdown Valves

شماره پیمان:

053 - 073 - 9184

نسخه	سریال	نوع مدرک	رشته	تجهیزات	صادر کننده	بسته کاری	پروژه
D02	0010	DT	IN	120	PEDCO	GCS	BK

شماره صفحه: 2 از 44

REVISION RECORD SHEET

Page	D00	D01	D02	D03	D04	Page	D00	D01	D02	D03	D04
1	X	X	X			65					
2	X	X	X			66					
3	X	X	X			67					
4	X	X	X			68					
5	X	X	X			69					
6	X	X	X			70					
7	X	X	X			71					
8	X	X	X			72					
9	X	X	X			73					
10	X	X	X			74					
11	X	X	X			75					
12	X	X	X			76					
13	X	X	X			77					
14	X	X	X			78					
15	X	X	X			79					
16	X	X	X			80					
17	X	X	X			81					
18	X	X	X			82					
19	X	X	X			83					
20	X	X	X			84					
21	X	X	X			85					
22	X	X	X			86					
23	X	X	X			87					
24	X	X	X			88					
25	X	X	X			89					
26	X	X	X			90					
27	X	X	X			91					
28	X	X	X			92					
29	X	X	X			93					
30	X	X	X			94					
31	X	X	X			95					
32	X	X	X			96					
33	X	X	X			97					
34	X	X	X			98					
35	X	X	X			99					
36	X	X	X			100					
37	X	X	X			101					
38			X			102					
39			X			103					
40			X			104					
41			X			105					
42			X			106					
43			X			107					
44			X			108					
45						109					
46						110					
47						111					
48						112					
49						113					
50						114					
51						115					
52						116					
53						117					
54						118					
55						119					
56						120					
57						121					
58						122					
59						123					
60						124					
61						125					
62						126					
63						127					
64						128					



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



Data Sheets For ON/OFF & Shutdown Valves

شماره پیمان:

053 - 073 - 9184

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
D02	0010	DT	IN	120	PEDCO	GCS	BK

شماره صفحه: 3 از 44

REFERENCE DOCUMENTS :

Specification For Instrumentation	BK-GNRAL-PEDCO-000-IN-SP-0001
Process Basis Of Design	BK-GNRAL-PEDCO-000-PR-DB-0001
Piping Material Specification	BK-GCS-PEDCO-120-PI-SP-0001
Instrument & Control System Design Criteria	BK-GCS-PEDCO-120-IN-DC-0002
Specification For Hazardous Area Classification	BK-GNRAL-PEDCO-000-SA-SP-0002
Specification For On-off /Shut Down Valves(ESDV/MOV)	BK-GNRAL-PEDCO-000-IN-SP-0006
Specification For Painting	BK-GNRAL-PEDCO-000-PI-SP-0006

D02

Symbol & Legend For PFD and P&ID	BK-GCS-PEDCO-120-PR-PI-0001
P&ID - Gas Compression Inlet Gas Pipeline (Binak)	BK-GCS-PEDCO-120-PR-PI-0002
P&ID - Gas Compression Inlet Gas Pipeline (Golkhari)	BK-GCS-PEDCO-120-PR-PI-0003
P&ID - Slug Catcher System	BK-GCS-PEDCO-120-PR-PI-0004
P&ID - Gas Compression Inlet Knock Out Drum	BK-GCS-PEDCO-120-PR-PI-0005
P&ID - 1st Stage Gas Compression Suction Drums	BK-GCS-PEDCO-120-PR-PI-0006
P&ID - 1st Stage Gas Compression Compressors	BK-GCS-PEDCO-120-PR-PI-0007
P&ID - 1st Stage Gas Compression Air Coolers	BK-GCS-PEDCO-120-PR-PI-0008
P&ID - 2nd Stage Gas Compression Suction Drums	BK-GCS-PEDCO-120-PR-PI-0009
P&ID - 2nd Stage Gas Compression Compressors	BK-GCS-PEDCO-120-PR-PI-0010
P&ID - 2nd Stage Gas Compression Air Coolers	BK-GCS-PEDCO-120-PR-PI-0011
P&ID - 2nd Stage Gas Compression Discharge Drum	BK-GCS-PEDCO-120-PR-PI-0012
P&ID - Gas Compression Dehydration Package	BK-GCS-PEDCO-120-PR-PI-0013
P&ID - Lean Glycol Storage Tank	BK-GCS-PEDCO-120-PR-PI-0014
P&ID - Instrument & Plant Air System	BK-GCS-PEDCO-120-PR-PI-0015
P&ID - Nitrogen Generation System	BK-GCS-PEDCO-120-PR-PI-0016
P&ID - Close Drain System	BK-GCS-PEDCO-120-PR-PI-0017
P&ID - Corrosion Inhibitor Package	BK-GCS-PEDCO-120-PR-PI-0018
P&ID - Methanol Injection Package	BK-GCS-PEDCO-120-PR-PI-0019
P&ID - LP Flare System	BK-GCS-PEDCO-120-PR-PI-0020
P&ID - Oily Water Sewer	BK-GCS-PEDCO-120-PR-PI-0021
P&ID - Fuel Gas System	BK-GCS-PEDCO-120-PR-PI-0022
P&ID - Diesel Oil System	BK-GCS-PEDCO-120-PR-PI-0023
P&ID - Potable Water System	BK-GCS-PEDCO-120-PR-PI-0024
P&ID - Glycol Sump Drum	BK-GCS-PEDCO-120-PR-PI-0025
P&ID - Fire Water Network	BK-GCS-PEDCO-120-SA-PI-0001
P&ID - Total Flooding System For Extension of Existing Elect. Building	BK-GCS-PEDCO-120-SA-PI-0002



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



Data Sheets For ON/OFF & Shutdown Valves

شماره پیمان:
053 - 073 - 9184

نسخه	سریال	نوع مدرک	رشته	تهیهات	صادر کننده	پسته کاری	پروژه
D02	0010	DT	IN	120	PEDCO	GCS	BK

شماره صفحه: 4 از 44

GENERAL NOTES:

- Calculations shall be provided for each completely piped actuated valve assembly (including solenoid valve), the stroking times i.e. to close and to open.
- The duty, failure action and stroke time shall all be approved by the Purchaser.
- The actuator shall be designed to operate the valve through its full stroke.
- The maximum valve stroking time to achieve the safety position shall be defined according to size of the body (5 seconds for body until 4", 1 second per inch for body greater than 4"). The maximum fully stroke time shall be 10 seconds.
- The piping indicates corrosion allowance selected as per document "Piping & Pipeline Material Specification, No. " BK-GCS-PEDCO-120-PI-SP-0001 "
- Hydro-test duration shall be in accordance with API 6D.
- All ball valves shall be fitted with suitable 'end of travel' stops at the fully open and fully closed positions and a local position indicator . The design shall prevent the ingress of foreign material and corrosion products which would impair the operation of the stops. Devices capable of locking the valves in their safe position (ESDV in open or closed position) shall be provided for maintenance and shall be vendor's standard proven design.
- Vendor shall guarantee and demonstrate the required stroking speed, during the Functional Test (FAT).
- All accessories shall be mounted, together with solenoid valve, etc, on a 316SS sub-plate. Tubing shall be suitably sized TP 316L stainless steel with stainless steel double ferrule compression fittings
- Solenoid valve shall be selected in accordance with low power type.
- All on/off valves shall be preferably fitted with single acting, spring return pneumatic actuators, completed with mounting kit. Also Partial Stroking test or pilot valve to be considered.
- The actuator shall be fail safe in operation (as specified in data sheets) in loss of electrical signal or loss of air supply.
- The spring return actuator shall be "pre stressed".
- Pneumatic actuators will be sized on the basis of a minimum safety factor of 1.5 and a minimum air pressure of 3 Bar g.
The valve actuator torque shall be in excess of the required valve torque under all operating conditions.
- All actuators and accessories shall be clearly and permanently identified by nameplate. the nameplate shall be in stainless steel and affixed to the VALVE, actuator and accessories.
- 16 - Environmental condition for field instrumentation of Binak Oilfield shall be considered as per the followings:

Maximum ambient temperature: 50 (°C)
Minimum ambient temperature: 5 (°C)
Maximum steel surface exposed to sun: 85 (°C)
Maximum summer dry bulb: 50 (°C)
DB/RH for Summer HVAC Design: 41 °C / 61 %
DB FOR Winter HVAC Design: 6 °C

Relative Humidity:

- Maximum Design relative humidity (%): 100
- Minimum Design relative humidity (%): 0

17 - Material Test Certificate and calibration Certificate for all transmitters to be submitted by Vendor.

18 - Flow direction shall be permanently and clearly indicated on the valve body.

19- External grounding shall be provided for each solenoid valve.

20- BDV's shall have a minimum body size of 2" with tight shutoff (ANSI B16.104, class VI), air volume tanks for larger valves and should be sized for three full open/closed operations at 3-barg instrument air pressure.

21- Valves in safety related services should have been fire tested and certification to be provided by Vendor.

22- Seat rings shall be spring loaded and so designed that line pressure will assist in sealing round the ball.

23- Valve stem extension shall be detachable for easy replacements.

24- At least two stem seals shall be provided with facility for injection of secondary sealant and with stainless steel fittings.


25- Stem seal shall be replaceable while the valve is in closed operation position.

26- Short stroke single acting pneumatic piston actuators shall preferably be used on emergency shutdown service.

27- Body of all On/Off Valves except ss316 body material, shall be painted with white color. Also actuator of ESDV and BDV valves shall be painted with Red color as well as actuator of XV valves shall be painted by Blue color.

D02

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض								 HURGAN 							
		احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves															
شماره پیمان:		پروژه	بسته کاری	صادر کننده	تهیهات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 5 از 44 D02							
053 - 073 - 9038		BK	GCS	PEDCO	120	IN	DT	0010	D02								
Shut Down Valve																	
TAG NO:		ESDV-2101		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0002_D08				SERVICE: Gas Compression Inlet Gas Pipeline (Binak)							
FLUID STATE:		PROCESS GAS		PHASE:		GAS				AREA CLASSIFICATION: Zone2, IIB, T4							
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off			
	1	FLOW RATE					kg/h		7220.4928		6564		1969.23		-		
	2	INLET PRESSURE					bar(g)		7.5		7.5		7.5		-		
	3	OUTLET PRESSURE					bar(g)		7.5		7.5		7.5		-		
	4	DIFFERENTIAL PRESSURE					bar(g)		-		-		-		18.2		
	5	INLET TEMPERATURE					°C		26.67~46.11		26.67~46.11		26.67~46.11		-		
	6	DENSITY					kg/m3		5.43 ~ 6.66		5.43 ~ 6.66		5.43 ~ 6.66		-		
	7	VISCOSITY					CP		0.011 ~ 0.012		0.011 ~ 0.012		0.011 ~ 0.012		-		
	8	VAPOR PRESSURE Pv					bar(a)		-		-		-		-		
9	CRITICAL PRESSURE					bar(a)		107.1		107.1		107.1		-			
LINE	PIPE LINE SIZE & SCHEDULE		IN	6"	80	CORROSION ALLOWANCE(mm)		6		53		TYPE		Single Acting , Spring Return			
			OUT	6"	80					54		SIZE		VTA			
VALVE BODY & BONNET	LINE NO.		GAS-111-0001-AN07-6"-PT							55		SPRING FAIL ACTION		Fail to Close			
	TYPE		OUT					Full Bore Ball Valve/Trunnion Mounted				56		MAX ALLOWABLE PRESSURE		VTA	
	SIZE		OUT					6"				57		MIN REQUIRES PRESSURE		VTA	
	MAX PRESS./TEMP.		OUT					As per PMS				58		AVAILABLE AIR SUPPLY PRESSURE		MAX/NORM/MIN: 10/7/3 bar-g	
	MFR. & MODEL		OUT					Will be finalized later				59		BENCH RANGE		VTA	
	BODY / BONNET MATL		OUT					ASTM A216 Gr. WCB				60		TRAVELING TIME		6 S	
	LINER MATERIAL / ID		OUT					VTA				61		FUNCTION		On/Off	
	END CONNECTION		IN	6"		/300#					62		LOCAL POSITION INDICATOR		Required		
			OUT	6"		/300#					63		ACT. ORIENTATION		VTA		
	FLG FACE FINISH		RF									64		HAND WHEEL TYPE		Clutchable side mounted	
	END EXT.MATL.		N/A									65		ADJUSTABLE LIMIT STOP		Yes	
	FLOW DIRECTION		(Note 18 in Page 4)									66		INPUT SIGNAL		24VDC	
	TYPE OF BONNET		Standard									67		MFR. & MODEL		Will be finalized later	
	LUBE & ISO VALVE		No									68		TYPE		N/A	
	PACKING MATERIAL		PACKING TYPE		PTFE		Standard				69		MFR. & MODEL		Will be finalized later		
	ENTRY DESIGN		Top Entry									70		ON INCR SIGNAL OUTPUT INCR / DECR		N/A	
	NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES									71		GAUGES		N/A	
	TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE				72		CAM CHARACTERISTIC		N/A	
	SIZE		RATED TRAVEL		VTA		VTA				73		AIR CONNECTION		N/A		
	CHARACTERISTICS		On/Off									74		TAG NO. :		EZSO-2101 / EZSO-2101	
	BALANCED / UNBALANCED		BALANCED								75		TYPE	QUANTITY	Magnetically operated 'REED' contacts	2	
	RATED Cv		FL	XT		VTA		VTA	VTA			76		CONTACTS / RATING		110V DC , 10A	
	PLUG / BALL / DISK MATERIAL		316 SS									77		ACTUATION POINT		Fully Open/Close	
	SEAT		TYPE	MATERIAL		Soft Seat		PTFE				78		ENCLOSURE MATERIAL		Die Cast Aluminum	
CAGE / GUIDE MATERIAL		VTA									79		WEATHER PROTECTION		IP-65		
STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS				80		ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 × 1.5	
LEAKAGE CLASS		ANSI Class VI									81		MFR. & MODEL		Will be finalized later		
VALVE STEM EXTENSION REQUIREMENT		YES									82		SET PRESSURE		Yes		
TAG NO		ESOVS-2101									83		PNEUMATIC CONNECTION		1/4" NPT		
TYPE		3 Way									84		GAUGES	FILTER	Required	Required	
BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65				85		MFR. & MODEL		Will be finalized later			
ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 × 1.5				86		ANSI/FCI LEAKAGE CLASS		Required			
MANUAL RESET		Yes									87		HYDRO PRESSURE		Required		
Power Supply		24 VDC									88		FUNCTIONAL TEST		Required		
Pnu. Connection		1/4" NPT									89						
FUSIBLE LEAKAGE		No									90						
BLOCK RELAY		No									91						
QUICK EXHUST		Yes									92		PASSIVE FIRE PROTECTION		Yes		
FILTER REGULATOR		Yes									93		API 6FA REQUIREMENTS		Yes		
VOLUME TANK		No									94		SIL 3 REQUIREMENTS		Yes		
MECHANICAL POSITION INDICATOR		Required									95		PARTIAL STROKING VALVE TEST		Yes		
MANUAL PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes									96						
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																	

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض																
		احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves																
شماره پیمان: 053 - 073 – 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه		شماره صفحه: 44 از 6							
		BK	GCS	PEDCO	120	IN	DT	0010	D02									
Shut Down Valve																		
TAG NO: ESDV-2102		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0003-D08					SERVICE: Gas Compression Inlet Gas Pipeline (Golkhari)									
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4									
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow	Min. Flow	Shut-Off						
	1	FLOW RATE					kg/h	12395.9	11269.0	3380.0	-							
	2	INLET PRESSURE					bar(g)	7.5	7.5	7.5	-							
	3	OUTLET PRESSURE					bar(g)	7.5	7.5	7.5	90							
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	-							
	5	INLET TEMPERATURE					°C	15.5 ~ 32	15.5 ~ 32	15.5 ~ 32	-							
	6	DENSITY					kg/m3	6.19 ~6.21	6.19 ~6.21	6.19 ~6.21	-							
	7	VISCOSITY					CP	0.011	0.011	0.011	-							
	8	VAPOR PRESSURE Pv					bar(a)	-	-	-	-							
	CRITICAL PRESSURE					bar(a)	103.1	103.1	103.1	-								
LINE	PIPE LINE SIZE & SCHEDULE		IN	8"	100	CORROSION ALLOWANCE(mm)	6	53	TYPE		Single Acting , Spring Return							
			OUT	8"	100			54	SIZE		VTA							
VALVE BODY & BONNET	11		LINE NO.		GAS-111-0001-FN07-8"-PT					55	SPRING FAIL ACTION		Fail to Close					
	12		TYPE		Full Bore Ball Valve/Trunnion Mounted					56	MAX ALLOWABLE PRESSURE		VTA					
	13		SIZE		8"					57	MIN REQUIRES PRESSURE		VTA					
	14		MAX PRESS./TEMP.		As per PMS					58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g					
	15		MFR. & MODEL		Will be finalized later					59	BENCH RANGE		VTA					
	16		BODY / BONNET MATL		ASTM A216 Gr. WCB					60	TRAVELING TIME		9 S					
	17		LINER MATERIAL / ID		VTA					61	FUNCTION		On/Off					
	18		END CONNECTION		IN	8" /600#		62	LOCAL POSITION INDICATOR		Required							
					OUT	8" /600#												
	19		FLG FACE FINISH		RF					63	ACT. ORIENTATION		VTA					
	20		END EXT./MATL.		N/A					64	HAND WHEEL TYPE		Clutchable side mounted					
	21		FLOW DIRECTION		(Note 18 in Page 4)					65	ADJUSTABLE LIMIT STOP		Yes					
	22		TYPE OF BONNET		Standard					66	INPUT SIGNAL		24VDC					
	23		LUBE & ISO VALVE		No					67	MFR. & MODEL		Will be finalized later					
	24		PACKING MATERIAL		PACKING TYPE		PTFE		Standard		68	TYPE		N/A				
	25		ENTRY DESIGN		Top Entry					69	MFR. & MODEL		Will be finalized later					
	26		NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES					70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A					
	27		TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE		71	GAUGES		N/A			
	28		SIZE		RATED TRAVEL		VTA		VTA		72	CAM CHARACTERISTIC		N/A				
29		CHARACTERISTICS		On/Off					73	AIR CONNECTION		N/A						
TRIM	30		BALANCED / UNBALANCED		BALANCED						74	TAG NO. :		EZSC-2102 / EZSO-2102				
	31		RATED Cv		FL	XT		VTA		VTA		VTA		75	TYPE	QUANTITY	Magnetically operated "REED" contacts	2
	32		PLUG / BALL / DISK MATERIAL		316 SS					76	CONTACTS / RATING		110V DC , 10A					
	33		SEAT		TYPE	MATERIAL		Soft Seat		RPTFE		77	ACTUATION POINT		Fully Open/Close			
	34		CAGE / GUIDE MATERIAL		VTA					78	ENCLOSURE MATERIAL		Die Cast Aluminum					
	35		STEM		TYPE	MATERIAL		Anti-Blow Out		Forged, 13% chromium steel		79	WEATHER PROTECTION		IP-65			
	36		LEAKAGE CLASS		ANSI Class VI					80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4		ISO M20 × 1.5			
	37		VALVE STEM EXTENSION REQUIREMENT		YES					81	MFR. & MODEL		Will be finalized later					
SOLENOID VALVE	38		TAG NO		ESOV-2102					AIR SET		82	SET PRESSURE		Yes			
	39		TYPE		3 Way							83	PNEUMATIC CONNECTION		1/4" NPT			
	40		BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65			84	GAUGES	FILTER	Required	Required		
	41		ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5		85	MFR. & MODEL		Will be finalized later				
	42		MANUAL RESET		Yes					TEST		86	ANSUPCI LEAKAGE CLASS		Required			
	43		Power Supply		24 VDC							87	HYDRO PRESSURE		Required			
	44		Pnu. Connection		1/4" NPT							88	FUNCTIONAL TEST		Required			
SPECIAL / ACCESS.	45		FUSIBLE LEAKAGE		No					89								
	46		BLOCK RELAY		No					90								
	47		QUICK EXHUST		Yes					91								
	49		FILTER REGULATOR		Yes					FIRE PROOF DESIGN		92	PASSIVE FIRE PROTECTION		Yes			
	50		VOLUME TANK		No							93	API 6FA REQUIREMENTS		Yes			
	51		MECHANICAL POSITION INDICATOR		Required							94	SIL 3 REQUIREMENTS		Yes			
	52		MANUAL PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes							95	PARTIAL STROKING VALVE TEST		Yes			
										96								
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																		

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								 					
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 8 از 44					
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02						
Shut Down Valve															
TAG NO: ESDV-2272		P&ID NO :			BK-GCS-PEDCO-120-PR-PI-0022-D08				SERVICE: Fuel Gas System						
FLUID STATE: FUEL GAS		PHASE: GAS							AREA CLASSIFICATION: Zone2, IIB, T4						
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE					kg/h		556.3		505.8		151.7		-	
	2 INLET PRESSURE					bar(g)		5.1		5.1		5.1		-	
	3 OUTLET PRESSURE					bar(g)		5.1		5.1		5.1		-	
	4 DIFFERENTIAL PRESSURE					bar(g)		-		-		-		18.2	
	5 INLET TEMPERATURE					°C		37		37		37		-	
	6 DENSITY					kg/m3		5.77		5.77		5.77		-	
	7 VISCOSITY					CP		0.011		0.011		0.011		-	
	8 VAPOR PRESSURE Pv					bar(a)		-		-		-		-	
9 CRITICAL PRESSURE					bar(a)		94.66		94.66		94.66		-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	3"	80	CORROSION ALLOWANCE(mm)		6		53 TYPE		Single Acting , Spring Return			
			OUT	3"	80					54 SIZE		VTA			
VALVE BODY & BONNET	11 LINE NO.		GAS-111-0004-AN07-3"-PT							55 SPRING FAIL ACTION		Fail to Close			
	12 TYPE		Full Bore Ball Valve/Trunnion Mounted							56 MAX ALLOWABLE PRESSURE		VTA			
	13 SIZE		3"							57 MIN REQUIRES PRESSURE		VTA			
	14 MAX PRESS./TEMP.		As per PMS							58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NORM/MIN: 10/7/3 bar-g			
	15 MFR. & MODEL		Will be finalized later							59 BENCH RANGE		VTA			
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB							60 TRAVELING TIME		5 S			
	17 LINER MATERIAL / ID		VTA							61 FUNCTION		On/Off			
	18 END CONNECTION		IN	3" /300#						62 LOCAL POSITION INDICATOR		Required			
			OUT	3" /300#						63 ACT. ORIENTATION		VTA			
	19 FLG FACE FINISH		RF							64 HAND WHEEL TYPE		Clutchable side mounted			
	20 END EXT.MATL.		N/A							65 ADJUSTABLE LIMIT STOP		Yes			
	21 FLOW DIRECTION		(Note 18 in Page 4)							66 INPUT SIGNAL		24VDC			
	22 TYPE OF BONNET		Standard							67 MFR. & MODEL		Will be finalized later			
	23 LUBE & ISO VALVE		No							68 TYPE		N/A			
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard				69 MFR. & MODEL		Will be finalized later		
	25 ENTRY DESIGN		Top Entry							70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A			
	26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES							71 GAUGES		N/A			
	27 TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE		72 CAM CHARACTERISTIC		N/A			
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A				
	29 CHARACTERISTICS		On/Off							74 TAG NO. :		EZSC-2272 / EZSO-2272			
	TRIM	30 BALANCED / UNBALANCED		BALANCED						75 TYPE		QUANTITY	Magnetically operated "REED" contacts		2
		31 RATED Cv		FL	XT		VTA		VTA	VTA	76 CONTACTS / RATING		110V DC , 10A		
		32 PLUG / BALL / DISK MATERIAL		316 SS							77 ACTUATION POINT		Fully Open/Close		
33 SEAT		TYPE	MATERIAL		Soft Seat		PTFE		78 ENCLOSURE MATERIAL		Die Cast Aluminum				
34 CAGE / GUIDE MATERIAL		VTA							79 WEATHER PROTECTION		IP-65				
35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 × 1.5		
36 LEAKAGE CLASS		ANSI Class VI							81 MFR. & MODEL		Will be finalized later				
37 VALVE STEM EXTENSION REQUIREMENT		YES							82 SET PRESSURE		Yes				
SOLENOID VALVE	38 TAG NO		ESOV-2272							83 PNEUMATIC CONNECTION		1/4" NPT			
	39 TYPE		3 Way							84 GAUGES		FILTER	Required	Required	
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL		Will be finalized later				
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS		Required				
	42 MANUAL RESET		Yes							87 HYDRO PRESSURE		Required			
SPECIAL / ACCESS.	43 Power Supply		24 VDC							88 FUNCTIONAL TEST		Required			
	44 Pnu. Connection		1/4" NPT							89					
	45 FUSIBLE LEAKAGE		No							90					
	46 BLOCK RELAY		No							91					
	47 QUICK EXHUST		Yes							92 PASSIVE FIRE PROTECTION		No			
	49 FILTER REGULATOR		Yes							93 API 6FA REQUIREMENTS		Yes			
	50 VOLUME TANK		No							94 SIL 3 REQUIREMENTS		Yes			
	51 MECHANICAL POSITION INDICATOR		Required							95 PARTIAL STROKING VALVE TEST		Yes			
52 MANUAL PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes							96						
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM															
(1) PMS: Piping material specification.															
(2) All material shall be suitable for minimum design metal temperature.															
(3) Shall be stated by vendor at quotation stage.															
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.															

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 				
شماره پیمان: 053 - 073 - 9038		پروژه	پسته کاری	صادرکننده	تهیهات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 9 از 44			
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02				
Blow Down Valve													
TAG NO: BDV-2110		P&ID NO: BK-GCS-PEDCO-120-PR-PI-0005-D08					SERVICE: Gas Compression Inlet Knock Out Drum to Flare Header						
FLUID STATE: PROCESS GAS		PHASE: GAS					AREA CLASSIFICATION: Zone2, IIB, T4						
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off		
	1	FLOW RATE					kg/h	-	5665.4	-	-		
	2	INLET PRESSURE					bar(g)	-	5.3 ~ 9	-	-		
	3	OUTLET PRESSURE					bar(g)	-	5.3 ~ 9	-	-		
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	18.2		
	5	INLET TEMPERATURE					°C	-	19 ~ 37.17	-	-		
	6	DENSITY					kg/m3	-	5.96 ~ 1012	-	-		
	7	VISCOSITY					CP	-	0.011 ~ 0.0115	-	-		
	8	VAPOR PRESSURE Pv					bar(a)	-	-	-	-		
9	CRITICAL PRESSURE					bar(a)	-	94.65	-	-			
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	3"	160	CORROSION ALLOWANCE(mm)	6	53	TYPE		Single Acting, Spring Return		
	11	LINE NO.	OUT	3	160			54	SIZE		VTA		
VALVE BODY & BONNET	GAS-111-0225-AN07-3"-PT					ACTUATOR	55	SPRING FAIL ACTION		Fail to Open			
	12	TYPE					56	MAX ALLOWABLE PRESSURE		VTA			
	13	SIZE					57	MIN REQUIRES PRESSURE		VTA			
	14	MAX PRESS./TEMP.					58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g			
	15	MFR. & MODEL					59	BENCH RANGE		VTA			
	16	BODY / BONNET MATL					60	TRAVELING TIME		5 S			
	17	LINER MATERIAL / ID					61	FUNCTION		On/Off			
	18	END CONNECTION	IN	3"/300#	VTA		62	LOCAL POSITION INDICATOR		Required			
	OUT	3"/300#	63	ACT. ORIENTATION			VTA						
	19	FLG FACE FINISH					64	HAND WHEEL TYPE		Clutchable side mounted			
	20	END EXT./MATL.					65	ADJUSTABLE LIMIT STOP		Yes			
	21	FLOW DIRECTION					66	INPUT SIGNAL		24VDC			
	22	TYPE OF BONNET					67	MFR. & MODEL		Will be finalized later			
	23	LUBE & ISO VALVE					68	TYPE		N/A			
TRIM	24	PACKING MATERIAL	PACKING TYPE		PTFE	POSITIONER	69	MFR. & MODEL		Will be finalized later			
	25	ENTRY DESIGN					70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A			
	26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)					71	GAUGES		N/A			
	27	TRIM	TYPE	MATERIAL	VTA		316 SS+PTFE	72	CAM CHARACTERISTIC		N/A		
	28	SIZE	RATED TRAVEL		VTA		VTA	73	AIR CONNECTION		N/A		
	29	CHARACTERISTICS					74	TAG NO. :		BZSC-2110 / BZSO-2110			
	30	BALANCED / UNBALANCED					BALANCED	75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2	
SOLENOID VALVE	31	RATED Cv	FL	XT	VTA	VTA	VTA	76	CONTACTS / RATING		110V DC , 10A		
	32	PLUG / BALL / DISK MATERIAL					316 SS	77	ACTUATION POINT		Fully Open/Close		
	33	SEAT	TYPE	MATERIAL	Soft Seat	PTFE	78	ENCLOSURE MATERIAL		Die Cast Aluminum			
	34	CAGE / GUIDE MATERIAL					VTA	79	WEATHER PROTECTION		IP-65		
	35	STEM	TYPE	MATERIAL	Anti-Blow Out	316 SS	80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 x 1.5		
	36	LEAKAGE CLASS					ANSI Class VI	81	MFR. & MODEL		Will be finalized later		
	37	VALVE STEM EXTENSION REQUIREMENT					YES	82	SET PRESSURE		Yes		
	38	TAG NO					BSOV-2110 , PSOV-2110	83	PNEUMATIC CONNECTION		1/4" NPT		
	39	TYPE					3 Way	84	GAUGES	FILTER	Required	Required	
	40	BODY MATERIAL		WEATHER IP.		AISt 316 S.S	IP-65	85	MFR. & MODEL		Will be finalized later		
SPECIAL / ACCESS.	41	ELE. CERTIFICATE	ELE. CONNECTION		EEx "d", IIB T4	ISO M20 x 1.5	TEST	86	ANSI/FCI LEAKAGE CLASS		Required		
	42	MANUAL RESET						Yes	87	HYDRO PRESSURE		Required	
	43	Power Supply						24 VDC	88	FUNCTIONAL TEST		Required	
	44	Pnu. Connection						1/4" NPT	89				
	45	FUSIBLE LEAKAGE						No	90				
	46	BLOCK RELAY						No	91				
	47	QUICK EXHUST						Yes	FIRE PROOF DESIGN	92	PASSIVE FIRE PROTECTION		No
	48	FILTER REGULATOR						Yes		93	API 6FA REQUIREMENTS		Yes
	49	VOLUME TANK						Yes		94	SIL 3 REQUIREMENTS		Yes
	50	MECHANICAL POSITION INDICATOR						Required		95	PARTIAL STROKING VALVE TEST		Yes
51	MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes	96						
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.													



NISOC

تجهادداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

Data Sheets For ON/OFF & Shutdown Valves




شماره پیمان:

053 - 073 – 9038

پروژه

بسته کاری

صادر کننده

تسهيلات

رشته

نوع مدرک

سریال

نسخه

BK

GCS

PEDCO

120

IN

DT

0010

D02

شماره صفحه: 10 از 44

D02

Blow Down Valve

TAG NO:

BDV-2134A

P&ID NO :

BK-GCS-PEDCO-120-PR-P1-0009-D08 (1/3)

SERVICE:

2nd Stage Gas Compression Suction Drums

FLUID STATE:

VENT GAS

PHASE:

GAS

AREA CLASSIFICATION:

Zone2, IIB, T4

53

TYPE

Single Acting , Spring Return

54

SIZE

VTA

55

SPRING FAIL ACTION

Fail to Open

56

MAX ALLOWABLE PRESSURE

VTA

57

MIN REQUIRES PRESSURE

VTA

58

AVAILABLE AIR SUPPLY PRESSURE

MAX/NOR/MIN: 10/7/3 bar-g

59

BENCH RANGE

VTA

60

TRAVELING TIME

5 S

61

FUNCTION

On/Off

62

LOCAL POSITION INDICATOR

Required

63

ACT. ORIENTATION

VTA

64

HAND WHEEL TYPE

Declutchable side mounted

65

ADJUSTABLE LIMIT STOP

No

66

INPUT SIGNAL

24VDC

67

MFR. & MODEL

Will be finalized later

68

TYPE

N/A

69

MFR. & MODEL

Will be finalized later

70

ON INCR SIGNAL OUTPUT INCR / DECR

N/A

71

GAUGES

N/A

72

CAM CHARACTERISTIC

N/A

73

AIR CONNECTION

N/A

74

TAG NO. :

BZSC-2134A / BZSO-2134A

75

TYPE

QUANTITY

Magetically operated "REED" contacts

2

76

CONTACTS / RATING

110V DC , 10A

77

ACTUATION POINT

Fully Open/Close

78

ENCLOSURE MATERIAL

Die Cast Aluminum

79

WEATHER PROTECTION

IP-65

80

ELEC. CERTIFICATE

ELEC. CONNECTION

EEx "d", IIB T4

ISO M20 × 1.5

81

MFR. & MODEL

Will be finalized later

82

SET PRESSURE

Yes

83

PNEUMATIC CONNECTION

1/4" NPT

84

GAUGES

FILTER

Required

Required

85

MFR. & MODEL

Will be finalized later

86

ANSI/FCI LEAKAGE CLASS

Required

87

HYDRO PRESSURE

Required

88

FUNCTIONAL TEST

Required

89

90

91

PASSIVE FIRE PROTECTION

No

92

API 6FA REQUIREMENTS

No

93

SIL 3 REQUIREMENTS

Yes

94

PARTIAL STROKING VALVE TEST

Yes

95

NOTE:

VTA : VENDOR TO ADVISE AT BIDDING STAGE

VTC: VENDOR TO CONFIRM

(1) PMS: Piping material specification.

(2) All material shall be suitable for minimum design metal temperature.

(3) Shall be stated by vendor at quotation stage.

(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک								 				
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 11 از 44				
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02					
Blow Down Valve														
TAG NO: BDV-2134B		P&ID NO :		BK-GCS-PEDCO-120-PR-P1-0009-D08 (2/3)					SERVICE: 2nd Stage Gas Compression Suction Drums					
FLUID STATE: VENT GAS		PHASE: GAS							AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE				kg/h		-		796.4		-		-	
	2 INLET PRESSURE				bar(g)		-		18.1~ 22		-		-	
	3 OUTLET PRESSURE				bar(g)		-		18.1~ 22		-		-	
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		47.7	
	5 INLET TEMPERATURE				°C		-		22 ~ 59.88		-		-	
	6 DENSITY				kg/m3		-		18.08~ 1011		-		-	
	7 VISCOSITY				CP		-		0.013 ~0.98		-		-	
	8 VAPOR PRESSURE Pv				bar(a)		-		-		-		-	
9 CRITICAL PRESSURE				bar(a)		-		94.65		-		-		
LINE	PIPE LINE SIZE & SCHEDULE		IN 2" 80		CORROSION ALLOWANCE(mm)		6							
	OUT 2" 80													
VALVE BODY & BONNET	11 LINE NO.		GAS-111-0160B-CN05-2"-PT											
	12 TYPE		Full Bore Ball Valve/ Floating Type											
	13 SIZE		2"											
	14 MAX PRESS./TEMP.		As per PMS											
	15 MFR. & MODEL		Will be finalized later											
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M											
	17 LINER MATERIAL / ID		VTA											
	18 END CONNECTION		IN		2" /300#									
			OUT		2"/300#									
	19 FLG FACE FINISH		RF											
	20 END EXT.MATL.		N/A											
	21 FLOW DIRECTION		(Note 18 in Page 4)											
	22 TYPE OF BONNET		Standard											
	23 LUBE & ISO VALVE		No											
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard							
	25 ENTRY DESIGN		Top Entry											
	26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES											
	TRIM	27 TRIM		TYPE		MATERIAL		VTA		316 SS+RPTFE				
		28 SIZE		RATED TRAVEL		VTA		VTA						
		29 CHARACTERISTICS		On/Off										
		30 BALANCED / UNBALANCED		BALANCED										
31 RATED Cv		FL		XT		VTA		VTA		VTA				
32 PLUG / BALL / DISK MATERIAL		316 SS												
33 SEAT		TYPE		MATERIAL		Soft Seat		RPTFE						
34 CAGE / GUIDE MATERIAL		VTA												
35 STEM		TYPE		MATERIAL		Anti-Blow Out		316 SS						
36 LEAKAGE CLASS		ANSI Class VI												
37 VALVE STEM EXTENSION REQUIREMENT		YES												
SOLENOID VALVE	38 TAG NO		BSOV-2134B , PSOV-2134B											
	39 TYPE		3 Way											
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65							
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5							
	42 MANUAL RESET		Yes											
	43 Power Supply		24 VDC											
	44 Pnu. Connection		1/4" NPT											
	45 FUSIBLE LEAKAGE		No											
SPECIAL / ACCESS.	46 BLOCK RELAY		No											
	47 QUICK EXHUST		Yes											
	49 FILTER REGULATOR		Yes											
	50 VOLUME TANK		No											
	51 MECHANICAL POSITION INDICATOR		Required											
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NISOC		تجهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 					
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 12 از 44 D02				
		BK	GCS	PEDCO	120	IN	DT	0010	D02					
Blow Down Valve														
TAG NO: BDV-2134C		P&ID NO :		BK-GCS-PEDCO-120-PR-P1-0009-D08 (3/3)					SERVICE: 2nd Stage Gas Compression Suction Drums					
FLUID STATE: VENT GAS		PHASE: GAS					AREA CLASSIFICATION: Zone2, IIB, T4							
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE				kg/h		-		796.4		-		-	
	2 INLET PRESSURE				bar(g)		-		18.1~ 22		-		-	
	3 OUTLET PRESSURE				bar(g)		-		18.1~ 22		-		-	
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		47.7	
	5 INLET TEMPERATURE				°C		-		22 ~ 59.88		-		-	
	6 DENSITY				kg/m3		-		18.08~ 1011		-		-	
	7 VISCOSITY				CP		-		0.013 ~0.98		-		-	
	8 VAPOR PRESSURE Pv				bar(a)		-		-		-		-	
9 CRITICAL PRESSURE				bar(a)		-		94.65		-		-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	80	CORROSION ALLOWANCE(mm)		6		53 TYPE Single Acting , Spring Return				
			OUT	2"	80					54 SIZE VTA				
VALVE BODY & BONNET	11 LINE NO.		GAS-111-0160G-CN05-2"-PT							55 SPRING FAIL ACTION Fail to Open				
	12 TYPE		Full Bore Ball Valve/ Floating Type							56 MAX ALLOWABLE PRESSURE VTA				
	13 SIZE		2"							57 MIN REQUIRES PRESSURE VTA				
	14 MAX PRESS./TEMP.		As per PMS							58 AVAILABLE AIR SUPPLY PRESSURE MAX/NOR/MIN: 10/7/3 bar-g				
	15 MFR. & MODEL		Will be finalized later							59 BENCH RANGE VTA				
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB							60 TRAVELING TIME 5 S				
	17 LINER MATERIAL / ID		VTA							61 FUNCTION On/Off				
	18 END CONNECTION		IN	2" /300#						62 LOCAL POSITION INDICATOR Required				
			OUT	2"/300#						63 ACT. ORIENTATION VTA				
	19 FLG FACE FINISH		RF							64 HAND WHEEL TYPE Declutchable side mounted				
	20 END EXT.MATL.		N/A							65 ADJUSTABLE LIMIT STOP No				
	21 FLOW DIRECTION		(Note 18 in Page 4)							66 INPUT SIGNAL 24VDC				
	22 TYPE OF BONNET		Standard							67 MFR. & MODEL Will be finalized later				
	23 LUBE & ISO VALVE		No							68 TYPE N/A				
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard		69 MFR. & MODEL Will be finalized later					
	25 ENTRY DESIGN		Top Entry							70 ON INCR SIGNAL OUTPUT INCR / DECR N/A				
	26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES							71 GAUGES N/A				
	TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE		72 CAM CHARACTERISTIC N/A			
		28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION N/A				
29 CHARACTERISTICS		On/Off							74 TAG NO. : BZSC-2134C / BZSO-2134C					
30 BALANCED / UNBALANCED		BALANCED						75 TYPE QUANTITY		Magnetically operated "REED" contacts 2				
31 RATED Cv		FL	XT		VTA		VTA VTA		76 CONTACTS / RATING 110V DC , 10A					
32 PLUG / BALL / DISK MATERIAL		316 SS							77 ACTUATION POINT Fully Open/Close					
33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE		78 ENCLOSURE MATERIAL Die Cast Aluminum					
34 CAGE / GUIDE MATERIAL		VTA							79 WEATHER PROTECTION IP-65					
35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE ELEC. CONNECTION		EEx "d", IIB T4 ISO M20 × 1.5			
SOLENOID VALVE	36 LEAKAGE CLASS		ANSI Class VI							81 MFR. & MODEL Will be finalized later				
	37 VALVE STEM EXTENSION REQUIREMENT		YES							82 SET PRESSURE Yes				
	38 TAG NO		BSOV-2134C , PSOV-2134C							83 PNEUMATIC CONNECTION 1/4" NPT				
	39 TYPE		3 Way							84 GAUGES		FILTER Required Required		
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL Will be finalized later					
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS Required					
	42 MANUAL RESET		Yes							87 HYDRO PRESSURE Required				
	43 Power Supply		24 VDC							88 FUNCTIONAL TEST Required				
SPECIAL / ACCESS.	44 Pnu. Connection		1/4" NPT							89				
	45 FUSIBLE LEAKAGE		No							90				
	46 BLOCK RELAY		No							91 PASSIVE FIRE PROTECTION No				
	47 QUICK EXHUST		Yes							92 API 6FA REQUIREMENTS No				
	49 FILTER REGULATOR		Yes							93 SIL 3 REQUIREMENTS Yes				
	50 VOLUME TANK		No							94 PARTIAL STROKING VALVE TEST Yes				
	51 MECHANICAL POSITION INDICATOR		Required							95				
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NISOC		تجهیزات و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 					
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 13				
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02					
Blow Down Valve														
TAG NO: BDV-2132A		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0011-D09 (1/3)					SERVICE: 2nd Stage Gas Compression Air Coolers					
FLUID STATE: VENT GAS		PHASE: GAS					AREA CLASSIFICATION: Zone2, IIB, T4							
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow	Shut-Off		
	1	FLOW RATE			kg/h		-		1414		-			
	2	INLET PRESSURE			bar(g)		-		54.1 ~ 62		-			
	3	OUTLET PRESSURE			bar(g)		-		54.1 ~ 62		-			
	4	DIFFERENTIAL PRESSURE			bar(g)		-		-		62.4			
	5	INLET TEMPERATURE			°C		-		22 ~ 60		-			
	6	DENSITY			kg/m3		-		59.63~ 1012		-			
	7	VISCOSITY			CP		-		0.014 ~ 0.976		-			
	8	VAPOR PRESSURE Pv			bar(a)		-		-		-			
9	CRITICAL PRESSURE			bar(a)		-		94.65		-				
LINE	10	PIPE LINE SIZE & SCHEDULE		IN	1 1/2"	40S	CORROSION ALLOWANCE(mm)		0					
				OUT	1 1/2"	40S								
VALVE BODY & BONNET	11	LINE NO.		GAS-111-0054A-FS00-1 1/2"JS										
	12	TYPE		Full Bore Ball Valve/ Floating Type										
	13	SIZE		1 1/2"										
	14	MAX PRESS./TEMP.		As per PMS										
	15	MFR. & MODEL		Will be finalized later										
	16	BODY / BONNET MATL		ASTM A351 GR.CF3M										
	17	LINER MATERIAL / ID		VTA										
	18	END CONNECTION		IN	1 1/2" /600#									
				OUT	1 1/2" /600#									
	19	FLG FACE FINISH		RF										
	20	END EXT.MATL.		N/A										
	21	FLOW DIRECTION		(Note 18 in Page 4)										
	22	TYPE OF BONNET		Standard										
	23	LUBE & ISO VALVE		No										
	24	PACKING MATERIAL		PACKING TYPE		PTFE		Standard						
	25	ENTRY DESIGN		Top Entry										
	26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES										
	TRIM	27	TRIM	TYPE	MATERIAL		VTA		316 SS+RPTFE					
		28	SIZE	RATED TRAVEL		VTA		VTA						
		29	CHARACTERISTICS		On/Off									
		30	BALANCED / UNBALANCED		BALANCED									
		31	RATED Cv	FL	XT		VTA		VTA					
		32	PLUG / BALL / DISK MATERIAL		316 SS									
		33	SEAT	TYPE	MATERIAL		Soft Seat		RPTFE					
34		CAGE / GUIDE MATERIAL		VTA										
35		STEM	TYPE	MATERIAL		Anti-Blow Out		316 SS						
36		LEAKAGE CLASS		ANSI Class VI										
37	VALVE STEM EXTENSION REQUIREMENT		YES											
SOLENOID VALVE	38	TAG NO		BSOV-2132A , PSOV-2132A										
	39	TYPE		3 Way										
	40	BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65						
	41	ELE. CERTIFICATE	ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5							
	42	MANUAL RESET		Yes										
	43	Power Supply		24 VDC										
	44	Pnu. Connection		1/4" NPT										
	45	FUSIBLE LEAKAGE		No										
SPECIAL / ACCESS.	46	BLOCK RELAY		No										
	47	QUICK EXHUST		Yes										
	49	FILTER REGULATOR		Yes										
	50	VOLUME TANK		No										
	51	MECHANICAL POSITION INDICATOR		Required										
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NISOC		تجهاد است و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves								 				
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 14				
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02					
Blow Down Valve														
TAG NO: BDV-2132B		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0011-D09 (2/3)						SERVICE: 2nd Stage Gas Compression Air Coolers				
FLUID STATE: VENT GAS		PHASE:		GAS						AREA CLASSIFICATION: Zone2, IIB, T4				
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE				kg/h		-		1414		-		-	
	2 INLET PRESSURE				bar(g)		-		54.1 ~ 62		-		-	
	3 OUTLET PRESSURE				bar(g)		-		54.1 ~ 62		-		-	
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		62.4	
	5 INLET TEMPERATURE				°C		-		22 ~ 60		-		-	
	6 DENSITY				kg/m3		-		59.63~ 1012		-		-	
	7 VISCOSITY				CP		-		0.014 ~ 0.976		-		-	
	8 VAPOR PRESSURE Pv				bar(a)		-		-		-		-	
9 CRITICAL PRESSURE				bar(a)		-		94.65		-		-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	1 1/2"	40S	CORROSION ALLOWANCE(mm)		0						
			OUT	1 1/2"	40S									
11 LINE NO.		GAS-111-0054B-FS00-1 1/2"JS												
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/ Floating Type											
	13 SIZE		1 1/2"											
	14 MAX PRESS./TEMP.		As per PMS											
	15 MFR. & MODEL		Will be finalized later											
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M											
	17 LINER MATERIAL / ID		VTA											
	18 END CONNECTION	IN	1 1/2" /600#											
		OUT	1 1/2" /600#											
	19 FLG FACE FINISH		RF											
	20 END EXT.MATL.		N/A											
	21 FLOW DIRECTION		(Note 18 in Page 4)											
	22 TYPE OF BONNET		Standard											
	23 LUBE & ISO VALVE		No											
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard							
25 ENTRY DESIGN		Top Entry												
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES												
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE						
	28 SIZE		RATED TRAVEL		VTA		VTA							
	29 CHARACTERISTICS		On/Off											
	30 BALANCED / UNBALANCED		BALANCED											
	31 RATED Cv		FL	XT		VTA		VTA		VTA				
	32 PLUG / BALL / DISK MATERIAL		316 SS											
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE						
34 CAGE / GUIDE MATERIAL		VTA												
35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS							
36 LEAKAGE CLASS		ANSI Class VI												
37 VALVE STEM EXTENSION REQUIREMENT		YES												
SOLENOID VALVE	38 TAG NO		BSOV-2132B , PSOV-2132B											
	39 TYPE		3 Way											
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65							
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5							
	42 MANUAL RESET		Yes											
	43 Power Supply		24 VDC											
	44 Pnu. Connection		1/4" NPT											
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No											
	46 BLOCK RELAY		No											
	47 QUICK EXHUST		Yes											
	49 FILTER REGULATOR		Yes											
	50 VOLUME TANK		No											
51 MECHANICAL POSITION INDICATOR		Required												
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														


NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM

(1) PMS: Piping material specification.

(2) All material shall be suitable for minimum design metal temperature.

(3) Shall be stated by vendor at quotation stage.

(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.

 NISOC		نگهداشت و افزایش تولید میدان نفتی سنگ الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک							 									
شماره پیمان: 053 - 073 – 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه		شماره صفحه: 17 از 44							
		BK	GCS	PEDCO	120	IN	DT	0010	D02									
Blow Down Valve																		
TAG NO: BDV-2151		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0013-D08					SERVICE: Dehydration Package									
FLUID STATE: VENT GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4									
SERVICE CONDITION	ITEM			UNITS			Max Flow		Norm. Flow		Min. Flow	Shut-Off						
	1	FLOW RATE			kg/h			-		4843		-	-					
	2	INLET PRESSURE			bar(g)			-		52.9 ~ 62		-	-					
	3	OUTLET PRESSURE			bar(g)			-		52.9 ~ 62		-	-					
	4	DIFFERENTIAL PRESSURE			bar(g)			-		-		-	90					
	5	INLET TEMPERATURE			°C			-		22~ 59.4		-	-					
	6	DENSITY			kg/m3			-		58.06 ~ 1012		-	-					
	7	VISCOSITY			CP			-		0.013 ~ 0.964		-	-					
	8	VAPOR PRESSURE Pv			bar(a)			-		-		-	-					
9	CRITICAL PRESSURE			bar(a)			-		105.9		-	-						
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	3"	80	CORROSION ALLOWANCE(mm)		6		53	TYPE		Single Acting , Spring Return					
	11	LINE NO.	OUT	3"	80					54	SIZE		VTA					
VALVE BODY & BONNET	12	TYPE			Full Bore Ball Valve/ Floating Type			ACTUATOR	55	SPRING FAIL ACTION			Fail to Open					
	13	SIZE			3"				56	MAX ALLOWABLE PRESSURE			VTA					
	14	MAX PRESS./TEMP.			As per PMS				57	MIN REQUIRES PRESSURE			VTA					
	15	MFR. & MODEL			Will be finalized later				58	AVAILABLE AIR SUPPLY PRESSURE			MAX/NOR/MIN: 10/7/3 bar-g					
	16	BODY / BONNET MATL			ASTM A216 Gr. WCB				59	BENCH RANGE			VTA					
	17	LINER MATERIAL / ID			VTA				60	TRAVELING TIME			5 S					
	18	END CONNECTION	IN	3"	/600#				61	FUNCTION			On/Off					
	19	FLG FACE FINISH			RF				62	LOCAL POSITION INDICATOR			Required					
	20	END EXT.MATL.			N/A				63	ACT. ORIENTATION			VTA					
	21	FLOW DIRECTION			(Note 18 in Page 4)				64	HAND WHEEL TYPE			Decatchable side mounted					
	22	TYPE OF BONNET			Standard				65	ADJUSTABLE LIMIT STOP			No					
	23	LUBE & ISO VALVE			No				66	INPUT SIGNAL			24VDC					
	24	PACKING MATERIAL		PACKING TYPE		PTFE			Standard		67	MFR. & MODEL			Will be finalized later			
	25	ENTRY DESIGN			Top Entry				POSITIONER	68	TYPE			N/A				
	26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)			YES					69	MFR. & MODEL			Will be finalized later				
	TRIM	27	TRIM	TYPE	MATERIAL		VTA		316 SS+RPTFE		70	ON INCR SIGNAL OUTPUT INCR / DECR			N/A			
28		SIZE	RATED TRAVEL		VTA		VTA		71	GAUGES			N/A					
29		CHARACTERISTICS			On/Off			LIMIT SWITCHES	72	CAM CHARACTERISTIC			N/A					
30		BALANCED / UNBALANCED			BALANCED				73	AIR CONNECTION			N/A					
31		RATED Cv	FL	XT		VTA			VTA		VTA		74	TAG NO. :			BZSC-2151 / BZSO-2151	
32		PLUG / BALL / DISK MATERIAL.			316 SS				75	TYPE	QUANTITY	Magnetically operated 'REED' contacts		2				
33		SEAT	TYPE	MATERIAL		Soft Seat			RPTFE		76	CONTACTS / RATING			110V DC , 10A			
34		CAGE / GUIDE MATERIAL.			VTA				77	ACTUATION POINT			Fully Open/Close					
35	STEM	TYPE	MATERIAL		Anti-Blow Out		316 SS		78	ENCLOSURE MATERIAL			Die Cast Aluminum					
36	LEAKAGE CLASS			ANSI Class VI			79		WEATHER PROTECTION			IP-65						
SOLENOID VALVE	37	VALVE STEM EXTENSION REQUIREMENT			YES			AIR SET	80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d", IIB T4		ISO M20 × 1.5				
	38	TAG NO			BSOV-2151				81	MFR. & MODEL			Will be finalized later					
	39	TYPE			3'Way				82	SET PRESSURE			Yes					
	40	BODY MATERIAL		WEATHER IP.		AISI 316 S.S			IP-65		83	PNEUMATIC CONNECTION		1/4" NPT				
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		84	GAUGES	FILTER	Required					
	42	MANUAL RESET			Yes			TEST	85	MFR. & MODEL			Will be finalized later					
	43	Power Supply			24 VDC				86	ANSI/FCI LEAKAGE CLASS			Required					
	44	Pnu. Connection			1/4" NPT				87	HYDRO PRESSURE			Required					
SPECIAL / ACCESS.	45	FUSIBLE LEAKAGE			No				FIRE PROOF DESIGN	88	FUNCTIONAL TEST			Required				
	46	BLOCK RELAY			No			89										
	47	QUICK EXHUST			Yes			90										
	48	FILTER REGULATOR			Yes			91		PASSIVE FIRE PROTECTION			No					
	49	VOLUME TANK			No			92		API 6FA REQUIREMENTS			No					
	50	MECHANICAL POSITION INDICATOR			Required			93		SIL 3 REQUIREMENTS			Yes					
NOTE:												VTA : VENDOR TO ADVISE AT BIDDING STAGE		VTC: VENDOR TO CONFIRM				
(1) PMS: Piping material specification.																		
(2) All material shall be suitable for minimum design metal temperature.																		
(3) Shall be stated by vendor at quotation stage.																		
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																		

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 					
شماره پیمان: 053 - 073 - 9038		پروژه	پسته کاری	صادرکننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 18			
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02	D02			
On-Off Valve													
TAG NO: XV-2112		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0004-D09 (2/2)				SERVICE: Slug Catcher System					
FLUID STATE: SLUG		PHASE:		LIQUID				AREA CLASSIFICATION: Zme2, IIB, T4					
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off		
	1	FLOW RATE				Kg/H		7873.8	7158.0	2505.3	-		
	2	INLET PRESSURE				bar(g)		18.5	18.5	18.5	-		
	3	OUTLET PRESSURE				bar(g)		18.5	18.5	18.5	-		
	4	DIFFERENTIAL PRESSURE				bar(g)		-	-	-	47.7		
	5	INLET TEMPERATURE				°C		15.2~ 32.0	15.2~ 32.0	15.2~ 32.0	-		
	6	DENSITY				kg/m3		715	715	715	-		
	7	VISCOSITY				CP		0.58	0.58	0.58	-		
	8	VAPOR PRESSURE Pv				bar(a)		6.487	6.487	6.487	-		
9	CRITICAL PRESSURE				bar(a)		78	78	78	-			
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	4"	40	CORROSION ALLOWANCE(mm)	6	53 TYPE		Single Acting, Spring Return			
	11	LINE NO.	OUT	4"	40			54 SIZE		VTA			
VALVE BODY & BONNET	CDH-112-118-CN07-4"-PT					ACTUATOR	55 SPRING FAIL ACTION		Fail to Close				
	12	TYPE					56 MAX ALLOWABLE PRESSURE		VTA				
	13	SIZE					57 MIN REQUIRES PRESSURE		VTA				
	14	MAX PRESS./TEMP.					58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g				
	15	MFR. & MODEL					59 BENCH RANGE		VTA				
	16	BODY / BONNET MATL					60 TRAVELING TIME		5 S				
	17	LINER MATERIAL / ID					61 FUNCTION		On/Off				
	18	END CONNECTION	IN	4"/300#			62 LOCAL POSITION INDICATOR	Required					
		OUT	4"/300#		63 ACT. ORIENTATION		VTA						
	19	FLG FACE FINISH					64 HAND WHEEL TYPE		Clutchable side mounted				
	20	END EXT./MATL.					65 ADJUSTABLE LIMIT STOP		Yes				
	21	FLOW DIRECTION					66 INPUT SIGNAL		24VDC				
	22	TYPE OF BONNET					67 MFR. & MODEL		Will be finalized later				
TRIM	23	LUBE & ISO VALVE				POSITIONER	68 TYPE		N/A				
	24	PACKING MATERIAL	PACKING TYPE		69 MFR. & MODEL		Will be finalized later						
	25	ENTRY DESIGN					70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A				
	26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)					71 GAUGES		N/A				
SOLENOID VALVE	27	TRIM	TYPE	MATERIAL	VTA	316 SS+RPTFE	LIMIT SWITCHES	72 CAM CHARACTERISTIC		N/A			
	28	SIZE	RATED TRAVEL		VTA	VTA		73 AIR CONNECTION		N/A			
	29	CHARACTERISTICS				On/Off		74 TAG NO. :		XZSC-2112 / XZSO-2112			
	30	BALANCED / UNBALANCED				BALANCED		75 TYPE	QUANTITY	Magnetically operated 'REED' contacts	2		
	31	RATED Cv	FL	XT	VTA	VTA		VTA	76 CONTACTS / RATING		110V DC , 10A		
	32	PLUG / BALL / DISK MATERIAL				316 SS		77 ACTUATION POINT		Fully Open/Close			
	33	SEAT	TYPE	MATERIAL	Soft Seat	RPTFE		78 ENCLOSURE MATERIAL		Die Cast Aluminum			
	34	CAGE / GUIDE MATERIAL				VTA		79 WEATHER PROTECTION		IP-65			
	35	STEM	TYPE	MATERIAL	Anti-Blow Out	316 SS		80 ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 × 1.5		
	36	LEAKAGE CLASS				ANSI Class VI		81 MFR. & MODEL		Will be finalized later			
	37	VALVE STEM EXTENSION REQUIREMENT				YES		82 SET PRESSURE		Yes			
SPECIAL / ACCESS.	38	TAG NO				ESOV-2112		AIR SET	83 PNEUMATIC CONNECTION		1/4" NPT		
	39	TYPE				3 Way			84 GAUGES	FILTER	Required	Required	
	40	BODY MATERIAL				WEATHER IP.			AISI 316 S.S		IP-65		
	41	ELEC. CERTIFICATE				ELEC. CONNECTION			EEx "d", IIB T4		ISO M20 x 1.5		
	42	MANUAL RESET				Yes			85 MFR. & MODEL		Will be finalized later		
	43	Power Supply				24 VDC			TEST	86 ANSI/FCI LEAKAGE CLASS		Required	
	44	Pnu. Connection				1/4" NPT				87 HYDRO PRESSURE		Required	
45	FUSIBLE LEAKAGE				No		88 FUNCTIONAL TEST			Required			
46	BLOCK RELAY				No		89						
47	QUICK EXHUST				Yes		90						
48	FILTER REGULATOR				Yes		91						
49	VOLUME TANK				Yes								
50	MECHANICAL POSITION INDICATOR				Required								
51	MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE				Yes								
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.													

 NISOC		تک‌داشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 						
شماره پیمان: 053 - 073 – 9038		پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 19 از 44					
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02						
On-Off Valve															
TAG NO: XV-2121A		P&ID NO :		BK-GCS-PEDCO-120-PR-P1-0006-D09 (1/3)					SERVICE: 1st Stage Gas Compression Suction Drums						
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4						
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off		
	1 FLOW RATE				kg/h		9530.4		8664.0		3032.4		-		
	2 INLET PRESSURE				bar(g)		5.1		5.1		5.1		-		
	3 OUTLET PRESSURE				bar(g)		5.1		5.1		5.1		-		
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		18.2		
	5 INLET TEMPERATURE				°C		19.02~ 36.92		19.02~ 36.92		19.02~ 36.92		-		
	6 DENSITY				kg/m3		5.56 ~ 5.96		5.56 ~ 5.96		5.56 ~ 5.96		-		
	7 VISCOSITY				CP		0.011		0.011		0.011		-		
	8 VAPOR PRESSURE Pv				bar(a)		-		-		-		-		
9 CRITICAL PRESSURE				bar(a)		94.65		94.65		94.65		-			
LINE	PIPE LINE SIZE & SCHEDULE		IN	8"	60	CORROSION ALLOWANCE(mm)		6							
			OUT	8"	60										
11 LINE NO.		GAS-111-0026A-AN07-8"-PT													
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/Trunion Mounted												
	13 SIZE		8"												
	14 MAX PRESS./TEMP.		As per PMS												
	15 MFR. & MODEL		Will be finalized later												
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB												
	17 LINER MATERIAL / ID		VTA												
	18 END CONNECTION		IN	8"/300#											
			OUT	8"/300#											
	19 FLG FACE FINISH		RF												
	20 END EXT.MATL.		N/A												
	21 FLOW DIRECTION		(Note 18 in Page 4)												
	22 TYPE OF BONNET		Standard												
	23 LUBE & ISO VALVE		No												
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard								
25 ENTRY DESIGN		Top Entry													
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES													
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE							
	28 SIZE		RATED TRAVEL		VTA		VTA								
	29 CHARACTERISTICS		On/Off												
	30 BALANCED / UNBALANCED		BALANCED												
	31 RATED Cv		FL	XT		VTA		VTA							
	32 PLUG / BALL / DISK MATERIAL		316 SS												
	33 SEAT		TYPE	MATERIAL		Soft Seat		PTFE							
	34 CAGE / GUIDE MATERIAL		VTA												
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS							
	36 LEAKAGE CLASS		ANSI Class VI												
37 VALVE STEM EXTENSION REQUIREMENT		YES													
SOLENOID VALVE	38 TAG NO		PSOV-2121A , ESOV-2121A												
	39 TYPE		3 Way												
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65								
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5								
	42 MANUAL RESET		Yes												
	43 Power Supply		24 VDC												
	44 Pnu. Connection		1/4" NPT												
	45 FUSIBLE LEAKAGE		No												
SPECIAL / ACCESS.	46 BLOCK RELAY		No												
	47 QUICK EXHUST		Yes												
	49 FILTER REGULATOR		Yes												
	50 VOLUME TANK		Yes												
	51 MECHANICAL POSITION INDICATOR		Required												
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes												
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM															
(1) PMS: Piping material specification.															
(2) All material shall be suitable for minimum design metal temperature.															
(3) Shall be stated by vendor at quotation stage.															
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.															

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 					
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 20 از 44 D02				
		BK	GCS	PEDCO	120	IN	DT	0010	D02					
On-Off Valve														
TAG NO: XV-2121B		P&ID NO :		BK-GCS-PEDCO-120-PR-P1-0006-D09 (2/3)					SERVICE: 1st Stage Gas Compression Suction Drums					
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE				kg/h		9530.4		8664.0		3032.4		-	
	2 INLET PRESSURE				bar(g)		5.1		5.1		5.1		-	
	3 OUTLET PRESSURE				bar(g)		5.1		5.1		5.1		-	
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		18.2	
	5 INLET TEMPERATURE				°C		19.02~ 36.92		19.02~ 36.92		19.02~ 36.92		-	
	6 DENSITY				kg/m3		5.56 ~ 5.96		5.56 ~ 5.96		5.56 ~ 5.96		-	
	7 VISCOSITY				CP		0.011		0.011		0.011		-	
	8 VAPOR PRESSURE Pv				bar(a)		-		-		-		-	
9 CRITICAL PRESSURE				bar(a)		94.65		94.65		94.65		-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	8"	60	CORROSION ALLOWANCE(mm)		6						
			OUT	8"	60									
11 LINE NO.		GAS-111-0026B-AN27-8"-PT												
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/Trunion Mounted											
	13 SIZE		8"											
	14 MAX PRESS./TEMP.		As per PMS											
	15 MFR. & MODEL		Will be finalized later											
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB											
	17 LINER MATERIAL / ID		VTA											
	18 END CONNECTION		IN	8"/300#										
			OUT	8"/300#										
	19 FLG FACE FINISH		RF											
	20 END EXT.MATL.		N/A											
	21 FLOW DIRECTION		(Note 18 in Page 4)											
	22 TYPE OF BONNET		Standard											
	23 LUBE & ISO VALVE		No											
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard							
25 ENTRY DESIGN		Top Entry												
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES												
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE						
	28 SIZE		RATED TRAVEL		VTA		VTA							
	29 CHARACTERISTICS		On/Off											
	30 BALANCED / UNBALANCED		BALANCED											
	31 RATED Cv		FL	XT		VTA		VTA						
	32 PLUG / BALL / DISK MATERIAL		316 SS											
	33 SEAT		TYPE	MATERIAL		Soft Seat		PTFE						
	34 CAGE / GUIDE MATERIAL		VTA											
SOLENOID VALVE	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS						
	36 LEAKAGE CLASS		ANSI Class VI											
	37 VALVE STEM EXTENSION REQUIREMENT		YES											
	38 TAG NO		PSOV-2121B, ESQV-2121B											
SPECIAL / ACCESS.	39 TYPE		3 Way											
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65							
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5							
	42 MANUAL RESET		Yes											
	43 Power Supply		24 VDC											
	44 Pnu. Connection		1/4" NPT											
	45 FUSIBLE LEAKAGE		No											
46 BLOCK RELAY		No												
47 QUICK EXHUST		Yes												
49 FILTER REGULATOR		Yes												
50 VOLUME TANK		Yes												
51 MECHANICAL POSITION INDICATOR		Required												
52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes												
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک							 						
شماره پیمان: 053 - 073 – 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 21 از 44					
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02						
On-Off Valve															
TAG NO: XV-2121C		P&ID NO :		BK-GCS-PEDCO-120-PR-P1-0006-D09 (3/3)					SERVICE: 1st Stage Gas Compression Suction Drums						
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4						
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off		
	1 FLOW RATE				kg/h		9530.4		8664.0		3032.4		-		
	2 INLET PRESSURE				bar(g)		5.1		5.1		5.1		-		
	3 OUTLET PRESSURE				bar(g)		5.1		5.1		5.1		-		
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		18.2		
	5 INLET TEMPERATURE				°C		19.02~ 36.92		19.02~ 36.92		19.02~ 36.92		-		
	6 DENSITY				kg/m3		5.56 ~ 5.96		5.56 ~ 5.96		5.56 ~ 5.96		-		
	7 VISCOSITY				CP		0.011		0.011		0.011		-		
	8 VAPOR PRESSURE Pv				bar(a)		-		-		-		-		
9 CRITICAL PRESSURE				bar(a)		94.65		94.65		94.65		-			
LINE	PIPE LINE SIZE & SCHEDULE		IN	8"	60	CORROSION ALLOWANCE(mm)		6							
			OUT	8"	60										
11 LINE NO.		GAS-111-0026C-AN07-8"-PT													
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/Trunion Mounted												
	13 SIZE		8"												
	14 MAX PRESS./TEMP.		As per PMS												
	15 MFR. & MODEL		Will be finalized later												
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB												
	17 LINER MATERIAL / ID		VTA												
	18 END CONNECTION	IN	8"/300#												
		OUT	8"/300#												
	19 FLG FACE FINISH		RF												
	20 END EXT.MATL.		N/A												
	21 FLOW DIRECTION		(Note 18 in Page 4)												
	22 TYPE OF BONNET		Standard												
	23 LUBE & ISO VALVE		No												
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard								
25 ENTRY DESIGN		Top Entry													
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES													
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE							
	28 SIZE		RATED TRAVEL		VTA		VTA								
	29 CHARACTERISTICS		On/Off												
	30 BALANCED / UNBALANCED		BALANCED				VTA		VTA						
	31 RATED Cv		FL	XT		VTA		VTA		VTA					
	32 PLUG / BALL / DISK MATERIAL		316 SS												
	33 SEAT		TYPE	MATERIAL		Soft Seat		PTFE							
	34 CAGE / GUIDE MATERIAL		VTA												
SOLENOID VALVE	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS							
	36 LEAKAGE CLASS		ANSI Class VI												
	37 VALVE STEM EXTENSION REQUIREMENT		YES												
	38 TAG NO		PSOV-2121C, ESQV-2121C												
SPECIAL / ACCESS.	39 TYPE		3 Way												
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65								
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5								
	42 MANUAL RESET		Yes												
	43 Power Supply		24 VDC												
	44 Pnu. Connection		1/4" NPT												
	45 FUSIBLE LEAKAGE		No												
46 BLOCK RELAY		No													
47 QUICK EXHUST		Yes													
49 FILTER REGULATOR		Yes													
50 VOLUME TANK		Yes													
51 MECHANICAL POSITION INDICATOR		Required													
52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes													
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM															
(1) PMS: Piping material specification.															
(2) All material shall be suitable for minimum design metal temperature.															
(3) Shall be stated by vendor at quotation stage.															
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.															



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

Data Sheets For ON/OFF & Shutdown Valves




شماره پیمان:

053 - 073 – 9038

پروژه

بسته کاری

صادر کننده

تسهیلات

رشته

نوع مدرک

سریال

نسخه

BK

GCS

PEDCO

120

IN

DT

0010

D02

شماره صفحه: 22 از 44

D02

On-Off Valve

TAG NO:

XV-2122A

P&ID NO :

BK-GCS-PEDCO-120-PR-P1-0006-D09 (1/3)

SERVICE:

1st Stage Gas Compression Suction Drums

FLUID STATE:

CLOSED DRAIN

PHASE:

LIQUID

AREA CLASSIFICATION:

Zone2, IIB, T4

NOTE:

VTA : VENDOR TO ADVISE AT BIDDING STAGE

VTC: VENDOR TO CONFIRM

(1) PMS: Piping material specification.

(2) All material shall be suitable for minimum design metal temperature.

(3) Shall be stated by vendor at quotation stage.

(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 			
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 23 از 44		
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02			
On-Off Valve												
TAG NO: XV-2122B		P&ID NO :		BK-GCS-PEDCO-120-PR-P1-0006-D09 (2/3)					SERVICE: 1st Stage Gas Compression Suction Drums			
FLUID STATE: CLOSED DRAIN		PHASE:		LIQUID					AREA CLASSIFICATION: Zone2, IIB, T4			
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off	
	1 FLOW RATE					kg/h		-	10000	-	-	
	2 INLET PRESSURE					bar(g)		-	4.9	-	-	
	3 OUTLET PRESSURE					bar(g)		-	4.9	-	-	
	4 DIFFERENTIAL PRESSURE					bar(g)		-	-	-	13.9	
	5 INLET TEMPERATURE					°C		-	36.78	-	-	
	6 DENSITY					kg/m3		-	998.5	-	-	
	7 VISCOSITY					CP		-	0.69	-	-	
	8 VAPOR PRESSURE Pv					bar(a)		0.61	0.61	0.61	-	
9 CRITICAL PRESSURE					bar(a)		221.3	221.3	221.3	-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	10S	CORROSION ALLOWANCE(mm)		0				
	OUT		2"	10S								
11 LINE NO.		CDB-112-0021B-CS00-2"-NP										
VALVE BODY & BONNET	12 TYPE					Full Bore Ball Valve/Trunion Mounted						
	13 SIZE					2"						
	14 MAX PRESS./TEMP.					As per PMS						
	15 MFR. & MODEL					Will be finalized later						
	16 BODY / BONNET MATL					ASTM A351 GR.CF3M						
	17 LINER MATERIAL / ID					VTA						
	18 END CONNECTION		IN	2"/300#								
	OUT		2"/300#									
	19 FLG FACE FINISH					RF						
	20 END EXT.MATL.					N/A						
	21 FLOW DIRECTION					(Note 18 in Page 4)						
	22 TYPE OF BONNET					Standard						
	23 LUBE & ISO VALVE					No						
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard					
25 ENTRY DESIGN					Top Entry							
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)					No							
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE				
	28 SIZE		RATED TRAVEL		VTA		VTA					
	29 CHARACTERISTICS					On/Off						
	30 BALANCED / UNBALANCED					BALANCED						
	31 RATED Cv		FL	XT		VTA		VTA		VTA		
	32 PLUG / BALL / DISK MATERIAL		316 SS									
	33 SEAT		TYPE	MATERIAL		Soft Seat		PTFE				
	34 CAGE / GUIDE MATERIAL					VTA						
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS				
	36 LEAKAGE CLASS					ANSI Class VI						
37 VALVE STEM EXTENSION REQUIREMENT					YES							
SOLENOID VALVE	38 TAG NO					PSOV-2122B , ESOV-2122B						
	39 TYPE					3 Way						
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65					
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5					
	42 MANUAL RESET					Yes						
	43 Power Supply					24 VDC						
	44 Pnu. Connection					1/4" NPT						
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE					No						
	46 BLOCK RELAY					No						
	47 QUICK EXHUST					Yes						
	49 FILTER REGULATOR					Yes						
	50 VOLUME TANK					Yes						
	51 MECHANICAL POSITION INDICATOR					Required						
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes						
53 TYPE		Single Acting, Spring Return										
54 SIZE		VTA										
55 SPRING FAIL ACTION		Fail to Close										
56 MAX ALLOWABLE PRESSURE		VTA										
57 MIN REQUIRES PRESSURE		VTA										
58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g										
59 BENCH RANGE		VTA										
60 TRAVELING TIME		5 S										
61 FUNCTION		On/Off										
62 LOCAL POSITION INDICATOR		Required										
63 ACT. ORIENTATION		VTA										
64 HAND WHEEL TYPE		Clutchable side mounted										
65 ADJUSTABLE LIMIT STOP		Yes										
66 INPUT SIGNAL		24VDC										
67 MFR. & MODEL		Will be finalized later										
68 TYPE		N/A										
69 MFR. & MODEL		Will be finalized later										
70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A										
71 GAUGES		N/A										
72 CAM CHARACTERISTIC		N/A										
73 AIR CONNECTION		N/A										
74 TAG NO. :		XZSC-2122B / XZSO-2122B										
75 TYPE		QUANTITY		Magnetically operated "REED" contacts						2		
76 CONTACTS / RATING		110V DC , 10A										
77 ACTUATION POINT		Fully Open/Close										
78 ENCLOSURE MATERIAL		Die Cast Aluminum										
79 WEATHER PROTECTION		IP-65										
80 ELEC. CERTIFICATE		ELEC. CONNECTION		EEx "d", IIB T4						ISO M20 x 1.5		
81 MFR. & MODEL		Will be finalized later										
82 SET PRESSURE		Yes										
83 PNEUMATIC CONNECTION		1/4" NPT										
84 GAUGES		FILTER		Required						Required		
85 MFR. & MODEL		Will be finalized later										
86 ANSI/FCI LEAKAGE CLASS		Required										
87 HYDRO PRESSURE		Required										
88 FUNCTIONAL TEST		Required										
89												
90												
91												
92 PASSIVE FIRE PROTECTION		No										
93 API 6FA REQUIREMENTS		Yes										
94 SIL 3 REQUIREMENTS		Yes										
95 PARTIAL STROKING VALVE TEST		Yes										
96												
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												

 NISOC		تکهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 							
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 25 از 44						
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02							
On-Off Valve																
TAG NO: XV-2123A		P&ID NO : BK-GCS-PEDCO-120-PR-P1-0006-D09 (1/3)							SERVICE: 1st Stage Gas Compression Suction Drums							
FLUID STATE: Process Gas		PHASE: Gas							AREA CLASSIFICATION: Zone2, IIB, T4							
SERVICE CONDITION	ITEM				UNITS			Max Flow		Norm. Flow		Min. Flow		Shut-Off		
	1 FLOW RATE				kg/h			9530.4		8664.0		3032.4		-		
	2 INLET PRESSURE				bar(g)			5.1		5.1		5.1		-		
	3 OUTLET PRESSURE				bar(g)			5.1		5.1		5.1		-		
	4 DIFFERENTIAL PRESSURE				bar(g)			-		-		-		18.2		
	5 INLET TEMPERATURE				°C			19.02~ 36.92		19.02~ 36.92		19.02~ 36.92		-		
	6 DENSITY				kg/m3			5.56 ~ 5.96		5.56 ~ 5.96		5.56 ~ 5.96		-		
	7 VISCOSITY				CP			0.011		0.011		0.011		-		
	8 VAPOR PRESSURE Pv				bar(a)			-		-		-		-		
9 CRITICAL PRESSURE				bar(a)			94.65		94.65		94.65		-			
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	160	CORROSION ALLOWANCE(mm)		6		53 TYPE		Single Acting, Spring Return				
			OUT	2"	160					54 SIZE		VTA				
VALVE BODY & BONNET	11 LINE NO.		GAS-111-0024A-AN07-2"-PT							55 SPRING FAIL ACTION		Fail to Close				
	12 TYPE		Full Bore Ball Valve/Trunion Mounted							56 MAX ALLOWABLE PRESSURE		VTA				
	13 SIZE		2"							57 MIN REQUIRES PRESSURE		VTA				
	14 MAX PRESS./TEMP.		As per PMS							58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g				
	15 MFR. & MODEL		Will be finalized later							59 BENCH RANGE		VTA				
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M							60 TRAVELING TIME		5 S				
	17 LINER MATERIAL / ID		VTA							61 FUNCTION		On/Off				
	18 END CONNECTION		IN	2"/300#							62 LOCAL POSITION INDICATOR		Required			
			OUT	2"/300#							63 ACT. ORIENTATION		VTA			
	19 FLG FACE FINISH		RF							64 HAND WHEEL TYPE		Clutchable side mounted				
	20 END EXT.MATL.		N/A							65 ADJUSTABLE LIMIT STOP		Yes				
	21 FLOW DIRECTION		(Note 18 in Page 4)							66 INPUT SIGNAL		24VDC				
	22 TYPE OF BONNET		Standard							67 MFR. & MODEL		Will be finalized later				
	23 LUBE & ISO VALVE		No							68 TYPE		N/A				
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard			69 MFR. & MODEL		Will be finalized later				
	25 ENTRY DESIGN		Top Entry							70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A				
	26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		No							71 GAUGES		N/A				
	TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE		72 CAM CHARACTERISTIC		N/A			
		28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A				
		29 CHARACTERISTICS		On/Off							74 TAG NO. :		XZSC-2123A / XZSO-2123A			
		30 BALANCED / UNBALANCED		BALANCED							75 TYPE		QUANTITY	Magnetically operated "REED" contacts		2
31 RATED Cv		FL	XT		VTA		VTA		76 CONTACTS / RATING		110V DC , 10A					
32 PLUG / BALL / DISK MATERIAL		316 SS							77 ACTUATION POINT		Fully Open/Close					
33 SEAT		TYPE	MATERIAL		Soft Seat		PTFE		78 ENCLOSURE MATERIAL		Die Cast Aluminum					
34 CAGE / GUIDE MATERIAL		VTA							79 WEATHER PROTECTION		IP-65					
35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 × 1.5			
36 LEAKAGE CLASS		ANSI Class VI							81 MFR. & MODEL		Will be finalized later					
SOLENOID VALVE	37 VALVE STEM EXTENSION REQUIREMENT		YES							82 SET PRESSURE		Yes				
	38 TAG NO		PSOV-2123A , ESOV-2123A							83 PNEUMATIC CONNECTION		1/4" NPT				
	39 TYPE		3 Way							84 GAUGES		FILTER	Required	Required		
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL		Will be finalized later					
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS		Required					
	42 MANUAL RESET		Yes							87 HYDRO PRESSURE		Required				
	43 Power Supply		24 VDC							88 FUNCTIONAL TEST		Required				
	44 Pnu. Connection		1/4" NPT							89						
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No							90						
	46 BLOCK RELAY		No							91						
	47 QUICK EXHUST		Yes							92 PASSIVE FIRE PROTECTION		No				
	49 FILTER REGULATOR		Yes							93 API 6FA REQUIREMENTS		Yes				
	50 VOLUME TANK		Yes							94 SIL 3 REQUIREMENTS		Yes				
	51 MECHANICAL POSITION INDICATOR		Required							95 PARTIAL STROKING VALVE TEST		Yes				
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes							96						
	NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.															

 NISOC		تکهداشت و افزایش تولید میدان نفتی بینک سطح الارض																		
		احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک																		
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 27 از 44										
		BK	GCS	PEDCO	120	IN	DT	0010	D02											
On-Off Valve																				
TAG NO:		XV-2123C			P&ID NO :					BK-GCS-PEDCO-120-PR-P1-0006-D09 (3/3)				SERVICE:		1st Stage Gas Compression Suction Drums				
FLUID STATE:		Process Gas			PHASE:					Gas					AREA CLASSIFICATION:				Zone2, IIB, T4	
SERVICE CONDITION	ITEM				UNITS				Max Flow		Norm. Flow		Min. Flow		Shut-Off					
	1 FLOW RATE				kg/h				9530.4		8664.0		3032.4		-					
	2 INLET PRESSURE				bar(g)				5.1		5.1		5.1		-					
	3 OUTLET PRESSURE				bar(g)				5.1		5.1		5.1		-					
	4 DIFFERENTIAL PRESSURE				bar(g)				-		-		-		18.2					
	5 INLET TEMPERATURE				°C				19.02~ 36.92		19.02~ 36.92		19.02~ 36.92		-					
	6 DENSITY				kg/m3				5.56 ~ 5.96		5.56 ~ 5.96		5.56 ~ 5.96		-					
	7 VISCOSITY				CP				0.011		0.011		0.011		-					
	8 VAPOR PRESSURE Pv				bar(a)				-		-		-		-					
9 CRITICAL PRESSURE				bar(a)				94.65		94.65		94.65		-						
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	160	CORROSION ALLOWANCE(mm)		6		53 TYPE		Single Acting, Spring Return								
			OUT	2"	160					54 SIZE		VTA								
VALVE BODY & BONNET	11 LINE NO.		GAS-111-0024C-AN07-2"-PT								55 SPRING FAIL ACTION		Fail to Close							
	12 TYPE		Full Bore Ball Valve/Trunion Mounted								56 MAX ALLOWABLE PRESSURE		VTA							
	13 SIZE		2"								57 MIN REQUIRES PRESSURE		VTA							
	14 MAX PRESS./TEMP.		As per PMS								58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g							
	15 MFR. & MODEL		Will be finalized later								59 BENCH RANGE		VTA							
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M								60 TRAVELING TIME		5 S							
	17 LINER MATERIAL / ID		VTA								61 FUNCTION		On/Off							
	18 END CONNECTION		IN	2"/300#						62 LOCAL POSITION INDICATOR		Required								
			OUT	2"/300#						63 ACT. ORIENTATION		VTA								
	19 FLG FACE FINISH		RF								64 HAND WHEEL TYPE		Clutchable side mounted							
	20 END EXT.MATL.		N/A								65 ADJUSTABLE LIMIT STOP		Yes							
	21 FLOW DIRECTION		(Note 18 in Page 4)								66 INPUT SIGNAL		24VDC							
	22 TYPE OF BONNET		Standard								67 MFR. & MODEL		Will be finalized later							
	23 LUBE & ISO VALVE		No								68 TYPE		N/A							
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard		69 MFR. & MODEL		Will be finalized later									
	25 ENTRY DESIGN		Top Entry								70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A							
	26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		No								71 GAUGES		N/A							
	TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE		72 CAM CHARACTERISTIC		N/A							
		28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A								
		29 CHARACTERISTICS		On/Off								74 TAG NO. :		XZSC-2123C / XZSO-2123C						
30 BALANCED / UNBALANCED		BALANCED								75 TYPE		QUANTITY	Magnetically operated "REED" contacts		2					
31 RATED Cv		FL	XT		VTA		VTA		76 CONTACTS / RATING		110V DC , 10A									
32 PLUG / BALL / DISK MATERIAL		316 SS								77 ACTUATION POINT		Fully Open/Close								
33 SEAT		TYPE	MATERIAL		Soft Seat		PTFE		78 ENCLOSURE MATERIAL		Die Cast Aluminum									
34 CAGE / GUIDE MATERIAL		VTA								79 WEATHER PROTECTION		IP-65								
35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 × 1.5							
36 LEAKAGE CLASS		ANSI Class VI								81 MFR. & MODEL		Will be finalized later								
SOLENOID VALVE	37 VALVE STEM EXTENSION REQUIREMENT		YES								82 SET PRESSURE		Yes							
	38 TAG NO		PSOV-2123C , ESOV-2123C								83 PNEUMATIC CONNECTION		1/4" NPT							
	39 TYPE		3 Way								84 GAUGES		FILTER	Required	Required					
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL		Will be finalized later									
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS		Required									
	42 MANUAL RESET		Yes								87 HYDRO PRESSURE		Required							
	43 Power Supply		24 VDC								88 FUNCTIONAL TEST		Required							
	44 Pnu. Connection		1/4" NPT								89									
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No								90									
	46 BLOCK RELAY		No								91									
	47 QUICK EXHUST		Yes								92 PASSIVE FIRE PROTECTION		No							
	49 FILTER REGULATOR		Yes								93 API 6FA REQUIREMENTS		Yes							
	50 VOLUME TANK		Yes								94 SIL 3 REQUIREMENTS		Yes							
	51 MECHANICAL POSITION INDICATOR		Required								95 PARTIAL STROKING VALVE TEST		Yes							
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes								96									
	NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM																			
(1) PMS: Piping material specification.																				
(2) All material shall be suitable for minimum design metal temperature.																				
(3) Shall be stated by vendor at quotation stage.																				
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																				



NISOC

تکهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

Data Sheets For ON/OFF & Shutdown Valves




شماره پیمان:

053 - 073 – 9038

نسخه

0010

سریال

DT

نوع مدرک

IN

رشته

120

تسهيلات

GCS

صادر کننده

BK

پروژه

PEDCO

شماره صفحه: 29 از 44

D02

On-Off Valve

D02

NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM

(1) PMS: Piping material specification.

(2) All material shall be suitable for minimum design metal temperature.

(3) Shall be stated by vendor at quotation stage.

(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.


 NISOC		تکهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 				
شماره پیمان: 053 - 073 – 9038		پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه	 D02	شماره صفحه: 30 از 44		
		BK	GCS	PEDCO	120	IN	DT	0010	D02				
On-Off Valve													
TAG NO: XV-2124C		P&ID NO : BK-GCS-PEDCO-120-PR-P1-0006-D09 (3/3)							SERVICE: 1st Stage Gas Compression Suction Drums				
FLUID STATE: Gas		PHASE: Nitrogen							AREA CLASSIFICATION: Zone2, IIB, T4				
SERVICE CONDITION	ITEM				UNITS			Max Flow	Norm. Flow	Min. Flow	Shut-Off		
	1	FLOW RATE				kg/h			-	25	-		
	2	INLET PRESSURE				bar(g)			-	7.5	-		
	3	OUTLET PRESSURE				bar(g)			-	7.5	-		
	4	DIFFERENTIAL PRESSURE				bar(g)			-	-	-	12.5	
	5	INLET TEMPERATURE				°C			-	60	-		
	6	DENSITY				kg/m3			-	8.62	-		
	7	VISCOSITY				CP			-	0.02	-		
	8	VAPOR PRESSURE Pv				bar(a)			-	-	-	-	
	CRITICAL PRESSURE				bar(a)			-	33.94	-	-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	40	CORROSION ALLOWANCE(mm)		1					
			OUT	2"	40								
VALVE BODY & BONNET	11		LINE NO.									NIT-112-0006C-AN01-2"-PT	
	12		TYPE									Full Bore Ball Valve/Trunion Mounted	
	13		SIZE									2"	
	14		MAX PRESS./TEMP.									As per PMS	
	15		MFR. & MODEL									Will be finalized later	
	16		BODY / BONNET MATL									ASTM A351 GR.CF3M	
	17		LINER MATERIAL / ID									VTA	
	18		END CONNECTION		IN	2"/300#							
					OUT	2"/300#							
	19		FLG FACE FINISH									RF	
	20		END EXT.MATL.									N/A	
	21		FLOW DIRECTION									(Note 18 in Page 4)	
	22		TYPE OF BONNET									Standard	
	23		LUBE & ISO VALVE									No	
	24		PACKING MATERIAL		PACKING TYPE		PTFE		Standard				
	25		ENTRY DESIGN									Top Entry	
	26		NACE REQUIREMENTNACE (MR-0175/ISO 15156)									No	
	27		TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE			
	28		SIZE		RATED TRAVEL		VTA		VTA				
	29		CHARACTERISTICS									On/Off	
	30		BALANCED / UNBALANCED									BALANCED	
	31		RATED Cv		FL	XT		VTA		VTA			
	32		PLUG / BALL / DISK MATERIAL									316 SS	
	33		SEAT		TYPE	MATERIAL		Soft Seat		PTFE			
	34		CAGE / GUIDE MATERIAL									VTA	
35		STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS				
36		LEAKAGE CLASS									ANSI Class VI		
37		VALVE STEM EXTENSION REQUIREMENT									YES		
38		TAG NO									PSOV-2124C , ESOV-2124C		
39		TYPE									3 Way		
40		BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65					
41		ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5					
42		MANUAL RESET									Yes		
43		Power Supply									24 VDC		
44		Pnu. Connection									1/4" NPT		
45		FUSIBLE LEAKAGE									No		
46		BLOCK RELAY									No		
47		QUICK EXHUST									Yes		
49		FILTER REGULATOR									Yes		
50		VOLUME TANK									Yes		
51		MECHANICAL POSITION INDICATOR									Required		
52		MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE									Yes		
53		TYPE									Single Acting, Spring Return		
54		SIZE									VTA		
55		SPRING FAIL ACTION									Fail to Close		
56		MAX ALLOWABLE PRESSURE									VTA		
57		MIN REQUIRES PRESSURE									VTA		
58		AVAILABLE AIR SUPPLY PRESSURE									MAX/NOR/MIN: 10/7/3 bar-g		
59		BENCH RANGE									VTA		
60		TRAVELING TIME									5 S		
61		FUNCTION									On/Off		
62		LOCAL POSITION INDICATOR									Required		
63		ACT. ORIENTATION									VTA		
64		HAND WHEEL TYPE									Clutchable side mounted		
65		ADJUSTABLE LIMIT STOP									Yes		
66		INPUT SIGNAL									24VDC		
67		MFR. & MODEL									Will be finalized later		
68		TYPE									N/A		
69		MFR. & MODEL									Will be finalized later		
70		ON INCR SIGNAL OUTPUT INCR / DECR									N/A		
71		GAUGES									N/A		
72		CAM CHARACTERISTIC									N/A		
73		AIR CONNECTION									N/A		
74		TAG NO. :									XZSC-2124C / XZSO-2124C		
75		TYPE		QUANTITY		Magnetically operated "REED" contacts		2					
76		CONTACTS / RATING									110V DC , 10A		
77		ACTUATION POINT									Fully Open/Close		
78		ENCLOSURE MATERIAL									Die Cast Aluminum		
79		WEATHER PROTECTION									IP-65		
80		ELEC. CERTIFICATE		ELEC. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5					
81		MFR. & MODEL									Will be finalized later		
82		SET PRESSURE									Yes		
83		PNEUMATIC CONNECTION									1/4" NPT		
84		GAUGES		FILTER		Required		Required					
85		MFR. & MODEL									Will be finalized later		
86		ANSI/FCI LEAKAGE CLASS									Required		
87		HYDRO PRESSURE									Required		
88		FUNCTIONAL TEST									Required		
89													
90													
91													
92		PASSIVE FIRE PROTECTION									No		
93		API 6FA REQUIREMENTS									Yes		
94		SIL 3 REQUIREMENTS									Yes		
95		PARTIAL STROKING VALVE TEST									Yes		
96													
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.													


 NISOC		تجهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 						
شماره پیمان: 053 - 073 – 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 31 از 44					
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02						
On-Off Valve															
TAG NO: XV-2131A		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D08 (1 of 3)					SERVICE: 2nd Stage Gas Compression Suction Drums						
FLUID STATE: CLOSED DRAIN		PHASE:		LIQUID					AREA CLASSIFICATION: Zone2, IIB, T4						
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE					kg/h		-		10000		-		-	
	2 INLET PRESSURE					bar(g)		-		18.1		-		-	
	3 OUTLET PRESSURE					bar(g)		-		18.1		-		-	
	4 DIFFERENTIAL PRESSURE					bar(g)		-		-		-		30.3	
	5 INLET TEMPERATURE					°C		-		59.88		-		-	
	6 DENSITY					kg/m3		-		981.1		-		-	
	7 VISCOSITY					CP		-		0.496		-		-	
	8 VAPOR PRESSURE Pv					bar(a)		-		3.23		-		-	
9 CRITICAL PRESSURE					bar(a)		221.5		221.5		221.5		-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	10S	CORROSION ALLOWANCE(mm)		0		53 TYPE		Single Acting, Spring Return			
			OUT	2"	10S					54 SIZE		VTA			
11 LINE NO.		CDH-111-0023A-CS00-2"-NP										55 SPRING FAIL ACTION		Fail to Close	
VALVE BODY & BONNET	12 TYPE					Full Bore Ball Valve/Trunion Mounted					56 MAX ALLOWABLE PRESSURE		VTA		
	13 SIZE					2"					57 MIN REQUIRES PRESSURE		VTA		
	14 MAX PRESS./TEMP.					As per PMS					58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g		
	15 MFR. & MODEL					Will be finalized later					59 BENCH RANGE		VTA		
	16 BODY / BONNET MATL					ASTM A351 GR.CF3M					60 TRAVELING TIME		5 S		
	17 LINER MATERIAL / ID					VTA					61 FUNCTION		On/Off		
	18 END CONNECTION		IN	2"/300#			62 LOCAL POSITION INDICATOR					Required			
			OUT	2"/300#			63 ACT. ORIENTATION					VTA			
	19 FLG FACE FINISH					RF					64 HAND WHEEL TYPE		Clutchable side mounted		
	20 END EXT.MATL.					N/A					65 ADJUSTABLE LIMIT STOP		Yes		
	21 FLOW DIRECTION					(Note 18 in Page 4)					66 INPUT SIGNAL		24VDC		
	22 TYPE OF BONNET					Standard					67 MFR. & MODEL		Will be finalized later		
	23 LUBE & ISO VALVE					No					68 TYPE		N/A		
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard		69 MFR. & MODEL		Will be finalized later				
25 ENTRY DESIGN					Top Entry					70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A			
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)					No					71 GAUGES		N/A			
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE		72 CAM CHARACTERISTIC		N/A			
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A				
	29 CHARACTERISTICS					On/Off					74 TAG NO. :		XZSC-2131A / XZSO-2131A		
	30 BALANCED / UNBALANCED					BALANCED				75 TYPE		QUANTITY	Magnetically operated "REED" contacts		
	31 RATED Cv		FL	XT		VTA		VTA	VTA	76 CONTACTS / RATING		110V DC , 10A			
	32 PLUG / BALL / DISK MATERIAL					316 SS					77 ACTUATION POINT		Fully Open/Close		
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE		78 ENCLOSURE MATERIAL		Die Cast Aluminum			
	34 CAGE / GUIDE MATERIAL					VTA					79 WEATHER PROTECTION		IP-65		
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 x 1.5	
	36 LEAKAGE CLASS					ANSI Class VI					81 MFR. & MODEL		Will be finalized later		
37 VALVE STEM EXTENSION REQUIREMENT					YES					82 SET PRESSURE		Yes			
SOLENOID VALVE	38 TAG NO		PSOV-2131A , ESOV-2131A					83 PNEUMATIC CONNECTION		1/4" NPT					
	39 TYPE		3 Way					84 GAUGES		FILTER	Required	Required			
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL		Will be finalized later				
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS		Required				
	42 MANUAL RESET					Yes					87 HYDRO PRESSURE		Required		
	43 Power Supply					24 VDC					88 FUNCTIONAL TEST		Required		
	44 Pnu. Connection					1/4" NPT					89				
	45 FUSIBLE LEAKAGE					No					90				
SPECIAL / ACCESS.	46 BLOCK RELAY					No					91				
	47 QUICK EXHUST					Yes					92 PASSIVE FIRE PROTECTION		No		
	49 FILTER REGULATOR					Yes					93 API 6FA REQUIREMENTS		Yes		
	50 VOLUME TANK					Yes					94 SIL 3 REQUIREMENTS		Yes		
	51 MECHANICAL POSITION INDICATOR					Required					95 PARTIAL STROKING VALVE TEST		Yes		
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes					96				
	NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
	(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.															
(3) Shall be stated by vendor at quotation stage.															
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.															


 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 			
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 32		
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02			
On-Off Valve												
TAG NO: XV-2131B		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D08 (2 of 3)					SERVICE: 2nd Stage Gas Compression Suction Drums			
FLUID STATE: CLOSED DRAIN		PHASE:		LIQUID					AREA CLASSIFICATION: Zone2, IIB, T4			
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow		
	1 FLOW RATE					kg/h		-		10000		
	2 INLET PRESSURE					bar(g)		-		18.1		
	3 OUTLET PRESSURE					bar(g)		-		18.1		
	4 DIFFERENTIAL PRESSURE					bar(g)		-		-		
	5 INLET TEMPERATURE					°C		-		59.88		
	6 DENSITY					kg/m3		-		981.1		
	7 VISCOSITY					CP		-		0.496		
	8 VAPOR PRESSURE Pv					bar(a)		-		3.23		
9 CRITICAL PRESSURE					bar(a)		221.5		221.5		221.5	
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	10S	CORROSION ALLOWANCE(mm)		0		53 TYPE Single Acting, Spring Return		
			OUT	2"	10S					54 SIZE VTA		
VALVE BODY & BONNET	11 LINE NO.		CDH-111-0023B-CS00-2"-NP					55 SPRING FAIL ACTION		Fail to Close		
	12 TYPE		Full Bore Ball Valve/Trunion Mounted					56 MAX ALLOWABLE PRESSURE		VTA		
	13 SIZE		2"					57 MIN REQUIRES PRESSURE		VTA		
	14 MAX PRESS./TEMP.		As per PMS					58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g		
	15 MFR. & MODEL		Will be finalized later					59 BENCH RANGE		VTA		
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M					60 TRAVELING TIME		5 S		
	17 LINER MATERIAL / ID		VTA					61 FUNCTION		On/Off		
	18 END CONNECTION		IN	2"/300#				62 LOCAL POSITION INDICATOR		Required		
			OUT	2"/300#				63 ACT. ORIENTATION		VTA		
	19 FLG FACE FINISH		RF					64 HAND WHEEL TYPE		Clutchable side mounted		
	20 END EXT.MATL.		N/A					65 ADJUSTABLE LIMIT STOP		Yes		
	21 FLOW DIRECTION		(Note 18 in Page 4)					66 INPUT SIGNAL		24VDC		
	22 TYPE OF BONNET		Standard					67 MFR. & MODEL		Will be finalized later		
	23 LUBE & ISO VALVE		No					68 TYPE		N/A		
PACKING MATERIAL	PACKING TYPE		PTFE		Standard		69 MFR. & MODEL		Will be finalized later			
	25 ENTRY DESIGN		Top Entry					70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A		
	26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		No					71 GAUGES		N/A		
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE		72 CAM CHARACTERISTIC		N/A
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A	
	29 CHARACTERISTICS		On/Off					74 TAG NO. :		XZSC-2131B / XZSO-2131B		
	30 BALANCED / UNBALANCED		BALANCED				75 TYPE		QUANTITY	Magnetically operated "REED" contacts		
	31 RATED Cv		FL	XT		VTA		VTA		VTA		
	32 PLUG / BALL / DISK MATERIAL		316 SS					76 CONTACTS / RATING		110V DC , 10A		
	33 SEAT		TYPE	MATERIAL		Soft Seat		77 ACTUATION POINT		Fully Open/Close		
	34 CAGE / GUIDE MATERIAL		VTA					78 ENCLOSURE MATERIAL		Die Cast Aluminum		
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		79 WEATHER PROTECTION		IP-65		
	36 LEAKAGE CLASS		ANSI Class VI					80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 x 1.5
37 VALVE STEM EXTENSION REQUIREMENT		YES					81 MFR. & MODEL		Will be finalized later			
SOLENOID VALVE	38 TAG NO		PSOV-2131B, ESQV-2131B					82 SET PRESSURE		Yes		
	39 TYPE		3 Way					83 PNEUMATIC CONNECTION		1/4" NPT		
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		84 GAUGES		FILTER	Required	Required	
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		85 MFR. & MODEL		Will be finalized later			
	42 MANUAL RESET		Yes					86 ANSI/FCI LEAKAGE CLASS		Required		
	43 Power Supply		24 VDC					87 HYDRO PRESSURE		Required		
	44 Pnu. Connection		1/4" NPT					88 FUNCTIONAL TEST		Required		
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No					89				
	46 BLOCK RELAY		No					90				
	47 QUICK EXHUST		Yes					91				
	49 FILTER REGULATOR		Yes					92 PASSIVE FIRE PROTECTION		No		
	50 VOLUME TANK		Yes					93 API 6FA REQUIREMENTS		Yes		
	51 MECHANICAL POSITION INDICATOR		Required					94 SIL 3 REQUIREMENTS		Yes		
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes					95 PARTIAL STROKING VALVE TEST		Yes		
								96				
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												


 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 					
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 33 از 44 D02				
		BK	GCS	PEDCO	120	IN	DT	0010	D02					
On-Off Valve														
TAG NO: XV-2131C		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D08 (3 of 3)					SERVICE: 2nd Stage Gas Compression Suction Drums					
FLUID STATE: CLOSED DRAIN		PHASE:		LIQUID					AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE				kg/h		-		10000		-		-	
	2 INLET PRESSURE				bar(g)		-		18.1		-		-	
	3 OUTLET PRESSURE				bar(g)		-		18.1		-		-	
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		30.3	
	5 INLET TEMPERATURE				°C		-		59.88		-		-	
	6 DENSITY				kg/m3		-		981.1		-		-	
	7 VISCOSITY				CP		-		0.496		-		-	
	8 VAPOR PRESSURE Pv				bar(a)		-		3.23		-		-	
9 CRITICAL PRESSURE				bar(a)		221.5		221.5		221.5		-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	10S	CORROSION ALLOWANCE(mm)		0		53 TYPE		Single Acting, Spring Return		
			OUT	2"	10S					54 SIZE		VTA		
11 LINE NO.		CDH-111-0023C-CS00-2"-NP									55 SPRING FAIL ACTION		Fail to Close	
VALVE BODY & BONNET	12 TYPE				Full Bore Ball Valve/Trunion Mounted						56 MAX ALLOWABLE PRESSURE		VTA	
	13 SIZE				2"						57 MIN REQUIRES PRESSURE		VTA	
	14 MAX PRESS./TEMP.				As per PMS						58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g	
	15 MFR. & MODEL				Will be finalized later						59 BENCH RANGE		VTA	
	16 BODY / BONNET MATL				ASTM A351 GR.CF3M						60 TRAVELING TIME		5 S	
	17 LINER MATERIAL / ID				VTA						61 FUNCTION		On/Off	
	18 END CONNECTION		IN	2"/300#					62 LOCAL POSITION INDICATOR		Required			
			OUT	2"/300#					63 ACT. ORIENTATION		VTA			
	19 FLG FACE FINISH				RF						64 HAND WHEEL TYPE		Clutchable side mounted	
	20 END EXT.MATL.				N/A						65 ADJUSTABLE LIMIT STOP		Yes	
	21 FLOW DIRECTION				(Note 18 in Page 4)						66 INPUT SIGNAL		24VDC	
	22 TYPE OF BONNET				Standard						67 MFR. & MODEL		Will be finalized later	
	23 LUBE & ISO VALVE				No						68 TYPE		N/A	
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard		69 MFR. & MODEL		Will be finalized later			
25 ENTRY DESIGN				Top Entry						70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A		
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)				No						71 GAUGES		N/A		
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE		72 CAM CHARACTERISTIC		N/A		
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A			
	29 CHARACTERISTICS				On/Off						74 TAG NO. :		XZSC-2131C / XZSO-2131C	
	30 BALANCED / UNBALANCED				BALANCED				75 TYPE		QUANTITY	Magnetically operated "REED" contacts		2
	31 RATED Cv		FL	XT		VTA		VTA	VTA	76 CONTACTS / RATING		110V DC , 10A		
	32 PLUG / BALL / DISK MATERIAL				316 SS						77 ACTUATION POINT		Fully Open/Close	
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE		78 ENCLOSURE MATERIAL		Die Cast Aluminum		
	34 CAGE / GUIDE MATERIAL				VTA						79 WEATHER PROTECTION		IP-65	
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 x 1.5
	36 LEAKAGE CLASS				ANSI Class VI						81 MFR. & MODEL		Will be finalized later	
37 VALVE STEM EXTENSION REQUIREMENT				YES						82 SET PRESSURE		Yes		
SOLENOID VALVE	38 TAG NO		PSOV-2131C, ESQV-2131C						83 PNEUMATIC CONNECTION		1/4" NPT			
	39 TYPE		3 Way						84 GAUGES		FILTER	Required	Required	
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL		Will be finalized later			
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS		Required			
	42 MANUAL RESET				Yes						87 HYDRO PRESSURE		Required	
	43 Power Supply				24 VDC						88 FUNCTIONAL TEST		Required	
	44 Pnu. Connection				1/4" NPT						89			
	45 FUSIBLE LEAKAGE				No						90			
SPECIAL / ACCESS.	46 BLOCK RELAY				No						91			
	47 QUICK EXHUST				Yes						92 PASSIVE FIRE PROTECTION		No	
	49 FILTER REGULATOR				Yes						93 API 6FA REQUIREMENTS		Yes	
	50 VOLUME TANK				Yes						94 SIL 3 REQUIREMENTS		Yes	
	51 MECHANICAL POSITION INDICATOR				Required						95 PARTIAL STROKING VALVE TEST		Yes	
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE				Yes						96			
	NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM													
	(1) PMS: Piping material specification.													
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 			
شماره پیمان: 053 - 073 - 9038		پروژه	پسته کاری	صادرکننده	تهیهات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 34	
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02	D02	
On-Off Valve											
TAG NO: XV-2133A		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0011-D09 (1 of 3)				SERVICE: 2nd Stage Gas Compression Air Coolers			
FLUID STATE: PROCESS GAS		PHASE:		GAS				AREA CLASSIFICATION: Zone2, IIB, T4			
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off
	1	FLOW RATE					kg/h	9530.4	8664	3032.4	-
	2	INLET PRESSURE					bar(g)	54.1	54.1	54.1	-
	3	OUTLET PRESSURE					bar(g)	54.1	54.1	54.1	-
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	62.4
	5	INLET TEMPERATURE					°C	-	60	-	-
	6	DENSITY					kg/m3	49.41 ~ 59.63	49.41 ~ 59.63	49.41 ~ 59.63	-
	7	VISCOSITY					CP	0.014	0.014	0.014	-
	8	VAPOR PRESSURE Pv					bar(a)	-	-	-	-
9	CRITICAL PRESSURE					bar(a)	94.66	94.66	94.66	-	
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	6"	40S	CORROSION ALLOWANCE(mm)	0	53	TYPE		Single Acting, Spring Return
	11	LINE NO.	OUT	6"	40S			54	SIZE		VTA
VALVE BODY & BONNET						GAS-111-0055A-FS00-6"-JS		55	SPRING FAIL ACTION		Fail to Close
	12	TYPE					Full Bore Ball Valve/Trunnion Mounted	56	MAX ALLOWABLE PRESSURE		VTA
	13	SIZE					6"	57	MIN REQUIRES PRESSURE		VTA
	14	MAX PRESS./TEMP.					As per PMS	58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g
	15	MFR. & MODEL					Will be finalized later	59	BENCH RANGE		VTA
	16	BODY / BONNET MATL					ASTM A351 GR.CF3M	60	TRAVELING TIME		7 S
	17	LINER MATERIAL / ID					VTA	61	FUNCTION		On/Off
	18	END CONNECTION	IN	6"600#		6"600#	62	LOCAL POSITION INDICATOR		Required	
	OUT	6"600#		63	ACT. ORIENTATION		VTA				
	19	FLG FACE FINISH					RF	64	HAND WHEEL TYPE		Clutchable side mounted
	20	END EXT./MATL.					N/A	65	ADJUSTABLE LIMIT STOP		Yes
	21	FLOW DIRECTION					(Note 18 in Page 4)	66	INPUT SIGNAL		24VDC
	22	TYPE OF BONNET					Standard	67	MFR. & MODEL		Will be finalized later
	23	LUBE & ISO VALVE					No	68	TYPE		N/A
TRIM	24	PACKING MATERIAL	PACKING TYPE		PTFE	Standard	69	MFR. & MODEL		Will be finalized later	
	25	ENTRY DESIGN					Top Entry	70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A
	26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)					No	71	GAUGES		N/A
	27	TRIM	TYPE	MATERIAL	VTA	316 SS+RPTFE	72	CAM CHARACTERISTIC		N/A	
	28	SIZE	RATED TRAVEL		VTA	VTA	73	AIR CONNECTION		N/A	
	29	CHARACTERISTICS					On/Off	74	TAG NO. :		XZSC-2133A / XZSO-2133A
	30	BALANCED / UNBALANCED					BALANCED	75	TYPE	QUANTITY	Magnetically operated 'REED' contacts 2
	31	RATED Cv	FL	XT	VTA	VTA	VTA	76	CONTACTS / RATING		110V DC , 10A
	32	PLUG / BALL / DISK MATERIAL					316 SS	77	ACTUATION POINT		Fully Open/Close
	33	SEAT	TYPE	MATERIAL	Soft Seat	RPTFE	78	ENCLOSURE MATERIAL		Die Cast Aluminum	
SOLENOID VALVE	34	CAGE / GUIDE MATERIAL					VTA	79	WEATHER PROTECTION		IP-65
	35	STEM	TYPE	MATERIAL	Anti-Blow Out	316 SS	80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4 ISO M20 × 1.5	
	36	LEAKAGE CLASS					ANSI Class VI	81	MFR. & MODEL		Will be finalized later
	37	VALVE STEM EXTENSION REQUIREMENT					YES	82	SET PRESSURE		Yes
	38	TAG NO					PSOV-2133A, ESOV-2133A	83	PNEUMATIC CONNECTION		1/4" NPT
	39	TYPE					3 Way	84	GAUGES	FILTER	Required Required
	40	BODY MATERIAL		WEATHER IP.		AISt 316 S.S	IP-65	85	MFR. & MODEL		Will be finalized later
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4	ISO M20 x 1.5	86	ANSI/FCI LEAKAGE CLASS		Required
	42	MANUAL RESET					Yes	87	HYDRO PRESSURE		Required
	43	Power Supply					24 VDC	88	FUNCTIONAL TEST		Required
SPECIAL / ACCESS.	44	Pnu. Connection					1/4" NPT	89			
	45	FUSIBLE LEAKAGE					No	90			
	46	BLOCK RELAY					No	91			
	47	QUICK EXHUST					Yes	92	PASSIVE FIRE PROTECTION		No
	48	FILTER REGULATOR					Yes	93	API 6FA REQUIREMENTS		Yes
	49	VOLUME TANK					Yes	94	SIL 3 REQUIREMENTS		Yes
	50	MECHANICAL POSITION INDICATOR					Required	95	PARTIAL STROKING VALVE TEST		Yes
	51	MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes	96			
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.											

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 				
شماره پیمان: 053 - 073 - 9038		پروژه	پسته کاری	صادرکننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه		شماره صفحه: 44 از 35	
		BK	GCS	PEDCO	120	IN	DT	0010	D02			
On-Off Valve												
TAG NO: XV-2133B		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0011-D09 (2 of 3)					SERVICE: 2nd Stage Gas Compression Air Coolers			
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zme2, IIB, T4			
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off	
	1	FLOW RATE					kg/h	9530.4	8664	3032.4	-	
	2	INLET PRESSURE					bar(g)	54.1	54.1	54.1	-	
	3	OUTLET PRESSURE					bar(g)	54.1	54.1	54.1	-	
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	62.4	
	5	INLET TEMPERATURE					°C	-	60	-	-	
	6	DENSITY					kg/m3	49.41 ~ 59.63	49.41 ~ 59.63	49.41 ~ 59.63	-	
	7	VISCOSITY					CP	0.014	0.014	0.014	-	
	8	VAPOR PRESSURE Pv					bar(a)	-	-	-	-	
9	CRITICAL PRESSURE					bar(a)	94.66	94.66	94.66	-		
LINE	10	PIPE LINE SIZE & SCHEDULE		IN	6"	40S	CORROSION ALLOWANCE(mm)		0			
	11	LINE NO.		OUT	6"	40S						
						GAS-111-0055B-FS00-6"-JS						
VALVE BODY & BONNET	12	TYPE					Full Bore Ball Valve/Trunnion Mounted					
	13	SIZE					6"					
	14	MAX PRESS./TEMP.					As per PMS					
	15	MFR. & MODEL					Will be finalized later					
	16	BODY / BONNET MATL					ASTM A351 GR.CF3M					
	17	LINER MATERIAL / ID					VTA					
	18	END CONNECTION		IN	6"600#							
				OUT	6"600#							
	19	FLG FACE FINISH					RF					
	20	END EXT./MATL.					N/A					
	21	FLOW DIRECTION					(Note 18 in Page 4)					
	22	TYPE OF BONNET					Standard					
	23	LUBE & ISO VALVE					No					
24	PACKING MATERIAL		PACKING TYPE		PTFE		Standard					
25	ENTRY DESIGN					Top Entry						
26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)					No						
TRIM	27	TRIM	TYPE	MATERIAL		VTA		316 SS+RPTFE				
	28	SIZE	RATED TRAVEL		VTA		VTA					
	29	CHARACTERISTICS					On/Off					
	30	BALANCED / UNBALANCED					BALANCED					
	31	RATED Cv	FL	XT		VTA		VTA		VTA		
	32	PLUG / BALL / DISK MATERIAL					316 SS					
	33	SEAT	TYPE	MATERIAL		Soft Seat		RPTFE				
	34	CAGE / GUIDE MATERIAL					VTA					
	35	STEM	TYPE	MATERIAL		Anti-Blow Out		316 SS				
	36	LEAKAGE CLASS					ANSI Class VI					
37	VALVE STEM EXTENSION REQUIREMENT					YES						
SOLENOID VALVE	38	TAG NO					PSOV-2133B, ESOV-2133B					
	39	TYPE					3 Way					
	40	BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65				
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5				
	42	MANUAL RESET					Yes					
	43	Power Supply					24 VDC					
	44	Fm. Connection					1/4" NPT					
SPECIAL / ACCESS.	45	FUSIBLE LEAKAGE					No					
	46	BLOCK RELAY					No					
	47	QUICK EXHUST					Yes					
	49	FILTER REGULATOR					Yes					
	50	VOLUME TANK					Yes					
	51	MECHANICAL POSITION INDICATOR					Required					
	52	MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes					
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM												
(1) PMS: Piping material specification.												
(2) All material shall be suitable for minimum design metal temperature.												
(3) Shall be stated by vendor at quotation stage.												
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 				
شماره پیمان: 053 - 073 - 9038		پروژه	پسته کاری	صادرکننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه		شماره صفحه: 36 از 44	
		BK	GCS	PEDCO	120	IN	DT	0010	D02			
On-Off Valve												
TAG NO: XV-2133C		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0011-D09 (3 of 3)					SERVICE: 2nd Stage Gas Compression Air Coolers			
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4			
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off	
	1	FLOW RATE					kg/h	9530.4	8664	3032.4	-	
	2	INLET PRESSURE					bar(g)	54.1	54.1	54.1	-	
	3	OUTLET PRESSURE					bar(g)	54.1	54.1	54.1	-	
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	62.4	
	5	INLET TEMPERATURE					°C	-	60	-	-	
	6	DENSITY					kg/m3	49.41 ~ 59.63	49.41 ~ 59.63	49.41 ~ 59.63	-	
	7	VISCOSITY					CP	0.014	0.014	0.014	-	
	8	VAPOR PRESSURE Pv					bar(a)	-	-	-	-	
9	CRITICAL PRESSURE					bar(a)	94.66	94.66	94.66	-		
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	6"	40S	CORROSION ALLOWANCE(mm)	0	53	TYPE		Single Acting, Spring Return	
	11	LINE NO.	OUT	6"	40S			54	SIZE		VTA	
						GAS-111-0055C-FS00-6"-JS		55	SPRING FAIL ACTION		Fail to Close	
VALVE BODY & BONNET	12	TYPE					Full Bore Ball Valve/Trunnion Mounted	56	MAX ALLOWABLE PRESSURE		VTA	
	13	SIZE					6"	57	MIN REQUIRES PRESSURE		VTA	
	14	MAX PRESS./TEMP.					As per PMS	58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g	
	15	MFR. & MODEL					Will be finalized later	59	BENCH RANGE		VTA	
	16	BODY / BONNET MATL					ASTM A351 GR.CF3M	60	TRAVELING TIME		7 S	
	17	LINER MATERIAL / ID					VTA	61	FUNCTION		On/Off	
	18	END CONNECTION	IN	6"600#		6"600#	62	LOCAL POSITION INDICATOR		Required		
	19	FLG FACE FINISH	OUT	6"600#			63	ACT. ORIENTATION		VTA		
	20	END EXT./MATL.					N/A	64	HAND WHEEL TYPE		Clutchable side mounted	
	21	FLOW DIRECTION					(Note 18 in Page 4)	65	ADJUSTABLE LIMIT STOP		Yes	
	22	TYPE OF BONNET					Standard	66	INPUT SIGNAL		24VDC	
	23	LUBE & ISO VALVE					No	67	MFR. & MODEL		Will be finalized later	
	24	PACKING MATERIAL		PACKING TYPE		PTFE	Standard	68	TYPE		N/A	
25	ENTRY DESIGN					Top Entry	69	MFR. & MODEL		Will be finalized later		
26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)					No	70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A		
TRIM	27	TRIM	TYPE	MATERIAL		VTA	316 SS+RPTFE	71	GAUGES		N/A	
	28	SIZE	RATED TRAVEL		VTA	VTA	72	CAM CHARACTERISTIC		N/A		
	29	CHARACTERISTICS					On/Off	73	AIR CONNECTION		N/A	
	30	BALANCED / UNBALANCED					BALANCED	74	TAG NO. :		XZSC-2133C / XZSO-2133C	
	31	RATED Cv	FL	XT	VTA	VTA	VTA	75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2
	32	PLUG / BALL / DISK MATERIAL					316 SS	76	CONTACTS / RATING		110V DC , 10A	
	33	SEAT	TYPE	MATERIAL		Soft Seat	RPTFE	77	ACTUATION POINT		Fully Open/Close	
	34	CAGE / GUIDE MATERIAL					VTA	78	ENCLOSURE MATERIAL		Die Cast Aluminum	
	35	STEM	TYPE	MATERIAL		Anti-Blow Out	316 SS	79	WEATHER PROTECTION		IP-65	
	36	LEAKAGE CLASS					ANSI Class VI	80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 × 1.5
SOLENOID VALVE	37	VALVE STEM EXTENSION REQUIREMENT					YES	81	MFR. & MODEL		Will be finalized later	
	38	TAG NO					PSOV-2133C, ESOV-2133C	82	SET PRESSURE		Yes	
	39	TYPE					3 Way	83	PNEUMATIC CONNECTION		1/4" NPT	
	40	BODY MATERIAL		WEATHER IP.		AISt 316 S.S	IP-65	84	GAUGES	FILTER	Required	Required
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4	ISO M20 x 1.5	85	MFR. & MODEL		Will be finalized later	
	42	MANUAL RESET					Yes	86	ANSI/FCI LEAKAGE CLASS		Required	
	43	Power Supply					24 VDC	87	HYDRO PRESSURE		Required	
	44	Pnu. Connection					1/4" NPT	88	FUNCTIONAL TEST		Required	
SPECIAL / ACCESS.	45	FUSIBLE LEAKAGE					No	89				
	46	BLOCK RELAY					No	90				
	47	QUICK EXHUST					Yes	91				
	48	FILTER REGULATOR					Yes	92	PASSIVE FIRE PROTECTION		No	
	49	VOLUME TANK					Yes	93	API 6FA REQUIREMENTS		Yes	
	50	MECHANICAL POSITION INDICATOR					Required	94	SIL 3 REQUIREMENTS		Yes	
	51	MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes	95	PARTIAL STROKING VALVE TEST		Yes	
	52							96				
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												

 NISOC		تکهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 					
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه	 D02	شماره صفحه: 37 از 44			
		BK	GCS	PEDCO	120	IN	DT	0010	D02					
On-Off Valve														
TAG NO: XV-2134A		P&ID NO : BK-GCS-PEDCO-120-PR-P1-0011-D09 (1/3)							SERVICE: 2nd Stage Gas Compression Air Coolers					
FLUID STATE: Purge Gas		PHASE: Gas							AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow	Min. Flow	Shut-Off		
	1	FLOW RATE					kg/h	-	25	-	-	-		
	2	INLET PRESSURE					bar(g)	-	54.1	-	-	-		
	3	OUTLET PRESSURE					bar(g)	-	54.1	-	-	-		
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	-	62		
	5	INLET TEMPERATURE					°C	-	60	-	-	-		
	6	DENSITY					kg/m3	-	8.62	-	-	-		
	7	VISCOSITY					CP	-	0.02	-	-	-		
	8	VAPOR PRESSURE Pv					bar(a)	-	-	-	-	-		
	CRITICAL PRESSURE					bar(a)	-	-	-	-	-			
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	40S	CORROSION ALLOWANCE(mm)		0						
			OUT	2"	40S									
VALVE BODY & BONNET	11		LINE NO.		GAS-111-0030A-FS00-2"-NP									
	12		TYPE		Full Bore Ball Valve/Trunion Mounted									
	13		SIZE		2"									
	14		MAX PRESS./TEMP.		As per PMS									
	15		MFR. & MODEL		Will be finalized later									
	16		BODY / BONNET MATL		ASTM A351 GR.CF3M									
	17		LINER MATERIAL / ID		VTA									
	18		END CONNECTION		IN	2"/600#								
					OUT	2"/600#								
	19		FLG FACE FINISH		RF									
	20		END EXT.MATL.		N/A									
	21		FLOW DIRECTION		(Note 18 in Page 4)									
	22		TYPE OF BONNET		Standard									
	23		LUBE & ISO VALVE		No									
	24		PACKING MATERIAL		PACKING TYPE		PTFE		Standard					
	25		ENTRY DESIGN		Top Entry									
	26		NACE REQUIREMENTNACE(MR-0175/ISO 15156)		No									
	27		TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE				
	28		SIZE		RATED TRAVEL		VTA		VTA					
	29		CHARACTERISTICS		On/Off									
	30		BALANCED / UNBALANCED		BALANCED									
	31		RATED Cv		FL	XT		VTA		VTA				
	32		PLUG / BALL / DISK MATERIAL		316 SS									
	33		SEAT		TYPE	MATERIAL		Soft Seat		PTFE				
	34		CAGE / GUIDE MATERIAL		VTA									
35		STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS					
36		LEAKAGE CLASS		ANSI Class VI										
37		VALVE STEM EXTENSION REQUIREMENT		YES										
SOLENOID VALVE	38		TAG NO		PSOV-2134A , ESOV-2134A									
	39		TYPE		3 Way									
	40		BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65					
	41		ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5					
	42		MANUAL RESET		Yes									
	43		Power Supply		24 VDC									
	44		Pnu. Connection		1/4" NPT									
	45		FUSIBLE LEAKAGE		No									
SPECIAL / ACCESS.	46		BLOCK RELAY		No									
	47		QUICK EXHUST		Yes									
	49		FILTER REGULATOR		Yes									
	50		VOLUME TANK		Yes									
	51		MECHANICAL POSITION INDICATOR		Required									
	52		MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes									
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NISOC		تکهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves							 					
شماره پیمان: 053 - 073 – 9038		پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه	 D02	شماره صفحه: 39 از 44			
		BK	GCS	PEDCO	120	IN	DT	0010	D02					
On-Off Valve														
TAG NO: XV-2134C		P&ID NO : BK-GCS-PEDCO-120-PR-P1-0011-D09 (3/3)							SERVICE: 2nd Stage Gas Compression Air Coolers					
FLUID STATE: Purge Gas		PHASE: Gas							AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow	Min. Flow	Shut-Off		
	1	FLOW RATE					kg/h	-	25	-	-	-		
	2	INLET PRESSURE					bar(g)	-	54.1	-	-	-		
	3	OUTLET PRESSURE					bar(g)	-	54.1	-	-	-		
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	-	62		
	5	INLET TEMPERATURE					°C	-	60	-	-	-		
	6	DENSITY					kg/m3	-	8.62	-	-	-		
	7	VISCOSITY					CP	-	0.02	-	-	-		
	8	VAPOR PRESSURE Pv					bar(a)	-	-	-	-	-		
	CRITICAL PRESSURE					bar(a)	-	-	-	-	-			
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	40S	CORROSION ALLOWANCE(mm)		0						
			OUT	2"	40S									
VALVE BODY & BONNET	11		LINE NO.		GAS-111-0030C-FS00-2"-NP									
	12		TYPE		Full Bore Ball Valve/Trunion Mounted									
	13		SIZE		2"									
	14		MAX PRESS./TEMP.		As per PMS									
	15		MFR. & MODEL		Will be finalized later									
	16		BODY / BONNET MATL		ASTM A351 GR.CF3M									
	17		LINER MATERIAL / ID		VTA									
	18		END CONNECTION		IN	2"/600#								
					OUT	2"/600#								
	19		FLG FACE FINISH		RF									
	20		END EXT.MATL.		N/A									
	21		FLOW DIRECTION		(Note 18 in Page 4)									
	22		TYPE OF BONNET		Standard									
	23		LUBE & ISO VALVE		No									
	24		PACKING MATERIAL		PACKING TYPE		PTFE		Standard					
	25		ENTRY DESIGN		Top Entry									
	26		NACE REQUIREMENTNACE (MR-0175/ISO 15156)		No									
	27		TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE				
	28		SIZE		RATED TRAVEL		VTA		VTA					
	29		CHARACTERISTICS		On/Off									
	30		BALANCED / UNBALANCED		BALANCED									
	31		RATED Cv		FL	XT		VTA		VTA				
	32		PLUG / BALL / DISK MATERIAL		316 SS									
	33		SEAT		TYPE	MATERIAL		Soft Seat		PTFE				
	34		CAGE / GUIDE MATERIAL		VTA									
35		STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS					
36		LEAKAGE CLASS		ANSI Class VI										
37		VALVE STEM EXTENSION REQUIREMENT		YES										
SOLENOID VALVE	38		TAG NO		PSOV-2134C , ESOV-2134C									
	39		TYPE		3 Way									
	40		BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65					
	41		ELE. CERTIFICATE		ELE. CONNECTION		EEEx "d", IIB T4		ISO M20 x 1.5					
	42		MANUAL RESET		Yes									
	43		Power Supply		24 VDC									
	44		Pnu. Connection		1/4" NPT									
	45		FUSIBLE LEAKAGE		No									
SPECIAL / ACCESS.	46		BLOCK RELAY		No									
	47		QUICK EXHUST		Yes									
	49		FILTER REGULATOR		Yes									
	50		VOLUME TANK		Yes									
	51		MECHANICAL POSITION INDICATOR		Required									
	52		MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes									
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 					
شماره پیمان: 053 - 073 - 9038		پروژه	پسته کاری	صادرکننده	تهیهات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 40			
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02	D02			
On-Off Valve													
TAG NO: XV-2142		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0012-D08				SERVICE: 2nd Stage Gas Compression Discharge Drum					
FLUID STATE: PROCESS GAS		PHASE:		GAS				AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off		
	1	FLOW RATE					kg/h	18977.7	17252.5	6038.4	-		
	2	INLET PRESSURE					bar(g)	53.9	53.9	53.9	-		
	3	OUTLET PRESSURE					bar(g)	53.9	53.9	53.9	-		
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	90		
	5	INLET TEMPERATURE					°C	59.89	59.89	59.89	-		
	6	DENSITY					kg/m3	49.41~ 59.17	49.41~ 59.17	49.41~ 59.17	-		
	7	VISCOSITY					CP	0.014	0.014	0.014	-		
	8	VAPOR PRESSURE Pv					bar(a)	3.23	3.23	3.23	-		
9	CRITICAL PRESSURE					bar(a)	106	106	106	-			
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	6"	80	CORROSION ALLOWANCE(mm)	3	53	TYPE			Single Acting, Spring Return	
	11	LINE NO.	OUT	6"	80			54	SIZE			VTA	
VALVE BODY & BONNET	GAS-111-0067-FN05-6"-IS					ACTUATOR	55	SPRING FAIL ACTION			Fail to Close		
	12	TYPE					56	MAX ALLOWABLE PRESSURE			VTA		
	13	SIZE					57	MIN REQUIRES PRESSURE			VTA		
	14	MAX PRESS./TEMP.					58	AVAILABLE AIR SUPPLY PRESSURE			MAX/NOR/MIN: 10/7/3 bar-g		
	15	MFR. & MODEL					59	BENCH RANGE			VTA		
	16	BODY / BONNET MATL					60	TRAVELING TIME			7 S		
	17	LINER MATERIAL / ID					61	FUNCTION			On/Off		
	18	END CONNECTION	IN	6"	600#		62	LOCAL POSITION INDICATOR			Required		
		OUT	6"	600#	63		ACT. ORIENTATION			VTA			
	19	FLG FACE FINISH					64	HAND WHEEL TYPE			Clutchable side mounted		
	20	END EXT./MATL.					65	ADJUSTABLE LIMIT STOP			Yes		
	21	FLOW DIRECTION					66	INPUT SIGNAL			24VDC		
	22	TYPE OF BONNET					67	MFR. & MODEL			Will be finalized later		
	23	LUBE & ISO VALVE					68	TYPE			N/A		
TRIM	24	PACKING MATERIAL	PACKING TYPE		PTFE	Standard	69	MFR. & MODEL			Will be finalized later		
	25	ENTRY DESIGN					70	ON INCR SIGNAL OUTPUT INCR / DECR			N/A		
	26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)					71	GAUGES			N/A		
	27	TRIM	TYPE	MATERIAL	VTA	316 SS+RPTFE	72	CAM CHARACTERISTIC			N/A		
	28	SIZE	RATED TRAVEL		VTA	VTA	73	AIR CONNECTION			N/A		
	29	CHARACTERISTICS					74	TAG NO. :			XZSC-2142 / XZSO-2142		
SOLENOID VALVE	30	BALANCED / UNBALANCED					LIMIT SWITCHES	75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2	
	31	RATED Cv	FL	XT	VTA	VTA		VTA	76	CONTACTS / RATING			110V DC , 10A
	32	PLUG / BALL / DISK MATERIAL						316 SS	77	ACTUATION POINT			Fully Open/Close
	33	SEAT	TYPE	MATERIAL	Soft Seat	RPTFE		78	ENCLOSURE MATERIAL			Die Cast Aluminum	
	34	CAGE / GUIDE MATERIAL						VTA	79	WEATHER PROTECTION			IP-65
	35	STEM	TYPE	MATERIAL	Anti-Blow Out	316 SS		80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 x 1.5	
	36	LEAKAGE CLASS						ANSI Class VI	81	MFR. & MODEL			Will be finalized later
	37	VALVE STEM EXTENSION REQUIREMENT						YES	82	SET PRESSURE			Yes
SPECIAL / ACCESS.	38	TAG NO					PSOV-2142, ESOV-2142	AIR SET	83	PNEUMATIC CONNECTION			1/4" NPT
	39	TYPE					3 Way		84	GAUGES	FILTER	Required	Required
	40	BODY MATERIAL		WEATHER IP.		AISt 316 S.S	IP-65		85	MFR. & MODEL			Will be finalized later
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4	ISO M20 x 1.5		86	ANSI/FCI LEAKAGE CLASS			Required
	42	MANUAL RESET					Yes		87	HYDRO PRESSURE			Required
	43	Power Supply					24 VDC		88	FUNCTIONAL TEST			Required
	44	Pnu. Connection					1/4" NPT		89				
SPECIAL / ACCESS.	45	FUSIBLE LEAKAGE					No	FIRE PROOF DESIGN	90				
	46	BLOCK RELAY					No		91				
	47	QUICK EXHUST					Yes		92	PASSIVE FIRE PROTECTION			No
	48	FILTER REGULATOR					Yes		93	API 6FA REQUIREMENTS			Yes
	49	VOLUME TANK					Yes		94	SIL 3 REQUIREMENTS			Yes
	50	MECHANICAL POSITION INDICATOR					Required		95	PARTIAL STROKING VALVE TEST			Yes
	51	MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes		96				
	52												
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.													

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 			
شماره پیمان: 053 - 073 - 9038		پروژه	بسته کاری	صادرکننده	تهیه کننده	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 41	
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02	
On-Off Valve											
TAG NO: XV-2143		P&ID NO : BK-GCS-PEDCO-120-PR-PI-0012-D08			SERVICE: 2nd Stage Gas Compression Discharge Drum						
FLUID STATE: PROCESS GAS		PHASE: GAS			AREA CLASSIFICATION: Zone2, IIB, T4						
SERVICE CONDITION	ITEM				UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off	
	1 FLOW RATE				kg/h		-	1500.0	-	-	
	2 INLET PRESSURE				bar(g)		53.9	53.9	53.9	-	
	3 OUTLET PRESSURE				bar(g)		53.9	53.9	53.9	-	
	4 DIFFERENTIAL PRESSURE				bar(g)		-	-	-	90	
	5 INLET TEMPERATURE				°C		59.89	59.89	59.89	-	
	6 DENSITY				kg/m3		49.23~ 59.17	49.23~ 59.17	49.23~ 59.17	-	
	7 VISCOSITY				CP		0.014	0.014	0.014	-	
	8 VAPOR PRESSURE Pv				bar(a)		-	-	-	-	
9 CRITICAL PRESSURE				bar(a)		106	106	106	-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	2"	80	CORROSION ALLOWANCE(mm)		3			
			OUT	2"	80						
VALVE BODY & BONNET	11 LINE NO.		GAS-111-0061-FN05-2"-IS								
	12 TYPE		Full Bore Ball Valve/Trunnion Mounted								
	13 SIZE		2"								
	14 MAX PRESS./TEMP.		As per PMS								
	15 MFR. & MODEL		Will be finalized later								
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB								
	17 LINER MATERIAL /ID		VTA								
	18 END CONNECTION		IN	2"	600#						
			OUT	2"	600#						
	19 FLG FACE FINISH		RF								
	20 END EXT.MATL.		N/A								
	21 FLOW DIRECTION		(Note 18 in Page 4)								
	22 TYPE OF BONNET		Standard								
	23 LUBE & ISO VALVE		No								
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard				
	25 ENTRY DESIGN		Top Entry								
	26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES								
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE			
	28 SIZE		RATED TRAVEL		VTA		VTA				
	29 CHARACTERISTICS		On/Off								
	30 BALANCED / UNBALANCED		BALANCED								
	31 RATED Cv		FL	XT	VTA		VTA		VTA		
	32 PLUG / BALL / DISK MATERIAL		316 SS								
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE			
	34 CAGE / GUIDE MATERIAL		VTA								
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS			
	36 LEAKAGE CLASS		ANSI Class V1								
37 VALVE STEM EXTENSION REQUIREMENT		YES									
SOLENOID VALVE	38 TAG NO		ESOV-2143, PSOV-2143								
	39 TYPE		3 Way								
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65				
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5				
	42 MANUAL RESET		Yes								
	43 Power Supply		24 VDC								
	44 Pnu. Connection		1/4" NPT								
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No								
	46 BLOCK RELAY		No								
	47 QUICK EXHUST		Yes								
	49 FILTER REGULATOR		Yes								
	50 VOLUME TANK		No								
	51 MECHANICAL POSITION INDICATOR		Required								
	52 MANUAL PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes								
53 TYPE Single Acting, Spring Return											
54 SIZE VTA											
55 SPRING FAIL ACTION Fail to Close											
56 MAX ALLOWABLE PRESSURE VTA											
57 MIN REQUIRES PRESSURE VTA											
58 AVAILABLE AIR SUPPLY PRESSURE MAX/NOR/MIN: 10/7/3 bar-g											
59 BENCH RANGE VTA											
60 TRAVELING TIME 7 S											
61 FUNCTION On/Off											
62 LOCAL POSITION INDICATOR Required											
63 ACT. ORIENTATION VTA											
64 HAND WHEEL TYPE Clutchable side mounted											
65 ADJUSTABLE LIMIT STOP Yes											
66 INPUT SIGNAL 24VDC											
67 MFR. & MODEL Will be finalized later											
68 TYPE N/A											
69 MFR. & MODEL Will be finalized later											
70 ON INCR SIGNAL OUTPUT INCR / DECR N/A											
71 GAUGES N/A											
72 CAM CHARACTERISTIC N/A											
73 AIR CONNECTION N/A											
74 TAG NO. : XZSC-2143 / XZSO-2143											
75 TYPE QUANTITY Magnetically operated "REED" contacts 2											
76 CONTACTS / RATING 110V DC , 10A											
77 ACTUATION POINT Fully Open/Close											
78 ENCLOSURE MATERIAL Die Cast Aluminum											
79 WEATHER PROTECTION IP-65											
80 ELEC. CERTIFICATE ELEC. CONNECTION EEx "d", IIB T4 ISO M20 x 1.5											
81 MFR. & MODEL Will be finalized later											
82 SET PRESSURE Yes											
83 PNEUMATIC CONNECTION 1/4" NPT											
84 GAUGES FILTER Required Required											
85 MFR. & MODEL Will be finalized later											
86 ANSI/FCI LEAKAGE CLASS Required											
87 HYDRO PRESSURE Required											
88 FUNCTIONAL TEST Required											
89											
90											
91											
92 PASSIVE FIRE PROTECTION No											
93 API 6FA REQUIREMENTS Yes											
94 SIL 3 REQUIREMENTS Yes											
95 PARTIAL STROKING VALVE TEST Yes											
96											
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM											
(1) PMS: Piping material specification.											
(2) All material shall be suitable for minimum design metal temperature.											
(3) Shall be stated by vendor at quotation stage.											
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.											

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 				
شماره پیمان: 053 - 073 - 9038		پروژه	پسته کاری	صادرکننده	تهیهات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 42		
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02		
On-Off Valve												
TAG NO: XV-2144		P&ID NO : BK-GCS-PEDCO-120-PR-PI-0012-D08			SERVICE: 2nd Stage Gas Compression Discharge Drum							
FLUID STATE: CLOSED DRAIN		PHASE: LIQUID			AREA CLASSIFICATION: Zone2, IIB, T4							
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off	
	1	FLOW RATE					kg/h	-	11500	-	-	
	2	INLET PRESSURE					bar(g)	-	53.9	-	-	
	3	OUTLET PRESSURE					bar(g)	-	53.9	-	-	
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	62.4	
	5	INLET TEMPERATURE					°C	-	59.9	-	-	
	6	DENSITY					kg/m3	-	830- 982	-	-	
	7	VISCOSITY					CP	-	0.442- 0.495	-	-	
	8	VAPOR PRESSURE Pv					bar(a)	4.43	4.43	4.43	-	
9	CRITICAL PRESSURE					bar(a)	221.9	221.9	221.9	-		
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	2"	40S	CORROSION ALLOWANCE(mm)	0	53	TYPE		Single Acting, Spring Return	
	11	LINE NO.	OUT	2"	40S			54	SIZE		VTA	
VALVE BODY & BONNET						CDH-112-0025-FS00-2"-NP		55	SPRING FAIL ACTION		Fail to Close	
	12	TYPE					Full Bore Ball Valve/Trunion Mounted	56	MAX ALLOWABLE PRESSURE		VTA	
	13	SIZE					2"	57	MIN REQUIRES PRESSURE		VTA	
	14	MAX PRESS./TEMP.					As per PMS	58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g	
	15	MFR. & MODEL					Will be finalized later	59	BENCH RANGE		VTA	
	16	BODY / BONNET MATL					ASTM A351 GR.CF3M	60	TRAVELING TIME		5 S	
	17	LINER MATERIAL / ID					VTA	61	FUNCTION		On/Off	
	18	END CONNECTION	IN	2" #600#		2" #600#	62	LOCAL POSITION INDICATOR		Required		
	19	FLG FACE FINISH					RF	63	ACT. ORIENTATION		VTA	
	20	END EXT./MATL.					N/A	64	HAND WHEEL TYPE		Clutchable side mounted	
	21	FLOW DIRECTION					(Note 18 in Page 4)	65	ADJUSTABLE LIMIT STOP		Yes	
	22	TYPE OF BONNET					Standard	66	INPUT SIGNAL		24VDC	
	23	LUBE & ISO VALVE					No	67	MFR. & MODEL		Will be finalized later	
	24	PACKING MATERIAL		PACKING TYPE		PTFE	Standard	68	TYPE		N/A	
TRIM	ENTRY DESIGN					Top Entry	69	MFR. & MODEL		Will be finalized later		
	NACE REQUIREMENTNACE (MR-0175/ISO 15156)					No	70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A		
	27	TRIM	TYPE	MATERIAL		VTA	316 SS+RPTFE	71	GAUGES		N/A	
	28	SIZE	RATED TRAVEL		VTA	VTA	72	CAM CHARACTERISTIC		N/A		
	29	CHARACTERISTICS					On/Off	73	AIR CONNECTION		N/A	
	30	BALANCED / UNBALANCED					BALANCED	74	TAG NO. :		XZSC-2144 / XZSO-2144	
	31	RATED Cv	FL	XT	VTA	VTA	VTA	75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2
	32	PLUG / BALL / DISK MATERIAL					316 SS	76	CONTACTS / RATING		110V DC , 10A	
	33	SEAT	TYPE	MATERIAL		Soft Seat	RPTFE	77	ACTUATION POINT		Fully Open/Close	
	34	CAGE / GUIDE MATERIAL					VTA	78	ENCLOSURE MATERIAL		Die Cast Aluminum	
SOLENOID VALVE	35	STEM	TYPE	MATERIAL		Anti-Blow Out	316 SS	79	WEATHER PROTECTION		IP-65	
	36	LEAKAGE CLASS					ANSI Class VI	80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 × 1.5
	37	VALVE STEM EXTENSION REQUIREMENT					YES	81	MFR. & MODEL		Will be finalized later	
	38	TAG NO					PSOV-2144, ESOV-2144	82	SET PRESSURE		Yes	
	39	TYPE					3 Way	83	PNEUMATIC CONNECTION		1/4" NPT	
	40	BODY MATERIAL		WEATHER IP.		AISt 316 S.S	IP-65	84	GAUGES	FILTER	Required	Required
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4	ISO M20 x 1.5	85	MFR. & MODEL		Will be finalized later	
	42	MANUAL RESET					Yes	86	ANSI/FCI LEAKAGE CLASS		Required	
SPECIAL / ACCESS.	43	Power Supply					24 VDC	87	HYDRO PRESSURE		Required	
	44	Pnu. Connection					1/4" NPT	88	FUNCTIONAL TEST		Required	
	45	FUSIBLE LEAKAGE					No	89				
	46	BLOCK RELAY					No	90				
	47	QUICK EXHUST					Yes	91				
	49	FILTER REGULATOR					Yes	92	PASSIVE FIRE PROTECTION		No	
	50	VOLUME TANK					Yes	93	API 6FA REQUIREMENTS		Yes	
51	MECHANICAL POSITION INDICATOR					Required	94	SIL 3 REQUIREMENTS		Yes		
52	MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes	95	PARTIAL STROKING VALVE TEST		Yes		
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM												
(1) PMS: Piping material specification.												
(2) All material shall be suitable for minimum design metal temperature.												
(3) Shall be stated by vendor at quotation stage.												
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 				
شماره پیمان: 053 - 073 - 9038		پروژه	پسته کاری	صادرکننده	تهیهات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: 44 از 43		
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02	D02		
On-Off Valve												
TAG NO: XV-2271		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0022-D08				SERVICE: Fuel Gas System				
FLUID STATE: CLOSED DRAIN		PHASE:		LIQUID				AREA CLASSIFICATION: Zone2, IIB, T4				
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off	
	1	FLOW RATE					kg/h	-	603.15	-	-	
	2	INLET PRESSURE					bar(g)	-	4.9	-	-	
	3	OUTLET PRESSURE					bar(g)	-	4.9	-	-	
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	18.2	
	5	INLET TEMPERATURE					°C	-	18.88~ 36.7	-	-	
	6	DENSITY					kg/m3	-	842~ 852	-	-	
	7	VISCOSITY					CP	-	0.6934 ~ 1.03	-	-	
	8	VAPOR PRESSURE Pv					bar(a)	-	0.448	-	-	
9	CRITICAL PRESSURE					bar(a)	-	221.3	-	-		
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	2"	160	CORROSION ALLOWANCE(mm)	6	53	TYPE		Single Acting, Spring Return	
	11	LINE NO.	OUT	2"	160			54	SIZE		VTA	
VALVE BODY & BONNET						CDH-112-0004-AN07-2"-PT		55	SPRING FAIL ACTION		Fail to Close	
	12	TYPE					Full Bore Ball Valve/Trunnion Mounted	56	MAX ALLOWABLE PRESSURE		VTA	
	13	SIZE					2"	57	MIN REQUIRES PRESSURE		VTA	
	14	MAX PRESS./TEMP.					As per PMS	58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g	
	15	MFR. & MODEL					Will be finalized later	59	BENCH RANGE		VTA	
	16	BODY / BONNET MATL					ASTM A216 Gr. WCB	60	TRAVELING TIME		5 S	
	17	LINER MATERIAL / ID					VTA	61	FUNCTION		On/Off	
	18	END CONNECTION	IN	2"	300#	2"	300#	62	LOCAL POSITION INDICATOR		Required	
	19	FLG FACE FINISH					RF	63	ACT. ORIENTATION		VTA	
	20	END EXT./MATL.					N/A	64	HAND WHEEL TYPE		Clutchable side mounted	
	21	FLOW DIRECTION					(Note 18 in Page 4)	65	ADJUSTABLE LIMIT STOP		Yes	
	22	TYPE OF BONNET					Standard	66	INPUT SIGNAL		24VDC	
	23	LUBE & ISO VALVE					No	67	MFR. & MODEL		Will be finalized later	
	24	PACKING MATERIAL		PACKING TYPE		PTFE	Standard	68	TYPE		N/A	
25	ENTRY DESIGN					Top Entry	69	MFR. & MODEL		Will be finalized later		
26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)					No	70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A		
TRIM	27	TRIM	TYPE	MATERIAL	VTA	316 SS+PTFE	71	GAUGES		N/A		
	28	SIZE	RATED TRAVEL		VTA	VTA	72	CAM CHARACTERISTIC		N/A		
	29	CHARACTERISTICS					On/Off	73	AIR CONNECTION		N/A	
	30	BALANCED / UNBALANCED					BALANCED	74	TAG NO. :		XZSC-2271 / XZSO-2271	
	31	RATED Cv	FL	XT	VTA	VTA	VTA	75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2
	32	PLUG / BALL / DISK MATERIAL					316 SS	76	CONTACTS / RATING		110V DC , 10A	
	33	SEAT	TYPE	MATERIAL	Soft Seat	PTFE	77	ACTUATION POINT		Fully Open/Close		
	34	CAGE / GUIDE MATERIAL					VTA	78	ENCLOSURE MATERIAL		Die Cast Aluminum	
	35	STEM	TYPE	MATERIAL	Anti-Blow Out	316 SS	79	WEATHER PROTECTION		IP-65		
	36	LEAKAGE CLASS					ANSI Class VI	80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 x 1.5
SOLENOID VALVE	37	VALVE STEM EXTENSION REQUIREMENT					YES	81	MFR. & MODEL		Will be finalized later	
	38	TAG NO					PSOV-2271, ESOV-2271	82	SET PRESSURE		Yes	
	39	TYPE					3 Way	83	PNEUMATIC CONNECTION		1/4" NPT	
	40	BODY MATERIAL		WEATHER IP.		AISt 316 S.S	IP-65	84	GAUGES	FILTER	Required	Required
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4	ISO M20 x 1.5	85	MFR. & MODEL		Will be finalized later	
	42	MANUAL RESET					Yes	86	ANSI/FCI LEAKAGE CLASS		Required	
	43	Power Supply					24 VDC	87	HYDRO PRESSURE		Required	
	44	Pnu. Connection					1/4" NPT	88	FUNCTIONAL TEST		Required	
SPECIAL / ACCESS.	45	FUSIBLE LEAKAGE					No	89				
	46	BLOCK RELAY					No	90				
	47	QUICK EXHUST					Yes	91				
	48	FILTER REGULATOR					Yes	92	PASSIVE FIRE PROTECTION		No	
	49	VOLUME TANK					Yes	93	API 6FA REQUIREMENTS		Yes	
	50	MECHANICAL POSITION INDICATOR					Required	94	SIL 3 REQUIREMENTS		Yes	
	51	MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes	95	PARTIAL STROKING VALVE TEST		Yes	
	52							96				
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												

