



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



DATA SHEET FOR ON OFF & SHUTDOWN VALVES

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

پروژه

بسته کاری

صادرکننده

تجهیزات

رشته

بوع مدرک

سریال

نسخه

BK

GCS

PEDCO

120

IN

DT

0010

D02

شماره صفحه: ۱ از ۳۸

طرح نگهداشت و افزایش تولید ۲۷ مخزن

DATA SHEET FOR ON OFF & SHUTDOWN VALVES

نگهداشت و افزایش تولید میدان نفتی بینک

D02	AUG.2023	AFC	P.Hajisadeghi	M.Fakharian	A.M.Mohseni	
D01	OCT.2022	IFA	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
D00	MAY.2022	IFC	P.Hajisadeghi	M.Fakharian	M.Mehrshad	
Rev.	Date	Purpose of Issue / Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Class: 1

CLIENT Doc. Number: F92-708931

status:

IDC: Inter-Discipline Check

IFC: Issued For Comment

IFA: Issued For Approval

AFD: Approved For Design

AFC: Approved For Construction

AFP: Approved For Purchase

AFQ: Approved For Quotation

IFI: Issued For Information

AB-R: As-Built for CLIENT Review

AB-A: As-Built -Approved



NISOC

تجهادداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



DATA SHEET FOR ON OFF & SHUTDOWN VALVES

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

پروژه

BK

بسته کاری

GCS

صادرکننده

PEDCO

تجهیزات

120

رشته

IN

بوع مدرک

DT

سریال

0010

نسخه

D02

شماره صفحه: ۲ از ۳۸

REVISION RECORD SHEET

Page	D00	D01	D02	D03	D04
1	X	X	X		
2	X	X	X		
3	X	X			
4	X	X			
5	X	X	X		
6	X	X	X		
7	X	X	X		
8	X	X	X		
9	X	X	X		
10	X	X	X		
11	X	X	X		
12	X	X	X		
13	X	X	X		
14	X	X	X		
15	X	X	X		
16	X	X	X		
17	X	X	X		
18	X	X	X		
19	X	X	X		
20	X	X	X		
21	X	X	X		
22	X	X	X		
23	X	X	X		
24	X	X	X		
25	X	X	X		
26	X	X	X		
27	X	X	X		
28	X	X	X		
29	X	X	X		
30	X	X	X		
31	X	X	X		
32	X	X	X		
33	X	X	X		
34	X	X	X		
35	X	X	X		
36	X	X	X		
37	X	X	X		
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					

Page	D00	D01	D02	D03	D04
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					
101					
102					
103					
104					
105					
106					
107					
108					
109					
110					
111					
112					
113					
114					
115					
116					
117					
118					
119					
120					
121					
122					
123					
124					
125					
126					
127					
128					



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



DATA SHEET FOR ON OFF & SHUTDOWN VALVES

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

نسخه	سریال	بوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
D02	0010	DT	IN	120	PEDCO	GCS	BK

شماره صفحه: ۳ از ۳۸

REFERENCE DOCUMENTS :

Specification For Instrumentation	BK-GNRAL-PEDCO-000-IN-SP-0001
Process Basis Of Design	BK-GNRAL-PEDCO-000-PR-DB-0001
Piping Material Specification	BK-GCS-PEDCO-120-PI-SP-0001
Instrument & Control System Design Criteria	BK-GCS-PEDCO-120-IN-DC-0002
Specification For Hazardous Area Classification	BK-GNRAL-PEDCO-000-SA-SP-0002
Specification For On-off /Shut Down Valves(ESDV/MOV)	BK-GNRAL-PEDCO-000-IN-SP-0006
Symbol & Legend For PFD and P&ID	BK-GCS-PEDCO-120-PR-PI-0001
P&ID - Gas Compression Inlet Gas Pipeline (Binak)	BK-GCS-PEDCO-120-PR-PI-0002
P&ID - Gas Compression Inlet Gas Pipeline (Golkhari)	BK-GCS-PEDCO-120-PR-PI-0003
P&ID - Slug Catcher System	BK-GCS-PEDCO-120-PR-PI-0004
P&ID - Gas Compression Inlet Knock Out Drum	BK-GCS-PEDCO-120-PR-PI-0005
P&ID - 1st Stage Gas Compression Suction Drums	BK-GCS-PEDCO-120-PR-PI-0006
P&ID - 1st Stage Gas Compression Compressors	BK-GCS-PEDCO-120-PR-PI-0007
P&ID - 1st Stage Gas Compression Air Coolers	BK-GCS-PEDCO-120-PR-PI-0008
P&ID - 2nd Stage Gas Compression Suction Drums	BK-GCS-PEDCO-120-PR-PI-0009
P&ID - 2nd Stage Gas Compression Compressors	BK-GCS-PEDCO-120-PR-PI-0010
P&ID - 2nd Stage Gas Compression Air Coolers	BK-GCS-PEDCO-120-PR-PI-0011
P&ID - 2nd Stage Gas Compression Discharge Drum	BK-GCS-PEDCO-120-PR-PI-0012
P&ID - Gas Compression Dehydration Package	BK-GCS-PEDCO-120-PR-PI-0013
P&ID - Lean Glycol Storage Tank	BK-GCS-PEDCO-120-PR-PI-0014
P&ID - Instrument & Plant Air System	BK-GCS-PEDCO-120-PR-PI-0015
P&ID - Nitrogen Generation System	BK-GCS-PEDCO-120-PR-PI-0016
P&ID - Close Drain System	BK-GCS-PEDCO-120-PR-PI-0017
P&ID - Corrosion Inhibitor Package	BK-GCS-PEDCO-120-PR-PI-0018
P&ID - Methanol Injection Package	BK-GCS-PEDCO-120-PR-PI-0019
P&ID - LP Flare System	BK-GCS-PEDCO-120-PR-PI-0020
P&ID - Oily Water Sewer	BK-GCS-PEDCO-120-PR-PI-0021
P&ID - Fuel Gas System	BK-GCS-PEDCO-120-PR-PI-0022
P&ID - Diesel Oil System	BK-GCS-PEDCO-120-PR-PI-0023
P&ID - Potable Water System	BK-GCS-PEDCO-120-PR-PI-0024
P&ID - Glycol Sump Drum	BK-GCS-PEDCO-120-PR-PI-0025
P&ID - Fire Water Network	BK-GCS-PEDCO-120-SA-PI-0001
P&ID - Total Flooding System For Extension of Existing Elect. Building	BK-GCS-PEDCO-120-SA-PI-0002



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



DATA SHEET FOR ON OFF & SHUTDOWN VALVES

شماره پیمان:

۰۵۳ - ۰۷۳ - ۹۱۸۴

پروژه

بسته کاری

صادر کننده

تجهیزات

رشته

نوع مدارک

سریال

نسخه

BK

GCS

PEDCO

120

IN

DT

0010

D02

شماره صفحه: ۴ از ۳۸

GENERAL NOTES:

1. Calculations shall be provided for each completely piped actuated valve assembly (including solenoid valve), the stroking times i.e. to close and to open.
2. The duty, failure action and stroke time shall all be approved by the Purchaser.
3. The actuator shall be designed to operate the valve through its full stroke.
4. The maximum valve stroking time to achieve the safety position shall be defined according to size of the body (5 seconds for body until 4", 1 second per inch for body greater than 4"). The maximum fully stroke time shall be 10 seconds.
5. The piping indicates corrosion allowance selected as per document "Piping & Pipeline Material Specification, No. " BK-GCS-PEDCO-120-PI-SP-0001 "
6. Hydro-test duration shall be in accordance with API 6D.
7. All ball valves shall be fitted with suitable 'end of travel' stops at the fully open and fully closed positions and a local position indicator . The design shall prevent the ingress of foreign material and corrosion products which would impair the operation of the stops. Devices capable of locking the valves in their safe position (ESDV in open or closed position) shall be provided for maintenance and shall be vendor's standard proven design.
8. Vendor shall guarantee and demonstrate the required stroking speed, during the Functional Test (FAT).
9. All accessories shall be mounted, together with solenoid valve, etc, on a 316SS sub-plate. Tubing shall be suitably sized TP 316L stainless steel with stainless steel double ferrule compression fittings
10. Solenoid valve shall be selected in accordance with low power type.
11. All on/off valves shall be preferably fitted with single acting, spring return pneumatic actuators, completed with mounting kit. Also Partial Stroking test or pilot valve to be considered.
12. The actuator shall be fail safe in operation (as specified in data sheets) in loss of electrical signal or loss of air supply.
13. The spring return actuator shall be "pre stressed".
14. Pneumatic actuators will be sized on the basis of a minimum safety factor of 1.5 and a minimum air pressure of 3 Bar g.
The valve actuator torque shall be in excess of the required valve torque under all operating conditions.
15. All actuators and accessories shall be clearly and permanently identified by nameplate. the nameplate shall be in stainless steel and affixed to the VALVE, actuator and accessories.
- 16 - Environmental condition for field instrumentation of Binak Oilfield shall be considered as per the followings:

Maximum ambient temperature: 50 (°C)
Minimum ambient temperature: 5 (°C)
Maximum steel surface exposed to sun: 85 (°C)
Maximum summer dry bulb: 50 (°C)
DB/RH for Summer HVAC Design: 41 °C / 61 %
DB FOR Winter HVAC Design: 6 °C


Relative Humidity:

- Maximum Design relative humidity (%): 100
- Minimum Design relative humidity (%): 0

- 17 - Material Test Certificate and calibration Certificate for all transmitters to be submitted by Vendor.
- 18 - Flow direction shall be permanently and clearly indicated on the valve body.
- 19- External grounding shall be provided for each solenoid valve.
- 20- BDV's shall have a minimum body size of 2" with tight shutoff (ANSI B16.104, class VI), air volume tanks for larger valves and should be sized for three full open/closed operations at 3-barg instrument air pressure.
- 21- Valves in safety related services should have been fire tested and certification to be provided by Vendor.
- 22- Seat rings shall be spring loaded and so designed that line pressure will assist in sealing round the ball.
- 23- Valve stem extension shall be detachable for easy replacements.
- 24- At least two stem seals shall be provided with facility for injection of secondary sealant and with stainless steel fittings.
- 25- Stem seal shall be replaceable while the valve is in closed operation position.
- 26- Short stroke single acting pneumatic piston actuators shall preferably be used on emergency shutdown service.
- 27- Body of all On/Off Valves except ss316 body material, shall be painted with white color. Also actuator of ESDV and BDV valves shall be painted with Red color as well as actuator of XV valves shall be painted by Blue color.

 NIS OC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض							 HIRGAN ENERGY		 TS			
		احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک												
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		Data Sheets For ON/OFF & Shutdown Valves							D02		شماره صفحه: ۵ از ۳۸			
		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال					نسخه	
		BK	GCS	PEDCO	120	IN	DT	0010	D02					
On-Off Valve														
TAG NO: ESDV-2101		P&ID NO: BK-GCS-PEDCO-120-PR-PI-0002_D06		SERVICE: Gas Compression Inlet Gas Pipeline (Binak)										
FLUID STATE: PROCESS GAS		PHASE: GAS		AREA CLASSIFICATION: Zone2, IIB, T4										
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE				kg/h		7220.4928		6564		1969.23		-	
	2 INLET PRESSURE				bar(g)		7.5		7.5		7.5		-	
	3 OUTLET PRESSURE				bar(g)		7.5		7.5		7.5		-	
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		18.2	
	5 INLET TEMPERATURE				°C		26.67~46.11		26.67~46.11		26.67~46.11		-	
	6 DENSITY				kg/m3		5.43 ~ 6.66		5.43 ~ 6.66		5.43 ~ 6.66		-	
	7 VISCOSITY				CP		0.011 ~ 0.012		0.011 ~ 0.012		0.011 ~ 0.012		-	
	8 VAPOR PRESSURE Pv				bar(a)		155.5		155.5		155.5		-	
9 CRITICAL PRESSURE				bar(a)		107.1		107.1		107.1		-		
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)	6"	80	6		53 TYPE		Single Acting , Spring Return			
			OUT		6"	80			54 SIZE		VTA			
11 LINE NO.		GAS-111-0001-AN07-6"-PT						55 SPRING FAIL ACTION		Fail to Close				
VALVE BODY & BONNET	12 TYPE		OUT		Full Bore Ball Valve/Trunion Mounted				56 MAX ALLOWABLE PRESSURE		VTA			
	13 SIZE		OUT		6"				57 MIN REQUIRES PRESSURE		VTA			
	14 MAX PRESS./TEMP.		OUT		As per PMS				58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g			
	15 MFR. & MODEL		OUT		Will be finalized later						VTA			
	16 BODY / BONNET MATL		OUT		ASTM A216 Gr. WCB						6 S			
	17 LINER MATERIAL / ID		OUT		VTA						On/Off			
	18 END CONNECTION		IN	6" /300#					INDICATOR		Required			
			OUT	6" /300#					DN		VTA			
	19 FLG FACE FINISH				RF				PE		Clutchable side mounted			
	20 END EXT./MATL.				N/A				MIT STOP		Yes			
	21 FLOW DIRECTION				(Note 18 in Page 4)						24VDC			
	22 TYPE OF BONNET				Standard						Will be finalized later			
	23 LUBE & ISO VALVE				No						N/A			
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard				Will be finalized later			
	25 ENTRY DESIGN				Top Entry				OUTPUT INCR /		N/A			
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)				YES				71 GAUGES		N/A				
TRIM	27 TRIM		TYPE	MATERIAL	VTA		316 SS+PTFE		72 CAM CHARACTERISTIC		N/A			
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A			
	29 CHARACTERISTICS				On/Off				74 TAG NO. :		BZSC-2110 / BZSO-2110			
	30 BALANCED / UNBALANCED				BALANCED				75 TYPE		QUANTITY	Magnetically operated "REED" contacts	2	
	31 RATED Cv		FL	XT	VTA		VTA	VTA	76 CONTACTS / RATING		110V DC , 10A			
	32 PLUG / BALL / DISK MATERIAL				316 SS				77 ACTUATION POINT		Fully Open/Close			
	33 SEAT		TYPE	MATERIAL	Soft Seat		PTFE		78 ENCLOSURE MATERIAL		Die Cast Amulium			
	34 CAGE / GUIDE MATERIAL				VTA				79 WEATHER PROTECTION		IP-65			
	35 STEM		TYPE	MATERIAL	Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 x 1.5	
	36 LEAKAGE CLASS				ANSI Class VI				81 MFR. & MODEL		Will be finalized later			
SOLENOID VALVE	37 VALVE STEM EXTENSION REQUIREMENT				YES				82 SET PRESSURE		Yes			
	38 TAG NO				ESOV-2101				83 PNEUMATIC CONNECTION		1/4" NPT			
	39 TYPE				3 Way				84 GAUGES		FILTER	Required	Required	
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL		Will be finalized later			
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS		Required			
SPECIAL / ACCESS.	42 MANUAL RESET				Yes				87 HYDRO PRESSURE		Required			
	43 Power Supply				24 VDC				88 FUNCTIONAL TEST		Required			
	44 Pnu. Connection				1/4" NPT				89					
	45 FUSIBLE LEAKAGE				No				90					
	46 BLOCK RELAY				No				91					
	47 QUICK EXHUST				Yes				92 PASSIVE FIRE PROTECTION		Yes			
	49 FILTER REGULATOR				Yes				93 API 6FA REQUIREMENTS		Yes			
	50 VOLUME TANK				No				94 SIL 3 REQUIREMENTS		Yes			
	51 MECHANICAL POSITION INDICATOR				Required				95 PARTIAL STROKING VALVE TEST		Yes			
	52 MANUAL PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE				Yes				96					
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NISOC		نگهداشت و افزایش تولید میدان نفتی بینک سطح الارضی						 HURGAN ENERGY		 TE			
شماره پیمان: ۰۳۸ - ۰۷۳ - ۰۵۳		پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۶ از ۳۸			
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02			
On-Off Valve													
TAG NO: ESDV-2102		P&ID NO: 6.5 barg?		-PR-PI-0003-D06				SERVICE: Gas Compression Inlet Gas Pipeline (Golghari)					
FLUID STATE: PROCESS GAS		PHASE:						AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	1	FLOW RATE			UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off			
	2	INLET PRESSURE			kg/h		12395.9	11269.0	3380.0	-			
	3	OUTLET PRESSURE			bar(g)		7.5	7.5	7.5	-			
	4	DIFFERENTIAL PRESSURE			bar(g)		7.5	7.5	7.5	90			
	5	INLET TEMPERATURE			bar(g)		-	-	-	-			
	6	DENSITY			°C		15.5 ~ 32	15.5 ~ 32	15.5 ~ 32	-			
	7	VISCOSITY			kg/m3		6.19 ~ 6.21	6.19 ~ 6.21	6.19 ~ 6.21	-			
	8	VAPOR PRESSURE Pv			CP		0.011	0.011	0.011	-			
	9	CRITICAL PRESSURE			r(a)		174.6	174.6	174.6	-			
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	CORROSION ALLOWANCE (mm)	8"	100	8"	100	53	TYPE	Single Acting , Spring Return		
	11	LINE NO.	OUT		8"	100			54	SIZE	VT A		
VALVE BODY & BONNET	12	TYPE			Full Bore Ball Valve/Trunion Mounted				55	SPRING FAIL ACTION		Fail to Close	
	13	SIZE			8"				56	MAX ALLOWABLE PRESSURE		VT A	
	14	MAX PRESS./TEMP.			As per PMS				57	MIN REQUIRES PRESSURE		VT A	
	15	MFR. & MODEL			Will be finalized later				58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g	
	16	BODY / BONNET MATL			ASTM A216 Gr. WCB				59	BENCH RANGE		VT A	
	17	LINER MATERIAL / ID			VT A				60	TRAVELING TIME		9 S	
	18	END CONNECTION	IN	8"	/600#			61	FUNCTION		On/Off		
	19	FLG FACE FINISH	OUT	8"	/600#			62	LOCAL POSITION INDICATOR		Required		
	20	END EXT./MATL.			N/A				63	ACT. ORIENTATION		VT A	
	21	FLOW DIRECTION			(Note 18 in Page 4)				64	HAND WHEEL TYPE		Clutchable side mounted	
	22	TYPE OF BONNET			Standard				65	ADJUSTABLE LIMIT STOP		Yes	
	23	LUBE & ISO VALVE			No				66	INPUT SIGNAL		24VDC	
	24	PACKING MATERIAL		PACKING TYPE		PTFE	Standard		67	MFR. & MODEL		Will be finalized later	
	25	ENTRY DESIGN			Top Entry				68	TYPE		N/A	
TRIM	26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)			YES				69	MFR. & MODEL		Will be finalized later	
	27	TRIM	TYPE	MATERIAL	VT A	316 SS+RPTFE		70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A		
	28	SIZE	RATED TRAVEL		VT A	VT A		71	GAUGES		N/A		
	29	CHARACTERISTICS			On/Off				72	CAM CHARACTERISTIC		N/A	
	30	BALANCED / UNBALANCED			BALANCED				73	AIR CONNECTION		N/A	
	31	RATED Cv	FL	XT	VT A	VT A	VT A	74	TAG NO. :		BZSC-2110 / BZSO-2110		
	32	PLUG / BALL / DISK MATERIAL			316 SS				75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2
	33	SEAT	TYPE	MATERIAL	Soft Seat	RPTFE		76	CONTACTS / RATING		110V DC , 10A		
	34	CAGE / GUIDE MATERIAL			VT A				77	ACTUATION POINT		Fully Open/Close	
	35	STEM	TYPE	MATERIAL	Anti-Blow Out	Forged, 13% chromium steel		78	ENCLOSURE MATERIAL		Die Cast Amulminum		
SOLENOID VALVE	36	LEAKAGE CLASS			ANSI Class VI				79	WEATHER PROTECTION		IP-65	
	37	VALVE STEM EXTENSION REQUIREMENT			YES				80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 x 1.5
	38	TAG NO			ESOV-2102				81	MFR. & MODEL		Will be finalized later	
	39	TYPE			3 Way				82	SET PRESSURE		Yes	
	40	BODY MATERIAL		WEATHER IP.		AISI 316 S.S	IP-65		83	PNEUMATIC CONNECTION		1/4" NPT	
SPECIAL / ACCESS.	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4	ISO M20 x 1.5		84	GAUGES	FILTER	Required	Required
	42	MANUAL RESET			Yes				85	MFR. & MODEL		Will be finalized later	
	43	Power Supply			24 VDC				86	ANSI/FCI LEAKAGE CLASS		Required	
	44	Pau. Connection			1/4" NPT				87	HYDRO PRESSURE		Required	
	45	FUSIBLE LEAKAGE			No				88	FUNCTIONAL TEST		Required	
	46	BLOCK RELAY			No				89				
	47	QUICK EXHUST			Yes				90				
	48	FILTER REGULATOR			Yes				91				
	49	VOLUME TANK			No				92	PASSIVE FIRE PROTECTION		Yes	
	50	MECHANICAL POSITION INDICATOR			Required				93	API 6FA REQUIREMENTS		Yes	
51	MANUAL PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE			Yes				94	SIL 3 REQUIREMENTS		Yes		
52								95	PARTIAL STROKING VALVE TEST		Yes		
53								96					
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM													
(1) PMS: Piping material specification.													
(2) All material shall be suitable for minimum design metal temperature.													
(3) Shall be stated by vendor at quotation stage.													
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.													

 NISOC		تجهیزات و افزایش تولید میدان نفتی بینک سطح الارض						 HIRGAN ENERGY								
		احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک						 HIRGAN ENERGY								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	 D02						
		BK	GCS	PEDCO	120	IN	DT	0010	D02							
TAG NO: ESDV-2113		On-Off Valve						SERVICE:								
FLUID STATE: PROCESS GAS		BK-GCS-PEDCO-120-PR-PI-0005-D06 (1 of 1)						AREA CLASSIFICATION: Zone2, IIB, T4								
SERVICE CONDITION	1	FLOW RATE					UNITS	Max Flow	Norm. Flow	Min. Flow	Shut-Off					
	2	INLET PRESSURE					kg/h	1119.5	1017.8	305.3	-					
	3	OUTLET PRESSURE					bar(g)	5.3	5.3	5.3	-					
	4	DIFFERENTIAL PRESSURE					bar(g)	5.3	5.3	5.3	-					
	5	INLET TEMPERATURE					bar(g)	-	-	-	18.2					
	6	DENSITY					°C	36.9	36.9	36.9	-					
	7	VISCOSITY					kg/m3	842.6	842.6	842.6	-					
	8	VAPOR PRESSURE Pv					cP	0.69	0.69	0.69	-					
	9	CRITICAL PRESSURE					bar(a)	0.612	0.612	0.612	-					
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	OUT	C	ALL										
	11	LINE NO.														
VALVE BODY & BONNET	12	TYPE					to make a uniform format, T, density and viscosity should be given in a range Reply: Noted									
	13	SIZE														
	14	MAX PRESS./TEMP.										As per PMS				
	15	MFR. & MODEL										Will be finalized later				
	16	BODY / BONNET MATL										ASTM A351 GR.CF3M				
	17	LINER MATERIAL / ID										VTA				
	18	END CONNECTION	IN	OUT								2" /300#				
	19	FLG FACE FINISH										RF				
	20	END EXT./MATL.										N/A				
	21	FLOW DIRECTION										(Note 18 in Page 4)				
	22	TYPE OF BONNET										Standard				
	23	LUBE & ISO VALVE										No				
	24	PACKING MATERIAL	PACKING TYPE			PTFE						Standard				
	25	ENTRY DESIGN										Top Entry				
	26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)										YES				
	TRIM	27	TRIM	TYPE	MATERIAL							VTA		316 SS+PTFE		
		28	SIZE	RATED TRAVEL		VTA						VTA				
		29	CHARACTERISTICS									On/Off				
30		BALANCED / UNBALANCED					BALANCED									
31		RATED Cv	FL	XT	VTA		VTA		VTA							
32		PLUG / BALL / DISK MATERIAL					316 SS									
33		SEAT	TYPE	MATERIAL		Soft Seat		PTFE								
34		CAGE / GUIDE MATERIAL					VTA									
35		STEM	TYPE	MATERIAL		Anti-Blow Out		316 SS								
36		LEAKAGE CLASS					ANSI Class VI									
SOLENOID VALVE	37	VALVE STEM EXTENSION REQUIREMENT					YES									
	38	TAG NO					ESOV-2113									
	39	TYPE					3 Way									
	40	BODY MATERIAL	WEATHER IP.			AISI 316 S.S		IP-65								
	41	ELE. CERTIFICATE	ELE. CONNECTION			EEx "d", IIB T4		ISO M20 x 1.5								
	42	MANUAL RESET					Yes									
SPECIAL / ACCESS.	43	Power Supply					24 VDC									
	44	Pnu. Connection					1/4" NPT									
	45	FUSIBLE LEAKAGE					No									
	46	BLOCK RELAY					No									
	47	QUICK EXHUST					Yes									
	49	FILTER REGULATOR					Yes									
50	VOLUME TANK					No										
51	MECHANICAL POSITION INDICATOR					Required										
52	MANUAL PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE					Yes										
ACTUATOR	53	TYPE					Single Acting , Spring Return									
	54	SIZE					VTA									
	55	SPRING FAIL ACTION					Fail to Close									
	56	MAX ALLOWABLE PRESSURE					VTA									
	57	MIN REQUIRES PRESSURE					VTA									
	58	AVAILABLE AIR SUPPLY PRESSURE					MAX/NOR/MIN: 10/7/3 bar-g									
	59	BENCH RANGE					VTA									
	60	TRAVELING TIME					5 S									
	61	FUNCTION					On/Off									
	62	LOCAL POSITION INDICATOR					Required									
	63	ACT. ORIENTATION					VTA									
	64	HAND WHEEL TYPE					Clutchable side mounted									
	65	ADJUSTABLE LIMIT STOP					Yes									
	66	INPUT SIGNAL					24VDC									
	67	MFR. & MODEL					Will be finalized later									
	POSITIONER	68	TYPE					N/A								
69		MFR. & MODEL					Will be finalized later									
70		ON INCR SIGNAL OUTPUT INCR / DECR					N/A									
71		GAUGES					N/A									
LIMIT SWITCHES	72	CAM CHARACTERISTIC					N/A									
	73	AIR CONNECTION					N/A									
	74	TAG NO. :					BZSC-2110 / BZSO-2110									
	75	TYPE	QUANTITY			Magnetically operated "REED" contacts		2								
	76	CONTACTS / RATING					110V DC , 10A									
	77	ACTUATION POINT					Fully Open/Close									
AIR SET	78	ENCLOSURE MATERIAL					Die Cast Amulimum									
	79	WEATHER PROTECTION					IP-65									
	80	ELEC. CERTIFICATE	ELEC. CONNECTION			EEx "d", IIB T4		ISO M20 x 1.5								
	81	MFR. & MODEL					Will be finalized later									
TEST	82	SET PRESSURE					Yes									
	83	PNEUMATIC CONNECTION					1/4" NPT									
	84	GAUGES	FILTER			Required		Required								
	85	MFR. & MODEL					Will be finalized later									
FIRE PROOF DESIGN	86	ANSI/FCI LEAKAGE CLASS					Required									
	87	HYDRO PRESSURE					Required									
	88	FUNCTIONAL TEST					Required									
	89															
90																
91																
92	PASSIVE FIRE PROTECTION					Yes										
93	API 6FA REQUIREMENTS					Yes										
94	SIL 3 REQUIREMENTS					Yes										
95	PARTIAL STROKING VALVE TEST					Yes										
96																
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONIFRM																
(1) PMS: Piping material specification.																
(2) All material shall be suitable for minimum design metal temperature.																
(3) Shall be stated by vendor at quotation stage.																
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																

 NIS OC		تکهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک										 HIRGAN توسعه انرژی				 TS							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه		بسته کاری		صادر کننده		تسهیلات		رشته		نوع مدرک		سریال		نسخه		شماره صفحه: ۹ از ۲۸					
BK		GCS		PEDCO		120		IN		DT		0010		D02									
On-Off Valve																							
TAG NO:		BDV-2110				P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0005-D06												Pressure Inlet Knock Out Drum to Flare Header			
FLUID STATE:				PROCESS GAS				PHASE:				GAS				Zone2, IIB, T4							
SERVICE CONDITION		ITEM										UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off			
		1 FLOW RATE										kg/h		-		5665.4		-		-			
		2 INLET PRESSURE										bar(g)		-		5.3 ~ 9		-		-			
		3 OUTLET PRESSURE										bar(g)		-		5.3 ~ 9		-		-			
		4 DIFFERENTIAL PR										bar(g)		-		-		-		18.2			
		5 INLET TEMPERAT										°C		-		19 ~ 37.17		-		-			
		6 DENSITY										kg/m3		-		5.96 ~ 1012		-		-			
		7 VISCOSITY										CP		-		0.011 ~ 1.027		-		-			
		8 VAPOR PRESSURE PV										bar(a)		-		167.7		-		-			
9 CRITICAL PRESSURE										bar(a)		-		94.65		-		-					
LINE		PIPE LINE SIZE & SCHEDULE		IN		OUT		CO		ALLO													
		LINE NO.																					
VALVE BODY & BONNET		12 TYPE										ACTUATOR		53 TYPE		Single Acting, Spring Return							
		13 SIZE												54 SIZE		VTA							
		14 MAX PRESS./TEMP.												55 SPRING FAIL ACTION		Fail to Close							
		15 MFR. & MODEL												56 MAX ALLOWABLE PRESSURE		VTA							
		16 BODY / BONNET MATL												57 MIN REQUIRES PRESSURE		VTA							
		17 LINER MATERIAL /ID												58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g							
		18 END CONNECTION												59 BENCH RANGE		VTA							
		19 FLG FACE FINISH												60 TRAVELING TIME		5 S							
		20 END EXT./MATL.												61 FUNCTION		On/Off							
		21 FLOW DIRECTION												62 LOCAL POSITION INDICATOR		Required							
		22 TYPE OF BONNET												63 ACT. ORIENTATION		VTA							
		23 LUBE & ISO VALVE												64 HAND WHEEL TYPE		Clutchable side mounted							
		24 PACKING MATERIAL												65 ADJUSTABLE LIMIT STOP		Yes							
		25 ENTRY DESIGN												66 INPUT SIGNAL		24VDC							
		26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)												67 MFR. & MODEL		Will be finalized later							
		27 TRIM												68 TYPE		N/A							
		28 SIZE												69 MFR. & MODEL		Will be finalized later							
		29 CHARACTERISTICS												70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A							
		TRIM		30 BALANCED / UNBALANCED										71 GAUGES		N/A							
31 RATED Cv										72 CAM CHARACTERISTIC		N/A											
32 PLUG / BALL / DISK MATERIAL										73 AIR CONNECTION		N/A											
33 SEAT										74 TAG NO. :		BZSC-2110 / BZSO-2110											
34 CAGE / GUIDE MATERIAL										75 TYPE		QUANTITY		Magnetically operated 'REED' contacts				2					
35 STEM										76 CONTACTS / RATING		110V DC , 10A											
36 LEAKAGE CLASS										77 ACTUATION POINT		Fully Open/Close											
37 VALVE STEM EXTENSION REQUIREMENT										78 ENCLOSURE MATERIAL		Die Cast Amulimum											
SOLENOID VALVE		38 TAG NO										79 WEATHER PROTECTION		IP-65									
		39 TYPE										80 ELEC. CERTIFICATE		ELEC. CONNECTION		EEx "d", IIB T4				ISO M20 x 1.5			
		40 BODY MATERIAL										81 MFR. & MODEL		Will be finalized later									
		41 ELE. CERTIFICATE										82 SET PRESSURE		Yes									
		42 MANUAL RESET										83 PNEUMATIC CONNECTION		1/4" NPT									
		43 Power Supply										84 GAUGES		FILTER		Required				Required			
SPECIAL / ACCESS.		44 Pnu. Connection										85 MFR. & MODEL		Will be finalized later									
		45 FUSIBLE LEAKAGE										86 ANSI/FCI LEAKAGE CLASS		Required									
		46 BLOCK RELAY										87 HYDRO PRESSURE		Required									
		47 QUICK EXHUST										88 FUNCTIONAL TEST		Required									
		49 FILTER REGULATOR																					
		50 VOLUME TANK																					
51 MECHANICAL POSITION INDICATOR																							
52 MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE																							
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM																							
(1) PMS: Piping material specification.																							
(2) All material shall be suitable for minimum design metal temperature.																							
(3) Shall be stated by vendor at quotation stage.																							
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																							



NIS OC

نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

Data Sheets For ON/OFF & Shutdown Valves



شماره صفحه: ۱۱ از ۳۸

D02

On-Off Valve

TAG NO: BDV-2122B

P&ID NO : BK-GCS-PEDCO-120-PR-PI-0007-D06(2/3)

SERVICE: Gas Compression Inlet Knock Out Drum to Flare Header

FLUID STATE:	PROCESS GAS
1. Subcooled liquid 2. Saturated liquid 3. Saturated vapor 4. Subcooled vapor	1. Subcooled liquid 2. Saturated liquid 3. Saturated vapor 4. Subcooled vapor

PHASE: _____ GAS: _____

AREA CLASSIFICATION: Zone2, IIB, T4

SERVICE CONDITION	ITEM						UNITS	Max Flow	Norm. Flow	Min. Flow	Shut-Off			
	1	FLOW RATE						kg/h	-	300.0	-	-		
	2	INLET PRESSURE						bar(g)	4.9	4.9	4.9	-		
	3	OUTLET PRESSURE						bar(g)	4.9	4.9	4.9	-		
	4	DIFFERENTIAL PRESSURE						bar(g)	-	-	-	18.2		
	5	INLET TEMPERATURE						°C	-	18.9 ~ 36.78	-	-		
	6	DENSITY						kg/m3	-	5.37 ~ 5.77	-	-		
	7	VISCOSITY						CP	-	0.011	-	-		
	8	VAPOR PRESSURE Pv						bar(a)	-	167.5	-	-		
	9	CRITICAL PRESSURE						bar(a)	-	94.65	-	-		
LINE	10	PIPE LINE SIZE & SCHEDULE		CORROSION ALLOWANCE (mm)	2" 80		6	ACTUATOR	53	TYPE		Single Acting, Spring Return		
	OUT	2" 80			54	SIZE			VTA					
11		LINE NO.		GAS-111-0035A-CN05-2"-PT					55	SPRING FAIL ACTION		Fail to Close		
VALVE BODY & BONNET	12	TYPE		Full Bore Ball Valve/Trunnion Mounted					56	MAX ALLOWABLE PRESSURE		VTA		
	13	SIZE		2"					57	MIN REQUIRES PRESSURE		VTA		
	14	MAX PRESS./TEMP.		As per PMS					58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g		
	15	MFR. & MODEL		Will be finalized later					59	BENCH RANGE		VTA		
	16	BODY / BONNET MATL		ASTM A216 Gr. WCB					60	TRAVELING TIME		5 S		
	17	LINER MATERIAL / ID		VTA					61	FUNCTION		On/Off		
	18	END CONNECTION	IN	2"/300#					62	LOCAL POSITION INDICATOR		Required		
			OUT	2"/300#				63	ACT. ORIENTATION		VTA			
	19	FLG FACE FINISH		RF				64	HAND WHEEL TYPE		Clutchable side mounted			
	20	END EXT.MATL.		N/A				65	ADJUSTABLE LIMIT STOP		Yes			
	21	FLOW DIRECTION		(Note 18 in Page 4)				66	INPUT SIGNAL		24VDC			
	22	TYPE OF BONNET		Standard				67	MFR. & MODEL		Will be finalized later			
	23	LUBE & ISO VALVE		No				POSITIONER	68	TYPE		N/A		
	24	PACKING MATERIAL	PACKING TYPE		PTFE		Standard		69	MFR. & MODEL		Will be finalized later		
ENTRY DESIGN			Top Entry		70	ON INCR SIGNAL OUTPUT INCR / DECR			N/A					
26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES				71		GAUGES		N/A			
TRIM	27	TRIM	TYPE	MATERIAL	VTA		316 SS+PTFE	72	CAM CHARACTERISTIC		N/A			
	28	SIZE	RATED TRAVEL		VTA		VTA	73	AIR CONNECTION		N/A			
	29	CHARACTERISTICS		On/Off				LIMIT SWITCHES	74	TAG NO. :		BZSC-2110 / BZSO-2110		
	30	BALANCED / UNBALANCED		BALANCED					75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2	
	31	RATED Cv	FL	XT	VTA		VTA		VTA	76	CONTACTS / RATING		110V DC , 10A	
	32	PLUG / BALL / DISK MATERIAL		316 SS					77	ACTUATION POINT		Fully Open/Close		
	33	SEAT	TYPE	MATERIAL	Soft Seat		PTFE		78	ENCLOSURE MATERIAL		Die Cast Aluminum		
	34	CAGE / GUIDE MATERIAL		VTA					79	WEATHER PROTECTION		IP-65		
	35	STEM	TYPE	MATERIAL	Anti-Blow Out		316 SS		80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 × 1.5	
	36	LEAKAGE CLASS		ANSI Class VI					81	MFR. & MODEL		Will be finalized later		
37	VALVE STEM EXTENSION REQUIREMENT		YES				AIR SET		82	SET PRESSURE		Yes		
38	TAG NO		PSOV-2110						83	PNEUMATIC CONNECTION		1/4" NPT		
39	TYPE		3 Way					84	GAUGES	FILTER	Required	Required		
40	BODY MATERIAL		WEATHER IP.		AISI 316 S.S			IP-65	85	MFR. & MODEL		Will be finalized later		
41	ELE. CERTIFICATE	ELE. CONNECTION		EEx "d", IIB T4		ISO M20 × 1.5		TEST	86	ANSI/FCI LEAKAGE CLASS		Required		
42	MANUAL RESET		Yes				87		HYDRO PRESSURE		Required			
43	Power Supply		24 VDC				88		FUNCTIONAL TEST		Required			
44	Pnu. Connection		1/4" NPT											
45	FUSIBLE LEAKAGE		No											
SPECIAL / ACCESS.	46	BLOCK RELAY		No										
	47	QUICK EXHUST		Yes										
	49	FILTER REGULATOR		Yes										
	50	VOLUME TANK		Yes										
	51	MECHANICAL POSITION INDICATOR		Required										
52	MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes											

NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE

VTC: VENDOR TO CONFIRM

(1) PMS: Piping material specification.

(2) All material shall be suitable for minimum design metal temperature.

(3) Shall be stated by vendor at quotation stage.

(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

Data Sheets For ON/OFF & Shutdown Valves



شماره صفحه: ۱۲ از ۳۸

D02

On-Off Valve

TAG NO: BDV-2122C

P&ID NO : BK-GCS-PEDCO-120-PR-PI-0007-D06(2/3)

SERVICE: Gas Compression Inlet Knock Out Drum to Flare Header

FLUID STATE: PROCESS GAS

PHASE: GAS

AREA CLASSIFICATION: Zone2, IIB, T4

--	--

ITEM

	Max Flow	Norm. Flow	Min. Flow	S
--	----------	------------	-----------	---

- (1) PMS: Piping material specification.
- (2) All material shall be suitable for minimum design metal temperature.
- (3) Shall be stated by vendor at quotation stage.
- (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.

 NIS OC		تجهاد است و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 HIRGAN ENERGY 										
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۳۸ از ۱۳								
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02	D02								
On-Off Valve																		
TAG NO:		BDV-2134A		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D06 (1 of 3)			SERVICE: 2nd Stage Gas Compression Suction Drums									
FLUID STATE:		VENT GAS		PHASE:		GAS			AREA CLASSIFICATION: Zone2, IIB, T4									
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off				
	1 FLOW RATE					kg/h		-		796		-		-				
	2 INLET PRESSURE					bar(g)		-		18.1~ 22		-		-				
	3 OUTLET PRESSURE					bar(g)		-		18.1~ 22		-		-				
	4 DIFFERENTIAL PRESSURE					bar(g)		-		-		-		47.7				
	5 INLET TEMPERATURE					°C		-		22 ~ 59.88		-		-				
	6 DENSITY					kg/m3		-		18.08-1011		-		-				
	7 VISCOSITY					CP		-		0.013 ~ 0.98		-		-				
	8 VAPOR PRESSURE Pv					bar(a)		-		-		-		-				
9 CRITICAL PRESSURE					bar(a)		-		94.65		-		-					
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		2" 80		6		53 TYPE			Single Acting , Spring Return					
			OUT			2" 80				54 SIZE			VTA					
	11 LINE NO.		GAS-111-0160A-CN05-2"-PT								55 SPRING FAIL ACTION			Fail to Open				
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/ Floating Type								56 MAX ALLOWABLE PRESSURE			VTA				
	13 SIZE		2"								57 MIN REQUIRES PRESSURE			VTA				
	14 MAX PRESS./TEMP.		As per PMS								58 AVAILABLE AIR SUPPLY PRESSURE			MAX/NOR/MIN: 10/7/3 bar-g				
	15 MFR. & MODEL		Will be finalized later								59 BENCH RANGE			VTA				
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB								60 TRAVELING TIME			5 S				
	17 LINER MATERIAL / ID		VTA								61 FUNCTION			On/Off				
	18 END CONNECTION		IN	2" /300#				62 LOCAL POSITION INDICATOR			Required							
			OUT	2"/300#				63 ACT. ORIENTATION			VTA							
	19 FLG FACE FINISH		RF								64 HAND WHEEL TYPE			Decutchable side mounted				
	20 END EXT./MATL.		N/A								65 ADJUSTABLE LIMIT STOP			No				
	21 FLOW DIRECTION		(Note 18 in Page 4)								66 INPUT SIGNAL			24VDC				
	22 TYPE OF BONNET		Standard								67 MFR. & MODEL			Will be finalized later				
	23 LUBE & ISO VALVE		No								68 TYPE			N/A				
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard		69 MFR. & MODEL			Will be finalized later						
	25 ENTRY DESIGN		Top Entry								70 ON INCR SIGNAL OUTPUT INCR / DECR			N/A				
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES								71 GAUGES			N/A					
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE		72 CAM CHARACTERISTIC			N/A					
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION			N/A						
	29 CHARACTERISTICS		On/Off								74 TAG NO. :			BZSC-2110 / BZSO-2110				
	30 BALANCED / UNBALANCED		BALANCED						75 TYPE		QUANTITY		Magnetically operated 'REED' contacts		2			
	31 RATED Cv		FL	XT		VTA		VTA		76 CONTACTS / RATING		110V DC , 10A						
	32 PLUG / BALL / DISK MATERIAL		316 SS								77 ACTUATION POINT			Fully Open/Close				
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE		78 ENCLOSURE MATERIAL			Die Cast Amulium					
	34 CAGE / GUIDE MATERIAL		VTA								79 WEATHER PROTECTION			IP-65				
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION		EEx "d" ,IIB T4		ISO M20 × 1.5		
	36 LEAKAGE CLASS		ANSI Class VI								81 MFR. & MODEL			Will be finalized later				
SOLENOID VALVE	37 VALVE STEM EXTENSION REQUIREMENT		YES								82 SET PRESSURE			Yes				
	38 TAG NO		BSOV-2134A , PSOV-2134A								83 PNEUMATIC CONNECTION			1/4" NPT				
	39 TYPE		3 Way								84 GAUGES		FILTER		Required		Required	
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL			Will be finalized later						
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS			Required						
	42 MANUAL RESET		Yes								87 HYDRO PRESSURE			Required				
	43 Power Supply		24 VDC								88 FUNCTIONAL TEST			Required				
	44 Pnu. Connection		1/4" NPT								89							
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No								90							
	46 BLOCK RELAY		No								91 PASSIVE FIRE PROTECTION			No				
	47 QUICK EXHUST		Yes								92 API 6FA REQUIREMENTS			Yes				
	49 FILTER REGULATOR		Yes								93 SIL 3 REQUIREMENTS			Yes				
	50 VOLUME TANK		No								94 PARTIAL STROKING VALVE TEST			Yes				
51 MECHANICAL POSITION INDICATOR		Required								95								
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																		

 NIS OC		تجهاد است و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 HIRGAN ENERGY 									
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۱۴ از ۳۸							
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02								
On-Off Valve																	
TAG NO:		BDV-2134B		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D06 (2 of 3)				SERVICE: 2nd Stage Gas Compression Suction Drums							
FLUID STATE:		VENT GAS		PHASE:		GAS				AREA CLASSIFICATION: Zone2, IIB, T4							
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off			
	1 FLOW RATE					kg/h		-		796		-		-			
	2 INLET PRESSURE					bar(g)		-		18.1~ 22		-		-			
	3 OUTLET PRESSURE					bar(g)		-		18.1~ 22		-		-			
	4 DIFFERENTIAL PRESSURE					bar(g)		-		-		-		47.7			
	5 INLET TEMPERATURE					°C		-		22 ~ 59.88		-		-			
	6 DENSITY					kg/m3		-		18.08~ 1011		-		-			
	7 VISCOSITY					CP		-		0.013 ~ 0.98		-		-			
	8 VAPOR PRESSURE Pv					bar(a)		-		-		-		-			
9 CRITICAL PRESSURE					bar(a)		-		94.65		-		-				
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		2" 80		6		53 TYPE		Single Acting , Spring Return					
			OUT			2" 80				54 SIZE		VTA					
	11 LINE NO.		GAS-111-0160B-CN05-2"-PT									55 SPRING FAIL ACTION		Fail to Open			
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/ Floating Type									56 MAX ALLOWABLE PRESSURE		VTA			
	13 SIZE		2"									57 MIN REQUIRES PRESSURE		VTA			
	14 MAX PRESS./TEMP.		As per PMS									58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g			
	15 MFR. & MODEL		Will be finalized later									59 BENCH RANGE		VTA			
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M									60 TRAVELING TIME		5 S			
	17 LINER MATERIAL / ID		VTA									61 FUNCTION		On/Off			
	18 END CONNECTION		IN	2" /300#						62 LOCAL POSITION INDICATOR		Required					
			OUT	2"/300#						63 ACT. ORIENTATION		VTA					
	19 FLG FACE FINISH		RF									64 HAND WHEEL TYPE		Decutchable side mounted			
	20 END EXT./MATL.		N/A									65 ADJUSTABLE LIMIT STOP		No			
	21 FLOW DIRECTION		(Note 18 in Page 4)									66 INPUT SIGNAL		24VDC			
	22 TYPE OF BONNET		Standard									67 MFR. & MODEL		Will be finalized later			
	23 LUBE & ISO VALVE		No									68 TYPE		N/A			
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard				69 MFR. & MODEL		Will be finalized later				
	25 ENTRY DESIGN		Top Entry									70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A			
	26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES									71 GAUGES		N/A			
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE		72 CAM CHARACTERISTIC		N/A					
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A						
	29 CHARACTERISTICS		On/Off									74 TAG NO. :		BZSC-2110 / BZSO-2110			
	30 BALANCED / UNBALANCED		BALANCED						75 TYPE		QUANTITY	Magnetically operated 'REED' contacts		2			
	31 RATED Cv		FL	XT	VTA		VTA	VTA	76 CONTACTS / RATING		110V DC , 10A						
	32 PLUG / BALL / DISK MATERIAL		316 SS									77 ACTUATION POINT			Fully Open/Close		
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE		78 ENCLOSURE MATERIAL			Die Cast Amulium				
	34 CAGE / GUIDE MATERIAL		VTA									79 WEATHER PROTECTION			IP-65		
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d" ,IIB T4		ISO M20 × 1.5		
	36 LEAKAGE CLASS		ANSI Class VI									81 MFR. & MODEL			Will be finalized later		
37 VALVE STEM EXTENSION REQUIREMENT		YES									82 SET PRESSURE			Yes			
SOLENOID VALVE	38 TAG NO		BSOV-2134B , PSOV-2134B									83 PNEUMATIC CONNECTION			1/4" NPT		
	39 TYPE		3 Way									84 GAUGES		FILTER	Required		Required
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL		Will be finalized later						
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS			Required					
	42 MANUAL RESET		Yes									87 HYDRO PRESSURE			Required		
	43 Power Supply		24 VDC									88 FUNCTIONAL TEST			Required		
	44 Pnu. Connection		1/4" NPT									89					
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No									90					
	46 BLOCK RELAY		No									91 PASSIVE FIRE PROTECTION			No		
	47 QUICK EXHUST		Yes									92 API 6FA REQUIREMENTS			Yes		
	49 FILTER REGULATOR		Yes									93 SIL 3 REQUIREMENTS			Yes		
	50 VOLUME TANK		No									94 PARTIAL STROKING VALVE TEST			Yes		
51 MECHANICAL POSITION INDICATOR		Required									95						
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																	

 NIS OC		تجهاد است و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 HIRGAN ENERGY 								
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۳۸ از ۱۵						
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02						
On-Off Valve																
TAG NO:		BDV-2134C		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D06 (3 of 3)			SERVICE: 2nd Stage Gas Compression Suction Drums							
FLUID STATE:		VENT GAS		PHASE:		GAS			AREA CLASSIFICATION: Zone2, IIB, T4							
SERVICE CONDITION	ITEM					UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off		
	1 FLOW RATE					kg/h		-		796		-		-		
	2 INLET PRESSURE					bar(g)		-		18.1~ 22		-		-		
	3 OUTLET PRESSURE					bar(g)		-		18.1~ 22		-		-		
	4 DIFFERENTIAL PRESSURE					bar(g)		-		-		-		47.7		
	5 INLET TEMPERATURE					°C		-		22 ~ 59.88		-		-		
	6 DENSITY					kg/m3		-		18.08~ 1011		-		-		
	7 VISCOSITY					CP		-		0.013 ~0.98		-		-		
	8 VAPOR PRESSURE Pv					bar(a)		-		-		-		-		
9 CRITICAL PRESSURE					bar(a)		-		94.65		-		-			
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		2" 80		6		53 TYPE		Single Acting , Spring Return				
			OUT			2" 80				54 SIZE		VTA				
	11 LINE NO.		GAS-111-0160C-CN05-2"-PT									55 SPRING FAIL ACTION		Fail to Open		
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/ Floating Type									56 MAX ALLOWABLE PRESSURE		VTA		
	13 SIZE		2"									57 MIN REQUIRES PRESSURE		VTA		
	14 MAX PRESS./TEMP.		As per PMS									58 AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g		
	15 MFR. & MODEL		Will be finalized later									59 BENCH RANGE		VTA		
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB									60 TRAVELING TIME		5 S		
	17 LINER MATERIAL / ID		VTA									61 FUNCTION		On/Off		
	18 END CONNECTION		IN	2" /300#						62 LOCAL POSITION INDICATOR		Required				
			OUT	2"/300#						63 ACT. ORIENTATION		VTA				
	19 FLG FACE FINISH		RF									64 HAND WHEEL TYPE		Decutchable side mounted		
	20 END EXT./MATL.		N/A									65 ADJUSTABLE LIMIT STOP		No		
	21 FLOW DIRECTION		(Note 18 in Page 4)									66 INPUT SIGNAL		24VDC		
	22 TYPE OF BONNET		Standard									67 MFR. & MODEL		Will be finalized later		
	23 LUBE & ISO VALVE		No									68 TYPE		N/A		
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard				69 MFR. & MODEL		Will be finalized later			
25 ENTRY DESIGN		Top Entry									70 ON INCR SIGNAL OUTPUT INCR / DECR		N/A			
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES									71 GAUGES		N/A			
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE		72 CAM CHARACTERISTIC		N/A				
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION		N/A					
	29 CHARACTERISTICS		On/Off									74 TAG NO. :		BZSC-2110 / BZSO-2110		
	30 BALANCED / UNBALANCED		BALANCED						75 TYPE		QUANTITY	Magnetically operated 'REED' contacts		2		
	31 RATED Cv		FL	XT	VTA		VTA		76 CONTACTS / RATING		110V DC , 10A					
	32 PLUG / BALL / DISK MATERIAL		316 SS									77 ACTUATION POINT		Fully Open/Close		
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE		78 ENCLOSURE MATERIAL		Die Cast Amulium				
	34 CAGE / GUIDE MATERIAL		VTA									79 WEATHER PROTECTION		IP-65		
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS		80 ELEC. CERTIFICATE		ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 × 1.5		
	36 LEAKAGE CLASS		ANSI Class VI									81 MFR. & MODEL		Will be finalized later		
37 VALVE STEM EXTENSION REQUIREMENT		YES									82 SET PRESSURE		Yes			
SOLENOID VALVE	38 TAG NO		BSOV-2134C , PSOV-2134C									83 PNEUMATIC CONNECTION		1/4" NPT		
	39 TYPE		3 Way									84 GAUGES		FILTER	Required	Required
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL		Will be finalized later					
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5		86 ANSI/FCI LEAKAGE CLASS		Required					
	42 MANUAL RESET		Yes									87 HYDRO PRESSURE		Required		
	43 Power Supply		24 VDC									88 FUNCTIONAL TEST		Required		
	44 Pnu. Connection		1/4" NPT									89				
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No									90				
	46 BLOCK RELAY		No									91 PASSIVE FIRE PROTECTION		No		
	47 QUICK EXHUST		Yes									92 API 6FA REQUIREMENTS		Yes		
	49 FILTER REGULATOR		Yes									93 SIL 3 REQUIREMENTS		Yes		
	50 VOLUME TANK		No									94 PARTIAL STROKING VALVE TEST		Yes		
51 MECHANICAL POSITION INDICATOR		Required									95					
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																

 NIS OC		تجهاد است و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 HIRGAN ENERGY 			
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تهیه کننده	نوع مدرک	سریال	نسخه	شماره صفحه: ۱۶ از ۳۸		
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02	
On-Off Valve											
TAG NO: BDV-2132A		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0011-D06 (1 of 3)				SERVICE: 2nd Stage Gas Compression Air Coolers			
FLUID STATE: VENT GAS		PHASE: GAS						AREA CLASSIFICATION: Zone2, IIB, T4			
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow	Min. Flow	Shut-Off
	1 FLOW RATE				kg/h		-		1414	-	-
	2 INLET PRESSURE				bar(g)		-		54.1 ~ 62	-	-
	3 OUTLET PRESSURE				bar(g)		-		54.1 ~ 62	-	-
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-	-	62.4
	5 INLET TEMPERATURE				°C		-		22 ~ 60	-	-
	6 DENSITY				kg/m3		-		59.63~ 1012	-	-
	7 VISCOSITY				CP		-		0.014 ~ 0.976	-	-
	8 VAPOR PRESSURE Pv				bar(a)		-		-	-	-
9 CRITICAL PRESSURE				bar(a)		-		94.65	-	-	
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		1 1/2"	40S		0		
			OUT			1 1/2"	40S				
	11 LINE NO.		GAS-111-0054A-FS00-1 1/2"-NP								
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/ Floating Type								
	13 SIZE		1 1/2"								
	14 MAX PRESS./TEMP.		As per PMS								
	15 MFR. & MODEL		Will be finalized later								
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M								
	17 LINER MATERIAL / ID		VTA								
	18 END CONNECTION		IN	1 1/2" /600#							
			OUT	1 1/2" /600#							
	19 FLG FACE FINISH		RF								
	20 END EXT.MATL		N/A								
	21 FLOW DIRECTION		(Note 18 in Page 4)								
	22 TYPE OF BONNET		Standard								
	23 LUBE & ISO VALVE		No								
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard				
25 ENTRY DESIGN		Top Entry									
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES									
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE			
	28 SIZE		RATED TRAVEL		VTA		VTA				
	29 CHARACTERISTICS		On/Off								
	30 BALANCED / UNBALANCED		BALANCED								
	31 RATED Cv		FL	XT	VTA		VTA		VTA		
	32 PLUG / BALL / DISK MATERIAL		316 SS								
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE			
	34 CAGE / GUIDE MATERIAL		VTA								
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS			
	36 LEAKAGE CLASS		ANSI Class VI								
37 VALVE STEM EXTENSION REQUIREMENT		YES									
SOLENOID VALVE	38 TAG NO		BSOV-2132A , PSOV-2132A								
	39 TYPE		3 Way								
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65				
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5				
	42 MANUAL RESET		Yes								
	43 Power Supply		24 VDC								
	44 Pmt. Connection		1/4" NPT								
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No								
	46 BLOCK RELAY		No								
	47 QUICK EXHUST		Yes								
	49 FILTER REGULATOR		Yes								
	50 VOLUME TANK		No								
51 MECHANICAL POSITION INDICATOR		Required									
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM											
(1) PMS: Piping material specification.											
(2) All material shall be suitable for minimum design metal temperature.											
(3) Shall be stated by vendor at quotation stage.											
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.											

 NIS OC		تکداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 شرکت توسعه و پارس			
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تهیهات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۱۷ از ۳۸	
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02	
On-Off Valve											
TAG NO: BDV-2132B		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0011-D06 (2 of 3)				SERVICE: 2nd Stage Gas Compression Air Coolers			
FLUID STATE: VENT GAS		PHASE: GAS						AREA CLASSIFICATION: Zone2, IIB, T4			
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off
	1 FLOW RATE					kg/h		-	1414	-	-
	2 INLET PRESSURE					bar(g)		-	54.1 ~ 62	-	-
	3 OUTLET PRESSURE					bar(g)		-	54.1 ~ 62	-	-
	4 DIFFERENTIAL PRESSURE					bar(g)		-	-	-	62.4
	5 INLET TEMPERATURE					°C		-	22 ~ 60	-	-
	6 DENSITY					kg/m3		-	59.63~ 1012	-	-
	7 VISCOSITY					CP		-	0.014 ~ 0.976	-	-
	8 VAPOR PRESSURE Pv					bar(a)		-	-	-	-
9 CRITICAL PRESSURE					bar(a)		-	94.65	-	-	
LINE	PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		1 1/2"	40S	0			
			OUT			1 1/2"	40S				
		LINE NO.		GAS-111-0054B-FS00-1 1/2"-NP							
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/ Floating Type								
	13 SIZE		1 1/2"								
	14 MAX PRESS./TEMP.		As per PMS								
	15 MFR. & MODEL		Will be finalized later								
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M								
	17 LINER MATERIAL / ID		VTA								
	18 END CONNECTION		IN	1 1/2" /600#							
			OUT	1 1/2" /600#							
	19 FLG FACE FINISH		RF								
	20 END EXT./MATL.		N/A								
	21 FLOW DIRECTION		(Note 18 in Page 4)								
	22 TYPE OF BONNET		Standard								
	23 LUBE & ISO VALVE		No								
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard				
25 ENTRY DESIGN		Top Entry									
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES									
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE			
	28 SIZE		RATED TRAVEL		VTA		VTA				
	29 CHARACTERISTICS		On/Off								
	30 BALANCED / UNBALANCED		BALANCED								
	31 RATED Cv		FL	XT	VTA		VTA		VTA		
	32 PLUG / BALL / DISK MATERIAL		316 SS								
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE			
	34 CAGE / GUIDE MATERIAL		VTA								
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS			
	36 LEAKAGE CLASS		ANSI Class VI								
37 VALVE STEM EXTENSION REQUIREMENT		YES									
SOLENOID VALVE	38 TAG NO		BSOV-2132B , PSOV-2132B								
	39 TYPE		3 Way								
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65				
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5				
	42 MANUAL RESET		Yes								
	43 Power Supply		24 VDC								
	44 Pmt. Connection		1/4" NPT								
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No								
	46 BLOCK RELAY		No								
	47 QUICK EXHUST		Yes								
	49 FILTER REGULATOR		Yes								
	50 VOLUME TANK		No								
51 MECHANICAL POSITION INDICATOR		Required									
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM											
(1) PMS: Piping material specification.											
(2) All material shall be suitable for minimum design metal temperature.											
(3) Shall be stated by vendor at quotation stage.											
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.											

 NIS OC		تجهیزات و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 شرکت توسعه و پارس			
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تهیه کننده	نوع مدرک	سریال	نسخه	شماره صفحه: ۱۸ از ۳۸		
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02		
On-Off Valve											
TAG NO: BDV-2132C		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0011-D06 (3 of 3)				SERVICE: 2nd Stage Gas Compression Air Coolers			
FLUID STATE: VENT GAS		PHASE: GAS						AREA CLASSIFICATION: Zone2, IIB, T4			
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off
	1 FLOW RATE					kg/h		-	1414	-	-
	2 INLET PRESSURE					bar(g)		-	54.1 ~ 62	-	-
	3 OUTLET PRESSURE					bar(g)		-	54.1 ~ 62	-	-
	4 DIFFERENTIAL PRESSURE					bar(g)		-	-	-	62.4
	5 INLET TEMPERATURE					°C		-	22 ~ 60	-	-
	6 DENSITY					kg/m3		-	59.63~ 1012	-	-
	7 VISCOSITY					CP		-	0.014 ~ 0.976	-	-
	8 VAPOR PRESSURE Pv					bar(a)		-	-	-	-
9 CRITICAL PRESSURE					bar(a)		-	94.65	-	-	
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		1 1/2"	40S	0			
			OUT			1 1/2"	40S				
	11 LINE NO.		GAS-111-0054C-FS00-1 1/2"-NP								
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/ Floating Type								
	13 SIZE		1 1/2"								
	14 MAX PRESS./TEMP.		As per PMS								
	15 MFR. & MODEL		Will be finalized later								
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M								
	17 LINER MATERIAL / ID		VTA								
	18 END CONNECTION		IN	1 1/2" /600#							
			OUT	1 1/2" /600#							
	19 FLG FACE FINISH		RF								
	20 END EXT./MATL.		N/A								
	21 FLOW DIRECTION		(Note 18 in Page 4)								
	22 TYPE OF BONNET		Standard								
	23 LUBE & ISO VALVE		No								
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard				
25 ENTRY DESIGN		Top Entry									
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		YES									
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE			
	28 SIZE		RATED TRAVEL		VTA		VTA				
	29 CHARACTERISTICS		On/Off								
	30 BALANCED / UNBALANCED		BALANCED								
	31 RATED Cv		FL	XT	VTA		VTA		VTA		
	32 PLUG / BALL / DISK MATERIAL		316 SS								
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE			
	34 CAGE / GUIDE MATERIAL		VTA								
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS			
	36 LEAKAGE CLASS		ANSI Class VI								
37 VALVE STEM EXTENSION REQUIREMENT		YES									
SOLENOID VALVE	38 TAG NO		BSOV-2132C , PSOV-2132C								
	39 TYPE		3 Way								
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65				
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5				
	42 MANUAL RESET		Yes								
	43 Power Supply		24 VDC								
	44 Pmt. Connection		1/4" NPT								
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No								
	46 BLOCK RELAY		No								
	47 QUICK EXHUST		Yes								
	49 FILTER REGULATOR		Yes								
	50 VOLUME TANK		No								
51 MECHANICAL POSITION INDICATOR		Required									
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM											
(1) PMS: Piping material specification.											
(2) All material shall be suitable for minimum design metal temperature.											
(3) Shall be stated by vendor at quotation stage.											
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.											

 NIS OC		تجهیزات و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 HIRGAN ENERGY 						
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۱۹ از ۳۸				
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02				
On-Off Valve														
TAG NO: BDV-2141		P&ID NO : BK-GCS-PEDCO-120-PR-PI-0012-D06			SERVICE: 2nd Stage Gas Compression Discharge Drum									
FLUID STATE: FLARE GAS		PHASE: GAS			AREA CLASSIFICATION: Zone2, IIB, T4									
SERVICE CONDITION	1	FLOW RATE					UNITS	Max Flow	Norm. Flow	Min. Flow	Shut-Off			
	2	INLET PRESSURE					kg/h		1825		-			
	3	OUTLET PRESSURE					bar(g)	53.9 ~ 62	53.9 ~ 62	53.9 ~ 62	-			
	4	DIFFERENTIAL PRESSURE					bar(g)	53.9 ~ 62	53.9 ~ 62	53.9 ~ 62	-			
	5	INLET TEMPERATURE					bar(g)	-	-	-	90			
	6	DENSITY					°C	21 ~ 59.89	21 ~ 59.89	21 ~ 59.89	-			
	7	VISCOSITY					kg/m3	59.17 ~ 1012	59.17 ~ 1012	59.17 ~ 1012	-			
	8	VAPOR PRESSURE Pv					CP	0.014 ~ 0.976	0.014 ~ 0.976	0.014 ~ 0.976	-			
	9	CRITICAL PRESSURE					bar(a)	3.25	3.25	3.25	-			
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	CORROSION ALLOWANCE (mm)	1 1/2" 160	3	ACTUATOR	53	TYPE		Single Acting , Spring Return			
	11	LINE NO.	OUT		1 1/2" 160			54	SIZE		VTA			
	GAS-111-0065-FN05-1 1/2"-PT							55	SPRING FAIL ACTION		Fail to Open			
	VALVE BODY & BONNET	12	TYPE			Full Bore Ball Valve/ Floating Type			56	MAX ALLOWABLE PRESSURE		VTA		
		13	SIZE			1 1/2"			57	MIN REQUIRES PRESSURE		VTA		
		14	MAX PRESS./TEMP.			As per PMS			58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g		
		15	MFR. & MODEL			Will be finalized later			59	BENCH RANGE		VTA		
		16	BODY / BONNET MATL			ASTM A216 Gr. WCB			60	TRAVELING TIME		5 S		
		17	LINER MATERIAL / ID			VTA			61	FUNCTION		On/Off		
		18	END CONNECTION	IN	1 1/2" /600#			62	LOCAL POSITION INDICATOR		Required			
19		FLG FACE FINISH	OUT	1 1/2" /600#			63	ACT. ORIENTATION		VTA				
20		END EXT./MATL.			N/A			64	HAND WHEEL TYPE		Decutchable side mounted			
21		FLOW DIRECTION			(Note 18 in Page 4)			65	ADJUSTABLE LIMIT STOP		No			
22		TYPE OF BONNET			Standard			66	INPUT SIGNAL		24VDC			
23		LUBE & ISO VALVE			No			67	MFR. & MODEL		Will be finalized later			
24		PACKING MATERIAL	PACKING TYPE		PTFE		Standard	POSITIONER	68	TYPE		N/A		
25		ENTRY DESIGN			Top Entry				69	MFR. & MODEL		Will be finalized later		
26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)			YES			70		ON INCR SIGNAL OUTPUT INCR / DECR		N/A			
TRIM	27	TRIM	TYPE	MATERIAL	VTA	316 SS+RPTFE		71	GAUGES		N/A			
	28	SIZE	RATED TRAVEL		VTA	VTA		72	CAM CHARACTERISTIC		N/A			
	29	CHARACTERISTICS			On/Off			73	AIR CONNECTION		N/A			
	30	BALANCED / UNBALANCED			BALANCED			74	TAG NO. :		BZSC-2110 / BZSO-2110			
	31	RATED Cv	FL	XT	VTA	VTA	VTA	LIMIT SWITCHES	75	TYPE	QUANTITY	Magnetically operated "REED" contacts	2	
	32	PLUG / BALL / DISK MATERIAL	316 SS						76	CONTACTS / RATING		110V DC , 10A		
	33	SEAT	TYPE	MATERIAL	Soft Seat	RPTFE			77	ACTUATION POINT		Fully Open/Close		
	34	CAGE / GUIDE MATERIAL			VTA				78	ENCLOSURE MATERIAL		Die Cast Amulium		
	35	STEM	TYPE	MATERIAL	Anti-Blow Out	316 SS			79	WEATHER PROTECTION		IP-65		
	36	LEAKAGE CLASS			ANSI Class VI				80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4	ISO M20 × 1.5	
37	VALVE STEM EXTENSION REQUIREMENT			YES			81		MFR. & MODEL		Will be finalized later			
SOLENOID VALVE	38	TAG NO			BSOV-2141			AIR SET	82	SET PRESSURE		Yes		
	39	TYPE			3 Way				83	PNEUMATIC CONNECTION		1/4" NPT		
	40	BODY MATERIAL			WEATHER IP.		AISI 316 S.S		IP-65	84	GAUGES	FILTER	Required	Required
	41	ELE. CERTIFICATE			ELE. CONNECTION		EEx "d" ,IIB T4	ISO M20 x 1.5	TEST	85	MFR. & MODEL		Will be finalized later	
	42	MANUAL RESET			Yes			86		ANSI/FCI LEAKAGE CLASS		Required		
	43	Power Supply			24 VDC			87		HYDRO PRESSURE		Required		
	44	Pnu. Connection			1/4" NPT			88		FUNCTIONAL TEST		Required		
SPECIAL / ACCESS.	45	FUSIBLE LEAKAGE			No			FIRE PROOF DESIGN	89					
	46	BLOCK RELAY			No				90					
	47	QUICK EXHUST			Yes				91	PASSIVE FIRE PROTECTION		No		
	48	FILTER REGULATOR			Yes				92	API 6FA REQUIREMENTS		Yes		
	49	VOLUME TANK			No				93	SIL 3 REQUIREMENTS		Yes		
	50	MECHANICAL POSITION INDICATOR			Required				94	PARTIAL STROKING VALVE TEST		Yes		
	51								95					
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NIS OC		تکه‌داشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 				
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۲۱ از ۳۸		
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02			
On-Off Valve												
TAG NO: XV-2112		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0004-D06 (2 of 2)				SERVICE: Slug Catcher System				
FLUID STATE: PROCESS GAS		PHASE: GAS						AREA CLASSIFICATION: Zone2, IIB, T4				
SERVICE CONDITION	ITEM			UNITS			Max Flow		Norm. Flow		Min. Flow	Shut-Off
	1 FLOW RATE			Kg/H			7873.8		7158.0		2505.3	-
	2 INLET PRESSURE			bar(g)			18.5		18.5		18.5	-
	3 OUTLET PRESSURE			bar(g)			18.5		18.5		18.5	-
	4 DIFFERENTIAL PRESSURE			bar(g)			-		-		-	47.7
	5 INLET TEMPERATURE			°C			15.2~ 32.0		15.2~ 32.0		15.2~ 32.0	-
	6 DENSITY			kg/m3			715		715		715	-
	7 VISCOSITY			CP			0.58		0.58		0.58	-
	8 VAPOR PRESSURE Pv			bar(a)			6.487		6.487		6.487	-
9 CRITICAL PRESSURE			bar(a)			78		78		78	-	
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		4"	40	6				
			OUT			4"	40					
	11 LINE NO.		CDH-112-0015-CN07.4"-PT									
VALVE BODY & BONNET	12 TYPE			Full Bore Ball Valve/Trunnion Mounted								
	13 SIZE			4"								
	14 MAX PRESS./TEMP.			As per PMS								
	15 MFR. & MODEL			Will be finalized later								
	16 BODY / BONNET MATL			ASTM A216 Gr. WCB								
	17 LINER MATERIAL /ID			VTA								
	18 END CONNECTION		IN	4"/300#								
			OUT	4"/300#								
	19 FLG FACE FINISH			RF								
	20 END EXT./MATL.			N/A								
	21 FLOW DIRECTION			(Note 18 in Page 4)								
	22 TYPE OF BONNET			Standard								
	23 LUBE & ISO VALVE			No								
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard					
25 ENTRY DESIGN			Top Entry									
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)			YES									
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE				
	28 SIZE		RATED TRAVEL		VTA		VTA					
	29 CHARACTERISTICS			On/Off								
	30 BALANCED / UNBALANCED			BALANCED								
	31 RATED Cv		FL	XT		VTA		VTA		VTA		
	32 PLUG / BALL / DISK MATERIAL			316 SS								
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE				
	34 CAGE / GUIDE MATERIAL			VTA								
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS				
	36 LEAKAGE CLASS			ANSI Class VI								
SOLENOID VALVE	37 VALVE STEM EXTENSION REQUIREMENT			YES								
	38 TAG NO			PSOV-2110								
	39 TYPE			3 Way								
	40 BODY MATERIAL		WEATHER IP.		AIS1 316 S.S		IP-65					
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5					
	42 MANUAL RESET			Yes								
	43 Power Supply			24 VDC								
	44 Pnu. Connection			1/4" NPT								
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE			No								
	46 BLOCK RELAY			No								
	47 QUICK EXHUST			Yes								
	49 FILTER REGULATOR			Yes								
	50 VOLUME TANK			Yes								
	51 MECHANICAL POSITION INDICATOR			Required								
	52 MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE			Yes								
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												

 NIS OC		تکده‌داشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 					
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۳۸ از ۳۳			
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02				
On-Off Valve													
TAG NO: XV-2121B		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0006-D06 (2 of 3)				SERVICE: 1st Stage Gas Compression Suction Drums					
FLUID STATE: PROCESS GAS		PHASE:		GAS				AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	ITEM			UNITS			Max Flow		Norm. Flow		Min. Flow	Shut-Off	
	1	FLOW RATE			kg/h			9530.4		8664.0		3032.4	-
	2	INLET PRESSURE			bar(g)			5.1		5.1		5.1	-
	3	OUTLET PRESSURE			bar(g)			5.1		5.1		5.1	-
	4	DIFFERENTIAL PRESSURE			bar(g)			-		-		-	18.2
	5	INLET TEMPERATURE			°C			19.02 ~ 36.92		19.02 ~ 36.92		19.02 ~ 36.92	-
	6	DENSITY			kg/m3			5.56 ~ 5.96		5.56 ~ 5.96		5.56 ~ 5.96	-
	7	VISCOSITY			CP			0.011		0.011		0.011	-
	8	VAPOR PRESSURE Pv			bar(a)			167.7		167.7		167.7	-
9	CRITICAL PRESSURE			bar(a)			94.65		94.65		94.65	-	
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	CORROSION ALLOWANCE (mm)	8"	60	6	53	TYPE		Single Acting, Spring Return		
	11	LINE NO.	OUT		8"	60		54	SIZE		VTA		
VALVE BODY & BONNET				GAS-111-0026B-AN27-8"-PT			ACTUATOR	55	SPRING FAIL ACTION		Fail to Close		
								56	MAX ALLOWABLE PRESSURE		VTA		
								57	MIN REQUIRES PRESSURE		VTA		
								58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g		
								59	BENCH RANGE		VTA		
								60	TRAVELING TIME		9 S		
								61	FUNCTION		On/Off		
								62	LOCAL POSITION INDICATOR		Required		
								63	ACT. ORIENTATION		VTA		
								64	HAND WHEEL TYPE		Clutchable side mounted		
								65	ADJUSTABLE LIMIT STOP		Yes		
								66	INPUT SIGNAL		24VDC		
								67	MFR. & MODEL		Will be finalized later		
								68	TYPE		N/A		
TRIM				PTFE			POSITIONER	69	MFR. & MODEL		Will be finalized later		
				Standard				70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A		
				Top Entry				71	GAUGES		N/A		
				YES				72	CAM CHARACTERISTIC		N/A		
				NACE REQUIREMENTNACE (MR-0175/ISO 15156)				73	AIR CONNECTION		N/A		
				VTA				74	TAG NO. :		BZSC-2110 / BZSO-2110		
				VTA				75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2	
				VTA				76	CONTACTS / RATING		110V DC , 10A		
				VTA				77	ACTUATION POINT		Fully Open/Close		
				VTA				78	ENCLOSURE MATERIAL		Die Cast Amuluminum		
SOLENOID VALVE				PTFE			LIMIT SWITCHES	79	WEATHER PROTECTION		IP-65		
				Soft Seat				80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 x 1.5	
				VTA				81	MFR. & MODEL		Will be finalized later		
				ANSI Class VI				82	SET PRESSURE		Yes		
				YES				83	PNEUMATIC CONNECTION		1/4" NPT		
				3 Way				84	GAUGES	FILTER	Required	Required	
				AISI 316 S.S				85	MFR. & MODEL		Will be finalized later		
				EEx "d", IIB T4				86	ANSI/FCI LEAKAGE CLASS		Required		
SPECIAL / ACCESS.				EEx "d", IIB T4			TEST	87	HYDRO PRESSURE		Required		
				ISO M20 x 1.5				88	FUNCTIONAL TEST		Required		
				Yes									
				Yes									
				Yes									
				Yes									
				Required									
				Yes									
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM													
(1) PMS: Piping material specification.													
(2) All material shall be suitable for minimum design metal temperature.													
(3) Shall be stated by vendor at quotation stage.													
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.													

 NIS OC		تکده‌داشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 				
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸		پروژه	بسته کاری	صادر کننده	تهیه‌ات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۳۸ از ۲۴		
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02			
On-Off Valve												
TAG NO: XV-2121C		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0006-D06 (3 of 3)				SERVICE: 1st Stage Gas Compression Suction Drums				
FLUID STATE: PROCESS GAS		PHASE:		GAS				AREA CLASSIFICATION: Zone2, IIB, T4				
SERVICE CONDITION	ITEM						UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off
	1 FLOW RATE						kg/h		9530.4	8664.0	3032.4	-
	2 INLET PRESSURE						bar(g)		5.1	5.1	5.1	-
	3 OUTLET PRESSURE						bar(g)		5.1	5.1	5.1	-
	4 DIFFERENTIAL PRESSURE						bar(g)		-	-	-	18.2
	5 INLET TEMPERATURE						°C		19.02 ~ 36.92	19.02 ~ 36.92	19.02 ~ 36.92	-
	6 DENSITY						kg/m3		5.56 ~ 5.96	5.56 ~ 5.96	5.56 ~ 5.96	-
	7 VISCOSITY						CP		0.011	0.011	0.011	-
	8 VAPOR PRESSURE Pv						bar(a)		167.7	167.7	167.7	-
9 CRITICAL PRESSURE						bar(a)		94.65	94.65	94.65	-	
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		8" 60	6					
	11 LINE NO.		OUT			8" 60						
						GAS-111-0026C-AN07-8"-PT						
VALVE BODY & BONNET	12 TYPE						Full Bore Ball Valve/Trunnion Mounted					
	13 SIZE						8"					
	14 MAX PRESS./TEMP.						As per PMS					
	15 MFR. & MODEL						Will be finalized later					
	16 BODY / BONNET MATL						ASTM A216 Gr. WCB					
	17 LINER MATERIAL /ID						VTA					
	18 END CONNECTION		IN			8"/300#						
			OUT			8"/300#						
	19 FLG FACE FINISH						RF					
	20 END EXT./MATL.						N/A					
	21 FLOW DIRECTION						(Note 18 in Page 4)					
	22 TYPE OF BONNET						Standard					
23 LUBE & ISO VALVE						No						
24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard						
25 ENTRY DESIGN						Top Entry						
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)						YES						
TRIM	27 TRIM		TYPE	MATERIAL		VTA	316 SS+PTFE					
	28 SIZE		RATED TRAVEL		VTA	VTA						
	29 CHARACTERISTICS						On/Off					
	30 BALANCED / UNBALANCED						BALANCED					
	31 RATED Cv		FL	XT		VTA	VTA	VTA				
	32 PLUG / BALL / DISK MATERIAL						316 SS					
	33 SEAT		TYPE	MATERIAL		Soft Seat	PTFE					
	34 CAGE / GUIDE MATERIAL						VTA					
	35 STEM		TYPE	MATERIAL		Anti-Blow Out	316 SS					
	36 LEAKAGE CLASS						ANSI Class VI					
37 VALVE STEM EXTENSION REQUIREMENT						YES						
SOLENOID VALVE	38 TAG NO		PSOV-2121C, ESOV-2121C									
	39 TYPE		3 Way									
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S	IP-65						
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4	ISO M20 x 1.5						
	42 MANUAL RESET						Yes					
	43 Power Supply						24 VDC					
	44 Pnu. Connection						1/4" NPT					
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE						No					
	46 BLOCK RELAY						No					
	47 QUICK EXHUST						Yes					
	49 FILTER REGULATOR						Yes					
	50 VOLUME TANK						Yes					
	51 MECHANICAL POSITION INDICATOR						Required					
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE						Yes					
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM												
(1) PMS: Piping material specification.												
(2) All material shall be suitable for minimum design metal temperature.												
(3) Shall be stated by vendor at quotation stage.												
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												

 NIS OC		تکده‌داشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 				
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۲۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۳۸ از ۲۵		
BK		GCS	PEDCO	120	IN	DT	0010	D02	D02			
On-Off Valve												
TAG NO: XV-2122A		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0006-D06 (1 of 3)				SERVICE: 1st Stage Gas Compression Suction Drums				
FLUID STATE: PROCESS GAS		PHASE:		GAS				AREA CLASSIFICATION: Zonec2, IIB, T4				
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off	
	1	FLOW RATE					kg/h	-	10000	-	-	
	2	INLET PRESSURE					bar(g)	-	4.9	-	-	
	3	OUTLET PRESSURE					bar(g)	-	4.9	-	-	
	4	DIFFERENTIAL PRESSURE					bar(g)	-	-	-	13.9	
	5	INLET TEMPERATURE					°C	-	36.78	-	-	
	6	DENSITY					kg/m3	-	998.5	-	-	
	7	VISCOSITY					CP	-	0.69	-	-	
	8	VAPOR PRESSURE Pv					bar(a)	0.61	0.61	0.61	-	
9	CRITICAL PRESSURE					bar(a)	221.3	221.3	221.3	-		
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	CORROSION ALLOWANCE (mm)	2"	10S	0	53	TYPE		Single Acting, Spring Return	
	11	LINE NO.	OUT		2"	10S		54	SIZE		VTA	
VALVE BODY & BONNET	CDH-112-0021A-AS00-2"-NP							55	SPRING FAIL ACTION		Fail to Close	
	12	TYPE			Full Bore Ball Valve/Trunnion Mounted			56	MAX ALLOWABLE PRESSURE		VTA	
	13	SIZE			2"			57	MIN REQUIRES PRESSURE		VTA	
	14	MAX PRESS./TEMP.			As per PMS			58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g	
	15	MFR. & MODEL			Will be finalized later			59	BENCH RANGE		VTA	
	16	BODY / BONNET MATL			ASTM A351 GR.CF3M			60	TRAVELING TIME		5 S	
	17	LINER MATERIAL /ID			VTA			61	FUNCTION		On/Off	
	18	END CONNECTION	IN	2"/300#			62	LOCAL POSITION INDICATOR		Required		
	19	FLG FACE FINISH	OUT	2"/300#			63	ACT. ORIENTATION		VTA		
	20	END EXT./MATL.			N/A			64	HAND WHEEL TYPE		Clutchable side mounted	
	21	FLOW DIRECTION			(Note 18 in Page 4)			65	ADJUSTABLE LIMIT STOP		Yes	
	22	TYPE OF BONNET			Standard			66	INPUT SIGNAL		24VDC	
	23	LUBE & ISO VALVE			No			67	MFR. & MODEL		Will be finalized later	
	24	PACKING MATERIAL		PACKING TYPE		PTFE		68	TYPE		N/A	
25	ENTRY DESIGN			Top Entry			69	MFR. & MODEL		Will be finalized later		
26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)			No			70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A		
TRIM	27	TRIM	TYPE	MATERIAL	VTA		71	GAUGES		N/A		
	28	SIZE	RATED TRAVEL		VTA		72	CAM CHARACTERISTIC		N/A		
	29	CHARACTERISTICS			On/Off			73	AIR CONNECTION		N/A	
	30	BALANCED / UNBALANCED			BALANCED		74	TAG NO. :		BZSC-2110 / BZSO-2110		
	31	RATED Cv	FL	XT	VTA	VTA	VTA	75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2
	32	PLUG / BALL / DISK MATERIAL			316 SS			76	CONTACTS / RATING		110V DC , 10A	
	33	SEAT	TYPE	MATERIAL	Soft Seat			77	ACTUATION POINT		Fully Open/Close	
	34	CAGE / GUIDE MATERIAL			VTA			78	ENCLOSURE MATERIAL		Die Cast Amulimum	
	35	STEM	TYPE	MATERIAL	Anti-Blow Out		316 SS	79	WEATHER PROTECTION		IP-65	
	36	LEAKAGE CLASS			ANSI Class VI			80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 x 1.5
SOLENOID VALVE	37	VALVE STEM EXTENSION REQUIREMENT			YES			81	MFR. & MODEL		Will be finalized later	
	38	TAG NO			PSOV-2122A , ESOV-2122A			82	SET PRESSURE		Yes	
	39	TYPE			3 Way			83	PNEUMATIC CONNECTION		1/4" NPT	
	40	BODY MATERIAL		WEATHER IP.		AISI 316 S.S		84	GAUGES	FILTER	Required	Required
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		85	MFR. & MODEL		Will be finalized later	
	42	MANUAL RESET			Yes			86	ANSI/FCI LEAKAGE CLASS		Required	
SPECIAL / ACCESS.	43	Power Supply			24 VDC			87	HYDRO PRESSURE		Required	
	44	Pnu. Connection			1/4" NPT			88	FUNCTIONAL TEST		Required	
	45	FUSIBLE LEAKAGE			No							
	46	BLOCK RELAY			No							
	47	QUICK EXHUST			Yes							
	48	FILTER REGULATOR			Yes							
49	VOLUME TANK			Yes								
50	MECHANICAL POSITION INDICATOR			Required								
51	MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE			Yes								
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.												

 NIS OC		تکده‌داشت و افزایش تولید میدان نفتی بینک سطح الارض						 HIRGAN ENERGY		 TS				
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۲۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۳۸ از ۳۸				
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02				
On-Off Valve														
TAG NO: XV-2131A		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D06 (1 of 3)					SERVICE: 2nd Stage Gas Compression Suction Drums					
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4					
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE				kg/h		-		10000		-		-	
	2 INLET PRESSURE				bar(g)		-		18.1		-		-	
	3 OUTLET PRESSURE				bar(g)		-		18.1		-		-	
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		30.3	
	5 INLET TEMPERATURE				°C		-		59.88		-		-	
	6 DENSITY				kg/m3		-		981.1		-		-	
	7 VISCOSITY				CP		-		0.496		-		-	
	8 VAPOR PRESSURE Pv				bar(a)		-		3.23		-		-	
9 CRITICAL PRESSURE				bar(a)		221.5		221.5		221.5		-		
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		2"	10S		0					
			OUT			2"	10S							
11 LINE NO.		CDH-111-0023A-CS00-2"-NP												
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/Trunnion Mounted											
	13 SIZE		2"											
	14 MAX PRESS./TEMP.		As per PMS											
	15 MFR. & MODEL		Will be finalized later											
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M											
	17 LINER MATERIAL /ID		VTA											
	18 END CONNECTION	IN		2"/300#										
		OUT		2"/300#										
	19 FLG FACE FINISH		RF											
	20 END EXT./MATL.		N/A											
	21 FLOW DIRECTION		(Note 18 in Page 4)											
	22 TYPE OF BONNET		Standard											
	23 LUBE & ISO VALVE		No											
	24 PACKING MATERIAL		PACKING TYPE		PTFE								Standard	
25 ENTRY DESIGN		Top Entry												
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		No												
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+RPTFE						
	28 SIZE		RATED TRAVEL		VTA		VTA							
	29 CHARACTERISTICS		On/Off											
	30 BALANCED / UNBALANCED		BALANCED											
	31 RATED Cv		FL	XT		VTA		VTA		VTA				
	32 PLUG / BALL / DISK MATERIAL		316 SS											
	33 SEAT		TYPE	MATERIAL		Soft Seat		RPTFE						
	34 CAGE / GUIDE MATERIAL		VTA											
	35 STEM		TYPE	MATERIAL		Anti-Blow Out		316 SS						
	36 LEAKAGE CLASS		ANSI Class VI											
37 VALVE STEM EXTENSION REQUIREMENT		YES												
SOLENOID VALVE	38 TAG NO		PSOV-2131A , ESOV-2131A											
	39 TYPE		3 Way											
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65							
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5							
	42 MANUAL RESET		Yes											
	43 Power Supply		24 VDC											
	44 Pnu. Connection		1/4" NPT											
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No											
	46 BLOCK RELAY		No											
	47 QUICK EXHUST		Yes											
	49 FILTER REGULATOR		Yes											
	50 VOLUME TANK		Yes											
	51 MECHANICAL POSITION INDICATOR		Required											
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes											
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM														
(1) PMS: Piping material specification.														
(2) All material shall be suitable for minimum design metal temperature.														
(3) Shall be stated by vendor at quotation stage.														
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.														

 NIS OC		تکده‌داشت و افزایش تولید میدان نفتی بینک سطح الارض						 							
شماره پیمان: ۰۵۳ - ۰۷۳ - ۰۹۲۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۲۹ از ۳۸					
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02					
On-Off Valve															
TAG NO: XV-2131B		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D06 (2 of 3)					SERVICE: 2nd Stage Gas Compression Suction Drums						
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4						
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow	Shut-Off			
	1	FLOW RATE				kg/h		-	10000		-	-			
	2	INLET PRESSURE				bar(g)		-	18.1		-	-			
	3	OUTLET PRESSURE				bar(g)		-	18.1		-	-			
	4	DIFFERENTIAL PRESSURE				bar(g)		-	-		-	30.3			
	5	INLET TEMPERATURE				°C		-	59.88		-	-			
	6	DENSITY				kg/m3		-	981.1		-	-			
	7	VISCOSITY				CP		-	0.496		-	-			
	8	VAPOR PRESSURE Pv				bar(a)		-	3.23		-	-			
9	CRITICAL PRESSURE				bar(a)		-	221.5		221.5		221.5	-		
LINE	10	PIPE LINE SIZE & SCHEDULE	IN	CORROSION ALLOWANCE (mm)	2"	10S	0	53	TYPE		Single Acting, Spring Return				
	11	LINE NO.	OUT		2"	10S		54	SIZE		VTA				
VALVE BODY & BONNET					CDH-111-0023B-CS00-2"-NP				55	SPRING FAIL ACTION		Fail to Close			
	12	TYPE				Full Bore Ball Valve/Trunnion Mounted				56	MAX ALLOWABLE PRESSURE		VTA		
	13	SIZE				2"				57	MIN REQUIRES PRESSURE		VTA		
	14	MAX PRESS./TEMP.				As per PMS				58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g		
	15	MFR. & MODEL				Will be finalized later				59	BENCH RANGE		VTA		
	16	BODY / BONNET MATL				ASTM A351 GR.CF3M				60	TRAVELING TIME		5 S		
	17	LINER MATERIAL /ID				VTA				61	FUNCTION		On/Off		
	18	END CONNECTION	IN			2"/300#		62	LOCAL POSITION INDICATOR		Required				
	19	FLG FACE FINISH				RF				63	ACT. ORIENTATION		VTA		
	20	END EXT./MATL.				N/A				64	HAND WHEEL TYPE		Clutchable side mounted		
	21	FLOW DIRECTION				(Note 18 in Page 4)				65	ADJUSTABLE LIMIT STOP		Yes		
	22	TYPE OF BONNET				Standard				66	INPUT SIGNAL		24VDC		
	23	LUBE & ISO VALVE				No				67	MFR. & MODEL		Will be finalized later		
	24	PACKING MATERIAL		PACKING TYPE		PTFE		Standard		68	TYPE		N/A		
25	ENTRY DESIGN				Top Entry				69	MFR. & MODEL		Will be finalized later			
26	NACE REQUIREMENTNACE (MR-0175/ISO 15156)				No				70	ON INCR SIGNAL OUTPUT INCR / DECR		N/A			
TRIM	27	TRIM	TYPE	MATERIAL	VTA		316 SS+RPTFE		71	GAUGES		N/A			
	28	SIZE	RATED TRAVEL		VTA		VTA		72	CAM CHARACTERISTIC		N/A			
	29	CHARACTERISTICS				On/Off				73	AIR CONNECTION		N/A		
	30	BALANCED / UNBALANCED				BALANCED				74	TAG NO. :		BZSC-2110 / BZSO-2110		
	31	RATED Cv	FL	XT	VTA		VTA		VTA		75	TYPE	QUANTITY	Magnetically operated 'REED' contacts	2
	32	PLUG / BALL / DISK MATERIAL				316 SS				76	CONTACTS / RATING		110V DC , 10A		
	33	SEAT	TYPE	MATERIAL		Soft Seat		RPTFE		77	ACTUATION POINT		Fully Open/Close		
	34	CAGE / GUIDE MATERIAL				VTA				78	ENCLOSURE MATERIAL		Die Cast Amulimum		
	35	STEM	TYPE	MATERIAL		Anti-Blow Out		316 SS		79	WEATHER PROTECTION		IP-65		
	36	LEAKAGE CLASS				ANSI Class VI				80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d", IIB T4	ISO M20 × 1.5	
SOLENOID VALVE	37	VALVE STEM EXTENSION REQUIREMENT				YES				81	MFR. & MODEL		Will be finalized later		
	38	TAG NO				PSOV-2131B, ESOV-2131B				82	SET PRESSURE		Yes		
	39	TYPE				3 Way				83	PNEUMATIC CONNECTION		1/4" NPT		
	40	BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		84	GAUGES	FILTER	Required	Required	
	41	ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		85	MFR. & MODEL		Will be finalized later		
	42	MANUAL RESET				Yes				86	ANSI/FCI LEAKAGE CLASS		Required		
SPECIAL / ACCESS.	43	Power Supply				24 VDC				87	HYDRO PRESSURE		Required		
	44	Pnu. Connection				1/4" NPT				88	FUNCTIONAL TEST		Required		
	45	FUSIBLE LEAKAGE				No									
	46	BLOCK RELAY				No									
	47	QUICK EXHUST				Yes									
	49	FILTER REGULATOR				Yes									
50	VOLUME TANK				Yes										
51	MECHANICAL POSITION INDICATOR				Required										
52	MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE				Yes										
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM															
(1) PMS: Piping material specification.															
(2) All material shall be suitable for minimum design metal temperature.															
(3) Shall be stated by vendor at quotation stage.															
(4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.															

 NIS OC		تکده‌داشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 			
شماره پیمان: ۰۵۳ - ۰۷۳ - ۰۹۲۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۳۸ از ۳۰	
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02	
On-Off Valve											
TAG NO: XV-2131C		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0009-D06 (3 of 3)					SERVICE: 2nd Stage Gas Compression Suction Drums		
FLUID STATE: PROCESS GAS		PHASE:		GAS					AREA CLASSIFICATION: Zone2, IIB, T4		
SERVICE CONDITION	ITEM					UNITS		Max Flow	Norm. Flow	Min. Flow	Shut-Off
	1 FLOW RATE					kg/h		-	10000	-	-
	2 INLET PRESSURE					bar(g)		-	18.1	-	-
	3 OUTLET PRESSURE					bar(g)		-	18.1	-	-
	4 DIFFERENTIAL PRESSURE					bar(g)		-	-	-	30.3
	5 INLET TEMPERATURE					°C		-	59.88	-	-
	6 DENSITY					kg/m3		-	981.1	-	-
	7 VISCOSITY					CP		-	0.496	-	-
	8 VAPOR PRESSURE Pv					bar(a)		-	3.23	-	-
9 CRITICAL PRESSURE					bar(a)		221.5	221.5	221.5	-	
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)	2" 10S	0	53 TYPE Single Acting, Spring Return				
			OUT		2" 10S		54 SIZE VTA				
11 LINE NO.		CDH-111-0023C-CS00-2"-NP					55 SPRING FAIL ACTION Fail to Close				
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/Trunnion Mounted			56 MAX ALLOWABLE PRESSURE VTA					
	13 SIZE		2"			57 MIN REQUIRES PRESSURE VTA					
	14 MAX PRESS./TEMP.		As per PMS			58 AVAILABLE AIR SUPPLY PRESSURE MAX/NOR/MIN: 10/7/3 bar-g					
	15 MFR. & MODEL		Will be finalized later			59 BENCH RANGE VTA					
	16 BODY / BONNET MATL		ASTM A351 GR.CF3M			60 TRAVELING TIME 5 S					
	17 LINER MATERIAL /ID		VTA			61 FUNCTION On/Off					
	18 END CONNECTION	IN	2"/300#			62 LOCAL POSITION INDICATOR Required					
		OUT	2"/300#			63 ACT. ORIENTATION VTA					
	19 FLG FACE FINISH		RF			64 HAND WHEEL TYPE Clutchable side mounted					
	20 END EXT./MATL.		N/A			65 ADJUSTABLE LIMIT STOP Yes					
	21 FLOW DIRECTION		(Note 18 in Page 4)			66 INPUT SIGNAL 24VDC					
	22 TYPE OF BONNET		Standard			67 MFR. & MODEL Will be finalized later					
	23 LUBE & ISO VALVE		No			68 TYPE N/A					
	24 PACKING MATERIAL		PACKING TYPE	PTFE		Standard	69 MFR. & MODEL Will be finalized later				
25 ENTRY DESIGN		Top Entry			70 ON INCR SIGNAL OUTPUT INCR / DECR N/A						
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		No			71 GAUGES N/A						
TRIM	27 TRIM	TYPE	MATERIAL	VTA		316 SS+RPTFE	72 CAM CHARACTERISTIC N/A				
	28 SIZE	RATED TRAVEL		VTA		VTA	73 AIR CONNECTION N/A				
	29 CHARACTERISTICS		On/Off			74 TAG NO. : BZSC-2110 / BZSO-2110					
	30 BALANCED / UNBALANCED		BALANCED			75 TYPE QUANTITY Magnetically operated 'REED' contacts 2					
	31 RATED Cv	FL	XT	VTA		VTA	VTA	76 CONTACTS / RATING 110V DC , 10A			
	32 PLUG / BALL / DISK MATERIAL		316 SS			77 ACTUATION POINT Fully Open/Close					
	33 SEAT	TYPE	MATERIAL	Soft Seat		RPTFE	78 ENCLOSURE MATERIAL Die Cast Amulimum				
	34 CAGE / GUIDE MATERIAL		VTA			79 WEATHER PROTECTION IP-65					
	35 STEM	TYPE	MATERIAL	Anti-Blow Out		316 SS	80 ELEC. CERTIFICATE ELEC. CONNECTION EEx "d", IIB T4 ISO M20 x 1.5				
	36 LEAKAGE CLASS		ANSI Class VI			81 MFR. & MODEL Will be finalized later					
37 VALVE STEM EXTENSION REQUIREMENT		YES			82 SET PRESSURE Yes						
SOLENOID VALVE	38 TAG NO		PSOV-2131C, ESOV-2131C			83 PNEUMATIC CONNECTION 1/4" NPT					
	39 TYPE		3 Way			84 GAUGES FILTER Required Required					
	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S	IP-65	85 MFR. & MODEL Will be finalized later				
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4	ISO M20 x 1.5	86 ANSI/FCI LEAKAGE CLASS Required				
	42 MANUAL RESET		Yes			87 HYDRO PRESSURE Required					
	43 Power Supply		24 VDC			88 FUNCTIONAL TEST Required					
44 Pnu. Connection		1/4" NPT									
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No								
	46 BLOCK RELAY		No								
	47 QUICK EXHUST		Yes								
	49 FILTER REGULATOR		Yes								
	50 VOLUME TANK		Yes								
	51 MECHANICAL POSITION INDICATOR		Required								
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		Yes								
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.											



NISOC

تکهداشت و افزایش تولید میدان نفتی بینک
 سطح الارض

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

Data Sheets For ON/OFF & Shutdown Valves




شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۳۸

پروژه بسته کاری صادرکننده تسهیلات رشته نوع مدارک سریال نسخه

BK GCS PEDCO 120 IN DT 0010 D02

شماره صفحه: ۳۸ از ۳۸

D02

TAG NO: XV-2143

P&ID NO: BK-GCS-PEDCO-120-PR-PI-0012-D06

SERVICE: Slug Catcher System

FLUID STATE: PROCESS GAS

PHASE: GAS

AREA CLASSIFICATION: Zone2, IIB, T4

NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM

(1) PMS: Piping material specification.
 (2) All material shall be suitable for minimum design metal temperature.
 (3) Shall be stated by vendor at quotation stage.
 (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.

 NIS OC		تکده‌داشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves						 													
شماره پیمان: ۰۵۳ - ۰۷۳ - ۹۰۲۸		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	شماره صفحه: ۳۸ از ۳۷											
		BK	GCS	PEDCO	120	IN	DT	0010	D02	D02											
On-Off Valve																					
TAG NO: XV-2271		P&ID NO :		BK-GCS-PEDCO-120-PR-PI-0022-D06					SERVICE: Fuel Gas System												
FLUID STATE: Fuel Gas		PHASE: GAS					AREA CLASSIFICATION: Zonec2, IIB, T4														
SERVICE CONDITION	ITEM				UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off								
	1 FLOW RATE				kg/h		-		603.15		-		-								
	2 INLET PRESSURE				bar(g)		-		4.9		-		-								
	3 OUTLET PRESSURE				bar(g)		-		4.9		-		-								
	4 DIFFERENTIAL PRESSURE				bar(g)		-		-		-		18.2								
	5 INLET TEMPERATURE				°C		-		18.88~ 36.7		-		-								
	6 DENSITY				kg/m3		-		842~ 852		-		-								
	7 VISCOSITY				CP		-		0.6934 ~ 1.03		-		-								
	8 VAPOR PRESSURE Pv				bar(a)		-		0.6		-		-								
9 CRITICAL PRESSURE				bar(a)		-		221.3		-		-									
LINE	10 PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		2" 160		6		53 TYPE			Single Acting, Spring Return								
			OUT	2" 160						54 SIZE			VTA								
	11 LINE NO.		CDH-112-0039-AN07-2"-PT					55 SPRING FAIL ACTION			Fail to Close										
VALVE BODY & BONNET	12 TYPE				Full Bore Ball Valve/Trunnion Mounted		ACTUATOR			56 MAX ALLOWABLE PRESSURE			VTA								
	13 SIZE				2"					57 MIN REQUIRES PRESSURE			VTA								
	14 MAX PRESS./TEMP.				As per PMS					58 AVAILABLE AIR SUPPLY PRESSURE			MAX/NOR/MIN: 10/7/3 bar-g								
	15 MFR. & MODEL				Will be finalized later					59 BENCH RANGE			VTA								
	16 BODY / BONNET MATL				ASTM A216 Gr. WCB					60 TRAVELING TIME			5 S								
	17 LINER MATERIAL /ID				VTA					61 FUNCTION			On/Off								
	18 END CONNECTION		IN	2" /300#		62 LOCAL POSITION INDICATOR				Required											
			OUT	2" /300#		63 ACT. ORIENTATION				VTA											
	19 FLG FACE FINISH				RF					64 HAND WHEEL TYPE			Clutchable side mounted								
	20 END EXT./MATL.				N/A					65 ADJUSTABLE LIMIT STOP			Yes								
	21 FLOW DIRECTION				(Note 18 in Page 4)					66 INPUT SIGNAL			24VDC								
	22 TYPE OF BONNET				Standard					67 MFR. & MODEL			Will be finalized later								
	23 LUBE & ISO VALVE				No					POSITIONER			68 TYPE			N/A					
	24 PACKING MATERIAL		PACKING TYPE		PTFE								Standard		69 MFR. & MODEL			Will be finalized later			
25 ENTRY DESIGN				Top Entry		70 ON INCR SIGNAL OUTPUT INCR / DECR			N/A												
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)				No		71 GAUGES			N/A												
TRIM	27 TRIM		TYPE	MATERIAL		VTA		316 SS+PTFE		72 CAM CHARACTERISTIC			N/A								
	28 SIZE		RATED TRAVEL		VTA		VTA		73 AIR CONNECTION			N/A									
	29 CHARACTERISTICS				On/Off		LIMIT SWITCHES			74 TAG NO. :			BZSC-2110 / BZSO-2110								
	30 BALANCED / UNBALANCED				BALANCED					75 TYPE		QUANTITY		Magnetically operated 'REED' contacts		2					
	31 RATED Cv		FL	XT		VTA				VTA		VTA		76 CONTACTS / RATING		110V DC , 10A					
	32 PLUG / BALL / DISK MATERIAL				316 SS					77 ACTUATION POINT			Fully Open/Close								
	33 SEAT		TYPE	MATERIAL		Soft Seat				PTFE		78 ENCLOSURE MATERIAL			Die Cast Amulimum						
	34 CAGE / GUIDE MATERIAL				VTA					79 WEATHER PROTECTION			IP-65								
	35 STEM		TYPE	MATERIAL		Anti-Blow Out				316 SS		80 ELEC. CERTIFICATE			ELEC. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		
	36 LEAKAGE CLASS				ANSI Class VI					AIR SET			81 MFR. & MODEL			Will be finalized later					
37 VALVE STEM EXTENSION REQUIREMENT				YES		82 SET PRESSURE							Yes								
38 TAG NO				PSOV-2271, ESOV-2271		83 PNEUMATIC CONNECTION							1/4" NPT								
39 TYPE		3 Way		84 GAUGES			FILTER		Required				Required								
SOLENOID VALVE	40 BODY MATERIAL		WEATHER IP.		AISI 316 S.S		IP-65		85 MFR. & MODEL			Will be finalized later									
	41 ELE. CERTIFICATE		ELE. CONNECTION		EEx "d", IIB T4		ISO M20 x 1.5		TEST			86 ANSI/FCI LEAKAGE CLASS		Required							
	42 MANUAL RESET				Yes		87 HYDRO PRESSURE					Required									
	43 Power Supply				24 VDC		88 FUNCTIONAL TEST					Required									
	44 Pnu. Connection				1/4" NPT																
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE				No																
	46 BLOCK RELAY				No																
	47 QUICK EXHUST				Yes																
	49 FILTER REGULATOR				Yes																
	50 VOLUME TANK				Yes																
	51 MECHANICAL POSITION INDICATOR				Required																
	52 MANUAL/PNEUMATIC BYPASS VALVE FOR SOLENOID VALVE				Yes																
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																					

 NIS OC				نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک Data Sheets For ON/OFF & Shutdown Valves								 					
شماره پیمان: ۹۰۳۸ - ۰۷۳ - ۰۵۳				نسخه: ۰۰۱۰ سریال: ۰۰۱۰ رشته: IN تهیلات: 120 صادرکننده: PEDCO بسته کاری: GCS پروژه: BK								شماره صفحه: ۳۸ از ۳۸					
On-Off Valve																	
TAG NO: XV-2301				P&ID NO : BK-GCS-PEDCO-120-SA-PI-0001-D01(1 of 2)				SERVICE: Fire Water System									
FLUID STATE: FIRE WATER				PHASE: GAS				AREA CLASSIFICATION: Zone2, IIB, T4									
SERVICE CONDITION	ITEM							UNITS		Max Flow		Norm. Flow		Min. Flow		Shut-Off	
	1 FLOW RATE							kg/h		-		29910		-		-	
	2 INLET PRESSURE							bar(g)		-		1		-		-	
	3 OUTLET PRESSURE							bar(g)		-		0.95		-		-	
	4 DIFFERENTIAL PRESSURE							bar(g)		-		0.05		-		-	
	5 INLET TEMPERATURE							°C		55		AMB		5		-	
	6 DENSITY							kg/m3		-		997		-		-	
	7 VISCOSITY							CP		-		0.81		-		-	
	8 VAPOR PRESSURE Pv									-		-		-		-	
9 CRITICAL PRESSURE							bar(a)		-		-		-		-		
LINE	PIPE LINE SIZE & SCHEDULE		IN	CORROSION ALLOWANCE (mm)		3" 40	3		ACTUATOR	53	TYPE		Single Acting, Spring Return				
			OUT			3" 40				54	SIZE		VTA				
	LINE NO.		FWA-112-0007-AN04-3"-PT							55	SPRING FAIL ACTION		Fail to Close				
VALVE BODY & BONNET	12 TYPE		Full Bore Ball Valve/Trunnion Mounted							56	MAX ALLOWABLE PRESSURE		VTA				
	13 SIZE		3"							57	MIN REQUIRES PRESSURE		VTA				
	14 MAX PRESS./TEMP.		As per PMS							58	AVAILABLE AIR SUPPLY PRESSURE		MAX/NOR/MIN: 10/7/3 bar-g				
	15 MFR. & MODEL		Will be finalized later							59	BENCH RANGE		VTA				
	16 BODY / BONNET MATL		ASTM A216 Gr. WCB							60	TRAVELING TIME		5 S				
	17 LINER MATERIAL / ID		VTA							61	FUNCTION		On/Off				
	18 END CONNECTION	IN	3" /300#		3				62	LOCAL POSITION INDICATOR		Required					
		OUT	3" /300#						63	ACT. ORIENTATION		VTA					
	19 FLG FACE FINISH		RF						64	HAND WHEEL TYPE		Clutchable side mounted					
	20 END EXT./MATL.		N/A						65	ADJUSTABLE LIMIT STOP		Yes					
	21 FLOW DIRECTION		(Note 18 in Page 4)						66	INPUT SIGNAL		24VDC					
	22 TYPE OF BONNET		Standard						67	MFR. & MODEL		Will be finalized later					
	23 LUBE & ISO VALVE		No						POSITIONER	68	TYPE		N/A				
	24 PACKING MATERIAL		PACKING TYPE		PTFE		Standard			69	MFR. & MODEL		Will be finalized later				
25 ENTRY DESIGN		Top Entry						70		ON INCR SIGNAL OUTPUT INCR / DECR		N/A					
26 NACE REQUIREMENTNACE (MR-0175/ISO 15156)		No						71		GAUGES		N/A					
TRIM	27 TRIM	TYPE	MATERIAL		VTA		316 SS+PTFE		LIMIT SWITCHES	74	TAG NO. :		BZSC-2110 / BZSO-2110				
	28 SIZE	RATED TRAVEL		VTA		VTA		75		TYPE	QUANTITY	Magnetically operated 'REED' contacts		2			
	29 CHARACTERISTICS		On/Off							76	CONTACTS / RATING		110V DC , 10A				
	30 BALANCED / UNBALANCED		BALANCED						77	ACTUATION POINT		Fully Open/Close					
	31 RATED Cv	FL	XT		VTA		VTA VTA		78	ENCLOSURE MATERIAL		Die Cast Amulimum					
	32 PLUG / BALL / DISK MATERIAL		316 SS						79	WEATHER PROTECTION		IP-65					
	33 SEAT	TYPE	MATERIAL		Soft Seat		PTFE		80	ELEC. CERTIFICATE	ELEC. CONNECTION	EEx "d" ,IIB T4		ISO M20 × 1.5			
	34 CAGE / GUIDE MATERIAL		VTA						81	MFR. & MODEL		Will be finalized later					
SOLENOID VALVE	35 STEM	TYPE	MATERIAL		Anti-Blow Out		316 SS		AIR SET	82	SET PRESSURE		Yes				
	36 LEAKAGE CLASS		ANSI Class VI							83	PNEUMATIC CONNECTION		1/4" NPT				
	37 VALVE STEM EXTENSION REQUIREMENT		YES							84	GAUGES	FILTER	Required Required				
	38 TAG NO	PSOV-2301						TEST	85	MFR. & MODEL		Will be finalized later					
	39 TYPE	3 Way							86	ANSI/FCI LEAKAGE CLASS		Required					
	40 BODY MATERIAL	WEATHER IP.		AISI 316 S.S		IP-65			87	HYDRO PRESSURE		Required					
	41 ELE. CERTIFICATE	ELE. CONNECTION		EEx "d" ,IIB T4		ISO M20 x 1.5			88	FUNCTIONAL TEST		Required					
	42 MANUAL RESET	Yes															
43 Power Supply	24 VDC																
44 Pnu. Connection	1/4" NPT																
SPECIAL / ACCESS.	45 FUSIBLE LEAKAGE		No														
	46 BLOCK RELAY		No														
	47 QUICK EXHUST		Yes														
	49 FILTER REGULATOR		Yes														
	50 VOLUME TANK		Yes														
	51 MECHANICAL POSITION INDICATOR		No														
52 MANUALPNEUMATIC BYPASS VALVE FOR SOLENOID VALVE		No															
NOTE: VTA : VENDOR TO ADVISE AT BIDDING STAGE VTC: VENDOR TO CONFIRM (1) PMS: Piping material specification. (2) All material shall be suitable for minimum design metal temperature. (3) Shall be stated by vendor at quotation stage. (4) Manual Reset to be consider for all Emergency Shut off solenoids as per P&ID.																	