

احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

1 A 1 P - 7 V - 7 A .

CALCULATION NOTE FOR DC CHARGER SYSTEM								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	PEDCO	120	EL	CN	0005	D04	

شماره صفحه: ۱ از ۱۱

طرح نگهداشت و افزایش تولید ۲۷ مخزن

CALCULATION NOTE FOR DC CHARGER SYSTEM

نگهداشت و افزایش تولید میدان نفتی بینک

D01	DEC. 2021	IFC	H.Shakiba	M.Fakharian	M.Mehrshad	
D02	May.2022 JAN.2022	IFA	H.Shakiba	M.Fakharian	M.Mehrshad	
D03	May.2023	AFD IFA	H.Shakiba H.Shakiba	M.Fakharian M.Fakharian	A.M.Mohseni M.Mehrshad	
D04	Oct.2024	AFD	H.Shakiba	M.Fakharian	M.Sadeghian	

Class: 2 Client Doc. Number: F0Z-709011

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for Client Review
AB-A: As-Built —Approved



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



	شماره پیمان:
• 24 - • 14 -	- 9114

CALCULATION NOTE FOR DC CHARGER SYSTEM							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	CN	0005	D04

شماره صفحه: ۲ از ۱۱

REVISION RECORD SHEET

				• • • • • • • • • • • • • • • • • • • •	=VISI0
PAGE	D00	D01	D02	D03	D04
1	Х	Χ	Χ	X	Х
2	Х	Х	X	X	Χ
3	X	X			
4	Х				
5	Х	X			
6	X	Х	Χ		X
7		Χ	Х		Х
8	X	Х	Χ		Χ
9	Х	Χ	Χ		Χ
10	X	X	Χ		Х
11	X	Х	Χ	Х	
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40	1				
41					
42	1				
43	1				
44	1				
45	1				
46	1				
47	<u> </u>				
48	†				
49	†				
50	1				

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65	-		-		
66	-		1		
67					
68					
69					
70					
71					
72 73					
74					
75 76					
77			1		
78					
79					
80					
81					
82					
83					
84					
85					
86					
87	1		1		
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

 $\cdot \Delta T - \cdot VT - 91 \Lambda F$

CALCULATION NOTE FOR DC CHARGER SYSTEM							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	CN	0005	D04

شماره صفحه: ۳ از ۱۱

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL DEFINITION	4
3.0	SCOPE	5
4.0	REFERENCES AND STANDARDS	5
5.0	DC SIZING ASSUMPTIONS	5
6.0	DC-UPS LOAD PROFILE	
7.0	DC LOAD CONSUMPTION	6
8.0	DC DUTY CYCLE	
8.1 8.2	BATTERY DUTY CYCLE DIAGRAM (110 VDC)	7 8
9.0	NUMBER OF CELL CALCULATION	8
9.1 9.2 9.3	110 VDC CELL 24 VDC CELL BATTERY SELECTION	8 8
10.0	BATTERY CHARGER RATING	
11.0	CONCLUSION*	
12.0	REFERENCE DOCUMENTS	10
13.0	ATTACHMENTS	11



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



ان:	پيما	ره	شما

۰۵۳	_	٠	٧٣	_	٩	١	۸۴	
ω ,			, ,		•	•	•••	

CALCULATION NOTE FOR DC CHARGER SYSTEM							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	GCS	PEDCO	120	EL	CN	0005	D04

شماره صفحه: ۴ از ۱۱

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

2.0 GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development – Surface Fcilities; New

Gas Compressor Station

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR: Joint Venture of : Hirgan Energy – Design & Inspection

(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by COMPANY (in writing) for the

inspection of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

· ۵۳ - · ۷۳ - 9114

CALCULATION NOTE FOR DC CHARGER SYSTEM								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	PEDCO	120	EL	CN	0005	D04	

شماره صفحه: ۵ از ۱۱

3.0 SCOPE

This specification describes the practices that shall be employed and the Standards that will be required to be met for the DC charger and batteries.

4.0 REFERENCES AND STANDARDS

- IEC 60478 Stabilized Power Supplies, DC Output

- IEC 60623 Secondary Cells and Batteries Containing Alkaline or Other non-acid

electrolytes Vented Nickel-Cadmium Prismatic Rechargeable Single Cells

- IEC 60947 LV Switchgear & Control Gear

· IEEE 1115 IEEE Recommended Practice for Sizing Nickel-Cadmium Batteries for

Stationary Applications

- IPS-E-EL-100 Engineering Standard for Electrical System Design

- IPS-M-EL-174 Material and Equipment Standard for Battery & Battery Charger

5.0 DC SIZING ASSUMPTIONS

The bases of the DC charger calculation performed in this document are summarized as below:

Table 1: DC UPS Characteristics for Compressor Station

Item	110 VDC	24 VDC (F&G)
Input AC Voltage	440/400/380 V=10%	440/400/380 V=10%
Input AC Voltage frequency	50Hz=5%	50Hz=5%
DC system Nominal Voltage	110 VDC	24 VDC
DC system Voltage Limits	104.89 VDC~151.8 VDC	22.88 VDC ~ 29.28 VDC
Overall Aging Factor	1.1	1.1
Design Margin Factor	1.1	1.1
Battery Backup Time	8 hours	24 hours + 5 Min.
Battery Configuration	2 x 50%	2 x 50%
Charger Configuration	2 x 100%	2 x 100%
Battery Type	Ni-Cd (SBLE)	Ni-Cd (SBLE)
Nominal Cell Voltage	1.2 V/Cell	1.2 V/Cell
Float Charge Voltage	1.42 V/Cell	1.42 V/Cell
Fast Charge Voltage	1.47 V/Cell	1.46 V/Cell
End Cell Voltage	1.14 V/Cell	1.144 V/Cell



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



ن:	پيما	اره	شم
----	------	-----	----

۰۵۳	- * Y \mathcal{V} -	۹۱۸۴ –

CALCULATION NOTE FOR DC CHARGER SYSTEM								
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه							
BK	GCS	PEDCO	120	EL	CN	0005	D04	

شماره صفحه: ۶ از ۱۱

D04

6.0 DC-UPS LOAD PROFILE

The load list of 110 VDC is in excel attached file, but the 24VDC F&G which has been derived from instrument discipline is as follow (I&C Power Consumption Sammary-BK-GCS-PEDCO-120-IN-0007)

Table 2: F&G Power Consumption

Item	Description	Unit Power Consumption (KW)	With 20% Spare Capacity	Back Up Time
1	F&G System	1.52	1.824	24 hr
2	F&G System	2.73	3.276	5 min

7.0 DC LOAD CONSUMPTION

DC load consists of the power absorbed by control and protection devices in switchgear cabinets. These devices include CB spring charging motors, CB closing coils, CB opening coils, contactors coils, auxiliary relays, protective relays, signal lamps, annunciations and transducers.

Depending on the type of a feeder, different equipment in the relevant cubicle shall be used. The DC power consumed in each cubicle equals to sum of the consumptions.

Where more than one equipment of the same type is used, a utilization factor is applied to consider the non-simultaneous operation. In, DC load of each substation is calculated in normal status and during plant shutdown. For each switchgear, there is a separate table comprising of all available types of feeders. Here also, a utilization factor is used for non-simultaneous operation of the similar feeders.

Total DC consumption of the switchgear is calculated at the bottom of the table.

Table 1 shows a summary of total DC consumption of each substation during normal and shutdown status.



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



	پیمان:	شماره
• 24 - • 44 -	۹۱۸'	۴

D04

CALCULATION NOTE FOR DC CHARGER SYSTEM								
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه							
BK	GCS	PEDCO	120	EL	CN	0005	D04	

شماره صفحه: ۷ از ۱۱

Table 3: Total DC Consumption


DC System Tag / Substation	Time	Consumption in N	lormal Condition	Consumption i Cond	
		Power (W)	Current (A)	Power (W)	Current (A)
DC-UPS-01 (110 VDC)	8 HR	2090	19	5090	46.27
DC-UPS-02 (24 VDC)	24 HR	912	38	-	-
DC-01-3-02 (24 VDC)	5 Min	1638	68.25	-	-

Note: According to Item 5.3 of IPS-M-EI-174(2), the DC power supply shall consist of two similar thyristor type chargers each rated for 100 percent of rated load, two battery banks each rated for 50 percent of the rated load and one DC distribution panel. Therefore to calculate the capacity of battery bank half of demand load shall be considered.

8.0 DC DUTY CYCLE

Duty cycle diagram shows the total load at any time during the cycle is an aid in the analysis of the duty cycle. This profile obtained based on two consecutives tripping of the switchgears. The details of the consumptions have been listed in separate Tables of Attachment #1 for 110 VDC. In addition, for 24 VDC calculation, 5000 W for 24 hours has been assumed.

8.1 Battery duty cycle diagram (110 VDC)





احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



	شماره پیمان:
۰۵۳ - ۰۷۳	·- 9114

CALCULATION NOTE FOR DC CHARGER SYSTEM							
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه						
BK	GCS	PEDCO	120	EL	CN	0005	D04

شماره صفحه: ۸ از ۱۱

8.2 Battery Duty Cycle Diagram (F&G)



9.0 NUMBER OF CELL CALCULATION

9.1 110 VDC Cell

With considering nominal DC link voltage equal to 110VDC, the No. of cells is obtaining as below:

No. of cells = Nominal DC Link Voltage /

= 110 / 1.2 ~ 92 cells Final discharge cell voltage

Note: The exact number depends on the type of battery and will be determined by the vendor.

9.2 24 VDC Cell

With considering nominal DC link voltage equal to 24VDC, the No. of cells is obtaining as below:

No. of cells = Nominal DC Link Voltage /

= 24 / 1.2 ~ 20 cells Final discharge cell voltage

Note: The exact number depends on the type of battery and will be determined by the vendor.

9.3 Battery Selection

Overall rating of batteries shall be so chosen to provide the load current for 8 hours for 2 x 50% load, according to project specification.

To calculate battery capacity, the following equation can be used.

$$C = \frac{1}{L} \sum_{i=1}^{n} I_i T_i \tag{1}$$

Where:

C: Rated Capacity (Ah)



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



پیمان:	ره	شما
--------	----	-----

CALCULATION NOTE FOR DC CHARGER SYSTEM								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	PEDCO	120	EL	CN	0005	D04	

شماره صفحه: ۹ از ۱۱

L: Maintenance Factor (1) (Design Margin 1.1 & Aging Factor 1.1)

n: Number of Loads

I: Load Current

T: Battery Discharge Time

In equation (1), T is the same 8 hours for 50% loads in the substations. Therefore,

$$C = \frac{1}{L}(T) \sum_{i=1}^{n} I_i \tag{2}$$

Where, "I" is the total current consumption. Using the values of the battery duty cycle diagram presented in clause 7 which obtained from attachment #1, battery capacity can be calculated. The battery calculation is performed by using SAFT BaSics Software. According to the results presented in Attachment #2 & #4, the selected battery set for 110 VDC system is 2 sets of (1×92×SBLE 325 AH). In addition according to Attachment #4, the selected battery set for 24 VDC system is 2 sets of (1×20×SBLE 1400 AH)



The stand proposal proposed in Attachment #3 & #5, also. It should be noted that this is only typical and the battery layout can be configured according to the space which is available using the adopted stand structure.

10.0 BATTERY CHARGER RATING

In the worst condition when batteries are completely discharged, the charger should provide power for DC loads and charge the batteries at the same time. The total size of battery chargers shall meet the following equation:

Battery charger current (A) = IC=LLc+2*(0.2*C5)

Where:

C5: battery Capacity (ampere-hours)

LLc: Continuous Dc Load (in amperes)

Battery Charger Rating for 110 VDC is as follow:

According to table 3, LLc is 2×19=38

 $IC=LLc+2*(0.2*C_5)$

 $IC = 38+2 \times (0.2\times325) = 168$

 $PC = 168x104.89 / 0.9 \sim 20 \text{ Kw}$



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



ماره پیمان:	ث
۹۱۱۴ – ۲۷۰ – ۳۵۰	

CALCULATION NOTE FOR DC CHARGER SYSTEM								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	l
BK	GCS	PEDCO	120	EL	CN	0005	D04	

شماره صفحه: ۱۰ از ۱۱

Battery Charger Rating for 24 VDC is as follow:

According to table 3, LLc is 2x38=76

 $IC = 76+2 \times (0.2 \times 1400) = 636$

PC = 636x22.88 / 0.9~16.16 Kw



11.0 CONCLUSION*

Item	Charger			Battery	Inverter	
item	Configuration	Size	Config	Cell No.x Cap.	Config	Size
DC-UPS-01(110VDC)	2x100% (Redundant)	168 A	2x50%	2 x (92 x SBLE 325)	-	-
DC-UPS-02 (24 VDC)	2x100% (Redundant)	636 A	2x50%	1 x (20 x SBLE 1400)	-	-

^{*}Note: Final calculations shall be provided and/or verified by selected vendor as per type and characteristics of equipment.

12.0 REFERENCE DOCUMENTS

Document No.	Title			
BK-GNRAL-PEDCO-000-EL-SP-0005	Specification for DC Charger			
BK-GCS-PEDCO-120-EL-SL-0001	Electrical Overall Single Line Diagram			
BK-GCS-PEDCO-120-EL-SL-0002	LV Switchgear/MCC Single Line Diagram			
BK-GCS-PEDCO-120-EL-SL-0003	Existent MV Switchgear Expansion Single Line Diagram			
BK-GCS-PEDCO-120-IN-LI-0007	I&C Power Consumption Summary			



احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:

۹۱۸۴ – ۳۷۰ – ۳۵۰

CALCULATION NOTE FOR DC CHARGER SYSTEM								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	PEDCO	120	EL	CN	0005	D04	

شماره صفحه: ۱۱ از ۱۱

13.0 ATTACHMENTS

ATTACHMENT A- Native file of 110 VDC Calculation

ATTACHMENT B- Native file of 24 VDC Calculation

ATTACHMENT 1- 110 VDC Load Consumption List for Substation

ATTACHMENT 2- Battery & Stand Sizing Report for 110 VDC

ATTACHMENT 3- Battery Stand proposal for 110 VDC

ATTACHMENT 4- Battery Datasheet for 110 VDC

ATTACHMENT 5- I&C Power Consumption Summary

ATTACHMENT 6- Battery &Stand Sizing Report for 24 VDC

ATTACHMENT 7- Battery Stand proposal for 24 VDC

ATTACHMENT 8- Battery Datasheet for 24 VDC