



شماره پیمان:

پروژه

053 - 073 - 9184

PMR FOR ON/OFF & SHUTDOWN VALVES								
بسته کاری	صادركننده	نسخه سريال نوع مدرك رشته تسهيلات صادركننده						
PPL	PEDCO	320	IN	MR	0004	D01		

شماره صفحه: 1 از 18

طرح نگهداشت و افزایش تولید 27 مخزن

PMR FOR ON/OFF & SHUTDOWN VALVES

نگهداشت و افزایش تولید میدان نفتی بینک

D00 JU	V. 2024 L. 2023 Date	IFI IFI Purpose of Issue/Status	P.Hajisadeghi P.Hajisadeghi Prepared by:	M.Fakharian M.Fakharian Checked by:	M.Sadeghian A.M.Mohseni Approved by:	CLIENT Approval
		11.1	, ,			
D01 NO	V. 2024	IFI	P.Hajisadeghi	M.Fakharian	M.Sadeghian	

Class: 3 CLIENT Doc. Number: F0Z-708678

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for CLIENT Review
AB-A: As-Built —Approved





شماره پیمان:

053 - 073 - 9184

PMR FOR ON/OFI	& SHUTDOWN	VALVES
----------------	------------	--------

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
BK	PPL	PEDCO	320	ZI	MR	0004	D01

شماره صفحه: 2 از 18

REVISION RECORD SHEET

D00	D01	D02	D03	D04
Χ	Χ			
X	X			
X				
X	X			
X	X			
X	X			
X	X			
	Χ			
X				
X	Х			
X				
X	Х			
X	Χ			
Χ				
X				
-				
+ -				
+ -				
1				
+ -			-	
+				
+				
1				
 				
-				
+				
	X X X X X X X X X X X X X X X X X X X	X	X X X X X X X X X X X X X X X X X X X	X X X X X X X X X X X X X X X X X X X

PAGE	D00	D01	D02	D03	D04
66					
67 68					
69					
70					
71					
72 73					
74					
75					
<u>76</u>					
77 78					
79 79					
80					
81					
82 83					
84					
85					
86					
87					
88 89					
90					
91					
92					
93 94					
95					
96					
97					
98 99					
100					
101					
102					
103 104					
105					
106					
107					
108 109					
110					
111					
112					
113 114			1		
115					
116					
117					
118 119			1		
119					
121					
122					
123			1		
124 125					
126					
127	_				
128					
129 130					
130	<u> </u>	<u> </u>	<u> </u>		<u> </u>





ينك

شماره پیمان:

053 - 073 - 9184

	PMR FOR ON/OFF & SHUIDOWN VALVES						
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	BK PPL PEDCO 320 IN MR 0004 D01						

شماره صفحه: 3 از 18

CONTENTS

1.0	INTRODUCTION	4
2.0	GENERAL	5
3.0	REFERENCE / ATTACHED DOCUMENTS	5
4.0	SUBJECT OF THE SUPPLY	5
5.0	LIMITS OF SUPPLY	6
5.1	SCOPE OF SUPPLY	6
5.2	EXCLUSIONS	7
5.3	BATTERY LIMITS	8
6.0	INSPECTION AND TESTS	8
7.0	VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE	8
8.0	UNIT RESPONSIBILITY	8
9.0	GUARANTEE AND WARRANTY	8
10.0	DEVIATION	9
11.0	PRICE BREAKDOWN	9
ATTAC	CHMENT 1	11
11.1	LIST OF REFERENCE / APPLICABLE DOCUMENTS	11
ATTAC	CHMENT 2	12
11.2	VENDOR DOCUMENTS MIN. REQUIREMENT	12
ATTAC	CHMENT 3	17
11.3	DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION	17
ATTAC	CHMENT 4	18
11.4	ALTERNATIVES TO JOB SPECIFICATION	18





ينك

شماره پیمان:

053 - 073 - 9184

D01

	PMR FOR ON/OFF & SHUTDOWN VALVES							
پروژه	نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه							
BK	BK PPL PEDCO 320 IN MR 0004 D01							

شماره صفحه: 4 از 18

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

As a part of the Project, a New Gas Compressor Station (adjacent to existing Binak GCS) shall be constructed to gather of 15 MMSCFD (approx.) associated gases and compress & transfer them to Siahmakan GIS.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company (NISOC)

PROJECT: Binak Oilfield Development – Surface Facilities; Gas &

Gas-Condensate Pipelines

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR/PURCHSER: Joint Venture of: Hirgan Energy – Design & Inspection

(D&I) Companies

VENDOR: The firm or person who will fabricate the equipment or

material.

SUB VENDOR: The firm or person who will have a direct contract with

the Vendor or another Subvendor to perform a part or

parts of the Work

EXECUTOR: Executor is the party which carries out all or part of

construction and/or commissioning for the project.

THIRD PARTY INSPECTOR (TPI): The firm appointed by EPD/EPC CONTRACTOR (GC)

and approved by CLIENT (in writing) for the inspection

of goods.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD CONTRACTOR,

supplier or VENDOR.

MAY: Is used where a provision is completely discretionary.





شماره پیمان:

053 - 073 - 9184

	PMR FOR ON/OFF & SHUTDOWN VALVES								
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه								
BK	BK PPL PEDCO 320 IN MR 0004 D01								

شماره صفحه: 5 از 18

2.0 GENERAL

- This document presents the item material requisitions for Contractor's use as appropriate.
- This material requisition covers the requirements for the design, manufacturing, testing and supply of On/Off & Shutdown Valves as listed in part 5. All equipment/devices/items shall conform to this requisition and all specifications which have been mentioned in attachment 1 of this material requisition.

3.0 REFERENCE / ATTACHED DOCUMENTS

- **a.** Specified documents in attachment 1 shall be considered as a part of this material Requisition.
- **b.** All codes and standards which have been referenced in above mentioned specs shall be considered.
- **c.** In case of any conflict between the contents of this document or any discrepancy between this document and other project documents or reference standards, this issue must be reported to the CLIENT. The final decision in this situation will be made by CLIENT.
- d. Deviations

Any exceptions/clarifications to codes/standards and specifications listed in attachment 1 must be clearly stated in a separate dedicated section of the proposal in the format submitted in attachment 3.

The proposed deviations/comments list shall include as minimum:

- Reference for the involved specification, chapter and paragraph.
- Technical justification for the non-compliance.
- Detailed description of the proposed alternative.



If no exceptions or clarifications exist, either for the complete referenced document or an individual paragraph, The supplier VENDOR shall be considered to be in full compliance with the relevant document.

The supplier VENDOR may propose materials of equivalent or better quality compared to those indicated in the equipment data sheet. Even these cases shall be duly included/technically supported in the deviations/clarifications list.

4.0 SUBJECT OF THE SUPPLY



The supplier VENDOR shall supply On/Off & Shutdown Valves. The scope of supply is detailed at part 5. The supplier VENDOR shall include in the supply, all other equipment/devices/items not listed in part 5, but necessary for a good design and a safe operation, taking into account process data and installation conditions such as area classification and climatic conditions.





PMR شماره پیمان:

053 - 073 - 9184

PMR FOR ON/OFF & SHUTDOWN VALVES								
پروژه	نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه							
BK	BK PPL PEDCO 320 IN MR 0004 D01							

شماره صفحه: 6 از 18

The grade of shop assembly of the equipment/devices/items supplied shall be at maximum extent to facilitate site erection and pre-commissioning activities.

5.0 LIMITS OF SUPPLY



5.1 SCOPE OF SUPPLY

5.1.1 MAIN DESCRIPTION

The scope of supply includes 2 Nos. On/Off & Shutdown Valves. Main feature are as below:

- On/Off & Shutdown Valves, Full Bore Ball Valve.
- ACTUATOR
- Limit Switch
- Painting and coating (As per Specification for Painting)

Accessories such as solenoid valves, electrical position switches, pressure pilots, pneumatic relays, etc., shall be supplied and mounted by the valve Vendor.

Detail of supply is listed below:

No.	Item	Description
1	ESDVs	On/Off Valve, As Per Data Sheets for On/Off & Shutdown Valves (BK-PPL-PEDCO-320-IN-DT-0006)



The supplier VENDOR shall assume overall responsibility for the design, manufacture, assembly, test and performance of all equipment/devices/items supplied as indicated in this requisition. This shall include, but not be limited to:

- Resolve engineering issues relating to equipment/devices/items within the scope of supply.
- Provide detailed design and documentation of all equipment/devices/items and components within the scope of supply in accordance with attachment 2 of this document.
- Provide all necessary information documents in order to allow the contractor to erect, install and verify the proposed equipment/devices/items.
- · Implement a quality assurance plan
- The quality plan applied to the scope of supply shall include:
 - QA/QC organization and procedures that shall be submitted for approval.





ىىمان:	٠.١	شما
ىسى.	ار ت	ww

053 - 073 - 9184

	PMR FOR ON/OFF & SHUTDOWN VALVES									
پروژه	نسخه سریال نوع مدرک رشته تسهیلات صادرکننده بسته کاری پروژه									
BK	PPL	PEDCO	320	IN	MR	0004	D01			

شماره صفحه: 7 از 18

- Plan for HOLD points in the production process proposed to PURCHASER for witness or approval particular activities.
- Production schedule indicating main quality manufacturing processes, inspection and tests.
- Qualification of all personnel performing tests to be reviewed by the inspector
- The supplier VENDOR shall also provide the description of the following quality activities:
 - Sub The supplier VENDORS products quality
 - Quality check and identification of the materials and equipment entering in their manufacturing shop.
- Calibration of test instruments and equipment
- Provide detailed specifications and data sheets.

5.1.2 SPARE PARTS

- The Vendor shall provide certain quantities of consumable for the installation, precommissioning, commissioning, start-up and up to the end of the guarantee period.
- The quantities shall be estimated by Vendor and shall be based upon the Vendor's experience. The following two periods shall be taken into account:
 - Pre-commissioning and commissioning period where the consumption of consumable is greater
 - Normal use of the System
- The VENDOR shall provide lists of recommended spare parts, which shall include the original part numbers with prices for commissioning, start-up and two years operation. All spare parts shall be identified individually.
- Spare parts for commissioning and start-up; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&C-QC-SP-1).
- Spare parts for two years operation; a qualified and complete list based on PROJECT SPARE PART SUPPLY PROCEDURE (Doc. No. E&C-QC-SP-1).
- The VENDOR shall be able to provide spares back up and support for the plant life of at least 20 years.
- SPIR form shall be approved by CLIENT prior to procurement.

5.1.3 OTHER ITEMS

Name plate

5.2 EXCLUSIONS

No exclusion is applicable.







شماره پیمان:

053 - 073 - 9184

	PMR FOR ON/OFF & SHUTDOWN VALVES									
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه			
BK	PPL	PEDCO	320	N	MR	0004	D01			

شماره صفحه: 8 از 18

5.3 BATTERY LIMITS

No battery limit is applicable.

6.0 INSPECTION AND TESTS



The equipment shall be inspected and tested in accordance with the Inspection &Test plan (ITP) issued by the vendor and approved by the CLIENT and EPC/EPD CONTRACTOR before the award of the order. The Inspection & Test plan (ITP) shall be at least according to the Commodity Procurement and Manufacturing Inspection Instruction (Docs .Nos. ICE-EID-MI-SP01-Rev01), Inspection Level of Commodity and Equipment (Docs .Nos. ICE-EID-MI-SP02-Rev01) and Data Sheets. The vendor shall in any case conduct all the tests required by contractual documents, specifications, codes and standards, manufacturer standard quality system and keep the relevant documentation. All required manufacturing and function test/inspection also Factory Acceptance Test /Site Acceptance Test and Quality Assurance requirements shall be considered in vendor responsibility as per project specification.

7.0 VENDOR DOCUMENTATION REQUIREMENTS & SCHEDULE



- Vendor document shall be according to attachment 2 of this document.
 - All documents, preliminary or final, are to be stamped and signed by The supplier VENDOR.
- Failure in dispatch of the required documents shall cause the supply to be considered as unfulfilled.
- PURCHASER's approval does not relieve vendor, in any way, from his obligation to fulfill the requirements of the purchase order documents.
- All vendor drawings and documents shall be in English language.

All drawings and documents are to be identified as per clause 1 "GENERAL DEFINITION"

8.0 UNIT RESPONSIBILITY

VENDOR shall be responsible for the design, engineering, co-ordination, supply, delivery, testing, final check-out and satisfactory operation of the equipment/devices/items. The engineering coordination also includes responsibility for handing and expediting drawings.



Also VENDOR shall be responsible for ensuring that all relevant information and documentation is passed on the sub-The supplier VENDORS.

9.0 GUARANTEE AND WARRANTY

All material and Equipment/Devices/Items in VENDOR's scope of work/supply shall be guaranteed by VENDOR.





شماره پیمان:

053 - 073 - 9184

	PMR FOR ON/OFF & SHUTDOWN VALVES									
خه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری پروژه										
BK	PPL	PEDCO	320	IN	MR	0004	D01			

شماره صفحه: 9 از 18

The guarantee period shall be eighteen (18) months from the date of delivery or twelve (12) months from the installation date of each equipment/package at site

VENDOR shall guarantee the performance of supplied items.

VENDOR shall guarantee that the Equipment/Device/Item is suitable for the operating conditions herein specified, and that all materials and components are free from any defects; verifications of all calculations are in VENDOR's responsibility.

VENDOR shall unconditionally guarantee the materials and workmanship of all material and/or services. If, within the guarantee period, any defects occur which are due to faulty material and/or services included in his scope (design, manufacturing, inspection, testing, supply & etc.), VENDOR shall, at his own expense, repair or adjust the condition, or replace the material and/or services to the complete satisfaction of CLIENT's representative. These repairs, replacement or adjustments shall be made only at such time as will be least detrimental to the operation of the CLIENT's business.

VENDOR warrants promptly repairing or replacing the defective parts in the warranty period.

Vendor shall ensure a correct and safe operation of the unit, providing all safety protection Devices.

Vendor shall be responsible for the safe, reliable, continuous functioning of the Equipment/Devices/Items.

VENDOR is fully responsible for the design of package for correct and safe operation based on project requirement during package life time; therefore, VENDOR shall specify any documents/specifications which may be required for design, manufacture and finalizing of Equipment/Devices/Items to avoid any problems during the package operation at site before P.O; otherwise, VENDOR shall be hold responsible for any corresponding deviation from expectations from the Equipment/Devices/Items.

10.0 DEVIATION

D01

VENDOR's proposal shall be prepared in strict compliance with the requirements set forth in the relevant specifications of tender documents.

VENDOR shall include in his proposal the statement of compliance with the tender documents should VENDOR wish to submit exception to the requirements of tender documents. They shall be submitted for PURCHASER's approval.

VENDOR is responsible to specify all deviation clearly in related signed and stamped form. Otherwise, deviation form shall fill by clear conformation for compliance with the requirements by VENDOR.

11.0 PRICE BREAKDOWN

Breakdown price of following items shall be included in the proposal, as well as total price.





ىان:	ە بىد	شماره

053 - 073 - 9184

	PMR FOR ON/OFF & SHUTDOWN VALVES									
پروژه	نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه									
BK	PPL	PEDCO	320	IN	MR	0004	D01			

شماره صفحه: 10 از 18

- 1) Material and Fabrication for each Section Separately
- 2) Pre-commissioning & commissioning spare parts (E&C-QC-SP-1)
- 3) 2 years operational spare parts (E&C-QC-SP-1)
- 4) Packing & transportation





شماره پیمان:

053 - 073 - 9184

	PMR FOR ON/OFF & SHUTDOWN VALVES									
ه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه										
BK	PPL	PEDCO	320	IN	MR	0004	D01			

شماره صفحه: 11 از 18

ATTACHMENT 1

11.1 <u>LIST OF REFERENCE / APPLICABLE DOCUMENTS</u>



NI.	December 1 No	D	D	
No.	Document No.	Document Title	Rev.	
	Inst	trument		
1.	BK-PPL-PEDCO-320-IN-DC-0001	Instrument & Control System Design Criteria	D02	
2.	BK-GNRAL-PEDCO-000-IN-SP-0001	Specification for Instrumentation	D04	
3.	BK-GNRAL-PEDCO-000-IN-SP-0006	Specification For On-off /Shut Down Valves (ESDV/MOV)	D03	
4.	BK-PPL-PEDCO-320-IN-DG-0002	K-PPL-PEDCO-320-IN-DG-0002 Instrument Hook-up Diagram		
5.	B BK-PPL-PEDCO-320-IN-DT-0006	Data Sheets For ON/OFF & Shutdown Valves	D03	
	Pr	ocess		
6.	BK-GNRAL-PEDCO-000-PR-DC-0001	Process Design Criteria		
7.	BK-GNRAL-PEDCO-000-PR-DB-0001	Process Basis Of Design	D08	
8.	BK-PPL-PEDCO-320-PR-PI-0001	P&ID - Gas Pipeline (to Siahmakan G.I. Station)		
	Р	IPING		
9.	BK-PPL-PEDCO-320-PI-SP-0001	Piping Material Specification	D03	
10.	BK-PPL-PEDCO-320-PL-SP-0001	Pipeline Material Specification	D05	
11.	BK-GNRAL-PEDCO-000-PI-SP-0006	Specification For Painting	D04	
	G	eneral		
12.	ICE-EID-MI-SP01-Rev01	دستورالعمل بازرسی، خرید و ساخت کالا	D01	
13.	ICE-EID-MI-SP02-Rev01	دستورالعمل انتخاب سطح بازرسی کالا و تجهیزات	D01	
14.	E&C-QC-SP-1	دستورالعمل تامین قطعات یدکی راه اندازی وراهبری دو سالانه	D00	
15.	BK-GNRAL-PEDCO-000-QC-PR-0022	Specification For Final Data Book (FDB) Requirements	-	
16.	BK-GNRAL-PEDCO-000-QC-PR-0045	Packing, Marking, Transportation Procedure	-	





شماره پیمان:

پروژه

053 - 073 - 9184

PMR	PMR FOR ON/OFF & SHUTDOWN VALVES								
بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه			
ם	DEDCO	220	INI	MD	0004	D01			

شماره صفحه: 12 از 18

ATTACHMENT 2

11.2 <u>VENDOR DOCUMENTS MIN. REQUIREMENT</u>

		WITH BID	AFTER ORDERING			AT THE	
NO.	DESCRIPTION	Q./TYPE (1)	Q./TY PE (1)	DELIVERY DATE (2)	PURPO SE (3)	FINAL ISSUE	FINAL INSPECTION (4)
	MA	NAGEMEN	Т				
1	Vendor Document Index and Schedule	4N	(5)	2W	Α	(5)	Х
2	Organization Brief	4N	(5)	2W	I	(5)	
3	Schedule Level 1, 2, 3 & 4 showing Engineering, Procurement, Fabrication, Inspection, Testing, and Delivery Plan.	4N	(5)	3W	А	(5)	Х
4	Physically Progress Report (Every 2 Weeks))		(5)	2W	1	(5)	
5	Project Organization Chart	4N	(5)	2W	I	(5)	Х
6	Reference List	4N	(5)	2W	I	(5)	
7	7 Vendor Catalogue		(5)	2W	I	(5)	Х
		HSE					
8	HSE Procedure		(5)	4W	А	(5)	Х
	EN	GINEERIN	3				
9	Specifications/Data Sheets/ Actuator sizing (Completed)		(5)	4W	А	(5)	Х
10	Dimensional Outlines	4N	(5)	4W	Α	(5)	Х
11	Mounting Details		(5)	4W	А	(5)	Х
12	Schematic Wiring and Tubing Diagram	4N	(5)	4W	А	(5)	Х
13	Electric Power & Utility Consumption List		(5)	4W	А	(5)	Х
14	General Arrangement	4N	(5)	4W	А	(5)	Х
15	Detailed Dimensions of Cut- Outs		(5)	4W	А	(5)	Х
16	Parts/Material List	4N	(5)	4W	А	(5)	Х





شماره پیمان:

053 - 073 - 9184

PMR FOR ON/OFF & SHUTDOWN VALVES

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 PPL
 PEDCO
 320
 IN
 MR
 0004
 D01

شماره صفحه: 13 از 18

		WITH BID		AFTER OR	DERING		AT THE
NO.	DESCRIPTION	Q./TYPE (1)	Q./TY PE (1)	DELIVERY DATE (2)	PURPO SE (3)	FINAL ISSUE	FINAL INSPECTION (4)
17	Technical Description and Relevant Catalogues	4N	(5)	4W	А	(5)	Х
18	List of Deviations from the Specification and Data Sheets		(5)	4W	Α	(5)	
	PRO	CUREMEN	IT.				
19	List of Sub-Vendors (table giving: part of equipment, tag no., sub-vendor reference)(5.1.3)	4N	(5)	4W	А	(5)	
20	Unpriced copy of sub-orders	4N	(5)	4W	ı	-	
21	Packing Spec. / Shipping Schedule	4N	(5)	4W	I	-	
22	Weight List/ Shipping List	4N	(5)	4W	I	(5)	
23	Mechanical & Performance Guarantees	4N	(5)	4W	I	-	
	QUALITY, MAN	UFACTUR	ING, TE	STING			
24	Quality Assurance Manual /Quality Management System Certificate (according to latest rev. of ISO)		(5)	3W	А	(5)	
25	Preliminary Project Schedule		(5)	4W	I	-	
26	Weld and NDT Map		(5)	4W	I	(5)	Х
27	Surface Preparation and Painting Procedures		(5)	4W	1	(5)	X
28	Welding Procedure Specification (including repair procedures).		(5)	4W	I	(5)	Х
29	Welder Qualification Procedure		(5)	4W	I	(5)	Х
30	Fabrication Degree		(5)	4W	I	(5)	Х
31	Hydrostatic/Pneumatic Test Procedure		(5)	4W	I	(5)	Х
32	Quality Control Plan		(5)	4W	I	(5)	Х
33	Manufacturing, Test & Inspection Procedures	4N	(5)	4W	А	(5)	Х
34	Performance & Functional Test Procedure		(5)	4W	А	(5)	Х
35	Non-Destructive Testing/Examination Procedures		(5)	4W	Α	(5)	Х
36	Factory Acceptance Test (FAT) Procedure		(5)	4W	Α	(5)	Х





شماره پیمان:

پروژه

053 - 073 - 9184

PMR FOR ON/OFF & SHUTDOWN VALVES									
نسخه سریال نوع مدرک رشته تسهیلات صادر کننده بسته کاری									
PPL	PEDCO	320	IN	MR	0004	D01			

شماره صفحه: 14 از 18

			WITH AFTER ORDERING					
NO.	DESCRIPTION	Q./TYPE (1)	Q./TY PE (1)	DELIVERY DATE (2)	PURPO SE (3)	FINAL ISSUE	FINAL INSPECTION (4)	
37	Site Acceptance Test (SAT) Procedure		(5)	4W	A	(5)	X	
	D01 RECORDS, REP	ORTS & C	ERTIFIC	CATES				
38	Material Conformity Certificate	4N	(5)	4W	I	(5)	Х	
39	Testing Authority Approval Certificate		(5)	4W	I	(5)	Х	
40	Hazardous Area Certificates.		(5)	4W	I	(5)	Х	
41	Ingress Protection Certificate		(5)	4W	I	(5)	Х	
42	Conformity Certificates (subvendor/equipment)		(5)	4W	I	(5)	Х	
43	Material Certificates Identification Diagram. (cross-reference material location; certificates for critical components)		(5)	4W	I	(5)	Х	
44	Welding Procedure Qualification Record.		(5)	4W	I	(5)		
45	Welding Inspection Reports		(5)	4W	I	(5)		
46	Welder Qualification Records.		(5)	4W	I	(5)		
47	NDT Operator Qualifications		(5)	4W	I	(5)	Х	
48	Detailed NDT Reports		(5)	4W	Α	(5)		
49	Weld/ NDT Identification Diagram. (Cross-reference weld locations, WPS, welders, NDT reports).		(5)	4W	А	(5)	Х	
50	Hardness Test Reports		(5)	4W	Α	(5)	Х	
51	PWHT Charts & Reports, including calibration records of recorders (for each heat treatment)		(5)	4W	I	(5)	Х	
52	Pressure Test Reports / Certificates		(5)	4W	Α	(5)	Х	
53	FAT Test Report / Certificates	^	(5)	4W	Α	(5)		
54	SAT Test Report / Certificates	D01	(5)	4W	А	(5)		
55	Performance Test Report / Certificates		(5)	4W	Α	(5)	Х	
56	Material Test Certificates		(5)	4W	I	(5)	Х	
57	Calibration Curves of Control Equipment		(5)	4W	I	(5)	Х	
58	Calibration Test Certificates		(5)	4W	I	(5)	Х	





شماره پیمان:

053 - 073 - 9184

PMR FOR ON/OFF & SHUTDOWN VALVES

پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
BK	PPL	PEDCO	320	IN	MR	0004	D01

شماره صفحه: 15 از 18

		WITH BID	AFTER ORDERING			AT THE	
NO.	IO. DESCRIPTION		Q./TY PE (1)	DELIVERY DATE (2)	PURPO SE (3)	FINAL ISSUE	FINAL INSPECTION (4)
59	Surface Preparation & Coating Reports		(5)	4W	Α	(5)	
60	Hydrostatic / Pneumatic Testing Certificates		(5)	4W	I	(5)	Х
61	Welding Consumable Certificate		(5)	4W	I	(5)	Х
62	Test & Inspection Reports	4N	(5)	4W	А	(5)	
63	Rust Prevention Report		(5)	4W	Α	(5)	
64	Non-Conformities Report		(5)	4W	Α	(5)	
65	Letter of Conformity		(5)	4W	Α	(5)	
66	Monthly Progress Report		(5)	4W	Α	(5)	
	INS	TALLATIO	N				
67	Sub-Assembly Documentation		(5)	4W	А	(5)	
68	Sub-Assembly Drawings		(5)	4W	Α	(5)	
69	Erection/Installation Manual		(5)	4W	Α	(5)	
70	Name Plate Documents	4N	(5)	4W	Α	(5)	
71	Handling, Transportation & Storage Instructions	4N	(5)	4W	Α	(5)	
72	Unpacking & Inspection Instructions		(5)	4W	Α	(5)	
73	Preliminary Packing List		(5)	4W	Α	(5)	
74	Packing List		(5)	4W	Α	(5)	
	OPERATIO	N & MAINT	ENANC	E			
75	Operating Instructions		(5)	4W	Α	(5)	
76	Maintenance Instructions		(5)	4W	А	(5)	
77	Commissioning & Start-up Manual		(5)	4W	А	(5)	
78	List of Spare Parts Commissioning & Start-up	4N	(5)	4W	Α	(5)	
79	List of Spare Parts 2 Years Operation	4N	(5)	4W	Α	(5)	
80	List of Special Tools	4N	(5)	4W	Α	(5)	
81	Lube Oil Schedule		(5)	4W	Α	(5)	
82	Software Manual (incl. Troubleshooting)		(5)	4W	Α	(5)	





شماره پیمان:

053 - 073 - 9184

PMR	FOR ON/C	FF & SH	UTDO	WN VALVE	S	
						_

 نسخه
 سریال
 نوع مدر ک
 رشته
 تسهیلات
 صادر کننده
 بسته کاری
 پروژه

 BK
 PPL
 PEDCO
 320
 IN
 MR
 0004
 D01

شماره صفحه: 16 از 18

		WITH BID		AFTER OR	AT THE FINAL		
NO.	DESCRIPTION	Q./TYPE (1)	Q./TY PE (1)	DELIVERY DATE (2)	PURPO SE (3)	FINAL ISSUE	INSPECTION (4)
83	Consumables List		(5)	4W	Α	(5)	
84	Function Test Procedure		(5)	4W	А	(5)	Х
		OTHERS					
85	Vendor Final Book		(5)	4W	А	(5)	x
86	All others documents will be listed in the order						

NOTES:

- *** The electronic file (Native/PDF) and Hardcopy version shall be provided in all stages by vendor.
- (1) Q : QUANTITY ; TYPE : C = COPY, R = REPRODUCIBLE, P = POLYESTER, M = MICROFILM, E = ELECTRONIC, N=NUMBER OF DOCUMENT
- (2) W = CONSECUTIVE CALENDAR WEEK, M = CONSECUTIVE CALENDAR MONTH
- (3) A = FOR APPROVAL I = FOR INFORMATION
- (4) X = DOCUMENTS TO BE SUBMITTED AT THE FINAL INSPECTION
- (5) "6 C+E" COPY OF DOCUMENT.
- (6) MECHANICAL CATALOGUE INCLUDING FINAL DRAWINGS/DOCUMENTS, UNPRICED PURCHASE ORDER & SUB- PURCHASE ORDER, MAINTENANCE DOSSIER ETC.
- (7) ALL DOCUMENTS AND/OR DRAWINGS FOR THIS PROJECT SHALL ALSO BE SUBMITTED IN THE ELECTRONIC FILES BY

USING THE FOLLOWING SOFTWARE.

MS OFFICE WORD 2013 OR UPPER VERSION (ENGLISH) FOR WORD PROCESSING MS OFFICE EXCEL 2013 OR UPPER VERSION (ENGLISH) FOR SPREAD SHEET AUTO CAD 2005 (ENGLISH) FOR DRAWING

- (8) IN ORDER TO DESIGN AND MANUFACTURE THE INSTRUMENTS, VENDOR SHALL CONSIDER THE SEISMIC FACTOR.
 - SUITABLE FOR SEISMIC UBC 97 zone 4, AND THE RESULTS SHALL BE PROVIDED BY VENDOR.
- (9) LIST OF DOCUMENTS WILL BE FINALIZED IN VDIS.





ينك

شماره پیمان:

053 - 073 - 9184

PMR FOR ON/OFF & SHUTDOWN VALVES								
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	PPL	PEDCO	320	IN	MR	0004	D01	

شماره صفحه: 17 از 18

ATTACHMENT 3

Requisition No.:

Equipment No.:

Description:

11.3 <u>DEVIATIONS / EXCEPTIONS TO JOB SPECIFICATION</u>

Item No.	Description of proposed exception	Recommended revision to job specification	Reason for proposed exception	Effect on base proposal if CONTRACTOR rejects exception





بينك

شماره پیمان:

053 - 073 - 9184

PMR FOR ON/OFF & SHUTDOWN VALVES								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه	
BK	PPL	PEDCO	320	IN	MR	0004	D01	

شماره صفحه: 18 از 18

ATTACHMENT 4

Requisition No.:

Description:

11.4 ALTERNATIVES TO JOB SPECIFICATION

E	Equipment No.:									
	Item No.	Job Specification No. & Paragraph No.	Requirements of Job Specification	Description of Proposed Alternative	Reason for Proposed Alternative					