



#### احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

، پیمان:	شماره
----------	-------

 $\boldsymbol{\cdot} \Delta \boldsymbol{\tau} - \boldsymbol{\cdot} \boldsymbol{V} \boldsymbol{\tau} - \boldsymbol{q} \boldsymbol{1} \boldsymbol{\lambda} \boldsymbol{f}$ 

	TBE For Emergency Diesel Generator								
پروژه	نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه								
BK	GCS	PEDCO	120	EL	TB	0004	D00		

شماره صفحه: 1 از 12

# طرح نگهداشت و افزایش تولید ۲۷ مخزن

#### TBE FOR EMERGENCY DIESEL GENERATOR

نگهداشت و افزایش تولید میدان نفتی بینک

Class: 2	Place: 2 Client Dec Number: 507 709334					
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	Client Approval
D00	Nov. 2024	IFI	M.Pourdasht	M.Fakharian	M.Sadeghian	
					·	

Class: 3 Client Doc. Number: F0Z-709334

Status:

IDC: Inter-Discipline Check
IFC: Issued For Comment
IFA: Issued For Approval
AFD: Approved For Design
AFC: Approved For Construction
AFP: Approved For Purchase
AFQ: Approved For Quotation
IFI: Issued For Information
AB-R: As-Built for Client Review
AB-A: As-Built —Approved



 $\bullet \Delta \Upsilon - \bullet V \Upsilon - 91 \lambda \Upsilon$ 

#### نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض

#### احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



پیمان:	شماره
--------	-------

 TBE For Emergency Diesel Generator

 نسخه سریال نوع مدر ک رشته تسهیلات صادر کننده بسته کاری پروژه

 BK
 GCS
 PEDCO
 120
 EL
 TB
 0004
 D00

شماره صفحه: 2 از 12

#### **REVISION RECORD SHEET**

					REVIS
PAGE	D00	D01	D02	D03	D04
1	X				
2	X				
3	Х				
4	X				
5	X				
6	Х				
7	X				
8	X				
9	X				
10	X				
11	X				
12	^				
13 14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41 42					
43 44					
44					
46					
46					
48					
48					
50					

PAGE	D00	D01	D02	D03	D04
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					



# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:		TBE FOR EMERGENCY DIESEL GENERATOR									
·۵۳ - ·۷۳ — ٩١٨۴	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سر يال	نسخه			
· W1 · V1 · V1/V1	ВК	GCS	PEDCO	120	EL	ТВ	0004	D00			

شماره صفحه: 3 از 12

		TBE For Em	ergency Diesel Generato	or				
MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	Purchaser Requirement	Mah Niroo	Status	Sazand	Status	Hadid Sanat Pars Niroo	Status
Item	Description	1						
1. Envi	ronmental Data (Process Basis Design, BK-GNR	AL-PEDCO-000-PR-DB-0001)						
1.1	Location	Binak Oilfield in Bushehr Province	Confirmed	A	Confirmed	A	Confirmed	A
1.2	Installation	Outdoor Under Shelter, Safe Area	Confirmed	A	Confirmed	A	Confirmed	A
1.3	Installation Elevation	12.5m (Above Sea Level)	Confirmed	A	Confirmed	A	Confirmed	A
1.4	Seismic Loads	Zone 3 UBC	Confirmed	A	As Manufacturer Standard	A	Confirmed	A
1.5	Relative Humidity	100%	Confirmed	A	Confirmed	A	Confirmed	A
1.6	Ambient Temperature Range	5 ~ 52°C	Confirmed	A	Confirmed	A	Confirmed	A
1.7	Atmosphere	Corrosive & Hot	Confirmed	A	Confirmed	A	Confirmed	A
2. Gene	eral							
2.1	Manufacturer's Name	By Vendor	Mah Niroo	A	Sazand Eng co.	A	Volvo	A
2.2	Model	By Vendor	-	С	Volvo + Stamford	A	TAD1641GE	A
2.3	Quantity/Tag Number	1 /GCS-DG-001	Confirmed	A	Confirmed	A	Confirmed	A
2.4	Electrical Standard	IPS-E-EL-100(1) IPS-M-EL-138 (1) BK-GNRAL-PEDCO-000-EL-SP-0009	Confirmed	A	Confirmed	A	Confirmed	A
2.5	Mechanical Standard	IPS-M-PM-290 (2) BK-GCS-PEDCO-120-ME-SP-0012	Confirmed	A	Confirmed	A	Confirmed	A
2.6	References	Calculation Note for Diesel Generator Sizing (BK-GCS-PEDCO-120-EL-CN-0007)	Confirmed	A	Confirmed	A	Confirmed	A
2.7	Description of Equipment	Gen Set with Diesel Engine Prime Mover (Diesel Generator)	Confirmed	A	Confirmed	A	Confirmed	A
3. Engi	ine Specifications							
3.1	Genset Operation Mode (Single or Parallel)	Single	Confirmed	A	Confirmed	A	Confirmed	A
3.2	Duty	Emergency Standby (Calculated for continuous operation)	Confirmed	A	Confirmed	A	Standby Duty	A
3.3	Aspiration	Turbo Charged, Intercooler	Confirmed	A	Confirmed	A	Confirmed	A
3.4	Cylinder configuration	By Vendor	In Line	A	In Line	A	In Line	A
3.5	Number of Cylinders	By Vendor	6	A	6	A	6	A
3.6	Туре	Industrial, 4 strAes, Direct Injection	Confirmed	A	Confirmed	A	Confirmed	A



# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:			TBE FC	OR EMERGENCY DIES	EL GENERATOR				t
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدر ک	سريال	نسخه	
- ۵۳ ۷۳ - 9118	BK	GCS	PEDCO	120	FI	TR	0004	D00	]

شماره صفحه : 4 از 12

		TBE For Em	ergency Diesel Generato	r				
MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	Purchaser Requirement	Mah Niroo	Status	Sazand	Status	Hadid Sanat Pars Niroo	Status
Item	Description		3.50.5					
3.7	Displacement (liter)	By Vendor	16.12	A	16.12	A	16.12	A
3.8	Bore/StrAe (mm)	By Vendor	144/165	A	144/165	A	Later	С
3.9	Compression Ratio	By Vendor	16.5:1	A	16.8:1	A	Later	С
3.10	Governor Type	Electronic	Confirmed	A	Confirmed	A	Confirmed	A
3.11	Air Cleaner Type	Heavy Duty	Confirmed	A	Replaceable	N	Standard	N
3.12	Engine speed (rpm)	1500	Confirmed	A	Confirmed	A	Confirmed	A
3.13	Derating Factor for Working at Site Conditions (55°C)	0.97 (Vendor Shall Advise This Value)	Confirmed	A	Engine : No Deration Alternator :90%	N	Later	С
3.14	ISO Gross Shaft Power at (kw) Continuous Prime Maximum Standby	By Vendor >494 >506	465 Confirmed Confirmed	A A A	670 Confirmed 710	A	658 HP	A
3.15	Cooling Fan Power Requirement (kw)	10	Confirmed	A	21	A	Later	С
3.16	ISO Net Shaft Power at (kw) Continuous Prime Maximum Standby	By Vendor >496 >510	440 Confirmed Confirmed	A A A	Confirmed	A	440 KW	A
3.17	Piston Speed (m/s)	By Vendor	8.3	A	8.3	A	Later	С
3.18	Starting System	Electrical	Confirmed	A	Confirmed	A	Confirmed	A
3.19	Type of Batteries	Vented Ni-Cd	Confirmed	A	Confirmed	A	Lead Acid	N
3.20	Number of Batteries (Cell)	20 Number Cells	Confirmed	A	Confirmed	A	NO	N
3.21	Size of Batteries (Ah)	Not Less than 200 Ah	190 KPH	A	Confirmed	A	200 AH	A
3.22	Max Startup & Loading Time up to Full Load (Sec)	10 Sec	15 Sec	A	Confirmed	A	Confirmed	A
4. Lubr	icating System							
4.1	Туре	Forced Feed by Gear Oil Pump	Confirmed	A	Confirmed	A	Confirmed	A
4.2	Total Oil Capacity Min/Max (liter)	By Vendor	42	A	48	A	Later	С
4.3	Oil Filter	By Vendor	Confirmed	A	Replaceable	A	Confirmed	A
4.4	Oil Cooler	Water Cooled	Confirmed	A	Confirmed	A	NO	N



# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:			TBE FC	OR EMERGENCY DIES	EL GENERATOR			
۰۵۳ - ۰۷۳ – ۹۱۸۴	پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه
· 61 = · 71 (1X1	BK	GCS	PEDCO	120	EL	ТВ	0004	D00

شماره صفحه: 5 از 12

		TBE For E	mergency Diesel Generato	or				
MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	Purchaser Requirement	Mah Niroo	Status	Sazand	Status	Hadid Sanat Pars Niroo	Status
Item	Description							
4.5	Oil Type Required	By Vendor	40W/15	A	10W/30	A	15W/40	A
4.6	Lube Oil Consumption at: (gr/h) Continuous Power Prime Power Standby POWER	By Vendor	Volvo Standard	A	Prime : 0.10 L/h Stand By : 0.11 L/h	A	Later	С
5. Fuel	System							
5.1	Type of Fuel	Gas oil	Confirmed	A	Confirmed	A	Confirmed	A
5.2	Fuel Filter Type	By Vendor	Double	A	Replaceable	A	Later	С
5.3	Permissible Suction Head	By Vendor	Double	A	As Manufacturer Standard	A	Later	С
5.4	Permissible Return Head	By Vendor	Volvo Standard	A	As Manufacturer Standard	A	Later	С
5.5	Specified Fuel Consumption at: (gr/kwh) 100% Maximum Standby Power Prime Power 100% Continuous Power	By Vendor	127 L/H IN 100% LOAD 115 L/H IN 100% LOAD 110 L/H IN 100% LOAD	A	Prime: 191 gr/Kwh Stand By: 193 gr/Kwh	A	90 L/H @ 75%	A
5.6	Daily Tank	For 8 Hours Operation	Confirmed	A	Confirmed	A	Confirmed	A
6. Cool	ing System							
6.1	Total Coolant Capacity (liter)	By Vendor	60	A	50	A	Later	С
6.2	Water Pump Type	Centrifugal	Confirmed	A	Confirmed	A	Later	С
6.3	Temp. Rise Across Engine at: °C Continuous Power Prime Power Standby Power	By Vendor	Volvo Standard	A	As Manufacturer Standard	A	Later	С
6.4	Heat Rejection to Exhaust (Prime Power) (kw)	By Vendor	-	С	415	A	Later	С
6.5	Heat Rejection to Coolant (Prime Power) (kw)	By Vendor	-	С	239	A	Later	С
6.6	Heat Rejection to Intercooler (Prime Power) (kw)	By Vendor	-	С	131	A	Later	С
6.7	Heat Rejection by Radiation From Engine Surface (Prime Power) (kw)	By Vendor	-	С	23	A	Later	С
6.8	Cooling Air Required for Radiator (Prime Power) (kw)	By Vendor	-	С	As Manufacturer Standard	A	Later	С
7. Air I								
7.1	Combustion Air Flow at: (m3/h) Standby Power	By Vendor	Volvo Standard	A	As Manufacturer Standard	A	Later	С



# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:		TBE FOR EMERGENCY DIESEL GENERATOR           نسخه سریال نوع مدر ک پوژه         سخه سریال نوع مدر ک پروژه						
۰۵۳ - ۰۷۳ – ۹۱۸۴	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
- 21 11 (17)	ВК	GCS	PEDCO	120	EL	ТВ	0004	D00

شماره صفحه: 6 از 12

		TBE For En	nergency Diesel Generato	or							
MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	- Purchaser Requirement	Mah Niroo	Status	Sazand	Status	Hadid Sanat Pars Niroo	Status			
Item	Description										
	Prime Power Continuous Power										
7.2	Max. Air Intake Restriction of Engine : hPa With New Filter With Used Filter	By Vendor	-	С	As Manufacturer Standard	A	Later	С			
7.3	Alternator Cooling Air (m³/h)	By Vendor	-	C	As Manufacturer Standard	A	Later	С			
8. Exhaust System											
8.1	Max. Allowable Back Pressure for Exhaust Line (pa)	By Vendor	Volvo Standard	A	As Manufacturer Standard	A	Later	С			
8.2	Exhaust Flow (at Standby Power) (m <sup>3</sup> /h)	By Vendor	-	С	As Manufacturer Standard	A	Later	С			
8.3	Exhaust Gas Temp. After Turbine (at Standby Power) (°C)	By Vendor	-	С	As Manufacturer Standard	A	Later	С			
8.4	Silencer Type	Residential	-	С	Industrial	N	Confirmed	A			
8.5	Spark Arrester	Required	Confirmed	A	Confirmed	A	NO	N			
9. Engi	ne Auxiliaries			•				·			
9.1	Alternator Manufacturer	By Vendor	Volvo Standard	A	Stamford	A	Stamford / MEC ALTE	A			
9.2	Alternator Voltage (v)	By Vendor	-	C	400	A	400	A			
9.3	Alternator Current (A)	By Vendor	-	С	1000	A	800	A			
9.4	Starter Manufacturer	By Vendor	-	С	As Manufacturer Standard	A	Later	C			
9.5	Starter Motor Voltage (v)	By Vendor	-	С	As Manufacturer Standard	A	24	A			
9.6	Starter Motor Power (kw)	By Vendor	-	C	As Manufacturer Standard	A	Later	C			
10. Gene	erator Specifications										
10.1	Quantity / Duty	1 X 100% / Continuous	Confirmed	A	Confirmed	A	Standby	N			
10.2	Manufacturer / Type	By Vendor	Stamford/HCI544E	A	Stamford / S5L1D-F	A	Later	С			
10.3	Continuous Rating (MCR) at Standard Condition for Class F Temperature Rise (kva)	> 512kVA to meet continuous operation > 539kVA to meet starting conditions	Confirmed	A	Confirmed	A	550 KVA Stanbay	N			
10.4	De-Rating Factor for Ambient Temperature K <sub>t</sub>	0.9 (MFR shall advise his value)	Confirmed	A	9% For Alternator	N	Later	С			
10.5	De-Rating Factor for Altitude K <sub>a</sub>	1.0	Confirmed	A	Confirmed	A	Later	С			



# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:			TRE FC	R EMERGENCY DIES	EL GENERATOR			
IDE FOR EMERGENOT DIEGE GENERATOR								
۰۵۳ - ۰۷۳ — ۹۱۸۴	پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
ω1 (1/Λ1)	BK	GCS	PEDCO	120	EL	ТВ	0004	D00

شماره صفحه : 7 از 12

TBE For Emergency Die	sel Generator
-----------------------	---------------

MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	Purchaser Requirement	Mah Niroo	Status	Sazand	Status	Hadid Sanat Pars Niroo	Status
Item	Description	Turenaser Requirement	IVIAN I (II OV	Status	Sazanu	Status	Traditi Sanat Lars Milos	Status
10.6	Total Generator De-Rating Factor K <sub>d</sub> =K <sub>a</sub> *K <sub>t</sub>	0.9 (MFR Shall Advise His Value)	Confirmed	A	9% For Alternator	N	Later	С
10.7	Continuous Rating (MCR) at Site Conditions for Class F Temp. Rise (kva)	394	Confirmed	A	Confirmed	A	Class H	N
10.8	Permissible Overload (Class H Temp. Rise & Standby Duty) (kva)	10% of Rated Current for a Period of One Hour (in Each 12 Hours Function)	Confirmed	A	Confirmed	A	Not Allowed	N
10.9	Starting Capability (12% Voltage Dip at gen. Terminal)	Starting of the biggest motor while having the other loads in operation PF=0.80	Confirmed	A	As Manufacturer Standard	A	Later	С
10.10	Unbalance Loading Capacity (%)	15%	Confirmed	A	As Manufacturer Standard	A	Not Specified	N
10.11	Power Factor	0.80	Confirmed	A	Confirmed	A	Confirmed	A
10.12	Terminal Voltage (v)	400	Confirmed	A	Confirmed	A	Confirmed	A
10.13	Stator Winding Connection	Series Star	Confirmed	A	Confirmed	A	Confirmed	A
10.14	Frequency (Hz)	50	Confirmed	A	Confirmed	A	Confirmed	A
10.15	Grounding	Solidly Grounded	Confirmed	A	Confirmed	A	Confirmed	A
10.16	Neutral Point	Brought out	Confirmed	A	Confirmed	A	Confirmed	A
10.17	Insulation Class	F	Confirmed	A	Н	N	Н	N
10.18	Temp. Rise for Continuous Duty	В	Confirmed	A	Confirmed	A	Н	N
10.19	Ingress Protection of Terminal Box	IP55W	Confirmed	A	IP55	N	Confirmed	A
10.20	Ingress Protection for Generator	IP23	Confirmed	A	Confirmed	A	Confirmed	A
10.21	Short Circuit Ratio at Rated Volts & Current	By Vendor	refer to catalog	С	As Manufacturer Standard	A	Later	C
10.22	Synchronous Reactance Xd (Base 600kVA, 400V, Saturated) (pu)	By Vendor	-	С	2.62	A	Later	С
10.23	Direct Axis Transient Reactance X'd1(pu)	By Vendor	-	С	0.14	A	Later	С
10.24	Direct Axis sub-Trans. Reactance X"d (pu)	By Vendor	-	С	0.1	A	Later	С
10.25	Quadrature Axis Reactance Xq (pu)	By Vendor	-	С	2.19	A	Later	С
10.26	Quadrature Axis Sub-Trans. Reactance X"q (pu)	By Vendor	-	С	0.23	A	Later	С
10.27	Zero Sequence Reactance X0 (pu)	By Vendor	-	С	0.08	A	Later	С
10.28	Negative Sequence Reactance X2 (pu)	By Vendor	-	С	0.16	A	Later	С



# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:			TBE FO	OR EMERGENCY DIES	EL GENERATOR			
·۵۳ - ·۷۳ — ٩١٨۴	پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه
W1 171 (171	BK	GCS	PEDCO	120	EL	TB	0004	D00

شماره صفحه: 8 از 12

		TBE For En	nergency Diesel Generato	or				
MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	- Purchaser Requirement	Mah Niroo	Status	Sazand	Status	Hadid Sanat Pars Niroo	Status
Item	Description							
10.29	Leakage Reactance XL (pu)	By Vendor	-	С	0.04	A	Later	С
10.30	Time Constants (sec) Td' Td" Ta	By Vendor	-	С	0.08 0.012 0.019	A	Later	С
10.31	Generator Efficiency at: 1/2 Full Load (%) 3/4 Full Load (%) 4/4 Full Load (%)	By Vendor - C 95.4 95.5 95		95.5	A	Later	С	
10.32	Number of Bearings	1 (2 is preferred)	Confirmed	A	Confirmed	A	Confirmed	A
10.33	Type of Bearings / Lubrication	Anti-friction / Grease	Confirmed	A	Ball / Confirmed	A	Confirmed	A
10.34	Generator Space Heater - Voltage (v) - Power (w)	Required 230 By Vendor	Confirmed Confirmed 500 W	A A	Confirmed	A	Confirmed	A
10.35	Exciter Type	Self-Excited (PMG is preferred) Brushless, 3 phase sensing	Confirmed	A	Self-Excited	A	Confirmed	A
10.36	Exciter Voltage	By Vendor	80	A	As Manufacturer Standard	A	Later	С
10.37	Exciter Manufacturer	By Vendor	Stamford	A	Stamford	A	Later	С
10.38	AVR Model	By Vendor	AS450	A	AS440	A	Later	С
10.39	Voltage Regulation	±5%	Confirmed	A	±1%	A	Later	С
10.40	Exciter Current at: (A) Continuous Operation Short time Overload	By Vendor	Stamford Standard	A	As Manufacturer Standard	A	Later	С
11. Conti	rol Panel							
11.1	Manufacturer	By Vendor	Mah niroo Ind	A	Sazand Eng Co.	A	Deep Sea	A
11.2	Standard	IEC, IPS-M-EL-143(3)	Stamford	A	As Manufacturer Standard	A	IEC	A
11.3	Туре	Fixed	Confirmed	A	Confirmed	A	Confirmed	A
11.4	Construction	Self-Standing	Confirmed	A	Confirmed	A	Skid Mounted	N
11.5	Sheet Steel Thickness	2mm Wall / 2.5 mm Frame	Confirmed	A	Confirmed	A	Later	С
11.6	Access	Front Via Hinged Door	Confirmed	A	Confirmed	A	Skid Mounted	N
11.7	Location	Outdoor (Under Shelter)	Confirmed	A	Confirmed	A	Inside Canopy	N



# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:		TBE FOR EMERGENCY DIESEL GENERATOR           نسخه سریال نوع مدر ک رشته سیلات صادر کننده بسته کاری پر							
۰۵۳ - ۰۷۳ – ۹۱۸۴	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدر ک	سريال	نسخه	
- 21 - 171 (171	ВК	GCS	PEDCO	120	EL	ТВ	0004	D00	

شماره صفحه : 9 از 12

TBE For Emergency D	Diesel Generator
---------------------	------------------

MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	- Purchaser Requirement	Mah Niroo	Status	Sazand	Status	Hadid Sanat Pars Niroo	Status
Item	Description	Turenuser requirement	Man 1 (11 00	Status	Suburu	Status		Status
11.8	Ingress Protection	IP54	Confirmed	A	Confirmed	A	XX	C
11.9	Busbar System	3Ph+N+PE	Confirmed	A	Confirmed	A	Confirmed	A
11.10	Rated Busbar Current (A)	800	Confirmed	A	Confirmed	A	Confirmed	A
11.11	Busbar Material	Copper (Insulated With Heat Shrink)	Confirmed	A	Confirmed	A	Confirmed	A
11.12	Protection Functions (Embedded in ACB Protection Unit)	- Overload 49 - Phase over current 50/51 Earth fault 50N/51N	Confirmed	A	Confirmed	A	Confirmed	A
11.13	Protection Functions (Other Than ACB Protection Unit)	According to "BK-GCS-PEDCO-120-EL-SL-0002"	Confirmed	A	Confirmed	A	Please Send For Review	
11.14	Controller Manufacturer / Model no.	By Vendor	Deep Sea 7320	A	Deep Sea 7320	A	Deep Sea	A
11.15	Indicators on Panel	- Gen. Voltages (Analogue) - Gen. Currents  - Gen. Frequency (Analogue) - Battery charging ammeter - Power factor meter - Jacket water temperature - Lubricating oil temp Lubricating oil press Hours run meter - Watt meter - Watt-hour meter - VAR-hour meter VAR meter	Confirmed	A	Confirmed	A	All In Controller Deep Sea	A
11.16	Transducers (4~20mA Output)	- Generator Voltage Frequency	Confirmed	A	Confirmed	A	NO	N
11.17	Generator Neutral CT Manufacturer Rating & Class	Required for 51G protection Required for 64R protection By Vendor 51G: 800/5A, Cl. 5P10	Confirmed Confirmed	A A	Confirmed	A	NO	N
11.18	Earth Fault Protections Manufacturer Type Setting Range	Required BY Vendor Solid state By Vendor	Confirmed (BY DEEP SEA)	A	Confirmed	A	Later	С
11.19	Panel Accessories	Anti-Condensation Heater Panel Lighting Removable Gland Plate	Confirmed	A	Confirmed	A	Confirmed	A
11.20	Finish Color	RAL 7032	Confirmed	A	7035	A	Later	С
11.21	Cable entry	Bottom via Cable Gland	Confirmed	A	Confirmed	A	Confirmed	A



# احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک



شماره پیمان:			TBE FC	R EMERGENCY DIES	EL GENERATOR			
•۵٣ - •٧٣ — ٩١٨۴	پروژه	بسته کاری	صادر كننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه
.ωι = . γι τιχι	ВК	GCS	PEDCO	120	EL	ТВ	0004	D00

شماره صفحه : 10 از 12

		TBE For En	nergency Diesel Generato	or				
MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	- Purchaser Requirement	Mah Niroo	Status	Sazand	Status	Hadid Sanat Pars Niroo	Status
Item	Description							
11.22	Cable Specification & Size From Generator to Local Panel: From Local Panel to LV switchgear:	CU/XLPE/AWA/PVC By Vendor 2x(1x300mm²) Phase 1 2x(1x300mm²) Phase 2 2x(1x300mm²) Phase 3 1x(1x3300mm²) Neutral	Confirmed	A	Later	C	Later	С
12. Swite	ching Device							
12.1	Type of Switching Device	ACB	MCCB	N	Confirmed	A	MCB	N
12.2	Manufacturer	By Vendor	Schneider / Abb / Siemens	A	Schneider	A	Later	С
12.3	Type Designation	By Vendor	AFTER PO	A	As Manufacturer Standard	A	XX	N
12.4	Operating Mechanism	Motor Operated, Spring Charged, Stored Energy, Trip Free Mechanism	Confirmed	A	Confirmed	A	Confirmed	A
12.5	Number of Poles	4	Confirmed	A	Confirmed	A	Confirmed	A
12.6	Rated Current (A)	800	Confirmed	A	Confirmed	A	Confirmed	A
12.7	Rated Voltage (V)	690	Confirmed	A	As Manufacturer Standard	A	Confirmed	A
12.8	Standard	IEC	Confirmed	A	Confirmed	A	Confirmed	A
12.9	Rated Breaking Current	Not Less Than 35kA	Confirmed	A	Confirmed	A	Confirmed	A
12.10	Charging Motor Operating Voltage (V)	24 (Fed from diesel batteries)	Confirmed	A	Confirmed	A	Confirmed	A
12.11	Trip Unit	Electronic type	Confirmed	A	Confirmed	A	Confirmed	A
12.12	Trip Unit Functions	49, 50, 51, 50N, 51N	Confirmed	A	Confirmed	A	Confirmed	A
12.13	Trip Unit Model	By Vendor	Confirmed	A	As Manufacturer Standard	A	XX	N
13. Gene	erator Accessories							
13.1	RTD (Pt100)	Yes (9 RTD's for S > 500kVA)	(7 RTD)	N	6 ( 2 Per Phase)	N	NO	N
13.2	Lifting Bolts	Yes	Confirmed	A	Confirmed	A	Confirmed	A
13.3	Earthing Bolt	Yes	Confirmed	A	Confirmed	A	Confirmed	A
13.4	Drain Plug	Yes	Confirmed	A	Confirmed	A	Confirmed	A



#### احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

TBE FOR EMERGENCY DIESEL GENERATOR شماره پیمان: بسته کاری صادر كننده نوع مدرك پروژه تسهيلات سريال · 27 - · 77 - 9114 BK GCS PEDCO 120 EL TB 0004 D00

شماره صفحه : 11 از 12

	TBE For Emergency Diesel Generator											
MR	PMR For Emergency Diesel Generator (BK-GCS-PEDCO-120-EL-MR-0004)	- Purchaser Requirement	Mah Niroo	Niroo Status	Sazand	Status	Hadid Sanat Pars Niroo	Status				
Item	Description		111111111100									
14. General												
14.1	Noise Level	Not More than 81dB @ No Load	With Canopy Or Diesel Room Confirmed	N	@ 1m = 103.6 db	N	85 db	N				
14.2	Weight of Diesel Engine Without Oil and Water (Kg)	By Vendor	1550 Kg	A	Wet Weight : 1810 Kg	A	Later	С				
14.3	Weight of Generator (Kg)	By Vendor	1200 Kg	A	1705 Kg	A	Later	C				
14.4	Weight of Diesel Generator Skid (Kg)	By Vendor	750 Kg	A	-	A	Later	С				
14.5	Overall Dimension of Diesel Generator Skid (W x D x H) (mm)	By Vendor	4000x1600x1750	A	3400 * 1400 * 2200	A	Later	С				
14.6	Dimension of Control Panel (W x D x H) (mm)	By Vendor	600x800x300	A	-	A	Later	С				

STATUS LEGENDS:

A=Acceptable

N=Not Acceptable

N/A=Not Applicable

INA=Information Not Available

C=Clarification is Required

CA= Conditionally Acceptable

M = Requirement is Mandatory



· ۵۳ - · ۷۳ - 9 1 1 4

#### نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض







#### احداث ردیف تراکم گاز در ایستگاه جمع آوری بینک

شماره پیمان: TBE FOR EMERGENCY DIESEL GENERATOR بسته کاری صادر كننده نوع مدرك پروژه تسهيلات سريال BK GCS PEDCO 120 EL TB 0004 D00

شماره صفحه : 12 از 12

#### **Conclusion Table:**

Item	Equipment	Mah Niroo	Sazand	Hadid Sanat Pars Niroo	
1	Diesel Generator	Acceptable	Acceptable	Acceptable	