

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 1 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

طرح نگهداشت و افزایش تولید 27 مخزن

Thermal/Mechanical Calculation Book

نگهداشت و افزایش تولید میدان نفتی بینک

V03	Oct.2024	AFC	AAC	M.FAKHARIAN	M.SADEGHIAN	
V02	Jul.2024	IFA	AAC	M.FAKHARIAN	M.SADEGHIAN	
V01	Mar.2024	IFA	AAC	M.FAKHARIAN	S.FRAMARZPOUR	
V00	Nov.2023	IFA	AAC	M.FAKHARIAN	S.FRAMARZPOUR	
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Status:

IFA: Issued For Approval
IFI: Issued For Information
AFC: Approved For Construction

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه: 2 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

REVISION RECORD SHEET

PAGE	V00	V01	V02	V03	V04
1	X	X	X	X	
2	X	X	X	X	
3	X		X	X	
4	X		X	X	
5	X	X	X		
6	X	X	X	X	
7	X	X	X	X	
8	X	X	X	X	
9			X	X	
10			X	X	
11			X	X	
12			X	X	
13			X	X	
14			X	X	
15			X	X	
16			X	X	
17			X	X	
18			X	X	
19			X	X	
20			X	X	
21			X	X	
22			X	X	
23			X	X	
24			X	X	
25			X	X	
26			X	X	
27			X	X	
28			X	X	
29			X	X	
30			X	X	
31			X	X	
32			X	X	
33			X	X	
34			X		
35			X		
36			X		
37			X		
38			X		
39			X		
40			X		
41			X		
42			X		
43			X		
44			X		
45			X		
46			X		
47			X		
48			X		
49			X		
50			X		
51			X		
52			X		
53			X		
54			X	X	
55			X	X	
56			X	X	
57			X	X	
58			X	X	
59			X	X	
60			X	X	
61			X	X	
62			X	X	
63			X	X	
64			X	X	
65			X	X	

PAGE	V00	V01	V02	V03	V04
66			X	X	
67			X	X	
68			X	X	
69			X	X	
70			X	X	
71			X	X	
72			X	X	
73			X	X	
74			X	X	
75			X		
76			X		
77			X		
78			X		
79			X		
80			X		
81			X		
82			X		
83			X		
84			X		
85			X		
86			X		
87			X		
88			X		
89			X		
90			X		
91			X		
92			X		
93					
94				X	
95				X	
96				X	
97				X	
98				X	
99				X	
100				X	
101				X	
102				X	
103				X	
104				X	
105				X	
106				X	
107				X	
108				X	
109				X	
110				X	
111				X	
112				X	
113				X	
114				X	
115				X	
116				X	
117				X	
118				X	
119				X	
120				X	
121				X	
122				X	
123				X	
124				X	
125				X	
126				X	
127				X	
128				X	
129				X	
130				X	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 3 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

REVISION RECORD SHEET

PAGE	V00	V01	V02	V03	V04
130				X	
131				X	
132				X	
133				X	
134				X	
135				X	
136				X	
137				X	
138				X	
139				X	
140				X	
141				X	
142				X	
143				X	
144				X	
145				X	
146				X	
147				X	
148				X	
149				X	
150				X	
151					
152					
153					
154					
155					
156					
157					
158					
159					
160					
161					
162					
163					
164					
165					
166					
167					
168					
169					
170					
171					
172					
173					
174					
175					
176					
177					
178					
179					
180					
181					
182					
183					
184					
185					
186					
187					
188					
189					
190					
191					
192					
193					
194					
195					

PAGE	V00	V01	V02	V03	V04
196					
197					
198					
199					
200					
201					
202					
203					
204					
205					
206					
207					
208					
209					
210					
211					
212					
213					
214					
215					
216					
217					
218					
219					
220					
221					
222					
223					
224					
225					
226					
227					
228					
229					
230					
231					
232					
233					
234					
235					
236					
237					
238					
239					
240					
241					
242					
243					
244					
245					
246					
247					
248					
249					
250					
251					
252					
253					
254					
255					
256					
257					
258					
259					
260					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 4 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			



Contents

1.0	INTRODUCTION	5
2.0	THERMAL/MECHANICAL CALCULATION BOOK	6
3.0	MECHANICAL CALCULATION BOOK.....	14
3.1	STATIONARY HEADER CALCULATION @ DESIGN PRESSURE FOR AE-2101.....	14
3.2	STATIONARY HEADER CALCULATION @ TEST PRESSURE FOR AE-2101.....	24
3.3	FLOATING HEADER CALCULATION @ DESIGN PRESSURE FOR AE-2101.....	34
3.4	FLOATING HEADER CALCULATION @ TEST PRESSURE FOR AE-2101.....	44
3.5	STATIONARY HEADER CALCULATION @ DESIGN PRESSURE FOR AE-2102.....	54
3.6	STATIONARY HEADER CALCULATION @ TEST PRESSURE FOR AE-2102.....	64
3.7	FLOATING HEADER CALCULATION @ DESIGN PRESSURE FOR AE-2102.....	75
3.8	FLOATING HEADER CALCULATION @ TEST PRESSURE FOR AE-2102.....	85
3.9	FINITE ELEMENT FOR AE-2101.....	95
3.10	FINITE ELEMENT FOR AE-2102.....	123

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 5 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT:	National Iranian South Oilfields Company (NISOC)
PROJECT:	Binak Oilfield Development – Manufacturing (w/Engineering & Material Supply) of Air Coolers
EPD/EPC CONTRACTOR (GC):	Petro Iran Development Company (PEDCO)
OWNER:	OWNER is collectively refer to National Iranian South Oil Company (NISOC) and Petro Iran Development Company (PEDCO)
EPC CONTRACTOR:	Joint Venture of : Hirgan Energy – Design & Inspection(D&I) Companies
VENDOR:	Aban Air Cooler (AAC)
EXECUTOR:	Executor is the party which carries out all or part of construction and/or commissioning for the project.
THIRD PARTY INSPECTOR (TPI):	Third Party Inspector
SHALL:	Is used where a provision is mandatory.
SHOULD:	Is used where a provision is advisory only.
WILL:	Is normally used in connection with the action by CLIENT rather than by an EPC/EPD CONTRACTOR, supplier or VENDOR.
MAY:	Is used where a provision is completely discretionary.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 6 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

2.0 THERMAL/MECHANICAL CALCULATION BOOK

03

HTRI				API 661 Air-Cooled Heat Exchanger - Specification Sheet			
Job No.		Page 1		Item No.		2101 (summer)	
Date				By		V03	
Proposal No.				Contract No.			
Inquiry No.				Order No.			
Manufacturer		Heat exchanged (MegaWatts)		0.3818			
Model no.		Surface/Item-Finned tube (m2)		658.66			
Customer PEDCO/NISOC		Bare tube (m2)		31.536			
Plant location BINAK Oilfield		MTD, Eff. (Deg. C)		29.1			
Service 1st stage Gas Compression Cool		Transfer rate-Finned (W/m2-K)		20.607			
Type draft INDUCED		Bare tube, service (W/m2-K)		430.41			
Bay size (WxL) (m) 1.9x 3.8		Bare tube, clean (W/m2-K)		483.18			
No. of bays/items 1							
Basic design data							
Pressure design code		Structural code					
Tube bundle code stamped		Flammable service					
Heating coil code stamped		Lethal/toxic service					
Performance Data - Tube Side							
Fluid name Hydrocarbon		In		Out			
Total fluid entering (kg/hr) 9530.4		Total flow rate (Liq/Vap) (kg/hr) / 9530.4		/ 9530.4			
Dew /bubble point (Deg. C) /		Water/Steam (kg/hr) /		/ 0			
(Deg. C) /		Noncondensables (kg/hr) /		/ 0			
Latent heat (kJ/kg) /		Molecular Wt. (Vap/Non-cond) /		/			
Inlet pressure (barG) 17.9		Density (Liq/Vap) (kg/m3) / 14.197		/ 17.141			
Pressure drop (All/Calc) (bar) 0.7 / 0.473		Specific heat (Liq/Vap) (kJ/kg-C) / 2.2057		/ 1.9724			
Velocity (Allow /Calc) (m/s) / 17.09		Thermal cond. (Liq/Vap) (W/m-K) / 0.0438		/ 0.0336			
Inside fouling resistance (m2-K/W) 0.0002		Viscosity (Liq/Vap) (mN-s/m2) / 0.0137		/ 0.0117			
Temperature (Deg. C) In 129 Out 60							
Performance Data - Air Side							
Air inlet temperature (Deg. C) 50.26		Face velocity (m/s) 2.99					
Air flow rate/item (m3/s) 24.4		Minimum design ambient temp. (Deg. C) 5					
Mass velocity (kg/s-m2) /		Altitude (m) 12.5					
Air outlet temperature (Deg. C) 65.2		Static pressure (Pa) 145.05					
Air flow rate/fan (m3/s) 12.2							
Design, Material, and Construction							
Design pressure (barG) 22		Heating Coil NO					
Test pressure (barG) 28.6		No. of tubes					
Design temperature (Deg. C) 155		Tube outside diameter (mm)					
Min. design metal temp. (Deg. C)		Tube material					
Tube bundle		Fin material and type					
Size (WxL) (m) 1.86X 3.8		Fin thickness (mm)					
No./Bay 1		ASME Code, Sec. VIII, Div. 1					
Number of tube rows 4		Heating fluid					
Bundles in parallel 1		Heating fluid flow rate (kg/hr)					
Bundles in series		Temperature (In/Out) (Deg. C) /					
Structure mounting		Inlet pressure (barG)					
Pipe rack beams		Pressure drop (All/Calc) (kPa) /					
Ladders, walkways, platforms		Design temperature (Deg. C)					
Structure surface prep.		Design pressure (barG)					
Header surface prep.		Inlet/Outlet nozzle /					
Louver YES		Header					
Material		Type Plug					
Action control Manual		Material SA-240 TP316L					
Action type		Corrosion Allowance (mm) 0					
		No. of passes 4					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)										
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 7 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			

		API 661 Air-Cooled Heat Exchanger - Specification Sheet	
		Job No.	Item No.
		Page	By
		Date	Revision
		Proposal No.	Contract No.
		Inquiry No.	Order No.
		2101 (summer)	
		V03	
Design, Material, and Construction (continued)			
Header (continued)		No./Bundle	
Slope 1% ON LAST PASS		104	
Plug material SA 182 F316L		Length (m) 3.8	
Gasket material Solid metal		Pitch (mm) 61	
Nozzle		Layout Triangular	
No.	Size, (in)	Rating/Facing	Fin
Inlet 1	6	300 RF	Type Extruded
Outlet 1	6	300 RF	Material Aluminum Alloy 1060 - O
Vent 1	2	300 RF	Thickness (mm) 0.48
Drain 1	2	300 RF	Selection temp. (C)
Chemical Cleaning			Outside diameter (mm) 57.15
Min. Wall Thk.			Fin density (fin/in) 10
Tube			ASME Code, Sec. VIII, Div. 1
Material SA-213 TP316L Tube (S) S31603			Customer Specifications
Tube outside diameter (mm) 25.4			
wall thickness (mm) 1.651			
Mechanical Equipment			
Fan		RFM	
Manufacturer		Service factor 1	
No./Bay 2		Enclosure EExd, IIB T3 (IF55)	
RFM (Revs/min.) 696		Voltage 400	
Diameter (mm) 1372		Phase 3	
No. of blades 5		Cycle 50	
Angle (degrees)		Fan noise level (dB) <85	
Pitch adjustment 50% Auto		Speed Reducer	
Blade material AL		Type V-BELT	
Hub material ALU/Steel		Manufacturer	
@design temp 3.4		No./Bay 2	
@min. ambient temp 4.5		Service factor	
Tip speed		Speed ratio	
Driver		Support	
Type		Vib. Switch YES, EExd, IIB T3 (IF55)	
Manufacturer		Enclosure	
No./Bay 2			
Driver (kW) 5.5			
Controls - Air Side			
Air recirculation		Louvers	
Degree control of outlet process temp. NO		Positioner	
(Max. Cooling), +/- /		Signal air pressure (barG)	
Action on control signal failure		From To	
Fan pitch		From To	
Louvers		Supply air pressure (barG)	
Actuator air supply		From To	
Fan		From To	
Shipping			
Plot area (WxL) (m) 1.9 x 3.8		Total (kg) 8986.5	
Bundle weight (kg) 2205.9		Shipping (kg)	
Bay (kg)			
Note: 1) Reported duty and flow rates include a user-specified multiplier of 1.10 2-Max allowable nozzle load = 3xAPI 3-Material will be meet requirements of NACE MR0175/ISO1516 and specification for material requirments in sour service (BK-GNRL-PECCO-000-PA-SP-0008) 4-HTRI Weight is reported			

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)		  
	شماره پیمان: 053-073-9184		شماره صفحه: 8 از 150
Thermal/Mechanical Calculation Book			
پروژه BK بسته کاری GCS صادرکننده AA تسهیلات 120 رشته PR نوع مدرک CN سریال 0001 نسخه V03			

		API 661 Air-Cooled Heat Exchanger - Specification Sheet	
Job No. _____ Page _____ Date _____ Proposal No. _____ Inquiry No. _____		Item No. 2101 (w inter) By _____ Revision V03 Contract No. _____ Order No. _____	
Manufacturer _____ Model no. _____ Customer PEDCO/NISOC Plant location Binak oilfield Service 1st stage Gas Compression Cooler Type draft INDUCED Bay size (WxL) (m) 1.9 x 3.8 No. of bays/items 1		Heat exchanged (MegaWatts) 0.268 Surface/Item-Finned tube (m2) 658.66 Bare tube (m2) 31.536 MTD, Eff. (Deg. C) 26.4 Transfer rate-Finned (W/m2-K) 19.508 Bare tube, service (W/m2-K) 407.45 Bare tube, clean (W/m2-K) 454.43	
Basic design data			
Pressure design code _____ Tube bundle code stamped _____ Heating coil code stamped _____		Structural code _____ Flammable service _____ Lethal/toxic service _____	
Performance Data - Tube Side			
Fluid name HYDROCARBON Total fluid entering (kg/hr) 8343.5 Dew/bubble point (Deg. C) / Latent heat (kJ/kg) Inlet pressure (barG) 17.9 Pressure drop (All/Calc) (bar) 0.7 / 0.36 Velocity (Allow /Calc) (m/s) / 14.63 Inside fouling resistance (m2-K/W) 0.0002 Temperature (Deg. C) In 116 Out 60		In Out Total flow rate (Liq/Vap) (kg/hr) / 8343.5 / 8343.5 Water/Steam (kg/hr) / / Noncondensables (kg/hr) Molecular Wt. (Vap/Non-cond) / / Density (Liq/Vap) (kg/m3) / 14.72 / 17.251 Specific heat (Liq/Vap) (kJ/kg-C) / 2.1616 / 1.9724 Thermal cond. (Liq/Vap) (W/m-K) / 0.0418 / 0.0336 Viscosity (Liq/Vap) (mN-s/m2) / 0.0133 / 0.0117	
Performance Data - Air Side			
Air inlet temperature (Deg. C) 50.26 Air flow rate/item (m3/s) 24.072 Mass velocity (kg/s-m2) Air outlet temperature (Deg. C) 60.76 Air flow rate/fan (m3/s) 12.036		Face velocity (m/s) 2.99 Minimum design ambient temp. (Deg. C) 5 Altitude (m) 12.5 Static pressure (Pa) 143.54	
Design, Material, and Construction			
Design pressure (barG) 22 Test pressure (barG) 28.6 Design temperature (Deg. C) 155 Min. design metal temp. (Deg. C) Tube bundle Size (WxL) (m) 1.86X 3.80 No./Bay 1 Number of tube row s 4 Bundles in parallel 1 Bundles in series Structure mounting Pipe rack beams Ladders, walkways, platforms Structure surface prep. Header surface prep. Louver Material YES Action control Manual Action type		Heating Coil NO No. of tubes Tube outside diameter (mm) Tube material Fin material and type Fin thickness (mm) ASME Code, Sec. VIII, Div. 1 Heating fluid Heating fluid flow rate (kg/hr) Temperature (In/Out) (Deg. C) / Inlet pressure (barG) Pressure drop (All/Calc) (kPa) / Design temperature (Deg. C) Design pressure (barG) Inlet/Outlet nozzle / Header Type plug Material SA-240 TP316L Corrosion Allowance (mm) 0 No. of passes 4	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 9 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

		API 661 Air-Cooled Heat Exchanger - Specification Sheet																					
		Job No. _____	Item No. <u>2101 (w inter)</u>																				
		Page _____	By _____																				
		Date _____	Revision _____																				
		Proposal No. _____	Contract No. _____																				
		Inquiry No. _____ Order No. _____																					
Design, Material, and Construction (continued)																							
Header (continued) Slope <u>1% ON LAST PASS</u> Plug material <u>SA 182 F316L</u> Gasket material <u>Solid Metal</u>		No./Bundle <u>104</u> Length (m) <u>3.8</u> Pitch (mm) <u>61</u> Layout <u>Triangular</u>																					
Nozzle <table border="1"> <thead> <tr> <th>No.</th> <th>Size, (in)</th> <th>Rating/Facing</th> </tr> </thead> <tbody> <tr> <td>Inlet</td> <td>1</td> <td>6 300 RF</td> </tr> <tr> <td>Outlet</td> <td>1</td> <td>6 300 RF</td> </tr> <tr> <td>Vent</td> <td>1</td> <td>2 300 RF</td> </tr> <tr> <td>Drain</td> <td>1</td> <td>2 300 RF</td> </tr> <tr> <td>Chemical Cleaning</td> <td></td> <td></td> </tr> <tr> <td>Min. Wall Thk.</td> <td></td> <td></td> </tr> </tbody> </table>	No.	Size, (in)	Rating/Facing	Inlet	1	6 300 RF	Outlet	1	6 300 RF	Vent	1	2 300 RF	Drain	1	2 300 RF	Chemical Cleaning			Min. Wall Thk.			Fin Type <u>EXTRUDED</u> Material <u>Aluminum Alloy 1060 - O</u> Thickness (mm) <u>0.48</u> Selection temp. (C) _____ Outside diameter (mm) <u>57.15</u> Fin density (fin/in) <u>10</u> ASME Code, Sec. VIII, Div. 1 _____ Customer Specifications _____	
No.	Size, (in)	Rating/Facing																					
Inlet	1	6 300 RF																					
Outlet	1	6 300 RF																					
Vent	1	2 300 RF																					
Drain	1	2 300 RF																					
Chemical Cleaning																							
Min. Wall Thk.																							
Tube Material <u>SA-213 TP316L Tube (S) S31603</u> Tube outside diameter (mm) <u>25.4</u> wall thickness (mm) <u>1.651</u>																							
Mechanical Equipment																							
Fan Manufacturer _____ No./Bay <u>2</u> RPM (Revs/min.) <u>696</u> Diameter (MM) <u>1372</u> No. of blades <u>4</u> Angle (degrees) _____ Pitch adjustment <u>50% Auto</u> Blade material <u>Al</u> Hub material <u>Alu/Steel</u> @design temp <u>3.4</u> @min. ambient temp <u>4.5</u> Tip speed _____ Driver Type _____ Manufacturer _____ No./Bay <u>2</u> Driver (kW) <u>5.5</u>		RPM <u>1500</u> Service factor <u>1</u> Enclosure <u>EEExd, IIB T3 (IP55)</u> Voltage <u>400</u> Phase <u>3</u> Cycle <u>50</u> Fan noise level (dB) <u><85</u> Speed Reducer Type <u>V-Belt</u> Manufacturer _____ No./Bay <u>2</u> Service factor <u>1.8</u> Speed ratio _____ Support _____ Vib. switch <u>YES EEExd, IIB T3 (IP55)</u> Enclosure _____																					
Controls - Air Side																							
Air recirculation <u>NO</u> Degree control of outlet process temp. (Max. Cooling), +/- <u>/</u> Action on control signal failure _____ Fan pitch _____ Louvers _____ Actuator air supply _____ Fan _____		Louvers _____ Positioner _____ Signal air pressure (barG) From _____ To _____ From _____ To _____ Supply air pressure (barG) From _____ To _____ From _____ To _____																					
Shipping																							
Plot area (WxL) (m) <u>1.86 x 3.8</u> Bundle weight (Note 4) (kg) <u>2205.9</u> Bay (kg) _____		Total (Note 4) (kg) <u>8986.5</u> Shipping (kg) _____																					
Note:1- Reported duty and flow rates include a user-specified multiplier of 1.10 2-Maximum allowable nozzle load = 3 x API 3-Material will meet requirements of NACE MR0175/ISO1516 and specification for material requirements in sour service (BK-GNRL-PEDCO-000-PI-SP-0008) 4-HTRI Weight is reported																							

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)		  														
	شماره پیمان: 053-073-9184		شماره صفحه: 10 از 150														
Thermal/Mechanical Calculation Book		<table border="1"> <tr> <td>نسخه</td> <td>0001</td> <td>سریال</td> <td>CN</td> <td>رشته</td> <td>PR</td> <td>تسهیلات</td> <td>120</td> <td>صادرکننده</td> <td>AA</td> <td>بسته کاری</td> <td>GCS</td> <td>پروژه</td> <td>BK</td> </tr> </table>		نسخه	0001	سریال	CN	رشته	PR	تسهیلات	120	صادرکننده	AA	بسته کاری	GCS	پروژه	BK
نسخه	0001	سریال	CN	رشته	PR	تسهیلات	120	صادرکننده	AA	بسته کاری	GCS	پروژه	BK				

		API 661 Air-Cooled Heat Exchanger - Specification Sheet			
Job No. _____ Page _____ Date <u>9/30/2024</u> Proposal No. _____ Inquiry No. _____		Item No. <u>2102 (Summer)</u> By _____ Revision <u>v03</u> Contract No. _____ Order No. _____			
Manufacturer _____ Model no. _____ Customer <u>PEDCO/NISOC</u> Plant location <u>BIHAK oilfield</u> Service <u>2st Stage Gas Compression Cooler</u> Type draft <u>INDUCED</u> Bay size (WxL) (m) <u>2.12 x 3.900</u> No. of bays/items <u>1</u>		Heat exchanged (MegaWatts) <u>0.4992</u> Surface/Item-Finned tube (m2) <u>1010.5</u> Bare tube (m2) <u>48.548</u> MTD, Eff. (Deg. C) <u>33.7</u> Transfer rate-Finned (W/m2-K) <u>17.389</u> Bare tube, service (W/m2-K) <u>361.95</u> Bare tube, clean (W/m2-K) <u>398.69</u>			
Basic design data					
Pressure design code _____ Tube bundle code stamped _____ Heating coil code stamped _____		Structural code _____ Flammable service _____ Lethal/toxic service _____			
Performance Data - Tube Side					
Fluid name <u>HYDROCARBON</u> Total fluid entering (kg/hr) <u>9530.4</u> Dew /bubble point (Deg. C) <u>/</u> Latent heat (kJ/kg) _____ Inlet pressure (barG) <u>54.8</u> Pressure drop (All/Calc) (bar) <u>0.7 / 0.091</u> Velocity (Allow/Calc) (m/s) <u>/ 3.67</u> Inside fouling resistance (m2-K/W) <u>0.0002</u> Temperature (Deg. C) In <u>148</u> Out <u>60</u>		In Out Total flow rate (Liq/Vap) (kg/hr) <u>/ 9530.4 / 9530.4</u> Water/Steam (kg/hr) <u>/ /</u> Noncondensables (kg/hr) _____ Molecular Wt. (Vap/Non-cond) <u>/ /</u> Density (Liq/Vap) (kg/m3) <u>/ 41.398 / 57.58</u> Specific heat (Liq/Vap) (kJ/kg-C) <u>/ 2.2852 / 2.0007</u> Thermal cond. (Liq/Vap) (W/m-K) <u>/ 0.0483 / 0.036</u> Viscosity (Liq/Vap) (mN-s/m2) <u>/ 0.0144 / 0.0121</u>			
Performance Data - Air Side					
Air inlet temperature (Deg. C) <u>50.26</u> Air flow rate/item (m3/s) <u>27.1</u> Mass velocity (kg/s-m2) _____ Air outlet temperature (Deg. C) <u>67.97</u> Air flow rate/fan (m3/s) <u>13.55</u>		Face velocity (m/s) <u>2.9</u> Minimum design ambient temp. (Deg. C) <u>5</u> Altitude (m) <u>12.5</u> Static pressure (Pa) <u>142.13</u>			
Design, Material, and Construction					
Design pressure (barG) <u>62</u> Test pressure (barG) <u>80.6</u> Design temperature (Deg. C) <u>175</u> Min. design metal temp. (Deg. C) <u>5</u> Tube bundle Size (WxL) (m) <u>2.06 X 3.900</u> No./Bay <u>1</u> Number of tube rows <u>6</u> Bundles in parallel <u>1</u> Bundles in series _____ Structure mounting _____ Pipe rack beams _____ Ladders, w/allow ways, platforms _____ Structure surface prep. _____ Header surface prep. _____ Louver Material <u>YES</u> Action control <u>Manual</u> Action type _____		Heating Coil <u>NO</u> No. of tubes _____ Tube outside diameter (mm) _____ Tube material _____ Fin material and type _____ Fin thickness (mm) _____ ASME Code, Sec. VIII, Div. 1 _____ Heating fluid _____ Heating fluid flow rate (kg/hr) _____ Temperature (In/Out) (Deg. C) <u>/ /</u> Inlet pressure (barG) _____ Pressure drop (All/Calc) (kPa) <u>/</u> Design temperature (Deg. C) _____ Design pressure (barG) _____ Inlet/Outlet nozzle <u>/</u> Header Type <u>PLUG</u> Material <u>SA-240 TP316L</u> Corrosion Allowance (mm) <u>0</u> No. of passes <u>4</u>			

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)		  
	Thermal/Mechanical Calculation Book		شماره صفحه : 11 از 150
شماره پیمان: 053-073-9184	پروژه BK بسته کاری GCS صادرکننده AA تسهیلات 120 رشته PR نوع مدرک CN سریال 0001 نسخه V03		

		API 661 Air-Cooled Heat Exchanger - Specification Sheet																
Job No. _____ Page _____ Date _____ Proposal No. _____ Inquiry No. _____		Item No. 2102 (Summer) By _____ Revision V03 Contract No. _____ Order No. _____																
Design, Material, and Construction (continued)																		
Header (continued) Slope 1% ON LAST PASS Plug material SA-182 F316 L Gasket material Solid METAL Nozzle <table border="1"> <thead> <tr> <th>No.</th> <th>Size, (in)</th> <th>Rating/Facing</th> </tr> </thead> <tbody> <tr> <td>Inlet 1</td> <td>4</td> <td>600 RF</td> </tr> <tr> <td>Outlet 1</td> <td>4</td> <td>600 RF</td> </tr> <tr> <td>Vent 1</td> <td>2</td> <td>600 RF</td> </tr> <tr> <td>Drain 1</td> <td>2</td> <td>600 RF</td> </tr> </tbody> </table> Chemical Cleaning _____ Min. Wall Thk. _____ Tube Material SA-213 TP316L Tube (S) S31603 Tube outside diameter (mm) 25.4 wall thickness (mm) 1.651		No.	Size, (in)	Rating/Facing	Inlet 1	4	600 RF	Outlet 1	4	600 RF	Vent 1	2	600 RF	Drain 1	2	600 RF	No./Bundle 156 Length (m) 3.9 Pitch (mm) 69 Layout Triangular Fin Type Extruded Material Aluminum Alloy 1060 - O Thickness (mm) 0.48 Selection temp. (C) _____ Outside diameter (mm) 57.15 Fin density (fin/in) 10 ASME Code, Sec. VIII, Div. 1 Customer Specifications _____	
No.	Size, (in)	Rating/Facing																
Inlet 1	4	600 RF																
Outlet 1	4	600 RF																
Vent 1	2	600 RF																
Drain 1	2	600 RF																
Mechanical Equipment																		
Fan Manufacturer _____ No./Bay 2 RPM (Revs/min.) 658.6 Diameter (mm) 1450 No. of blades 5 Angle (degrees) _____ Pitch adjustment 50% Auto Blade material Al Hub material steel/Alu @design temp 3.5 @min. ambient temp 5.2 Tip speed _____ Driver Type _____ Manufacturer _____ No./Bay 2 Driver (kW) 7.5		RPM 1500 Service factor 1 Enclosure EExd, IIB T3 (IP 55) Voltage 400 Phase 3 Cycle 50 Fan noise level (dB) <85 Speed Reducer Type V-Belt Manufacturer _____ No./Bay 2 Service factor 1.8 Speed ratio 2.28 Support _____ Vib. switch _____ Enclosure _____																
Controls - Air Side																		
Air recirculation NO Degree control of outlet process temp. _____ (Max. Cooling), +/- _____ / _____ Action on control signal failure _____ Fan pitch _____ Louvers _____ Actuator air supply _____ Fan _____		Louvers _____ Positioner _____ Signal air pressure (barG) From _____ To _____ From _____ To _____ Supply air pressure (barG) From _____ To _____ From _____ To _____																
Shipping																		
Plot area (WxL) (m) 2.12 x 3.900 Bundle weight (Note 4) (kg) 3265.9 Bay (kg) _____		Total (kg) 10429 Shipping (kg) _____																
Note: 1-Reported duty and flow rates include a user-specified multiplier of 1.10 2-Maximum allowable nozzle load = 3 x API 3-Material will be meet requirements of NACE MR0175/ISO1516 and specification for material requirements in sour service (BK-GNRAI-PEDCO-000-FI-SP-0008) 4- HTRI Weights are reported																		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)		  		
	شماره پیمان: 053-073-9184		شماره صفحه: 12 از 150		
Thermal/Mechanical Calculation Book		نسخه: 0001 سریال: CN رسته: PR تسهیلات: 120 صادرکننده: AA بسته کاری: GCS پروژه: BK			

		API 661 Air-Cooled Heat Exchanger - Specification Sheet			
		Job No. _____ Page _____ Date 9/30/2024 Proposal No. _____ Inquiry No. _____	Item No. 2102 (w inter) By _____ Revision V03 Contract No. _____ Order No. _____		
Manufacturer _____ Model no. _____ Customer PEDCO/NISOC Plant location BINA K oil field Service 2st Stage Gas Compression Cook Type draft INDUCED Bay size (WxL) (m) 2.12 x 3.900 No. of bays/items 1		Heat exchanged (MegaWatts) 0.4519 Surface/Item-Finned tube (m2) 1010.5 Bare tube (m2) 48.548 MTD, Eff. (Deg. C) 34.6 Transfer rate-Finned (W/m2-K) 16.708 Bare tube, service (W/m2-K) 347.77 Bare tube, clean (W/m2-K) 381.55			
Basic design data					
Pressure design code _____ Tube bundle code stamped _____ Heating coil code stamped _____		Structural code _____ Flammable service _____ Lethal/toxic service _____			
Performance Data - Tube Side					
Fluid name HYDROCARBON Total fluid entering (kg/hr) 8343.5 Dew /bubble point (Deg. C) / Latent heat (kJ/kg) Inlet pressure (barG) 54.8 Pressure drop (AI/Calc) (bar) 0.7 / 0.083 Velocity (Allow /Calc) (m/s) / 3.77 Inside fouling resistance (m2-K/W) 0.0002 Temperature (Deg. C) In 149 Out 60		In Out Total flow rate (Liq/Vap) (kg/hr) / 8343.5 / 8343.5 Water/Steam (kg/hr) / / Noncondensables (kg/hr) / / Molecular Wt. (Vap/Non-cond) / / Density (Liq/Vap) (kg/m3) / 35.721 / 48.434 Specific heat (Liq/Vap) (kJ/kg-C) / 2.3379 / 2.0425 Thermal cond. (Liq/Vap) (W/m-K) / 0.0511 / 0.0382 Viscosity (Liq/Vap) (mN-s/m2) / 0.0149 / 0.0125			
Performance Data - Air Side					
Air inlet temperature (Deg. C) 50.26 Air flow rate/fan (m3/s) 26.97 Mass velocity (kg/s-m2) Air outlet temperature (Deg. C) 66.3 Air flow rate/fan (m3/s) 13.484		Face velocity (m/s) 2.9 Minimum design ambient temp. (Deg. C) 5 Altitude (m) 12.5 Static pressure (Pa) 141.64			
Design, Material, and Construction					
Design pressure (barG) 62 Test pressure (barG) 80.6 Design temperature (Deg. C) 175 Min. design metal temp. (Deg. C) Tube bundle Size (WxL) (m) 2.058 X 3.900 No./Bay 1 Number of tube rows 6 Bundles in parallel 1 Bundles in series Structure mounting Pipe rack beams Ladders, walkways, platforms Structure surface prep. Header surface prep. Louver Material YES Action control Manual Action type		Heating Coil NO No. of tubes Tube outside diameter (mm) Tube material Fin material and type Fin thickness (mm) ASME Code, Sec. VIII, Div. 1 Heating fluid Heating fluid flow rate (kg/hr) Temperature (In/Out) (Deg. C) / Inlet pressure (barG) Pressure drop (AI/Calc) (kPa) / Design temperature (Deg. C) Design pressure (barG) Inlet/Outlet nozzle / Header Type Material SA-240 TP316L Corrosion Allowance (mm) 0 No. of passes 4			

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							 			
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 13 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			

		API 661 Air-Cooled Heat Exchanger - Specification Sheet				
		Job No.			Item No.	2102 (w winter)
		Page			By	
		Date			Revision	V03
		Proposal No.			Contract No.	
		Inquiry No.			Order No.	
Design, Material, and Construction (continued)						
Header (continued)		1% ON LAST PASS SA-182 F316 L Solid METAL		No./Bundle 156 Length (m) 3.9 Pitch (mm) 69 Layout Triangular		
Nozzle Inlet Outlet Vent Drain Chemical Cleaning Min. Wall Thk.	No. 1 1 1 1 	Size, (in) 4 4 2 2 	Rating/Facing 600 RF 600 RF 600 RF 600 RF 	Fin Type Extruded Material Aluminum Alloy 1060 - O Thickness (mm) 0.48 Selection temp. (C) Outside diameter (mm) 57.15 Fin density (fin/in) 10 ASME Code, Sec. VIII, Div. 1 Customer Specifications		
Tube Material Tube outside diameter (mm) wall thickness (mm)	SA-213 TP316L Tube (S) S31603 25.4 1.651					
Mechanical Equipment						
Fan Manufacturer No./Bay RPM (Revs/min.) Diameter (mm) No. of blades Angle (degrees) Pitch adjustment Blade material Hub material @design temp @min. ambient temp Tip speed Driver Type Manufacturer No./Bay Driver (kW)		RPM 1500 Service factor 1 Enclosure Voltage 400 Phase 3 Cycle 50 Fan noise level (dB) <85 Speed Reducer Type V-Belt Manufacturer No./Bay 2 Service factor 1.8 Speed ratio 2.28 Support Vib. switch YES, Exd, IB T3 (IP 65) Enclosure				
Controls - Air Side						
Air recirculation NO Degree control of outlet process temp. (Max. Cooling), +/- Action on control signal failure Fan pitch Louvers Actuator air supply Fan		Louvers Positioner Signal air pressure (barG) From To From To Supply air pressure (barG) From To From To				
Shipping						
Plot area (WxL) (m) 2.12 x 3.900 Bundle weight (Note 4) (kg) 3265.9 Bay (kg)		Total (kg) 10429 Shipping (kg)				
Note: 1-Reported duty and flow rates include a user-specified multiplier of 1.10 2-Maximum allowable nozzle load = 3 x API 3-Material will be meet requirements of NACE MR0175/ISO1516 and specification for material requirments in sour service (BK-GNRL-PEDCO-000-PL-SP-0008) 4- HTRI Weights are reported						

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 14 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

3.0 MECHANICAL CALCULATION BOOK

3.1 STATIONARY HEADER CALCULATION @ DESIGN PRESSURE FOR AE-2101.

Input Echo, COMPONENT 1, Description: St.AE-2101

Figure Number Analyzed A8

Design Internal Pressure P 22.0000 bars
Design Temperature Temp 155.0000 C

VESEL MATERIAL DATA:
Material Specification SA-240 316L
Shell Allowable Stress at Design Temp S 114.3898 N./mm²
Shell Allowable Stress at Ambient SA 115.1465 N./mm²
Shell Yield Stress at Design Temperature Sy 129.8699 N./mm²

SHORT-SIDE VESSEL DATA:
Short-side Length Dimension H 160.0000 mm.
Minimum Thickness of Short-side Plates t1 20.0000 mm.
Mid-side Joint Efficiency on Short-side E 0.8500
Corner Joint Efficiency on Short-side EC 0.8500

LONG-SIDE VESSEL DATA:
Long-side Length Dimension h 122.0000 mm.
Minimum Thickness of Long-side Plates t2 20.0000 mm.
Mid-side Joint Efficiency on Long-side E 0.8500

ADDITIONAL VESSEL DATA:
Minimum Thickness of End Plate t5 20.0000 mm.
C-Factor for End Plate Cf_Epl 0.2000

Long-side Plate # 1,
Pitch Distance p 61.0000 mm.
Uniform Hole Diameter d0 25.6500 mm.
Depth of Holes T0 20.0000 mm.

Long-side Plate # 2,
Pitch Distance p 61.0000 mm.
1: Hole Diameter d0 36.3000 mm.
Hole Depth T0 2.7000 mm.
2: Hole Diameter d1 28.5750 mm.
Hole Depth T1 17.3000 mm.

STAY PLATE MATERIAL DATA:
Stay Material Specification SA-240 316L
Stay Allowable Stress at Design Temp Sr 114.3898 N./mm²
Stay Allowable Stress at Ambient SA 115.1465 N./mm²
Stay Yield Stress at Design Temp Sy 129.8699 N./mm²

STAY PLATE DATA:
Minimum Thickness of Stay t3 10.0000 mm.
Minimum Thickness of Stay t4 10.0000 mm.
The Stay(s) Are Not Welded to the End Plate



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 15 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

Short-side 1 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Short-side 2 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Long-side 1 Calculations

Effective Diameter [De]: 25.650 mm.

Membrane Ligament Efficiency [Em]:
= $Pitch - De / Pitch$
= $61.000 - 25.650 / 61.000$
= 0.580

Bending Ligament Efficiency [Eb]:
As diameter holes are uniform $E_b = E_m$
= 0.580

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 16 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Long-side 2 Calculations

Effective Diameter [De]:

$$= (d_0 * T_0 + d_1 * T_1 + d_2 * T_2) / (t_1 - CA)$$

$$= (36.30 * 2.70 + 28.57 * 17.30 + 0.00 * 0.00) / (20.00 - 0.00)$$

$$= 29.618 \text{ mm.}$$

Membrane Ligament Efficiency [Em]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 61.000 - 29.618 / 61.000$$

$$= 0.514$$

Dist from Neutral axis of c/s to extreme fibers [Ci & Co]:

Calculation of Xbar:

$$= ((b_0 * T_0 * (T_0/2 + T_1 + T_2)) + (b_1 * T_1 * (T_1/2 + T_2))) / (b_0 * T_0 + b_1 * T_1 + b_2 * T_2)$$

$$= ((0.97 * 2.70 * (2.70/2 + 17.30 + 0.00)) + (1.28 * 17.30 * (17.30/2 + 0.00))) / (0.97 * 2.70 + 1.28 * 17.30 + 2.40 * 0.00)$$

$$= 9.713 \text{ mm.}$$

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:

$$Ci = Xbar$$

$$= 9.713 \text{ mm.}$$

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t - CA - Xbar)$$

$$= -(20.000 - 0.000 - 9.713)$$

$$= -10.287 \text{ mm.}$$

Moment of Inertia (Section 13-6, Equation (5)) [I]:

$$= 0.079 \text{ cm}^4$$

Effective Diameter [De]:

$$= \text{Pitch} - ((6 * I) / ((t - CA)^2 * (-Co)))$$

$$= 61.00 - ((6 * 0.08) / ((20.00 - 0.00)^2 * (10.29)))$$

$$= 31.851 \text{ mm.}$$

Bending Ligament Efficiency [Eb]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 61.000 - 31.851 / 61.000$$

$$= 0.478$$

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

		Em	Eb	Ci	Co
Short-side	1	0.850	0.850	10.000	-10.000
	2	0.850	0.850	10.000	-10.000
Long-side	1	0.580	0.580	10.000	-10.000
	2	0.514	0.478	9.713	-10.287

Moment of Inertia of a Strip of the Vessel Wall:

$$\text{Thickness } t_1, I_1 = 0.0667 \text{ cm}^4$$

$$\text{Thickness } t_2, I_2 = 0.0667 \text{ cm}^4$$

Rectangular Vessel Parameters:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 17 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

$$\begin{aligned} \text{Alpha} &= H / h = 1.3115 \\ K &= (I2/I1) * \text{Alpha} = 1.3115 \end{aligned}$$

Membrane Stress Calculations per Section 13-9

Membrane Stresses at Short-side 1

Membrane Stress at Short-side 1 [Sms]:

$$\begin{aligned} &= P * h / (2 * t1) * \{ 3 - [(6 + K * \\ &\quad (11 - \text{alpha}^2) / (3 + 5 * K)] \} \\ &= 22.00 * 122.00 / (2 * 20.00) * \{ 3 - [(6 + 1.31 * \\ &\quad (11 - 1.31^2) / (3 + 5 * 1.31)] \} \\ &= 7.37 \text{ N./mm}^2 \end{aligned}$$

Membrane Stresses at Short-side 2

Membrane Stress at Short-side 2 [Sms]:

$$\begin{aligned} &= P * h / (2 * t1) * \{ 3 - [(6 + K * \\ &\quad (11 - \text{alpha}^2) / (3 + 5 * K)] \} \\ &= 22.00 * 122.00 / (2 * 20.00) * \{ 3 - [(6 + 1.31 * \\ &\quad (11 - 1.31^2) / (3 + 5 * 1.31)] \} \\ &= 7.37 \text{ N./mm}^2 \end{aligned}$$

Membrane Stresses at Long-side 1

Membrane Stress at Long-side 1 at A [Sml]:

$$\begin{aligned} &= P * H / 2 * t2 \\ &= 22.00 * 160.00 / 2 * 20.00 \\ &= 8.80 \text{ N./mm}^2 \end{aligned}$$

If $E_m(0.580) < E(0.850)$ and $E_b(0.580) < E(0.850)$ then

$$\begin{aligned} S_{ml} &= S_{ml} / E_m \\ &= 8.80 / 0.58 \\ &= 15.19 \text{ N./mm}^2 \end{aligned}$$

Membrane Stresses at Long-side 2

Membrane Stress at Long-side 2 at A [Sml]:

$$\begin{aligned} &= P * H / 2 * t2 \\ &= 22.00 * 160.00 / 2 * 20.00 \\ &= 8.80 \text{ N./mm}^2 \end{aligned}$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$\begin{aligned} S_{ml} &= S_{ml} / E_m \\ &= 8.80 / 0.51 \\ &= 17.11 \text{ N./mm}^2 \end{aligned}$$

Membrane Stresses at Stay Plate

Membrane Stress at Stay Plate [t3]:

$$\begin{aligned} &= P * h / (2 * t3) * [(6 + K * (11 - \\ &\quad \text{alpha}^2) / (3 + 5 * K)] \\ &= 22.00 * 122.00 / (2 * 10.00) * [(6 + 1.31 * (11 - \\ &\quad 1.31^2) / (3 + 5 * 1.31)] \\ &= 25.52 \text{ N./mm}^2 \end{aligned}$$

Membrane Stress at Stay Plate [t4]:

$$= P * h / (2 * t4) * [(6 + K * (11 - \text{alpha}^2) / (3 + 5 * K)]$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 18 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

$$= 22.00 * 122.00 / (2 * 10.00) * [(6 + 1.31 * (11 - 1.31^2) / (3 + 5 * 1.31))]$$

$$= 25.52 \text{ N./mm}^2$$

MEMBRANE STRESSES: Membrane Stress Calculations per Section 13-9, Equations (13-15). (N./mm²) :



STRESS LOCATIONS	Actual	Allowable
Short-side 1	7.37	97.23
Short-side 2	7.37	97.23
Short-side Corner	7.37	97.23
Long-side 1 at A	15.19	114.39
Long-side 2 at A	17.11	114.39
Long-side Corner	8.80	97.23
Stay Plate (t3)	25.52	114.39
Stay Plate (t4)	25.52	114.39

Bending Stress Calculations per Section 13-9

Bending Stresses at Short-side 1

Bending Stress at Short-side 1 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 22.00 * 10.00 / (24 * 0.07) * [-3 * 160.00^2 + 2 * 122.00^2 * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))]$$

$$= -44.45 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 22.00 * -10.00 / (24 * 0.07) * [-3 * 160.00^2 + 2 * 122.00^2 * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))]$$

$$= 44.45 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))$$

$$= 22.00 * 122.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))$$

$$= 61.15 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))$$

$$= 22.00 * 122.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))$$

$$= -61.15 \text{ N./mm}^2$$

Bending Stresses at Short-side 2

Bending Stress at Short-side 2 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 22.00 * 10.00 / (24 * 0.07) * [-3 * 160.00^2 + 2 * 122.00^2 * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))]$$

$$= -44.45 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at N Outer[SbsNo]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 19 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

$$\begin{aligned}
 &= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * \\
 &\quad ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))] \\
 &= 22.00 * -10.00 / (24 * 0.07) * [-3 * 160.00^2 + 2 * 122.00^2 * \\
 &\quad ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))] \\
 &= 44.45 \text{ N./mm}^2
 \end{aligned}$$



Bending Stress at Short-side 2 at Q Inner[SbsQi]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I1) * ((3 + 5 * \\
 &\quad Alpha^2 * K) / (3 + 5 * K)) \\
 &= 22.00 * 122.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * \\
 &\quad 1.31^2 * 1.31) / (3 + 5 * 1.31)) \\
 &= 61.15 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Short-side 2 at Q Outer[SbsQo]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I1) * ((3 + 5 * \\
 &\quad Alpha^2 * K) / (3 + 5 * K)) \\
 &= 22.00 * 122.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * \\
 &\quad 1.31^2 * 1.31) / (3 + 5 * 1.31)) \\
 &= -61.15 \text{ N./mm}^2
 \end{aligned}$$

Bending Stresses at Long-side 1

Bending Stress at Long-side 1 at M Inner[SblMi]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I2) * [(3 + K * \\
 &\quad (6 - Alpha^2)) / (3 + 5 * K)] \\
 &= 22.00 * 122.00^2 * 10.00 / (12 * 0.07) * [(3 + 1.31 * \\
 &\quad (6 - 1.31^2)) / (3 + 5 * 1.31)] \\
 &= 36.89 \text{ N./mm}^2
 \end{aligned}$$

If $Em(0.580) < E(0.850)$ and $Eb(0.580) < E(0.850)$ then

$$\begin{aligned}
 SblMi &= SblMi / Eb \\
 &= 36.89 / 0.58 \\
 &= 63.66 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Long-side 1 at M Outer[SblMo]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I2) * [(3 + K * \\
 &\quad (6 - Alpha^2)) / (3 + 5 * K)] \\
 &= 22.00 * 122.00^2 * -10.00 / (12 * 0.07) * [(3 + 1.31 * \\
 &\quad (6 - 1.31^2)) / (3 + 5 * 1.31)] \\
 &= -36.89 \text{ N./mm}^2
 \end{aligned}$$

If $Em(0.580) < E(0.850)$ and $Eb(0.580) < E(0.850)$ then

$$\begin{aligned}
 SblMo &= SblMo / Eb \\
 &= -36.89 / 0.58 \\
 &= -63.66 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Long-side 1 at Q Inner[SblQi]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I2) * [(3 + 5 * \\
 &\quad Alpha^2 * K) / (3 + 5 * K)] \\
 &= 22.00 * 122.00^2 * 10.00 / (12 * 0.07) * [(3 + 5 * \\
 &\quad 1.31^2 * 1.31) / (3 + 5 * 1.31)] \\
 &= 61.15 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Long-side 1 at Q Outer[SblQo]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I2) * [(3 + 5 * \\
 &\quad Alpha^2 * K) / (3 + 5 * K)] \\
 &= 22.00 * 122.00^2 * -10.00 / (12 * 0.07) * [(3 + 5 * \\
 &\quad 1.31^2 * 1.31) / (3 + 5 * 1.31)] \\
 &= -61.15 \text{ N./mm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 20 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Bending Stresses at Long-side 2

Bending Stress at Long-side 2 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 22.00 * 122.00^2 * 9.71 / (12 * 0.07) * [(3 + 1.31 * (6 - 1.31^2)) / (3 + 5 * 1.31)]$$

$$= 35.83 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$SblMi = SblMi / E_b$$

$$= 35.83 / 0.48$$

$$= 74.98 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 22.00 * 122.00^2 * -10.29 / (12 * 0.07) * [(3 + 1.31 * (6 - 1.31^2)) / (3 + 5 * 1.31)]$$

$$= -37.95 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$SblMo = SblMo / E_b$$

$$= -37.95 / 0.48$$

$$= -79.42 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 22.00 * 122.00^2 * 9.71 / (12 * 0.07) * [(3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31)]$$

$$= 59.40 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 22.00 * 122.00^2 * -10.29 / (12 * 0.07) * [(3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31)]$$

$$= -62.91 \text{ N./mm}^2$$

BENDING STRESSES: Bending Stress Calculations per Section 13-9, Equations (16-19). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-44.45	44.45	145.85
at Q	61.15	-61.15	145.85
Short-side 2 at N	-44.45	44.45	145.85
at Q	61.15	-61.15	145.85
Long-side 1 at M	63.66	-63.66	171.58
at Q	61.15	-61.15	145.85
Long-side 2 at M	74.98	-79.42	171.58
at Q	59.40	-62.91	145.85

Total Stress Calculations per Section 13-9

Total Stresses at Short-side 1

Total Stress at short side 1 at N inner [STS_Ni]:



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 21 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 7.37 + -44.45 \\
 &= -37.08 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 7.37 + 44.45 \\
 &= 51.83 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 7.37 + 61.15 \\
 &= 68.53 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 7.37 + -61.15 \\
 &= -53.78 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Short-side 2

Total Stress at short side 2 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 7.37 + -44.45 \\
 &= -37.08 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 7.37 + 44.45 \\
 &= 51.83 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 7.37 + 61.15 \\
 &= 68.53 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 7.37 + -61.15 \\
 &= -53.78 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Long-side 1

Total Stress at long side 1 at M inner [STL_Mi]:

$$\begin{aligned}
 &= S_{ml} + S_{blMi} \\
 &= 15.19 + 63.66 \\
 &= 78.84 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at M outer [STL_Mo]:

$$\begin{aligned}
 &= S_{ml} + S_{blMo} \\
 &= 15.19 + -63.66 \\
 &= -48.47 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q inner [STL_Qi]:

$$\begin{aligned}
 &= S_{ml} + S_{blQi} \\
 &= 8.80 + 61.15 \\
 &= 69.95 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q outer [STL_Qo]:

$$= S_{mlB} + S_{blQo}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)										
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 22 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			

$$= 8.80 + -61.15$$

$$= -52.35 \text{ N./mm}^2$$

Total Stresses at Long-side 2

Total Stress at long side 2 at M inner [STL_Mi]:

$$= S_{ml} + S_{blMi}$$

$$= 17.11 + 74.98$$

$$= 92.08 \text{ N./mm}^2$$

Total Stress at long side 2 at M outer [STL_Mo]:

$$= S_{ml} + S_{blMo}$$

$$= 17.11 + -79.42$$

$$= -62.31 \text{ N./mm}^2$$

Total Stress at long side 2 at Q inner [STL_Qi]:

$$= S_{ml} + S_{blQi}$$

$$= 8.80 + 59.40$$

$$= 68.20 \text{ N./mm}^2$$

Total Stress at long side 2 at Q outer [STL_Qo]:

$$= S_{mlB} + S_{blQo}$$

$$= 8.80 + -62.91$$

$$= -54.11 \text{ N./mm}^2$$

TOTAL STRESSES: Total Stress Calculations per Section 13-9, Equations (20-24). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-37.08	51.83	145.85
at Q	68.53	-53.78	145.85
Short-side 2 at N	-37.08	51.83	145.85
at Q	68.53	-53.78	145.85
Long-side 1 at M	78.84	-48.47	171.58
at Q	69.95	-52.35	145.85
Long-side 2 at M	92.08	-62.31	171.58
at Q	68.20	-54.11	145.85

End Plate Stresses (N./mm²):

	Actual	Allowable
End Plate	67.73	114.39

Required End Plate thickness due to Internal Pressure [trEP]:

$$= d * \sqrt{Z * C * P / (SE)} + ca$$

$$= 160.000 * \sqrt{2.405 * 0.200 * 22.000 / (114.390)} + 0.000$$

$$= 15.390 \text{ mm.}$$

End Plate MAWP at given Thickness [MAWPEP]:

$$= ((T-ca)/d)^2 * ((SE)/(C*Z)) \text{ per UG-34 (c)(3)}$$

$$= ((20.0000-0.0000)/160.0000)^2 * ((114)/(0.20*2.41))$$

$$= 37.154 \text{ bars}$$

where Z is:

$$= \min(3.4 - 2.4(d/D), 2.5)$$

$$= \min(3.4 - 2.4(160.000 / 386.000), 2.5)$$

$$= 2.405$$

SUMMARY OF RESULTS:



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 23 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	25.52	N./mm ²
High Stress Percentage	22.31	%
M.A.W.P. for Membrane Stresses	98.63	bars

BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-79.42	N./mm ²
High Stress Percentage	46.28	%
M.A.W.P. for Bending Stresses	47.53	bars

TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	92.08	N./mm ²
High Stress Percentage	53.67	%
M.A.W.P. for Total Stresses	40.99	bars



Rectangular Vessel Results For Item 1 : A8

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	25.52	N./mm ²
High Stress Percentage	22.31	%
M.A.W.P. for Membrane Stresses	98.63	bars

BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-79.42	N./mm ²
High Stress Percentage	46.28	%
M.A.W.P. for Bending Stresses	47.53	bars

TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	92.08	N./mm ²
High Stress Percentage	53.67	%
M.A.W.P. for Total Stresses	40.99	bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 24 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

3.2 STATIONARY HEADER CALCULATION @ TEST PRESSURE FOR AE-2101.

Input Echo, COMPONENT 1, Description: St.AE-2101

Figure Number Analyzed	A8		
Design Internal Pressure	P	28.6000	bars
Design Temperature	Temp	25.0000	C
VESSEL MATERIAL DATA:			
Material Specification		SA-240 316L	
Shell Allowable Stress at Design Temp	S	155.0000	N./mm ²
Shell Allowable Stress at Ambient	SA	155.0000	N./mm ²
Shell Yield Stress at Design Temperature	Sy	172.3750	N./mm ²
SHORT-SIDE VESSEL DATA:			
Short-side Length Dimension	H	160.0000	mm.
Minimum Thickness of Short-side Plates	t1	20.0000	mm.
Mid-side Joint Efficiency on Short-side	E	0.8500	
Corner Joint Efficiency on Short-side	EC	0.8500	
LONG-SIDE VESSEL DATA:			
Long-side Length Dimension	h	122.0000	mm.
Minimum Thickness of Long-side Plates	t2	20.0000	mm.
Mid-side Joint Efficiency on Long-side	E	0.8500	
ADDITIONAL VESSEL DATA:			
Minimum Thickness of End Plate	t5	20.0000	mm.
C-Factor for End Plate	Cf_Epl	0.2000	
Long-side Plate # 1,			
Pitch Distance	p	61.0000	mm.
Uniform Hole Diameter	d0	25.6500	mm.
Depth of Holes	T0	20.0000	mm.
Long-side Plate # 2,			
Pitch Distance	p	61.0000	mm.
# 1: Hole Diameter	d0	36.3000	mm.
Hole Depth	T0	2.7000	mm.
# 2: Hole Diameter	d1	28.5750	mm.
Hole Depth	T1	17.3000	mm.
STAY PLATE MATERIAL DATA:			
Stay Material Specification		SA-240 316L	
Stay Allowable Stress at Design Temp	Sr	114.3898	N./mm ²
Stay Allowable Stress at Ambient	SA	115.1465	N./mm ²
Stay Yield Stress at Design Temp	Sy	129.8699	N./mm ²
STAY PLATE DATA:			
Minimum Thickness of Stay	t3	10.0000	mm.
Minimum Thickness of Stay	t4	10.0000	mm.
The Stay(s) Are Not Welded to the End Plate			



Rectangular Vessel Results, Item number 1, Desc: St.AE-2101
ASME Code, Section VIII, Division 1, 2019 App. 13

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

Short-side 1 Calculations

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 - 073 - 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 25 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vesssel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Short-side 2 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vesssel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Long-side 1 Calculations

Effective Diameter [De]: 25.650 mm.

Membrane Ligament Efficiency [Em]:
= $Pitch - De / Pitch$
= $61.000 - 25.650 / 61.000$
= 0.580

Bending Ligament Efficiency [Eb]:
As diameter holes are uniform $E_b = E_m$
= 0.580

Dist from Neutral axis of c/s to inside surface of the vesssel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Long-side 2 Calculations

Effective Diameter [De]:



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 26 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= (d_0 * T_0 + d_1 * T_1 + d_2 * T_2) / (t_1 - CA)$$

$$= (36.30 * 2.70 + 28.57 * 17.30 + 0.00 * 0.00) / (20.00 - 0.00)$$

$$= 29.618 \text{ mm.}$$

Membrane Ligament Efficiency [Em]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 61.000 - 29.618 / 61.000$$

$$= 0.514$$



Dist from Neutral axis of c/s to extreme fibers [Ci & Co]:

Calculation of Xbar:

$$= ((b_0 * T_0 * (T_0/2 + T_1 + T_2)) + (b_1 * T_1 * (T_1/2 + T_2)) + (b_2 * T_2 * (T_2/2))) / (b_0 * T_0 + b_1 * T_1 + b_2 * T_2)$$

$$= ((0.97 * 2.70 * (2.70/2 + 17.30 + 0.00)) + (1.28 * 17.30 * (17.30/2 + 0.00)) + (2.40 * 0.00 * (0.00/2))) / (0.97 * 2.70 + 1.28 * 17.30 + 2.40 * 0.00)$$

$$= 9.713 \text{ mm.}$$

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:

$$Ci = Xbar$$

$$= 9.713 \text{ mm.}$$

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t - CA - Xbar)$$

$$= -(20.000 - 0.000 - 9.713)$$

$$= -10.287 \text{ mm.}$$

Moment of Inertia (Section 13-6, Equation (5)) [I]:

$$= 0.079 \text{ cm}^4$$

Effective Diameter [De]:

$$= \text{Pitch} - ((6 * I) / ((t - CA)^2 * (-Co)))$$

$$= 61.00 - ((6 * 0.08) / ((20.00 - 0.00)^2 * (10.29)))$$

$$= 31.851 \text{ mm.}$$

Bending Ligament Efficiency [Eb]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 61.000 - 31.851 / 61.000$$

$$= 0.478$$

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

	Em	Eb	Ci	Co
Short-side 1	0.850	0.850	10.000	-10.000
2	0.850	0.850	10.000	-10.000
Long-side 1	0.580	0.580	10.000	-10.000
2	0.514	0.478	9.713	-10.287

Moment of Inertia of a Strip of the Vessel Wall:

$$\text{Thickness } t_1, I_1 = 0.0667 \text{ cm}^4$$

$$\text{Thickness } t_2, I_2 = 0.0667 \text{ cm}^4$$

Rectangular Vessel Parameters:

$$\text{Alpha} = H / h = 1.3115$$

$$K = (I_2/I_1) * \text{Alpha} = 1.3115$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 27 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Membrane Stress Calculations per Section 13-9

Membrane Stresses at Short-side 1

Membrane Stress at Short-side 1 [Sms]:

$$\begin{aligned}
 &= P * h / (2 * t_1) * \{ 3 - [(6 + K * \\
 &\quad (11 - \alpha^2) / (3 + 5 * K)] \} \\
 &= 28.60 * 122.00 / (2 * 20.00) * \{ 3 - [(6 + 1.31 * \\
 &\quad (11 - 1.31^2) / (3 + 5 * 1.31)] \} \\
 &= 9.59 \text{ N./mm}^2
 \end{aligned}$$

Membrane Stresses at Short-side 2

Membrane Stress at Short-side 2 [Sms]:

$$\begin{aligned}
 &= P * h / (2 * t_1) * \{ 3 - [(6 + K * \\
 &\quad (11 - \alpha^2) / (3 + 5 * K)] \} \\
 &= 28.60 * 122.00 / (2 * 20.00) * \{ 3 - [(6 + 1.31 * \\
 &\quad (11 - 1.31^2) / (3 + 5 * 1.31)] \} \\
 &= 9.59 \text{ N./mm}^2
 \end{aligned}$$

Membrane Stresses at Long-side 1

Membrane Stress at Long-side 1 at A [Sml]:

$$\begin{aligned}
 &= P * H / 2 * t_2 \\
 &= 28.60 * 160.00 / 2 * 20.00 \\
 &= 11.44 \text{ N./mm}^2
 \end{aligned}$$

If $E_m(0.580) < E(0.850)$ and $E_b(0.580) < E(0.850)$ then

$$\begin{aligned}
 S_{ml} &= S_{ml} / E_m \\
 &= 11.44 / 0.58 \\
 &= 19.74 \text{ N./mm}^2
 \end{aligned}$$

Membrane Stresses at Long-side 2

Membrane Stress at Long-side 2 at A [Sml]:

$$\begin{aligned}
 &= P * H / 2 * t_2 \\
 &= 28.60 * 160.00 / 2 * 20.00 \\
 &= 11.44 \text{ N./mm}^2
 \end{aligned}$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$\begin{aligned}
 S_{ml} &= S_{ml} / E_m \\
 &= 11.44 / 0.51 \\
 &= 22.24 \text{ N./mm}^2
 \end{aligned}$$

Membrane Stresses at Stay Plate

Membrane Stress at Stay Plate [t3]:

$$\begin{aligned}
 &= P * h / (2 * t_3) * [(6 + K * (11 - \\
 &\quad \alpha^2) / (3 + 5 * K)] \\
 &= 28.60 * 122.00 / (2 * 10.00) * [(6 + 1.31 * (11 - \\
 &\quad 1.31^2) / (3 + 5 * 1.31)] \\
 &= 33.17 \text{ N./mm}^2
 \end{aligned}$$


Membrane Stress at Stay Plate [t4]:

$$\begin{aligned}
 &= P * h / (2 * t_4) * [(6 + K * (11 - \\
 &\quad \alpha^2) / (3 + 5 * K)] \\
 &= 28.60 * 122.00 / (2 * 10.00) * [(6 + 1.31 * (11 - \\
 &\quad 1.31^2) / (3 + 5 * 1.31)] \\
 &= 33.17 \text{ N./mm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 28 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

**MEMBRANE STRESSES: Membrane Stress Calculations per Section 13-9,
Equations (13-15). (N./mm²) :**

STRESS LOCATIONS	Actual	Allowable
Short-side 1	9.59	131.75
Short-side 2	9.59	131.75
Short-side Corner	9.59	131.75
Long-side 1 at A	19.74	155.00
Long-side 2 at A	22.24	155.00
Long-side Corner	11.44	131.75
Stay Plate (t3)	33.17	114.39
Stay Plate (t4)	33.17	114.39



Bending Stress Calculations per Section 13-9

Bending Stresses at Short-side 1

Bending Stress at Short-side 1 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 28.60 * 10.00 / (24 * 0.07) * [-3 * 160.00^2 + 2 * 122.00^2 * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))]$$

$$= -57.79 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 28.60 * -10.00 / (24 * 0.07) * [-3 * 160.00^2 + 2 * 122.00^2 * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))]$$

$$= 57.79 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))$$

$$= 28.60 * 122.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))$$

$$= 79.50 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))$$

$$= 28.60 * 122.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))$$

$$= -79.50 \text{ N./mm}^2$$

Bending Stresses at Short-side 2

Bending Stress at Short-side 2 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 28.60 * 10.00 / (24 * 0.07) * [-3 * 160.00^2 + 2 * 122.00^2 * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))]$$

$$= -57.79 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 28.60 * -10.00 / (24 * 0.07) * [-3 * 160.00^2 + 2 * 122.00^2 * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))]$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 29 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

$$= 57.79 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K))$$

$$= 28.60 * 122.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))$$

$$= 79.50 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K))$$

$$= 28.60 * 122.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31))$$

$$= -79.50 \text{ N./mm}^2$$

Bending Stresses at Long-side 1

Bending Stress at Long-side 1 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 28.60 * 122.00^2 * 10.00 / (12 * 0.07) * [(3 + 1.31 * (6 - 1.31^2)) / (3 + 5 * 1.31)]$$

$$= 47.96 \text{ N./mm}^2$$

If $E_m(0.580) < E(0.850)$ and $E_b(0.580) < E(0.850)$ then

$$SblMi = SblMi / E_b$$

$$= 47.96 / 0.58$$

$$= 82.75 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 28.60 * 122.00^2 * -10.00 / (12 * 0.07) * [(3 + 1.31 * (6 - 1.31^2)) / (3 + 5 * 1.31)]$$

$$= -47.96 \text{ N./mm}^2$$

If $E_m(0.580) < E(0.850)$ and $E_b(0.580) < E(0.850)$ then

$$SblMo = SblMo / E_b$$

$$= -47.96 / 0.58$$

$$= -82.75 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 28.60 * 122.00^2 * 10.00 / (12 * 0.07) * [(3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31)]$$

$$= 79.50 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 28.60 * 122.00^2 * -10.00 / (12 * 0.07) * [(3 + 5 * 1.31^2 * 1.31) / (3 + 5 * 1.31)]$$

$$= -79.50 \text{ N./mm}^2$$

Bending Stresses at Long-side 2

Bending Stress at Long-side 2 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 30 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

$$= \frac{(6 - \alpha^2)}{(3 + 5 * K)} \cdot \left[\frac{28.60 * 122.00^2 * 9.71}{12 * 0.07} \right] * [(3 + 1.31 * \frac{(6 - 1.31^2)}{(3 + 5 * 1.31)})]$$

$$= 46.58 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$S_{blMi} = S_{blMi} / E_b$$

$$= 46.58 / 0.48$$

$$= 97.47 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \frac{(6 - \alpha^2)}{(3 + 5 * K)})]$$

$$= 28.60 * 122.00^2 * -10.29 / (12 * 0.07) * [(3 + 1.31 * \frac{(6 - 1.31^2)}{(3 + 5 * 1.31)})]$$

$$= -49.33 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$S_{blMo} = S_{blMo} / E_b$$

$$= -49.33 / 0.48$$

$$= -103.24 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \frac{\alpha^2 * K}{(3 + 5 * K)})]$$

$$= 28.60 * 122.00^2 * 9.71 / (12 * 0.07) * [(3 + 5 * \frac{1.31^2 * 1.31}{(3 + 5 * 1.31)})]$$

$$= 77.21 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \frac{\alpha^2 * K}{(3 + 5 * K)})]$$

$$= 28.60 * 122.00^2 * -10.29 / (12 * 0.07) * [(3 + 5 * \frac{1.31^2 * 1.31}{(3 + 5 * 1.31)})]$$

$$= -81.78 \text{ N./mm}^2$$

BENDING STRESSES: Bending Stress Calculations per Section 13-9, Equations (16-19). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-57.79	57.79	197.62
at Q	79.50	-79.50	197.62
Short-side 2 at N	-57.79	57.79	197.62
at Q	79.50	-79.50	197.62
Long-side 1 at M	82.75	-82.75	232.50
at Q	79.50	-79.50	197.62
Long-side 2 at M	97.47	-103.24	232.50
at Q	77.21	-81.78	197.62

Total Stress Calculations per Section 13-9

Total Stresses at Short-side 1

Total Stress at short side 1 at N inner [STS_Ni]:

$$= S_{ms} + S_{bsNi}$$

$$= 9.59 + -57.79$$

$$= -48.20 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 - 073 - 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 31 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

Total Stress at short side 1 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 9.59 + 57.79 \\
 &= 67.37 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 9.59 + 79.50 \\
 &= 89.08 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 9.59 + -79.50 \\
 &= -69.91 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Short-side 2

Total Stress at short side 2 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 9.59 + -57.79 \\
 &= -48.20 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 9.59 + 57.79 \\
 &= 67.37 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 9.59 + 79.50 \\
 &= 89.08 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 9.59 + -79.50 \\
 &= -69.91 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Long-side 1

Total Stress at long side 1 at M inner [STL_Mi]:

$$\begin{aligned}
 &= S_{ml} + S_{blMi} \\
 &= 19.74 + 82.75 \\
 &= 102.50 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at M outer [STL_Mo]:

$$\begin{aligned}
 &= S_{ml} + S_{blMo} \\
 &= 19.74 + -82.75 \\
 &= -63.01 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q inner [STL_Qi]:

$$\begin{aligned}
 &= S_{ml} + S_{blQi} \\
 &= 11.44 + 79.50 \\
 &= 90.94 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q outer [STL_Qo]:

$$\begin{aligned}
 &= S_{ml} + S_{blQo} \\
 &= 11.44 + -79.50 \\
 &= -68.06 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Long-side 2

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 32 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Total Stress at long side 2 at M inner [STL_Mi]:

$$= S_{ml} + S_{blMi}$$

$$= 22.24 + 97.47$$

$$= 119.71 \text{ N./mm}^2$$

Total Stress at long side 2 at M outer [STL_Mo]:

$$= S_{ml} + S_{blMo}$$

$$= 22.24 + -103.24$$

$$= -81.00 \text{ N./mm}^2$$

Total Stress at long side 2 at Q inner [STL_Qi]:

$$= S_{ml} + S_{blQi}$$

$$= 11.44 + 77.21$$

$$= 88.65 \text{ N./mm}^2$$

Total Stress at long side 2 at Q outer [STL_Qo]:

$$= S_{mlB} + S_{blQo}$$

$$= 11.44 + -81.78$$

$$= -70.34 \text{ N./mm}^2$$

**TOTAL STRESSES: Total Stress Calculations per Section 13-9,
Equations (20-24). (N./mm²) :**

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-48.20	67.37	197.62
at Q	89.08	-69.91	197.62
Short-side 2 at N	-48.20	67.37	197.62
at Q	89.08	-69.91	197.62
Long-side 1 at M	102.50	-63.01	232.50
at Q	90.94	-68.06	197.62
Long-side 2 at M	119.71	-81.00	232.50
at Q	88.65	-70.34	197.62

End Plate Stresses (N./mm²):

	Actual	Allowable
End Plate	88.05	155.00

Required End Plate thickness due to Internal Pressure [trEP]:

$$= d * \sqrt{Z * C * P / (SE)} + ca$$

$$= 160.000 * \sqrt{2.405 * 0.200 * 28.600 / (155.000)} + 0.000$$

$$= 15.074 \text{ mm.}$$

End Plate MAWP at given Thickness [MAWPEP]:

$$= ((T-ca)/d)^2 * ((SE)/(C*Z)) \text{ per UG-34 (c)(3)}$$

$$= ((20.0000-0.0000)/160.0000)^2 * ((155)/(.20*2.41))$$

$$= 50.344 \text{ bars}$$

where Z is:

$$= \min(3.4 - 2.4(d/D), 2.5)$$

$$= \min(3.4 - 2.4(160.000 / 386.000), 2.5)$$

$$= 2.405$$

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	33.17	N./mm ²
High Stress Percentage	29.00	%

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 33 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

M.A.W.P. for Membrane Stresses 98.63 bars

BENDING STRESS SUMMARY,
High Stress (Highest % of Allowable) -103.24 N./mm²
High Stress Percentage 44.40 %
M.A.W.P. for Bending Stresses 64.41 bars

TOTAL STRESS SUMMARY,
High Stress (Highest % of Allowable) 119.71 N./mm²
High Stress Percentage 51.49 %
M.A.W.P. for Total Stresses 55.55 bars



Rectangular Vessel Results For Item 1 : A8

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,
High Stress (Highest % of Allowable) 33.17 N./mm²
High Stress Percentage 29.00 %
M.A.W.P. for Membrane Stresses 98.63 bars

BENDING STRESS SUMMARY,
High Stress (Highest % of Allowable) -103.24 N./mm²
High Stress Percentage 44.40 %
M.A.W.P. for Bending Stresses 64.41 bars

TOTAL STRESS SUMMARY,
High Stress (Highest % of Allowable) 119.71 N./mm²
High Stress Percentage 51.49 %
M.A.W.P. for Total Stresses 55.55 bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 34 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

3.3 FLOATING HEADER CALCULATION @ DESIGN PRESSURE FOR AE-2101.

Input Echo, COMPONENT 1, Description: FI.AE-2101

Figure Number Analyzed	A7		
Design Internal Pressure	P	22.0000	bars
Design Temperature	Temp	155.0000	C
VESSEL MATERIAL DATA:			
Material Specification		SA-240 316L	
Shell Allowable Stress at Design Temp	S	114.3898	N./mm ²
Shell Allowable Stress at Ambient	SA	115.1465	N./mm ²
Shell Yield Stress at Design Temperature	Sy	129.8699	N./mm ²
SHORT-SIDE VESSEL DATA:			
Short-side Length Dimension	H	100.0000	mm.
Minimum Thickness of Short-side Plates	t1	15.0000	mm.
Mid-side Joint Efficiency on Short-side	E	0.8500	
Corner Joint Efficiency on Short-side	EC	0.8500	
LONG-SIDE VESSEL DATA:			
Long-side Length Dimension	h	122.0000	mm.
Minimum Thickness of Long-side Plates	t2	20.0000	mm.
Mid-side Joint Efficiency on Long-side	E	0.8500	
ADDITIONAL VESSEL DATA:			
Minimum Thickness of End Plate	t5	20.0000	mm.
C-Factor for End Plate	Cf_Epl	0.2000	
Long-side Plate # 1,			
Pitch Distance	p	61.0000	mm.
Uniform Hole Diameter	d0	25.6500	mm.
Depth of Holes	T0	20.0000	mm.
Long-side Plate # 2,			
Pitch Distance	p	61.0000	mm.
# 1: Hole Diameter	d0	36.3000	mm.
Hole Depth	T0	2.7000	mm.
# 2: Hole Diameter	d1	28.5750	mm.
Hole Depth	T1	17.3000	mm.
STAY PLATE MATERIAL DATA:			
Stay Material Specification		SA-240 316L	
Stay Allowable Stress at Design Temp	Sr	114.3898	N./mm ²
Stay Allowable Stress at Ambient	SA	115.1465	N./mm ²
Stay Yield Stress at Design Temp	Sy	129.8699	N./mm ²
STAY PLATE DATA:			
Minimum Thickness of Stay	t3	10.0000	mm.
The Stay(s) Are Not Welded to the End Plate			

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 35 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Rectangular Vessel Results, Item number 1, Desc: FI.AE-2101
ASME Code, Section VIII, Division 1, 2019 App. 13

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

Short-side 1 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $15.000 - 0.000 / 2$
= 7.500 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(15.000 - 0.000) / 2$
= -7.500 mm.

Short-side 2 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $15.000 - 0.000 / 2$
= 7.500 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(15.000 - 0.000) / 2$
= -7.500 mm.

Long-side 1 Calculations

Effective Diameter [De]: 25.700 mm.

Membrane Ligament Efficiency [Em]:
= $Pitch - De / Pitch$
= $61.000 - 25.700 / 61.000$
= 0.579

Bending Ligament Efficiency [Eb]:
As diameter holes are uniform $Eb = Em$
= 0.579

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 36 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t_1 - CA) / 2$$

$$= -(20.000 - 0.000) / 2$$

$$= -10.000 \text{ mm.}$$

Long-side 2 Calculations

Effective Diameter [De]:

$$= (d_0 * T_0 + d_1 * T_1 + d_2 * T_2) / (t_1 - CA)$$

$$= (36.30 * 2.70 + 28.57 * 17.30 + 0.00 * 0.00) / (20.00 - 0.00)$$

$$= 29.618 \text{ mm.}$$

Membrane Ligament Efficiency [Em]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 61.000 - 29.618 / 61.000$$

$$= 0.514$$

Dist from Neutral axis of c/s to extreme fibers [Ci & Co]:

Calculation of Xbar:

$$= ((b_0 * T_0 * (T_0/2 + T_1 + T_2)) + (b_1 * T_1 * (T_1/2 + T_2)) + (b_2 * T_2 * (T_2/2))) / (b_0 * T_0 + b_1 * T_1 + b_2 * T_2)$$

$$= ((0.97 * 2.70 * (2.70/2 + 17.30 + 0.00)) + (1.28 * 17.30 * (17.30/2 + 0.00)) + (2.40 * 0.00 * (0.00/2))) / (0.97 * 2.70 + 1.28 * 17.30 + 2.40 * 0.00)$$

$$= 9.713 \text{ mm.}$$

Dist from Neutral axis of c/s to inside surface of the vesssel [Ci]:

$$Ci = Xbar$$

$$= 9.713 \text{ mm.}$$

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t - CA - Xbar)$$

$$= -(20.000 - 0.000 - 9.713)$$

$$= -10.287 \text{ mm.}$$

Moment of Inertia (Section 13-6, Equation (5)) [I]:

$$= 0.079 \text{ cm}^4$$

Effective Diameter [De]:

$$= \text{Pitch} - ((6 * I) / ((t - CA)^2 * (-Co)))$$

$$= 61.00 - ((6 * 0.08) / ((20.00 - 0.00)^2 * (10.29)))$$

$$= 31.851 \text{ mm.}$$

Bending Ligament Efficiency [Eb]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 61.000 - 31.851 / 61.000$$

$$= 0.478$$

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

		Em	Eb	Ci	Co
Short-side	1	0.850	0.850	7.500	-7.500
	2	0.850	0.850	7.500	-7.500
Long-side	1	0.579	0.579	10.000	-10.000
	2	0.514	0.478	9.713	-10.287

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 37 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Moment of Inertia of a Strip of the Vessel Wall:

$$\text{Thickness } t_1, I_1 = 0.0281 \text{ cm}^4$$

$$\text{Thickness } t_2, I_2 = 0.0667 \text{ cm}^4$$

Rectangular Vessel Parameters:

$$\alpha = H / h = 0.8197$$

$$K = (I_2 / I_1) * \alpha = 1.9429$$

Membrane Stress Calculations per Section 13-9

Membrane Stresses at Short-side 1

Membrane Stress at Short-side 1 [Sms]:

$$= p * h / (4 * t_1) * \{ 4 - [(2 + K * (5 - \alpha^2)) / (1 + 2 * K)] \}$$

$$= 22.00 * 122.00 / (4 * 15.00) * \{ 4 - [(2 + 1.94 * (5 - 0.82^2)) / (1 + 2 * 1.94)] \}$$

$$= 8.36 \text{ N./mm}^2$$

Membrane Stresses at Short-side 2

Membrane Stress at Short-side 2 [Sms]:

$$= p * h / (4 * t_1) * \{ 4 - [(2 + K * (5 - \alpha^2)) / (1 + 2 * K)] \}$$

$$= 22.00 * 122.00 / (4 * 15.00) * \{ 4 - [(2 + 1.94 * (5 - 0.82^2)) / (1 + 2 * 1.94)] \}$$

$$= 8.36 \text{ N./mm}^2$$

Membrane Stresses at Long-side 1

Membrane Stress at Long-side 1 at A [Sml]:

$$= P * H / 2 * t_2$$

$$= 22.00 * 100.00 / 2 * 20.00$$

$$= 5.50 \text{ N./mm}^2$$

If $E_m(0.579) < E(0.850)$ and $E_b(0.579) < E(0.850)$ then

$$S_{ml} = S_{ml} / E_m$$

$$= 5.50 / 0.58$$

$$= 9.50 \text{ N./mm}^2$$

Membrane Stresses at Long-side 2

Membrane Stress at Long-side 2 at A [Sml]:

$$= P * H / 2 * t_2$$

$$= 22.00 * 100.00 / 2 * 20.00$$

$$= 5.50 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$S_{ml} = S_{ml} / E_m$$

$$= 5.50 / 0.51$$

$$= 10.69 \text{ N./mm}^2$$

Membrane Stresses at Stay Plate

Membrane Stress at Stay Plate [Smsp]:

$$= P * h / (2 * t_3) * [(2 + K * (5 - \alpha^2)) / (1 + 2 * K)]$$

$$= 22.00 * 122.00 / (2 * 10.00) * [(2 + 1.94 * (5 -$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 38 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$0.82^2) / (1 + 2 * 1.94)] \\ = 28.59 \text{ N./mm}^2$$

MEMBRANE STRESSES: Membrane Stress Calculations per Section 13-9, Equations (1-3). (N./mm²) :

STRESS LOCATIONS	Actual	Allowable
Short-side 1	8.36	97.23
Short-side 2	8.36	97.23
Short-side Corner	8.36	97.23
Long-side 1 at A	9.50	114.39
Long-side 2 at A	10.69	114.39
Long-side Corner	5.50	97.23
Stay Plate (t3)	28.59	114.39

Bending Stress Calculations per Section 13-9

Bending Stresses at Short-side 1

Bending Stress at Short-side 1 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))] \\ = 22.00 * 7.50 / (24 * 0.03) * [-3 * 100.00^2 + 2 * 122.00^2 * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))] \\ = -19.56 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))] \\ = 22.00 * -7.50 / (24 * 0.03) * [-3 * 100.00^2 + 2 * 122.00^2 * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))] \\ = 19.56 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K)) \\ = 22.00 * 122.00^2 * 7.50 / (12 * 0.03) * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)) \\ = 53.78 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K)) \\ = 22.00 * 122.00^2 * -7.50 / (12 * 0.03) * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)) \\ = -53.78 \text{ N./mm}^2$$

Bending Stresses at Short-side 2

Bending Stress at Short-side 2 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))] \\ = 22.00 * 7.50 / (24 * 0.03) * [-3 * 100.00^2 + 2 * 122.00^2 * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))] \\ = -19.56 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))] \\ = 19.56 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 39 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= 22.00 * -7.50 / (24 * 0.03) * [-3 * 100.00^2 + 2 * 122.00^2 * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))]$$

$$= 19.56 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))$$

$$= 22.00 * 122.00^2 * 7.50 / (12 * 0.03) * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))$$

$$= 53.78 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))$$

$$= 22.00 * 122.00^2 * -7.50 / (12 * 0.03) * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))$$

$$= -53.78 \text{ N./mm}^2$$

Bending Stresses at Long-side 1

Bending Stress at Long-side 1 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I2) * [(1 + K * (3 - Alpha^2)) / (1 + 2 * K)]$$

$$= 22.00 * 122.00^2 * 10.00 / (12 * 0.07) * [(1 + 1.94 * (3 - 0.82^2)) / (1 + 2 * 1.94)]$$

$$= 46.27 \text{ N./mm}^2$$

If $E_m(0.579) < E(0.850)$ and $E_b(0.579) < E(0.850)$ then

$$SblMi = SblMi / E_b$$

$$= 46.27 / 0.58$$

$$= 79.96 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I2) * [(1 + K * (3 - Alpha^2)) / (1 + 2 * K)]$$

$$= 22.00 * 122.00^2 * -10.00 / (12 * 0.07) * [(1 + 1.94 * (3 - 0.82^2)) / (1 + 2 * 1.94)]$$

$$= -46.27 \text{ N./mm}^2$$

If $E_m(0.579) < E(0.850)$ and $E_b(0.579) < E(0.850)$ then

$$SblMo = SblMo / E_b$$

$$= -46.27 / 0.58$$

$$= -79.96 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I2) * [(1 + 2 * Alpha^2 * K) / (1 + 2 * K)]$$

$$= 22.00 * 122.00^2 * 10.00 / (12 * 0.07) * [(1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)]$$

$$= 30.25 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I2) * [(1 + 2 * Alpha^2 * K) / (1 + 2 * K)]$$

$$= 22.00 * 122.00^2 * -10.00 / (12 * 0.07) * [(1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)]$$

$$= -30.25 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 40 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Bending Stresses at Long-side 2

Bending Stress at Long-side 2 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I^2) * [(1 + K * (3 - \alpha^2)) / (1 + 2 * K)]$$

$$= 22.00 * 122.00^2 * 9.71 / (12 * 0.07) * [(1 + 1.94 * (3 - 0.82^2)) / (1 + 2 * 1.94)]$$

$$= 44.94 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$SblMi = SblMi / E_b$$

$$= 44.94 / 0.48$$

$$= 94.05 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I^2) * [(1 + K * (3 - \alpha^2)) / (1 + 2 * K)]$$

$$= 22.00 * 122.00^2 * -10.29 / (12 * 0.07) * [(1 + 1.94 * (3 - 0.82^2)) / (1 + 2 * 1.94)]$$

$$= -47.60 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$SblMo = SblMo / E_b$$

$$= -47.60 / 0.48$$

$$= -99.62 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I^2) * [(1 + 2 * \alpha^2 * K) / (1 + 2 * K)]$$

$$= 22.00 * 122.00^2 * 9.71 / (12 * 0.07) * [(1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)]$$

$$= 29.38 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I^2) * [(1 + 2 * \alpha^2 * K) / (1 + 2 * K)]$$

$$= 22.00 * 122.00^2 * -10.29 / (12 * 0.07) * [(1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)]$$

$$= -31.12 \text{ N./mm}^2$$

BENDING STRESSES: Bending Stress Calculations per Section 13-9, Equations (4-7). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-19.56	19.56	145.85
at Q	53.78	-53.78	145.85
Short-side 2 at N	-19.56	19.56	145.85
at Q	53.78	-53.78	145.85
Long-side 1 at M	79.96	-79.96	171.58
at Q	30.25	-30.25	145.85
Long-side 2 at M	94.05	-99.62	171.58
at Q	29.38	-31.12	145.85

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 41 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Total Stress Calculations per Section 13-9

Total Stresses at Short-side 1

Total Stress at short side 1 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 8.36 + -19.56 \\
 &= -11.20 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 8.36 + 19.56 \\
 &= 27.92 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 8.36 + 53.78 \\
 &= 62.14 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 8.36 + -53.78 \\
 &= -45.42 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Short-side 2

Total Stress at short side 2 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 8.36 + -19.56 \\
 &= -11.20 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 8.36 + 19.56 \\
 &= 27.92 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 8.36 + 53.78 \\
 &= 62.14 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 8.36 + -53.78 \\
 &= -45.42 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Long-side 1

Total Stress at long side 1 at M inner [STL_Mi]:

$$\begin{aligned}
 &= S_{ml} + S_{blMi} \\
 &= 9.50 + 79.96 \\
 &= 89.47 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at M outer [STL_Mo]:

$$\begin{aligned}
 &= S_{ml} + S_{blMo} \\
 &= 9.50 + -79.96 \\
 &= -70.46 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q inner [STL_Qi]:

$$= S_{ml} + S_{blQi}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 42 از 150	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= 5.50 + 30.25$$

$$= 35.75 \text{ N./mm}^2$$

Total Stress at long side 1 at Q outer [STL_Qo]:

$$= S_{ml} + S_{blQo}$$

$$= 5.50 + -30.25$$

$$= -24.75 \text{ N./mm}^2$$

Total Stresses at Long-side 2

Total Stress at long side 2 at M inner [STL_Mi]:

$$= S_{ml} + S_{blMi}$$

$$= 10.69 + 94.05$$

$$= 104.75 \text{ N./mm}^2$$

Total Stress at long side 2 at M outer [STL_Mo]:

$$= S_{ml} + S_{blMo}$$

$$= 10.69 + -99.62$$

$$= -88.93 \text{ N./mm}^2$$

Total Stress at long side 2 at Q inner [STL_Qi]:

$$= S_{ml} + S_{blQi}$$

$$= 5.50 + 29.38$$

$$= 34.88 \text{ N./mm}^2$$

Total Stress at long side 2 at Q outer [STL_Qo]:

$$= S_{ml} + S_{blQo}$$

$$= 5.50 + -31.12$$

$$= -25.62 \text{ N./mm}^2$$

TOTAL STRESSES: Total Stress Calculations per Section 13-9, Equations (8-12). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-11.20	27.92	145.85
at Q	62.14	-45.42	145.85
Short-side 2 at N	-11.20	27.92	145.85
at Q	62.14	-45.42	145.85
Long-side 1 at M	89.47	-70.46	171.58
at Q	35.75	-24.75	145.85
Long-side 2 at M	104.75	-88.93	171.58
at Q	34.88	-25.62	145.85

End Plate Stresses (N./mm²):

	Actual	Allowable
End Plate	30.85	114.39

Required End Plate thickness due to Internal Pressure [trEP]:

$$= d * \sqrt{Z * C * P / (SE)} + ca$$

$$= 110.000 * \sqrt{2.318 * 0.200 * 22.000 / (114.390)} + 0.000$$

$$= 10.387 \text{ mm.}$$

End Plate MAWP at given Thickness [MAWPEP]:

$$= ((T-ca)/d)^2 * ((SE)/(C*Z)) \text{ per UG-34 (c)(3)}$$

$$= ((20.0000-0.0000)/110.0000)^2 * ((114)/(0.20*2.32))$$

$$= 81.562 \text{ bars}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 43 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

where Z is:

$$= \min(3.4 - 2.4(d/D), 2.5)$$

$$= \min(3.4 - 2.4(110.000 / 244.000), 2.5)$$

$$= 2.318$$

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	28.59	N./mm ²
High Stress Percentage	25.00	%
M.A.W.P. for Membrane Stresses	88.01	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-99.62	N./mm ²
High Stress Percentage	58.06	%
M.A.W.P. for Bending Stresses	37.89	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	104.75	N./mm ²
High Stress Percentage	61.05	%
M.A.W.P. for Total Stresses	36.04	bars

Rectangular Vessel Results For Item 1 : A7

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	28.59	N./mm ²
High Stress Percentage	25.00	%
M.A.W.P. for Membrane Stresses	88.01	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-99.62	N./mm ²
High Stress Percentage	58.06	%
M.A.W.P. for Bending Stresses	37.89	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	104.75	N./mm ²
High Stress Percentage	61.05	%
M.A.W.P. for Total Stresses	36.04	bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 44 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

3.4 FLOATING HEADER CALCULATION @ TEST PRESSURE FOR AE-2101.

Input Echo, COMPONENT 1, Description: FI.AE-2101

Figure Number Analyzed A7

Design Internal Pressure P 28.6000 bars
Design Temperature Temp 25.0000 C

VESSEL MATERIAL DATA:
Material Specification SA-240 316L
Shell Allowable Stress at Design Temp S 155.0000 N./mm²
Shell Allowable Stress at Ambient SA 155.0000 N./mm²
Shell Yield Stress at Design Temperature Sy 172.3750 N./mm²

SHORT-SIDE VESSEL DATA:
Short-side Length Dimension H 100.0000 mm.
Minimum Thickness of Short-side Plates t1 15.0000 mm.
Mid-side Joint Efficiency on Short-side E 0.8500
Corner Joint Efficiency on Short-side EC 0.8500

LONG-SIDE VESSEL DATA:
Long-side Length Dimension h 122.0000 mm.
Minimum Thickness of Long-side Plates t2 20.0000 mm.
Mid-side Joint Efficiency on Long-side E 0.8500

ADDITIONAL VESSEL DATA:
Minimum Thickness of End Plate t5 20.0000 mm.
C-Factor for End Plate Cf_Epl 0.2000

Long-side Plate # 1,
Pitch Distance p 61.0000 mm.
Uniform Hole Diameter d0 25.6500 mm.
Depth of Holes T0 20.0000 mm.
Long-side Plate # 2,
Pitch Distance p 61.0000 mm.
1: Hole Diameter d0 36.3000 mm.
Hole Depth T0 2.7000 mm.
2: Hole Diameter d1 28.5750 mm.
Hole Depth T1 17.3000 mm.

STAY PLATE MATERIAL DATA:
Stay Material Specification SA-240 316L
Stay Allowable Stress at Design Temp Sr 114.3898 N./mm²
Stay Allowable Stress at Ambient SA 115.1465 N./mm²
Stay Yield Stress at Design Temp Sy 129.8699 N./mm²

STAY PLATE DATA:
Minimum Thickness of Stay t3 10.0000 mm.
The Stay(s) Are Not Welded to the End Plate

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 45 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Rectangular Vessel Results, Item number 1, Desc: FI.AE-2101
ASME Code, Section VIII, Division 1, 2019 App. 13

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

Short-side 1 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $15.000 - 0.000 / 2$
= 7.500 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(15.000 - 0.000) / 2$
= -7.500 mm.

Short-side 2 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $15.000 - 0.000 / 2$
= 7.500 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(15.000 - 0.000) / 2$
= -7.500 mm.

Long-side 1 Calculations

Effective Diameter [De]: 25.650 mm.

Membrane Ligament Efficiency [Em]:
= $Pitch - De / Pitch$
= $61.000 - 25.650 / 61.000$
= 0.580

Bending Ligament Efficiency [Eb]:
As diameter holes are uniform $E_b = E_m$
= 0.580

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 46 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$\begin{aligned}
 &= -(t_1 - CA) / 2 \\
 &= -(20.000 - 0.000) / 2 \\
 &= -10.000 \text{ mm.}
 \end{aligned}$$

Long-side 2 Calculations

Effective Diameter [De]:

$$\begin{aligned}
 &= (d_0 * T_0 + d_1 * T_1 + d_2 * T_2) / (t_1 - CA) \\
 &= (36.30 * 2.70 + 28.57 * 17.30 + 0.00 * 0.00) / \\
 &\quad (20.00 - 0.00) \\
 &= 29.618 \text{ mm.}
 \end{aligned}$$

Membrane Ligament Efficiency [Em]:

$$\begin{aligned}
 &= \text{Pitch} - De / \text{Pitch} \\
 &= 61.000 - 29.618 / 61.000 \\
 &= 0.514
 \end{aligned}$$

Dist from Neutral axis of c/s to extreme fibers [Ci & Co]:

Calculation of Xbar:

$$\begin{aligned}
 &= ((b_0 * T_0 * (T_0/2 + T_1 + T_2)) + (b_1 * T_1 * \\
 &\quad (T_1/2 + T_2)) + (b_2 * T_2 * (T_2/2))) / \\
 &\quad (b_0 * T_0 + b_1 * T_1 + b_2 * T_2) \\
 &= ((0.97 * 2.70 * (2.70/2 + 17.30 + 0.00)) + (1.28 * 17.30 * \\
 &\quad (17.30/2 + 0.00)) + (2.40 * 0.00 * (0.00/2))) / \\
 &\quad (0.97 * 2.70 + 1.28 * 17.30 + 2.40 * 0.00) \\
 &= 9.713 \text{ mm.}
 \end{aligned}$$

Dist from Neutral axis of c/s to inside surface of the vesssel [Ci]:

$$\begin{aligned}
 Ci &= Xbar \\
 &= 9.713 \text{ mm.}
 \end{aligned}$$

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$\begin{aligned}
 &= -(t - CA - Xbar) \\
 &= -(20.000 - 0.000 - 9.713) \\
 &= -10.287 \text{ mm.}
 \end{aligned}$$

Moment of Inertia (Section 13-6, Equation (5)) [I]:

$$= 0.079 \text{ cm}^4$$

Effective Diameter [De]:

$$\begin{aligned}
 &= \text{Pitch} - ((6 * I) / ((t - CA)^2 * (-Co))) \\
 &= 61.00 - ((6 * 0.08) / ((20.00 - 0.00)^2 * (10.29))) \\
 &= 31.851 \text{ mm.}
 \end{aligned}$$

Bending Ligament Efficiency [Eb]:

$$\begin{aligned}
 &= \text{Pitch} - De / \text{Pitch} \\
 &= 61.000 - 31.851 / 61.000 \\
 &= 0.478
 \end{aligned}$$

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

		Em	Eb	Ci	Co
Short-side	1	0.850	0.850	7.500	-7.500
	2	0.850	0.850	7.500	-7.500
Long-side	1	0.580	0.580	10.000	-10.000
	2	0.514	0.478	9.713	-10.287

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 47 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Moment of Inertia of a Strip of the Vessel Wall:

$$\text{Thickness } t_1, I_1 = 0.0281 \text{ cm}^4$$

$$\text{Thickness } t_2, I_2 = 0.0667 \text{ cm}^4$$

Rectangular Vessel Parameters:

$$\alpha = H / h = 0.8197$$

$$K = (I_2/I_1) * \alpha = 1.9429$$

Membrane Stress Calculations per Section 13-9

Membrane Stresses at Short-side 1

Membrane Stress at Short-side 1 [Sms]:

$$= p * h / (4 * t_1) * \{ 4 - [(2 + K * (5 - \alpha^2)) / (1 + 2 * K)] \}$$

$$= 28.60 * 122.00 / (4 * 15.00) * \{ 4 - [(2 + 1.94 * (5 - 0.82^2)) / (1 + 2 * 1.94)] \}$$

$$= 10.87 \text{ N./mm}^2$$

Membrane Stresses at Short-side 2

Membrane Stress at Short-side 2 [Sms]:

$$= p * h / (4 * t_1) * \{ 4 - [(2 + K * (5 - \alpha^2)) / (1 + 2 * K)] \}$$

$$= 28.60 * 122.00 / (4 * 15.00) * \{ 4 - [(2 + 1.94 * (5 - 0.82^2)) / (1 + 2 * 1.94)] \}$$

$$= 10.87 \text{ N./mm}^2$$

Membrane Stresses at Long-side 1

Membrane Stress at Long-side 1 at A [Sml]:

$$= P * H / 2 * t_2$$

$$= 28.60 * 100.00 / 2 * 20.00$$

$$= 7.15 \text{ N./mm}^2$$

If $E_m(0.580) < E(0.850)$ and $E_b(0.580) < E(0.850)$ then

$$S_{ml} = S_{ml} / E_m$$

$$= 7.15 / 0.58$$

$$= 12.34 \text{ N./mm}^2$$

Membrane Stresses at Long-side 2

Membrane Stress at Long-side 2 at A [Sml]:

$$= P * H / 2 * t_2$$

$$= 28.60 * 100.00 / 2 * 20.00$$

$$= 7.15 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$S_{ml} = S_{ml} / E_m$$

$$= 7.15 / 0.51$$

$$= 13.90 \text{ N./mm}^2$$

Membrane Stresses at Stay Plate

Membrane Stress at Stay Plate [Smsp]:

$$= P * h / (2 * t_3) * [(2 + K * (5 - \alpha^2)) / (1 + 2 * K)]$$

$$= 28.60 * 122.00 / (2 * 10.00) * [(2 + 1.94 * (5 -$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 48 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$0.82^2) / (1 + 2 * 1.94)] \\ = 37.17 \text{ N./mm}^2$$

MEMBRANE STRESSES: Membrane Stress Calculations per Section 13-9, Equations (1-3). (N./mm²) :

STRESS LOCATIONS	Actual	Allowable
Short-side 1	10.87	131.75
Short-side 2	10.87	131.75
Short-side Corner	10.87	131.75
Long-side 1 at A	12.34	155.00
Long-side 2 at A	13.90	155.00
Long-side Corner	7.15	131.75
Stay Plate (t3)	37.17	114.39

Bending Stress Calculations per Section 13-9

Bending Stresses at Short-side 1

Bending Stress at Short-side 1 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))] \\ = 28.60 * 7.50 / (24 * 0.03) * [-3 * 100.00^2 + 2 * 122.00^2 * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))] \\ = -25.43 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))] \\ = 28.60 * -7.50 / (24 * 0.03) * [-3 * 100.00^2 + 2 * 122.00^2 * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))] \\ = 25.43 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K)) \\ = 28.60 * 122.00^2 * 7.50 / (12 * 0.03) * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)) \\ = 69.91 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K)) \\ = 28.60 * 122.00^2 * -7.50 / (12 * 0.03) * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)) \\ = -69.91 \text{ N./mm}^2$$

Bending Stresses at Short-side 2

Bending Stress at Short-side 2 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))] \\ = 28.60 * 7.50 / (24 * 0.03) * [-3 * 100.00^2 + 2 * 122.00^2 * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))] \\ = -25.43 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))] \\ = 25.43 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 49 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

$$= 28.60 * -7.50 / (24 * 0.03) * [-3 * 100.00^2 + 2 * 122.00^2 * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))]$$

$$= 25.43 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))$$

$$= 28.60 * 122.00^2 * 7.50 / (12 * 0.03) * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))$$

$$= 69.91 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((1 + 2 * Alpha^2 * K) / (1 + 2 * K))$$

$$= 28.60 * 122.00^2 * -7.50 / (12 * 0.03) * ((1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94))$$

$$= -69.91 \text{ N./mm}^2$$

Bending Stresses at Long-side 1

Bending Stress at Long-side 1 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I2) * [(1 + K * (3 - Alpha^2)) / (1 + 2 * K)]$$

$$= 28.60 * 122.00^2 * 10.00 / (12 * 0.07) * [(1 + 1.94 * (3 - 0.82^2)) / (1 + 2 * 1.94)]$$

$$= 60.16 \text{ N./mm}^2$$

If $E_m(0.580) < E(0.850)$ and $E_b(0.580) < E(0.850)$ then

$$SblMi = SblMi / E_b$$

$$= 60.16 / 0.58$$

$$= 103.81 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I2) * [(1 + K * (3 - Alpha^2)) / (1 + 2 * K)]$$

$$= 28.60 * 122.00^2 * -10.00 / (12 * 0.07) * [(1 + 1.94 * (3 - 0.82^2)) / (1 + 2 * 1.94)]$$

$$= -60.16 \text{ N./mm}^2$$

If $E_m(0.580) < E(0.850)$ and $E_b(0.580) < E(0.850)$ then

$$SblMo = SblMo / E_b$$

$$= -60.16 / 0.58$$

$$= -103.81 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I2) * [(1 + 2 * Alpha^2 * K) / (1 + 2 * K)]$$

$$= 28.60 * 122.00^2 * 10.00 / (12 * 0.07) * [(1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)]$$

$$= 39.33 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I2) * [(1 + 2 * Alpha^2 * K) / (1 + 2 * K)]$$

$$= 28.60 * 122.00^2 * -10.00 / (12 * 0.07) * [(1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)]$$

$$= -39.33 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 50 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Bending Stresses at Long-side 2

Bending Stress at Long-side 2 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I^2) * [(1 + K * (3 - \alpha^2)) / (1 + 2 * K)]$$

$$= 28.60 * 122.00^2 * 9.71 / (12 * 0.07) * [(1 + 1.94 * (3 - 0.82^2)) / (1 + 2 * 1.94)]$$

$$= 58.43 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$SblMi = SblMi / E_b$$

$$= 58.43 / 0.48$$

$$= 122.27 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I^2) * [(1 + K * (3 - \alpha^2)) / (1 + 2 * K)]$$

$$= 28.60 * 122.00^2 * -10.29 / (12 * 0.07) * [(1 + 1.94 * (3 - 0.82^2)) / (1 + 2 * 1.94)]$$

$$= -61.89 \text{ N./mm}^2$$

If $E_m(0.514) < E(0.850)$ and $E_b(0.478) < E(0.850)$ then

$$SblMo = SblMo / E_b$$

$$= -61.89 / 0.48$$

$$= -129.51 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I^2) * [(1 + 2 * \alpha^2 * K) / (1 + 2 * K)]$$

$$= 28.60 * 122.00^2 * 9.71 / (12 * 0.07) * [(1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)]$$

$$= 38.20 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I^2) * [(1 + 2 * \alpha^2 * K) / (1 + 2 * K)]$$

$$= 28.60 * 122.00^2 * -10.29 / (12 * 0.07) * [(1 + 2 * 0.82^2 * 1.94) / (1 + 2 * 1.94)]$$

$$= -40.46 \text{ N./mm}^2$$

BENDING STRESSES: Bending Stress Calculations per Section 13-9, Equations (4-7). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-25.43	25.43	197.62
at Q	69.91	-69.91	197.62
Short-side 2 at N	-25.43	25.43	197.62
at Q	69.91	-69.91	197.62
Long-side 1 at M	103.81	-103.81	232.50
at Q	39.33	-39.33	197.62
Long-side 2 at M	122.27	-129.51	232.50
at Q	38.20	-40.46	197.62

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 51 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Total Stress Calculations per Section 13-9

Total Stresses at Short-side 1

Total Stress at short side 1 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 10.87 + -25.43 \\
 &= -14.55 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 10.87 + 25.43 \\
 &= 36.30 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 10.87 + 69.91 \\
 &= 80.79 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 10.87 + -69.91 \\
 &= -59.04 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Short-side 2

Total Stress at short side 2 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 10.87 + -25.43 \\
 &= -14.55 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 10.87 + 25.43 \\
 &= 36.30 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 10.87 + 69.91 \\
 &= 80.79 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 10.87 + -69.91 \\
 &= -59.04 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Long-side 1

Total Stress at long side 1 at M inner [STL_Mi]:

$$\begin{aligned}
 &= S_{ml} + S_{blMi} \\
 &= 12.34 + 103.81 \\
 &= 116.15 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at M outer [STL_Mo]:

$$\begin{aligned}
 &= S_{ml} + S_{blMo} \\
 &= 12.34 + -103.81 \\
 &= -91.47 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q inner [STL_Qi]:

$$= S_{ml} + S_{blQi}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 52 از 150
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= 7.15 + 39.33$$

$$= 46.48 \text{ N./mm}^2$$

Total Stress at long side 1 at Q outer [STL_Qo]:

$$= S_{ml} + S_{blQo}$$

$$= 7.15 + -39.33$$

$$= -32.18 \text{ N./mm}^2$$

Total Stresses at Long-side 2

Total Stress at long side 2 at M inner [STL_Mi]:

$$= S_{ml} + S_{blMi}$$

$$= 13.90 + 122.27$$

$$= 136.17 \text{ N./mm}^2$$

Total Stress at long side 2 at M outer [STL_Mo]:

$$= S_{ml} + S_{blMo}$$

$$= 13.90 + -129.51$$

$$= -115.61 \text{ N./mm}^2$$

Total Stress at long side 2 at Q inner [STL_Qi]:

$$= S_{ml} + S_{blQi}$$

$$= 7.15 + 38.20$$

$$= 45.35 \text{ N./mm}^2$$

Total Stress at long side 2 at Q outer [STL_Qo]:

$$= S_{ml} + S_{blQo}$$

$$= 7.15 + -40.46$$

$$= -33.31 \text{ N./mm}^2$$

TOTAL STRESSES: Total Stress Calculations per Section 13-9, Equations (8-12). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-14.55	36.30	197.62
at Q	80.79	-59.04	197.62
Short-side 2 at N	-14.55	36.30	197.62
at Q	80.79	-59.04	197.62
Long-side 1 at M	116.15	-91.47	232.50
at Q	46.48	-32.18	197.62
Long-side 2 at M	136.17	-115.61	232.50
at Q	45.35	-33.31	197.62

End Plate Stresses (N./mm²):

	Actual	Allowable
End Plate	40.11	155.00

Required End Plate thickness due to Internal Pressure [trEP]:

$$= d * \sqrt{Z * C * P / (SE)} + ca$$

$$= 110.000 * \sqrt{2.318 * 0.200 * 28.600 / (155.000)} + 0.000$$

$$= 10.174 \text{ mm.}$$

End Plate MAWP at given Thickness [MAWPEP]:

$$= ((T-ca)/d)^2 * ((SE)/(C*Z)) \text{ per UG-34 (c)(3)}$$

$$= ((20.0000-0.0000)/110.0000)^2 * ((155)/(.20*2.32))$$

$$= 110.518 \text{ bars}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 53 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

where Z is:

$$= \min(3.4 - 2.4(d/D), 2.5)$$

$$= \min(3.4 - 2.4(110.000 / 244.000), 2.5)$$

$$= 2.318$$

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	37.17	N./mm ²
High Stress Percentage	32.49	%
M.A.W.P. for Membrane Stresses	88.01	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-129.51	N./mm ²
High Stress Percentage	55.70	%
M.A.W.P. for Bending Stresses	51.34	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	136.17	N./mm ²
High Stress Percentage	58.57	%
M.A.W.P. for Total Stresses	48.83	bars

Rectangular Vessel Results For Item 1 : A7

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	37.17	N./mm ²
High Stress Percentage	32.49	%
M.A.W.P. for Membrane Stresses	88.01	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-129.51	N./mm ²
High Stress Percentage	55.70	%
M.A.W.P. for Bending Stresses	51.34	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	136.17	N./mm ²
High Stress Percentage	58.57	%
M.A.W.P. for Total Stresses	48.83	bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 54 از 150
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	AA	120	PR	CN	0001	V03	

3.5 STATIONARY HEADER CALCULATION @ DESIGN PRESSURE FOR AE-2102.

Input Echo, COMPONENT 1, Description: St.AE-2102

Figure Number Analyzed	A8		
Design Internal Pressure	P	62.0000	bars
Design Temperature	Temp	175.0000	C
VESSEL MATERIAL DATA:			
Material Specification		SA-240 316L	
Shell Allowable Stress at Design Temp	S	111.9078	N./mm ²
Shell Allowable Stress at Ambient	SA	115.1465	N./mm ²
Shell Yield Stress at Design Temperature	Sy	126.1469	N./mm ²
SHORT-SIDE VESSEL DATA:			
Short-side Length Dimension	H	110.0000	mm.
Minimum Thickness of Short-side Plates	t1	20.0000	mm.
Mid-side Joint Efficiency on Short-side	E	0.8500	
Corner Joint Efficiency on Short-side	EC	0.8500	
LONG-SIDE VESSEL DATA:			
Long-side Length Dimension	h	130.0000	mm.
Minimum Thickness of Long-side Plates	t2	28.0000	mm.
Mid-side Joint Efficiency on Long-side	E	0.8500	
ADDITIONAL VESSEL DATA:			
Minimum Thickness of End Plate	t5	20.0000	mm.
C-Factor for End Plate	Cf_Epl	0.2000	
Long-side Plate # 1,			
Pitch Distance	p	69.0000	mm.
Uniform Hole Diameter	d0	25.6500	mm.
Depth of Holes	T0	28.0000	mm.
Long-side Plate # 2,			
Pitch Distance	p	69.0000	mm.
# 1: Hole Diameter	d0	36.3000	mm.
Hole Depth	T0	2.7000	mm.
# 2: Hole Diameter	d1	28.5750	mm.
Hole Depth	T1	25.3000	mm.
STAY PLATE MATERIAL DATA:			
Stay Material Specification		SA-240 316L	
Stay Allowable Stress at Design Temp	Sr	114.3898	N./mm ²
Stay Allowable Stress at Ambient	SA	115.1465	N./mm ²
Stay Yield Stress at Design Temp	Sy	129.8699	N./mm ²
STAY PLATE DATA:			
Minimum Thickness of Stay	t3	10.0000	mm.
Minimum Thickness of Stay	t4	10.0000	mm.
The Stay(s) Are Not Welded to the End Plate			



Rectangular Vessel Results, Item number 1, Desc: St.AE-2102

ASME Code, Section VIII, Division 1, 2019 App. 13

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

Short-side 1 Calculations

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 55 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Short-side 2 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Long-side 1 Calculations

Effective Diameter [De]: 25.650 mm.

Membrane Ligament Efficiency [Em]:
= $Pitch - De / Pitch$
= $69.000 - 25.650 / 69.000$
= 0.628

Bending Ligament Efficiency [Eb]:
As diameter holes are uniform $Eb = Em$
= 0.628

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $28.000 - 0.000 / 2$
= 14.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(28.000 - 0.000) / 2$
= -14.000 mm.

Long-side 2 Calculations

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 56 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

Effective Diameter [De]:

$$= (d_0 * T_0 + d_1 * T_1 + d_2 * T_2) / (t_1 - CA)$$

$$= (36.30 * 2.70 + 28.57 * 25.30 + 0.00 * 0.00) / (28.00 - 0.00)$$

$$= 29.320 \text{ mm.}$$



Membrane Ligament Efficiency [Em]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 69.000 - 29.320 / 69.000$$

$$= 0.575$$

Dist from Neutral axis of c/s to extreme fibers [Ci & Co]:

Calculation of Xbar:

$$= ((b_0 * T_0 * (T_0/2 + T_1 + T_2)) + (b_1 * T_1 * (T_1/2 + T_2))) / (b_0 * T_0 + b_1 * T_1 + b_2 * T_2)$$

$$= ((1.29 * 2.70 * (2.70/2 + 25.30 + 0.00)) + (1.59 * 25.30 * (25.30/2 + 0.00))) / (1.29 * 2.70 + 1.59 * 25.30 + 2.72 * 0.00)$$

$$= 13.763 \text{ mm.}$$

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:

$$Ci = Xbar$$

$$= 13.763 \text{ mm.}$$

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t - CA - Xbar)$$

$$= -(28.000 - 0.000 - 13.763)$$

$$= -14.237 \text{ mm.}$$

Moment of Inertia (Section 13-6, Equation (5)) [I]:

$$= 0.278 \text{ cm}^4$$

Effective Diameter [De]:

$$= \text{Pitch} - ((6 * I) / ((t - CA)^2 * (-Co)))$$

$$= 69.00 - ((6 * 0.28) / ((28.00 - 0.00)^2 * (14.24)))$$

$$= 31.084 \text{ mm.}$$

Bending Ligament Efficiency [Eb]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 69.000 - 31.084 / 69.000$$

$$= 0.550$$

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

	Em	Eb	Ci	Co
Short-side 1	0.850	0.850	10.000	-10.000
2	0.850	0.850	10.000	-10.000
Long-side 1	0.628	0.628	14.000	-14.000
2	0.575	0.550	13.763	-14.237

Moment of Inertia of a Strip of the Vessel Wall:

$$\text{Thickness } t_1, I_1 = 0.0667 \text{ cm}^4$$

$$\text{Thickness } t_2, I_2 = 0.1829 \text{ cm}^4$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 57 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

Rectangular Vessel Parameters:

$$\begin{aligned} \text{Alpha} &= H / h = 0.8462 \\ K &= (I2/I1) * \text{Alpha} = 2.3218 \end{aligned}$$

03

Membrane Stress Calculations per Section 13-9

Membrane Stresses at Short-side 1

Membrane Stress at Short-side 1 [Sms]:

$$\begin{aligned} &= P * h / (2 * t1) * \{ 3 - [(6 + K * \\ &\quad (11 - \text{alpha}^2) / (3 + 5 * K)] \} \\ &= 62.00 * 130.00 / (2 * 20.00) * \{ 3 - [(6 + 2.32 * \\ &\quad (11 - 0.85^2) / (3 + 5 * 2.32)] \} \\ &= 19.24 \text{ N./mm}^2 \end{aligned}$$

Membrane Stresses at Short-side 2

Membrane Stress at Short-side 2 [Sms]:

$$\begin{aligned} &= P * h / (2 * t1) * \{ 3 - [(6 + K * \\ &\quad (11 - \text{alpha}^2) / (3 + 5 * K)] \} \\ &= 62.00 * 130.00 / (2 * 20.00) * \{ 3 - [(6 + 2.32 * \\ &\quad (11 - 0.85^2) / (3 + 5 * 2.32)] \} \\ &= 19.24 \text{ N./mm}^2 \end{aligned}$$

Membrane Stresses at Long-side 1

Membrane Stress at Long-side 1 at A [Sml]:

$$\begin{aligned} &= P * H / 2 * t2 \\ &= 62.00 * 110.00 / 2 * 28.00 \\ &= 12.18 \text{ N./mm}^2 \end{aligned}$$

If $E_m(0.628) < E(0.850)$ and $E_b(0.628) < E(0.850)$ then

$$\begin{aligned} S_{ml} &= S_{ml} / E_m \\ &= 12.18 / 0.63 \\ &= 19.39 \text{ N./mm}^2 \end{aligned}$$

Membrane Stresses at Long-side 2

Membrane Stress at Long-side 2 at A [Sml]:

$$\begin{aligned} &= P * H / 2 * t2 \\ &= 62.00 * 110.00 / 2 * 28.00 \\ &= 12.18 \text{ N./mm}^2 \end{aligned}$$

If $E_m(0.575) < E(0.850)$ and $E_b(0.550) < E(0.850)$ then

$$\begin{aligned} S_{ml} &= S_{ml} / E_m \\ &= 12.18 / 0.58 \\ &= 21.18 \text{ N./mm}^2 \end{aligned}$$

Membrane Stresses at Stay Plate

Membrane Stress at Stay Plate [t3]:

$$\begin{aligned} &= P * h / (2 * t3) * [(6 + K * (11 - \\ &\quad \text{alpha}^2) / (3 + 5 * K)] \\ &= 62.00 * 130.00 / (2 * 10.00) * [(6 + 2.32 * (11 - \\ &\quad 0.85^2) / (3 + 5 * 2.32)] \\ &= 82.42 \text{ N./mm}^2 \end{aligned}$$

Membrane Stress at Stay Plate [t4]:

$$= P * h / (2 * t4) * [(6 + K * (11 -$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 58 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

$$\begin{aligned} & \alpha^2) / (3 + 5 * K)] \\ & = 62.00 * 130.00 / (2 * 10.00) * [(6 + 2.32 * (11 - \\ & 0.85^2) / (3 + 5 * 2.32)] \\ & = 82.42 \text{ N./mm}^2 \end{aligned}$$



MEMBRANE STRESSES: Membrane Stress Calculations per Section 13-9, Equations (13-15). (N./mm²) :

STRESS LOCATIONS	Actual	Allowable
Short-side 1	19.24	95.12
Short-side 2	19.24	95.12
Short-side Corner	19.24	95.12
Long-side 1 at A	19.39	111.91
Long-side 2 at A	21.18	111.91
Long-side Corner	12.18	95.12
Stay Plate (t3)	82.42	114.39
Stay Plate (t4)	82.42	114.39

Bending Stress Calculations per Section 13-9

Bending Stresses at Short-side 1

Bending Stress at Short-side 1 at N Inner[SbsNi]:

$$\begin{aligned} & = P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * \\ & ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))] \\ & = 62.00 * 10.00 / (24 * 0.07) * [-3 * 110.00^2 + 2 * 130.00^2 * \\ & ((3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32))] \\ & = -39.25 \text{ N./mm}^2 \end{aligned}$$

Bending Stress at Short-side 1 at N Outer[SbsNo]:

$$\begin{aligned} & = P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * \\ & ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))] \\ & = 62.00 * -10.00 / (24 * 0.07) * [-3 * 110.00^2 + 2 * 130.00^2 * \\ & ((3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32))] \\ & = 39.25 \text{ N./mm}^2 \end{aligned}$$

Bending Stress at Short-side 1 at Q Inner[SbsQi]:

$$\begin{aligned} & = P * h^2 * c / (12 * I1) * ((3 + 5 * \\ & \alpha^2 * K) / (3 + 5 * K)) \\ & = 62.00 * 130.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * \\ & 0.85^2 * 2.32) / (3 + 5 * 2.32)) \\ & = 101.42 \text{ N./mm}^2 \end{aligned}$$

Bending Stress at Short-side 1 at Q Outer[SbsQo]:

$$\begin{aligned} & = P * h^2 * c / (12 * I1) * ((3 + 5 * \\ & \alpha^2 * K) / (3 + 5 * K)) \\ & = 62.00 * 130.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * \\ & 0.85^2 * 2.32) / (3 + 5 * 2.32)) \\ & = -101.42 \text{ N./mm}^2 \end{aligned}$$

Bending Stresses at Short-side 2

Bending Stress at Short-side 2 at N Inner[SbsNi]:

$$\begin{aligned} & = P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * \\ & ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))] \\ & = 62.00 * 10.00 / (24 * 0.07) * [-3 * 110.00^2 + 2 * 130.00^2 * \\ & ((3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32))] \\ & = -39.25 \text{ N./mm}^2 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)										
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 59 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			

Bending Stress at Short-side 2 at N Outer[SbsNo]:

$$\begin{aligned}
 &= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * \\
 &\quad ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))] \\
 &= 62.00 * -10.00 / (24 * 0.07) * [-3 * 110.00^2 + 2 * 130.00^2 * \\
 &\quad ((3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32))] \\
 &= 39.25 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Short-side 2 at Q Inner[SbsQi]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I1) * ((3 + 5 * \\
 &\quad Alpha^2 * K) / (3 + 5 * K)) \\
 &= 62.00 * 130.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * \\
 &\quad 0.85^2 * 2.32) / (3 + 5 * 2.32)) \\
 &= 101.42 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Short-side 2 at Q Outer[SbsQo]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I1) * ((3 + 5 * \\
 &\quad Alpha^2 * K) / (3 + 5 * K)) \\
 &= 62.00 * 130.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * \\
 &\quad 0.85^2 * 2.32) / (3 + 5 * 2.32)) \\
 &= -101.42 \text{ N./mm}^2
 \end{aligned}$$

Bending Stresses at Long-side 1

Bending Stress at Long-side 1 at M Inner[SblMi]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I2) * [(3 + K * \\
 &\quad (6 - Alpha^2)) / (3 + 5 * K)] \\
 &= 62.00 * 130.00^2 * 14.00 / (12 * 0.18) * [(3 + 2.32 * \\
 &\quad (6 - 0.85^2)) / (3 + 5 * 2.32)] \\
 &= 69.84 \text{ N./mm}^2
 \end{aligned}$$

If $Em(0.628) < E(0.850)$ and $Eb(0.628) < E(0.850)$ then

$$\begin{aligned}
 SblMi &= SblMi / Eb \\
 &= 69.84 / 0.63 \\
 &= 111.17 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Long-side 1 at M Outer[SblMo]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I2) * [(3 + K * \\
 &\quad (6 - Alpha^2)) / (3 + 5 * K)] \\
 &= 62.00 * 130.00^2 * -14.00 / (12 * 0.18) * [(3 + 2.32 * \\
 &\quad (6 - 0.85^2)) / (3 + 5 * 2.32)] \\
 &= -69.84 \text{ N./mm}^2
 \end{aligned}$$

If $Em(0.628) < E(0.850)$ and $Eb(0.628) < E(0.850)$ then

$$\begin{aligned}
 SblMo &= SblMo / Eb \\
 &= -69.84 / 0.63 \\
 &= -111.17 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Long-side 1 at Q Inner[SblQi]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I2) * [(3 + 5 * \\
 &\quad Alpha^2 * K) / (3 + 5 * K)] \\
 &= 62.00 * 130.00^2 * 14.00 / (12 * 0.18) * [(3 + 5 * \\
 &\quad 0.85^2 * 2.32) / (3 + 5 * 2.32)] \\
 &= 51.74 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Long-side 1 at Q Outer[SblQo]:

$$\begin{aligned}
 &= P * h^2 * c / (12 * I2) * [(3 + 5 * \\
 &\quad Alpha^2 * K) / (3 + 5 * K)] \\
 &= 62.00 * 130.00^2 * -14.00 / (12 * 0.18) * [(3 + 5 * \\
 &\quad 0.85^2 * 2.32) / (3 + 5 * 2.32)] \\
 &= -51.74 \text{ N./mm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 60 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Bending Stresses at Long-side 2

Bending Stress at Long-side 2 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 62.00 * 130.00^2 * 13.76 / (12 * 0.18) * [(3 + 2.32 * (6 - 0.85^2)) / (3 + 5 * 2.32)]$$

$$= 68.66 \text{ N./mm}^2$$

If $E_m(0.575) < E(0.850)$ and $E_b(0.550) < E(0.850)$ then

$$SblMi = SblMi / E_b$$

$$= 68.66 / 0.55$$

$$= 124.95 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 62.00 * 130.00^2 * -14.24 / (12 * 0.18) * [(3 + 2.32 * (6 - 0.85^2)) / (3 + 5 * 2.32)]$$

$$= -71.03 \text{ N./mm}^2$$

If $E_m(0.575) < E(0.850)$ and $E_b(0.550) < E(0.850)$ then

$$SblMo = SblMo / E_b$$

$$= -71.03 / 0.55$$

$$= -129.26 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 62.00 * 130.00^2 * 13.76 / (12 * 0.18) * [(3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32)]$$

$$= 50.87 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 62.00 * 130.00^2 * -14.24 / (12 * 0.18) * [(3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32)]$$

$$= -52.62 \text{ N./mm}^2$$

BENDING STRESSES: Bending Stress Calculations per Section 13-9, Equations (16-19). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-39.25	39.25	142.68
at Q	101.42	-101.42	142.68
Short-side 2 at N	-39.25	39.25	142.68
at Q	101.42	-101.42	142.68
Long-side 1 at M	111.17	-111.17	167.86
at Q	51.74	-51.74	142.68
Long-side 2 at M	124.95	-129.26	167.86
at Q	50.87	-52.62	142.68

Total Stress Calculations per Section 13-9

Total Stresses at Short-side 1

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 61 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Total Stress at short side 1 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 19.24 + -39.25 \\
 &= -20.01 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 19.24 + 39.25 \\
 &= 58.49 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 19.24 + 101.42 \\
 &= 120.66 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 19.24 + -101.42 \\
 &= -82.18 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Short-side 2

Total Stress at short side 2 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 19.24 + -39.25 \\
 &= -20.01 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 19.24 + 39.25 \\
 &= 58.49 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 19.24 + 101.42 \\
 &= 120.66 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 19.24 + -101.42 \\
 &= -82.18 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Long-side 1

Total Stress at long side 1 at M inner [STL_Mi]:

$$\begin{aligned}
 &= S_{ml} + S_{blMi} \\
 &= 19.39 + 111.17 \\
 &= 130.56 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at M outer [STL_Mo]:

$$\begin{aligned}
 &= S_{ml} + S_{blMo} \\
 &= 19.39 + -111.17 \\
 &= -91.79 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q inner [STL_Qi]:

$$\begin{aligned}
 &= S_{ml} + S_{blQi} \\
 &= 12.18 + 51.74 \\
 &= 63.92 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q outer [STL_Qo]:



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 62 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

$$\begin{aligned}
 &= S_{mlB} + S_{blQo} \\
 &= 12.18 + -51.74 \\
 &= -39.57 \text{ N./mm}^2
 \end{aligned}$$



Total Stresses at Long-side 2

Total Stress at long side 2 at M inner [STL_Mi]:

$$\begin{aligned}
 &= S_{ml} + S_{blMi} \\
 &= 21.18 + 124.95 \\
 &= 146.13 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 2 at M outer [STL_Mo]:

$$\begin{aligned}
 &= S_{ml} + S_{blMo} \\
 &= 21.18 + -129.26 \\
 &= -108.08 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 2 at Q inner [STL_Qi]:

$$\begin{aligned}
 &= S_{ml} + S_{blQi} \\
 &= 12.18 + 50.87 \\
 &= 63.05 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 2 at Q outer [STL_Qo]:

$$\begin{aligned}
 &= S_{mlB} + S_{blQo} \\
 &= 12.18 + -52.62 \\
 &= -40.44 \text{ N./mm}^2
 \end{aligned}$$

TOTAL STRESSES: Total Stress Calculations per Section 13-9, Equations (20-24). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-20.01	58.49	142.68
at Q	120.66	-82.18	142.68
Short-side 2 at N	-20.01	58.49	142.68
at Q	120.66	-82.18	142.68
Long-side 1 at M	130.56	-91.79	167.86
at Q	63.92	-39.57	142.68
Long-side 2 at M	146.13	-108.08	167.86
at Q	63.05	-40.44	142.68

End Plate Stresses (N./mm²):

	Actual	Allowable
End Plate	93.78	111.91

Required End Plate thickness due to Internal Pressure [trEP]:

$$\begin{aligned}
 &= d * \sqrt{Z * C * P / (SE)} + ca \\
 &= 110.000 * \sqrt{2.500 * 0.200 * 62.000 / (111.908)} + 0.000 \\
 &= 18.309 \text{ mm.}
 \end{aligned}$$

End Plate MAWP at given Thickness [MAWPEP]:

$$\begin{aligned}
 &= ((T-ca)/d)^2 * ((SE)/(C*Z)) \text{ per UG-34 (c)(3)} \\
 &= ((20.0000-0.0000)/110.0000)^2 * ((111)/(0.20*2.50)) \\
 &= 73.984 \text{ bars}
 \end{aligned}$$

where Z is:

$$\begin{aligned}
 &= \min(3.4 - 2.4(d/D), 2.5) \\
 &= \min(3.4 - 2.4(110.000 / 410.000), 2.5) \\
 &= 2.500
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 63 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	82.42	N./mm ²
High Stress Percentage	72.06	%
M.A.W.P. for Membrane Stresses	86.04	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-129.26	N./mm ²
High Stress Percentage	77.00	%
M.A.W.P. for Bending Stresses	80.52	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	146.13	N./mm ²
High Stress Percentage	87.05	%
M.A.W.P. for Total Stresses	71.22	bars

03

Rectangular Vessel Results For Item 1 : A8

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	82.42	N./mm ²
High Stress Percentage	72.06	%
M.A.W.P. for Membrane Stresses	86.04	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-129.26	N./mm ²
High Stress Percentage	77.00	%
M.A.W.P. for Bending Stresses	80.52	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	146.13	N./mm ²
High Stress Percentage	87.05	%
M.A.W.P. for Total Stresses	71.22	bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 64 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

3.6 STATIONARY HEADER CALCULATION @ TEST PRESSURE FOR AE-2102.

Input Echo, COMPONENT 1, Description: St.AE-2102-Test

Figure Number Analyzed A8

Design Internal Pressure P 80.6000 bars
Design Temperature Temp 25.0000 C

VESSEL MATERIAL DATA:
Material Specification SA-240 316L
Shell Allowable Stress at Design Temp S 155.1000 N./mm²
Shell Allowable Stress at Ambient SA 155.1000 N./mm²
Shell Yield Stress at Design Temperature Sy 172.3750 N./mm²

SHORT-SIDE VESSEL DATA:
Short-side Length Dimension H 110.0000 mm.
Minimum Thickness of Short-side Plates t1 20.0000 mm.
Mid-side Joint Efficiency on Short-side E 0.8500
Corner Joint Efficiency on Short-side EC 0.8500

LONG-SIDE VESSEL DATA:
Long-side Length Dimension h 130.0000 mm.
Minimum Thickness of Long-side Plates t2 28.0000 mm.
Mid-side Joint Efficiency on Long-side E 0.8500

ADDITIONAL VESSEL DATA:
Minimum Thickness of End Plate t5 20.0000 mm.
C-Factor for End Plate Cf_Epl 0.2000

Long-side Plate # 1,
Pitch Distance p 69.0000 mm.
Uniform Hole Diameter d0 25.6500 mm.
Depth of Holes T0 28.0000 mm.
Long-side Plate # 2,
Pitch Distance p 69.0000 mm.
1: Hole Diameter d0 36.3000 mm.
Hole Depth T0 2.7000 mm.
2: Hole Diameter d1 28.5750 mm.
Hole Depth T1 25.3000 mm.

STAY PLATE MATERIAL DATA:
Stay Material Specification SA-240 316L
Stay Allowable Stress at Design Temp Sr 116.9000 N./mm²
Stay Allowable Stress at Ambient SA 116.9000 N./mm²
Stay Yield Stress at Design Temp Sy 129.8699 N./mm²

STAY PLATE DATA:
Minimum Thickness of Stay t3 10.0000 mm.
Minimum Thickness of Stay t4 10.0000 mm.
The Stay(s) Are Not Welded to the End Plate



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 - 073 - 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 65 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

**Rectangular Vessel Results, Item number 1, Desc: St.AE-2102-Test
ASME Code, Section VIII, Division 1, 2019 App. 13**

03

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

Short-side 1 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Short-side 2 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Long-side 1 Calculations

Effective Diameter [De]: 25.650 mm.

Membrane Ligament Efficiency [Em]:
= $Pitch - De / Pitch$
= $69.000 - 25.650 / 69.000$
= 0.628

Bending Ligament Efficiency [Eb]:
As diameter holes are uniform $Eb = Em$
= 0.628

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 66 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:

$$= t_1 - CA / 2$$

$$= 28.000 - 0.000 / 2$$

$$= 14.000 \text{ mm.}$$



Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t_1 - CA) / 2$$

$$= -(28.000 - 0.000) / 2$$

$$= -14.000 \text{ mm.}$$

Long-side 2 Calculations

Effective Diameter [De]:

$$= (d_0 * T_0 + d_1 * T_1 + d_2 * T_2) / (t_1 - CA)$$

$$= (36.30 * 2.70 + 28.57 * 25.30 + 0.00 * 0.00) /$$

$$(28.00 - 0.00)$$

$$= 29.320 \text{ mm.}$$

Membrane Ligament Efficiency [Em]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 69.000 - 29.320 / 69.000$$

$$= 0.575$$

Dist from Neutral axis of c/s to extreme fibers [Ci & Co]:

Calculation of Xbar:

$$= ((b_0 * T_0 * (T_0/2 + T_1 + T_2)) + (b_1 * T_1 * (T_1/2 + T_2)) + (b_2 * T_2 * (T_2/2))) /$$

$$(b_0 * T_0 + b_1 * T_1 + b_2 * T_2)$$

$$= ((1.29 * 2.70 * (2.70 / 2 + 25.30 + 0.00)) + (1.59 * 25.30 * (25.30 / 2 + 0.00)) + (2.72 * 0.00 * (0.00 / 2))) /$$

$$(1.29 * 2.70 + 1.59 * 25.30 + 2.72 * 0.00)$$

$$= 13.763 \text{ mm.}$$

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:

$$Ci = Xbar$$

$$= 13.763 \text{ mm.}$$

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t - CA - Xbar)$$

$$= -(28.000 - 0.000 - 13.763)$$

$$= -14.237 \text{ mm.}$$

Moment of Inertia (Section 13-6, Equation (5)) [I]:

$$= 0.278 \text{ cm}^4$$

Effective Diameter [De]:

$$= \text{Pitch} - ((6 * I) / ((t - CA)^2 * (-Co)))$$

$$= 69.00 - ((6 * 0.28) / ((28.00 - 0.00)^2 * (14.24)))$$

$$= 31.084 \text{ mm.}$$

Bending Ligament Efficiency [Eb]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 69.000 - 31.084 / 69.000$$

$$= 0.550$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)										
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 67 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

		Em	Eb	Ci	Co
Short-side	1	0.850	0.850	10.000	-10.000
	2	0.850	0.850	10.000	-10.000
Long-side	1	0.628	0.628	14.000	-14.000
	2	0.575	0.550	13.763	-14.237

03

Moment of Inertia of a Strip of the Vessel Wall:

Thickness t_1 , $I_1 = 0.0667 \text{ cm}^4$
 Thickness t_2 , $I_2 = 0.1829 \text{ cm}^4$

Rectangular Vessel Parameters:

$\alpha = H / h = 0.8462$
 $K = (I_2/I_1) * \alpha = 2.3218$

Membrane Stress Calculations per Section 13-9

Membrane Stresses at Short-side 1

Membrane Stress at Short-side 1 [Sms]:
 $= P * h / (2 * t_1) * \{ 3 - [(6 + K * (11 - \alpha^2) / (3 + 5 * K))] \}$
 $= 80.60 * 130.00 / (2 * 20.00) * \{ 3 - [(6 + 2.32 * (11 - 0.85^2) / (3 + 5 * 2.32))] \}$
 $= 25.01 \text{ N./mm}^2$

Membrane Stresses at Short-side 2

Membrane Stress at Short-side 2 [Sms]:
 $= P * h / (2 * t_1) * \{ 3 - [(6 + K * (11 - \alpha^2) / (3 + 5 * K))] \}$
 $= 80.60 * 130.00 / (2 * 20.00) * \{ 3 - [(6 + 2.32 * (11 - 0.85^2) / (3 + 5 * 2.32))] \}$
 $= 25.01 \text{ N./mm}^2$

Membrane Stresses at Long-side 1

Membrane Stress at Long-side 1 at A [Sml]:
 $= P * H / 2 * t_2$
 $= 80.60 * 110.00 / 2 * 28.00$
 $= 15.83 \text{ N./mm}^2$

If $E_m(0.628) < E(0.850)$ and $E_b(0.628) < E(0.850)$ then
 $S_{ml} = S_{ml} / E_m$
 $= 15.83 / 0.63$
 $= 25.20 \text{ N./mm}^2$

Membrane Stresses at Long-side 2

Membrane Stress at Long-side 2 at A [Sml]:
 $= P * H / 2 * t_2$
 $= 80.60 * 110.00 / 2 * 28.00$
 $= 15.83 \text{ N./mm}^2$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 68 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

If $E_m(0.575) < E(0.850)$ and $E_b(0.550) < E(0.850)$ then
 $S_{ml} = S_{ml} / E_m$
 $= 15.83 / 0.58$
 $= 27.53 \text{ N./mm}^2$

03

Membrane Stresses at Stay Plate

Membrane Stress at Stay Plate [t3]:

$$= P * h / (2 * t_3) * [(6 + K * (11 - \alpha^2)) / (3 + 5 * K)]$$

$$= 80.60 * 130.00 / (2 * 10.00) * [(6 + 2.32 * (11 - 0.85^2)) / (3 + 5 * 2.32)]$$

$$= 107.15 \text{ N./mm}^2$$

Membrane Stress at Stay Plate [t4]:

$$= P * h / (2 * t_4) * [(6 + K * (11 - \alpha^2)) / (3 + 5 * K)]$$

$$= 80.60 * 130.00 / (2 * 10.00) * [(6 + 2.32 * (11 - 0.85^2)) / (3 + 5 * 2.32)]$$

$$= 107.15 \text{ N./mm}^2$$

MEMBRANE STRESSES: Membrane Stress Calculations per Section 13-9, Equations (13-15). (N./mm²) :

STRESS LOCATIONS	Actual	Allowable
Short-side 1	25.01	131.84
Short-side 2	25.01	131.84
Short-side Corner	25.01	131.84
Long-side 1 at A	25.20	155.10
Long-side 2 at A	27.53	155.10
Long-side Corner	15.83	131.84
Stay Plate (t3)	107.15	116.90
Stay Plate (t4)	107.15	116.90

Bending Stress Calculations per Section 13-9

Bending Stresses at Short-side 1

Bending Stress at Short-side 1 at N Inner[SbsNi]:

$$= P * c / (24 * I_1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))]$$

$$= 80.60 * 10.00 / (24 * 0.07) * [-3 * 110.00^2 + 2 * 130.00^2 * ((3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32))]$$

$$= -51.03 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at N Outer[SbsNo]:

$$= P * c / (24 * I_1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))]$$

$$= 80.60 * -10.00 / (24 * 0.07) * [-3 * 110.00^2 + 2 * 130.00^2 * ((3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32))]$$

$$= 51.03 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I_1) * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 69 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$\begin{aligned}
 & \text{Alpha}^2 * K) / (3 + 5 * K)) \\
 & = 80.60 * 130.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * \\
 & 0.85^2 * 2.32) / (3 + 5 * 2.32)) \\
 & = 131.85 \text{ N./mm}^2
 \end{aligned}$$



Bending Stress at Short-side 1 at Q Outer[SbsQo]:

$$\begin{aligned}
 & = P * h^2 * c / (12 * I1) * ((3 + 5 * \\
 & \text{Alpha}^2 * K) / (3 + 5 * K)) \\
 & = 80.60 * 130.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * \\
 & 0.85^2 * 2.32) / (3 + 5 * 2.32)) \\
 & = -131.85 \text{ N./mm}^2
 \end{aligned}$$

Bending Stresses at Short-side 2

Bending Stress at Short-side 2 at N Inner[SbsNi]:

$$\begin{aligned}
 & = P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * \\
 & ((3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K))] \\
 & = 80.60 * 10.00 / (24 * 0.07) * [-3 * 110.00^2 + 2 * 130.00^2 * \\
 & ((3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32))] \\
 & = -51.03 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Short-side 2 at N Outer[SbsNo]:

$$\begin{aligned}
 & = P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * \\
 & ((3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K))] \\
 & = 80.60 * -10.00 / (24 * 0.07) * [-3 * 110.00^2 + 2 * 130.00^2 * \\
 & ((3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32))] \\
 & = 51.03 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Short-side 2 at Q Inner[SbsQi]:

$$\begin{aligned}
 & = P * h^2 * c / (12 * I1) * ((3 + 5 * \\
 & \text{Alpha}^2 * K) / (3 + 5 * K)) \\
 & = 80.60 * 130.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * \\
 & 0.85^2 * 2.32) / (3 + 5 * 2.32)) \\
 & = 131.85 \text{ N./mm}^2
 \end{aligned}$$

Bending Stress at Short-side 2 at Q Outer[SbsQo]:

$$\begin{aligned}
 & = P * h^2 * c / (12 * I1) * ((3 + 5 * \\
 & \text{Alpha}^2 * K) / (3 + 5 * K)) \\
 & = 80.60 * 130.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * \\
 & 0.85^2 * 2.32) / (3 + 5 * 2.32)) \\
 & = -131.85 \text{ N./mm}^2
 \end{aligned}$$

Bending Stresses at Long-side 1

Bending Stress at Long-side 1 at M Inner[SblMi]:

$$\begin{aligned}
 & = P * h^2 * c / (12 * I2) * [(3 + K * \\
 & (6 - \text{Alpha}^2)) / (3 + 5 * K)] \\
 & = 80.60 * 130.00^2 * 14.00 / (12 * 0.18) * [(3 + 2.32 * \\
 & (6 - 0.85^2)) / (3 + 5 * 2.32)] \\
 & = 90.80 \text{ N./mm}^2
 \end{aligned}$$

If $E_m(0.628) < E(0.850)$ and $E_b(0.628) < E(0.850)$ then

$$\begin{aligned}
 & \text{SblMi} = \text{SblMi} / E_b \\
 & = 90.80 / 0.63 \\
 & = 144.52 \text{ N./mm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 70 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Bending Stress at Long-side 1 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 80.60 * 130.00^2 * -14.00 / (12 * 0.18) * [(3 + 2.32 * (6 - 0.85^2)) / (3 + 5 * 2.32)]$$

$$= -90.80 \text{ N./mm}^2$$

If $E_m(0.628) < E(0.850)$ and $E_b(0.628) < E(0.850)$ then

$$\text{SblMo} = \text{SblMo} / E_b$$

$$= -90.80 / 0.63$$

$$= -144.52 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 80.60 * 130.00^2 * 14.00 / (12 * 0.18) * [(3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32)]$$

$$= 67.27 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 80.60 * 130.00^2 * -14.00 / (12 * 0.18) * [(3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32)]$$

$$= -67.27 \text{ N./mm}^2$$

Bending Stresses at Long-side 2

Bending Stress at Long-side 2 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 80.60 * 130.00^2 * 13.76 / (12 * 0.18) * [(3 + 2.32 * (6 - 0.85^2)) / (3 + 5 * 2.32)]$$

$$= 89.26 \text{ N./mm}^2$$

If $E_m(0.575) < E(0.850)$ and $E_b(0.550) < E(0.850)$ then

$$\text{SblMi} = \text{SblMi} / E_b$$

$$= 89.26 / 0.55$$

$$= 162.43 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 80.60 * 130.00^2 * -14.24 / (12 * 0.18) * [(3 + 2.32 * (6 - 0.85^2)) / (3 + 5 * 2.32)]$$

$$= -92.34 \text{ N./mm}^2$$

If $E_m(0.575) < E(0.850)$ and $E_b(0.550) < E(0.850)$ then

$$\text{SblMo} = \text{SblMo} / E_b$$

$$= -92.34 / 0.55$$

$$= -168.04 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 80.60 * 130.00^2 * 13.76 / (12 * 0.18) * [(3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32)]$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 71 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= 66.13 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 80.60 * 130.00^2 * -14.24 / (12 * 0.18) * [(3 + 5 * 0.85^2 * 2.32) / (3 + 5 * 2.32)]$$

$$= -68.41 \text{ N./mm}^2$$

03

BENDING STRESSES: Bending Stress Calculations per Section 13-9, Equations (16-19). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-51.03	51.03	197.75
at Q	131.85	-131.85	197.75
Short-side 2 at N	-51.03	51.03	197.75
at Q	131.85	-131.85	197.75
Long-side 1 at M	144.52	-144.52	232.65
at Q	67.27	-67.27	197.75
Long-side 2 at M	162.43	-168.04	232.65
at Q	66.13	-68.41	197.75

Total Stress Calculations per Section 13-9

Total Stresses at Short-side 1

Total Stress at short side 1 at N inner [STS_Ni]:

$$= S_{ms} + S_{bsNi}$$

$$= 25.01 + -51.03$$

$$= -26.01 \text{ N./mm}^2$$

Total Stress at short side 1 at N outer [STS_No]:

$$= S_{ms} + S_{bsNo}$$

$$= 25.01 + 51.03$$

$$= 76.04 \text{ N./mm}^2$$

Total Stress at short side 1 at Q inner [STS_Qi]:

$$= S_{ms} + S_{bsQi}$$

$$= 25.01 + 131.85$$

$$= 156.86 \text{ N./mm}^2$$

Total Stress at short side 1 at Q outer [STS_Qo]:

$$= S_{ms} + S_{bsQo}$$

$$= 25.01 + -131.85$$

$$= -106.83 \text{ N./mm}^2$$

Total Stresses at Short-side 2

Total Stress at short side 2 at N inner [STS_Ni]:

$$= S_{ms} + S_{bsNi}$$

$$= 25.01 + -51.03$$

$$= -26.01 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 72 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Total Stress at short side 2 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 25.01 + 51.03 \\
 &= 76.04 \text{ N./mm}^2
 \end{aligned}$$

03

Total Stress at short side 2 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 25.01 + 131.85 \\
 &= 156.86 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 25.01 + -131.85 \\
 &= -106.83 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Long-side 1

Total Stress at long side 1 at M inner [STL_Mi]:

$$\begin{aligned}
 &= S_{ml} + S_{blMi} \\
 &= 25.20 + 144.52 \\
 &= 169.72 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at M outer [STL_Mo]:

$$\begin{aligned}
 &= S_{ml} + S_{blMo} \\
 &= 25.20 + -144.52 \\
 &= -119.32 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q inner [STL_Qi]:

$$\begin{aligned}
 &= S_{ml} + S_{blQi} \\
 &= 15.83 + 67.27 \\
 &= 83.10 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 1 at Q outer [STL_Qo]:

$$\begin{aligned}
 &= S_{mlB} + S_{blQo} \\
 &= 15.83 + -67.27 \\
 &= -51.44 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Long-side 2

Total Stress at long side 2 at M inner [STL_Mi]:

$$\begin{aligned}
 &= S_{ml} + S_{blMi} \\
 &= 27.53 + 162.43 \\
 &= 189.96 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 2 at M outer [STL_Mo]:

$$\begin{aligned}
 &= S_{ml} + S_{blMo} \\
 &= 27.53 + -168.04 \\
 &= -140.50 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 2 at Q inner [STL_Qi]:

$$\begin{aligned}
 &= S_{ml} + S_{blQi} \\
 &= 15.83 + 66.13 \\
 &= 81.96 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at long side 2 at Q outer [STL_Qo]:

$$= S_{mlB} + S_{blQo}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 73 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= 15.83 + -68.41$$

$$= -52.58 \text{ N./mm}^2$$

03

**TOTAL STRESSES: Total Stress Calculations per Section 13-9,
Equations (20-24). (N./mm²) :**

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-26.01	76.04	197.75
at Q	156.86	-106.83	197.75
Short-side 2 at N	-26.01	76.04	197.75
at Q	156.86	-106.83	197.75
Long-side 1 at M	169.72	-119.32	232.65
at Q	83.10	-51.44	197.75
Long-side 2 at M	189.96	-140.50	232.65
at Q	81.96	-52.58	197.75

End Plate Stresses (N./mm²):

	Actual	Allowable
End Plate	121.91	155.10

Required End Plate thickness due to Internal Pressure [trEP]:

$$= d * \sqrt{Z * C * P / (SE)} + ca$$

$$= 110.000 * \sqrt{2.500 * 0.200 * 80.600 / (155.100)} + 0.000$$

$$= 17.732 \text{ mm.}$$

End Plate MAWP at given Thickness [MAWPEP]:

$$= ((T-ca)/d)^2 * ((SE)/(C*Z)) \text{ per UG-34 (c)(3)}$$

$$= ((20.0000-0.0000)/110.0000)^2 * ((155)/(0.20*2.50))$$

$$= 102.540 \text{ bars}$$

where Z is:

$$= \min(3.4 - 2.4(d/D), 2.5)$$

$$= \min(3.4 - 2.4(110.000 / 410.000), 2.5)$$

$$= 2.500$$

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,

High Stress (Highest % of Allowable)	107.15	N./mm ²
High Stress Percentage	91.66	%
M.A.W.P. for Membrane Stresses	87.93	bars

BENDING STRESS SUMMARY,

High Stress (Highest % of Allowable)	-168.04	N./mm ²
High Stress Percentage	72.23	%
M.A.W.P. for Bending Stresses	111.59	bars

TOTAL STRESS SUMMARY,

High Stress (Highest % of Allowable)	189.96	N./mm ²
High Stress Percentage	81.65	%
M.A.W.P. for Total Stresses	98.71	bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 74 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Rectangular Vessel Results For Item 1 : A8

03

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	107.15	N./mm ²
High Stress Percentage	91.66	%
M.A.W.P. for Membrane Stresses	87.93	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-168.04	N./mm ²
High Stress Percentage	72.23	%
M.A.W.P. for Bending Stresses	111.59	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	189.96	N./mm ²
High Stress Percentage	81.65	%
M.A.W.P. for Total Stresses	98.71	bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 75 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

3.7 FLOATING HEADER CALCULATION @ DESIGN PRESSURE FOR AE-2102.

Input Echo, COMPONENT 1, Description: FI.AE-2101

Figure Number Analyzed	A8		
Design Internal Pressure	P	62.0000	bars
Design Temperature	Temp	175.0000	C
VESSEL MATERIAL DATA:			
Material Specification		SA-240 316L	
Shell Allowable Stress at Design Temp	S	111.9078	N./mm ²
Shell Allowable Stress at Ambient	SA	115.1465	N./mm ²
Shell Yield Stress at Design Temperature	Sy	126.1469	N./mm ²
SHORT-SIDE VESSEL DATA:			
Short-side Length Dimension	H	100.0000	mm.
Minimum Thickness of Short-side Plates	t1	20.0000	mm.
Mid-side Joint Efficiency on Short-side	E	0.8500	
Corner Joint Efficiency on Short-side	EC	0.8500	
LONG-SIDE VESSEL DATA:			
Long-side Length Dimension	h	60.0000	mm.
Minimum Thickness of Long-side Plates	t2	20.0000	mm.
Mid-side Joint Efficiency on Long-side	E	0.8500	
ADDITIONAL VESSEL DATA:			
Minimum Thickness of End Plate	t5	20.0000	mm.
C-Factor for End Plate	Cf_Epl	0.2000	
Long-side Plate # 1,			
Pitch Distance	p	69.0000	mm.
Uniform Hole Diameter	d0	25.6500	mm.
Depth of Holes	T0	20.0000	mm.
Long-side Plate # 2,			
Pitch Distance	p	69.0000	mm.
# 1: Hole Diameter	d0	36.3000	mm.
Hole Depth	T0	2.7000	mm.
# 2: Hole Diameter	d1	28.5750	mm.
Hole Depth	T1	17.3000	mm.
STAY PLATE MATERIAL DATA:			
Stay Material Specification		SA-240 316L	
Stay Allowable Stress at Design Temp	Sr	114.3898	N./mm ²
Stay Allowable Stress at Ambient	SA	115.1465	N./mm ²
Stay Yield Stress at Design Temp	Sy	129.8699	N./mm ²
STAY PLATE DATA:			
Minimum Thickness of Stay	t3	10.0000	mm.
Minimum Thickness of Stay	t4	10.0000	mm.
The Stay(s) Are Not Welded to the End Plate			

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 - 073 - 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 76 از 150
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	AA	120	PR	CN	0001	V03

Rectangular Vessel Results, Item number 1, Desc: FI.AE-2101
ASME Code, Section VIII, Division 1, 2019 App. 13

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

Short-side 1 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Short-side 2 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Long-side 1 Calculations

Effective Diameter [De]: 25.650 mm.

Membrane Ligament Efficiency [Em]:
= $Pitch - De / Pitch$
= $69.000 - 25.650 / 69.000$
= 0.628

Bending Ligament Efficiency [Eb]:
As diameter holes are uniform $Eb = Em$
= 0.628

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 77 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t_1 - CA) / 2$$

$$= -(20.000 - 0.000) / 2$$

$$= -10.000 \text{ mm.}$$

Long-side 2 Calculations

Effective Diameter [De]:

$$= (d_0 * T_0 + d_1 * T_1 + d_2 * T_2) / (t_1 - CA)$$

$$= (36.30 * 2.70 + 28.57 * 17.30 + 0.00 * 0.00) / (20.00 - 0.00)$$

$$= 29.618 \text{ mm.}$$

Membrane Ligament Efficiency [Em]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 69.000 - 29.618 / 69.000$$

$$= 0.571$$

Dist from Neutral axis of c/s to extreme fibers [Ci & Co]:

Calculation of Xbar:

$$= ((b_0 * T_0 * (T_0/2 + T_1 + T_2)) + (b_1 * T_1 * (T_1/2 + T_2)) + (b_2 * T_2 * (T_2/2))) / (b_0 * T_0 + b_1 * T_1 + b_2 * T_2)$$

$$= ((1.29 * 2.70 * (2.70/2 + 17.30 + 0.00)) + (1.59 * 17.30 * (17.30/2 + 0.00)) + (2.72 * 0.00 * (0.00/2))) / (1.29 * 2.70 + 1.59 * 17.30 + 2.72 * 0.00)$$

$$= 9.771 \text{ mm.}$$

Dist from Neutral axis of c/s to inside surface of the vesssel [Ci]:

$$Ci = Xbar$$

$$= 9.771 \text{ mm.}$$

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t - CA - Xbar)$$

$$= -(20.000 - 0.000 - 9.771)$$

$$= -10.229 \text{ mm.}$$

Moment of Inertia (Section 13-6, Equation (5)) [I]:

$$= 0.100 \text{ cm}^4$$

Effective Diameter [De]:

$$= \text{Pitch} - ((6 * I) / ((t - CA)^2 * (-Co)))$$

$$= 69.00 - ((6 * 0.10) / ((20.00 - 0.00)^2 * (10.23)))$$

$$= 31.848 \text{ mm.}$$

Bending Ligament Efficiency [Eb]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 69.000 - 31.848 / 69.000$$

$$= 0.538$$

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

		Em	Eb	Ci	Co
Short-side	1	0.850	0.850	10.000	-10.000
	2	0.850	0.850	10.000	-10.000
Long-side	1	0.628	0.628	10.000	-10.000
	2	0.571	0.538	9.771	-10.229

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 78 از 150
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	AA	120	PR	CN	0001	V03

Moment of Inertia of a Strip of the Vessel Wall:

$$\text{Thickness } t_1, I_1 = 0.0667 \text{ cm}^4$$

$$\text{Thickness } t_2, I_2 = 0.0667 \text{ cm}^4$$

Rectangular Vessel Parameters:

$$\text{Alpha} = H / h = 1.6667$$

$$K = (I_2/I_1) * \text{Alpha} = 1.6667$$

Membrane Stress Calculations per Section 13-9

Membrane Stresses at Short-side 1

Membrane Stress at Short-side 1 [Sms]:

$$= P * h / (2 * t_1) * \{ 3 - [(6 + K * (11 - \alpha^2)) / (3 + 5 * K)] \}$$

$$= 62.00 * 60.00 / (2 * 20.00) * \{ 3 - [(6 + 1.67 * (11 - 1.67^2)) / (3 + 5 * 1.67)] \}$$

$$= 11.73 \text{ N./mm}^2$$

Membrane Stresses at Short-side 2

Membrane Stress at Short-side 2 [Sms]:

$$= P * h / (2 * t_1) * \{ 3 - [(6 + K * (11 - \alpha^2)) / (3 + 5 * K)] \}$$

$$= 62.00 * 60.00 / (2 * 20.00) * \{ 3 - [(6 + 1.67 * (11 - 1.67^2)) / (3 + 5 * 1.67)] \}$$

$$= 11.73 \text{ N./mm}^2$$

Membrane Stresses at Long-side 1

Membrane Stress at Long-side 1 at A [Sml]:

$$= P * H / 2 * t_2$$

$$= 62.00 * 100.00 / 2 * 20.00$$

$$= 15.50 \text{ N./mm}^2$$

If $E_m(0.628) < E(0.850)$ and $E_b(0.628) < E(0.850)$ then

$$S_{ml} = S_{ml} / E_m$$

$$= 15.50 / 0.63$$

$$= 24.67 \text{ N./mm}^2$$

Membrane Stresses at Long-side 2

Membrane Stress at Long-side 2 at A [Sml]:

$$= P * H / 2 * t_2$$

$$= 62.00 * 100.00 / 2 * 20.00$$

$$= 15.50 \text{ N./mm}^2$$

If $E_m(0.571) < E(0.850)$ and $E_b(0.538) < E(0.850)$ then

$$S_{ml} = S_{ml} / E_m$$

$$= 15.50 / 0.57$$

$$= 27.16 \text{ N./mm}^2$$

Membrane Stresses at Stay Plate

Membrane Stress at Stay Plate [t3]:

$$= P * h / (2 * t_3) * [(6 + K * (11 - \alpha^2)) / (3 + 5 * K)]$$

$$= 62.00 * 60.00 / (2 * 10.00) * [(6 + 1.67 * (11 - 1.67^2)) / (3 + 5 * 1.67)]$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 79 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= 1.67^2 / (3 + 5 * 1.67)]$$

$$= 32.34 \text{ N./mm}^2$$

Membrane Stress at Stay Plate [t4]:

$$= P * h / (2 * t4) * [(6 + K * (11 - \alpha^2) / (3 + 5 * K))]$$

$$= 62.00 * 60.00 / (2 * 10.00) * [(6 + 1.67 * (11 - 1.67^2) / (3 + 5 * 1.67))]$$

$$= 32.34 \text{ N./mm}^2$$

MEMBRANE STRESSES: Membrane Stress Calculations per Section 13-9, Equations (13-15). (N./mm²) :

STRESS LOCATIONS	Actual	Allowable
Short-side 1	11.73	95.12
Short-side 2	11.73	95.12
Short-side Corner	11.73	95.12
Long-side 1 at A	24.67	111.91
Long-side 2 at A	27.16	111.91
Long-side Corner	15.50	95.12
Stay Plate (t3)	32.34	114.39
Stay Plate (t4)	32.34	114.39

Bending Stress Calculations per Section 13-9

Bending Stresses at Short-side 1

Bending Stress at Short-side 1 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))]$$

$$= 62.00 * 10.00 / (24 * 0.07) * [-3 * 100.00^2 + 2 * 60.00^2 * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))]$$

$$= -51.88 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))]$$

$$= 62.00 * -10.00 / (24 * 0.07) * [-3 * 100.00^2 + 2 * 60.00^2 * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))]$$

$$= 51.88 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))$$

$$= 62.00 * 60.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))$$

$$= 64.37 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))$$

$$= 62.00 * 60.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))$$

$$= -64.37 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 - 073 - 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 80 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Bending Stresses at Short-side 2

Bending Stress at Short-side 2 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 62.00 * 10.00 / (24 * 0.07) * [-3 * 100.00^2 + 2 * 60.00^2 * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))]$$

$$= -51.88 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 62.00 * -10.00 / (24 * 0.07) * [-3 * 100.00^2 + 2 * 60.00^2 * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))]$$

$$= 51.88 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))$$

$$= 62.00 * 60.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))$$

$$= 64.37 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))$$

$$= 62.00 * 60.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))$$

$$= -64.37 \text{ N./mm}^2$$

Bending Stresses at Long-side 1

Bending Stress at Long-side 1 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I2) * [(3 + K * (6 - Alpha^2)) / (3 + 5 * K)]$$

$$= 62.00 * 60.00^2 * 10.00 / (12 * 0.07) * [(3 + 1.67 * (6 - 1.67^2)) / (3 + 5 * 1.67)]$$

$$= 20.61 \text{ N./mm}^2$$

If $Em(0.628) < E(0.850)$ and $Eb(0.628) < E(0.850)$ then

$$SblMi = SblMi / Eb$$

$$= 20.61 / 0.63$$

$$= 32.80 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I2) * [(3 + K * (6 - Alpha^2)) / (3 + 5 * K)]$$

$$= 62.00 * 60.00^2 * -10.00 / (12 * 0.07) * [(3 + 1.67 * (6 - 1.67^2)) / (3 + 5 * 1.67)]$$

$$= -20.61 \text{ N./mm}^2$$

If $Em(0.628) < E(0.850)$ and $Eb(0.628) < E(0.850)$ then

$$SblMo = SblMo / Eb$$

$$= -20.61 / 0.63$$

$$= -32.80 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I2) * [(3 + 5 * Alpha^2 * K) / (3 + 5 * K)]$$

$$= 62.00 * 60.00^2 * 10.00 / (12 * 0.07) * [(3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67)]$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 81 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= 1.67^2 * 1.67 / (3 + 5 * 1.67)]$$

$$= 64.37 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 62.00 * 60.00^2 * -10.00 / (12 * 0.07) * [(3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67)]$$

$$= -64.37 \text{ N./mm}^2$$

Bending Stresses at Long-side 2

Bending Stress at Long-side 2 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 62.00 * 60.00^2 * 9.77 / (12 * 0.07) * [(3 + 1.67 * (6 - 1.67^2)) / (3 + 5 * 1.67)]$$

$$= 20.14 \text{ N./mm}^2$$

If $E_m(0.571) < E(0.850)$ and $E_b(0.538) < E(0.850)$ then

$$SblMi = SblMi / E_b$$

$$= 20.14 / 0.54$$

$$= 37.40 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 62.00 * 60.00^2 * -10.23 / (12 * 0.07) * [(3 + 1.67 * (6 - 1.67^2)) / (3 + 5 * 1.67)]$$

$$= -21.08 \text{ N./mm}^2$$

If $E_m(0.571) < E(0.850)$ and $E_b(0.538) < E(0.850)$ then

$$SblMo = SblMo / E_b$$

$$= -21.08 / 0.54$$

$$= -39.15 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 62.00 * 60.00^2 * 9.77 / (12 * 0.07) * [(3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67)]$$

$$= 62.90 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 62.00 * 60.00^2 * -10.23 / (12 * 0.07) * [(3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67)]$$

$$= -65.85 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 82 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

BENDING STRESSES: Bending Stress Calculations per Section 13-9, Equations (16-19). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-51.88	51.88	142.68
at Q	64.37	-64.37	142.68
Short-side 2 at N	-51.88	51.88	142.68
at Q	64.37	-64.37	142.68
Long-side 1 at M	32.80	-32.80	167.86
at Q	64.37	-64.37	142.68
Long-side 2 at M	37.40	-39.15	167.86
at Q	62.90	-65.85	142.68

Total Stress Calculations per Section 13-9

Total Stresses at Short-side 1

Total Stress at short side 1 at N inner [STS_Ni]:
= S_{ms} + S_{bsNi}
= 11.73 + -51.88
= -40.15 N./mm²

Total Stress at short side 1 at N outer [STS_No]:
= S_{ms} + S_{bsNo}
= 11.73 + 51.88
= 63.61 N./mm²

Total Stress at short side 1 at Q inner [STS_Qi]:
= S_{ms} + S_{bsQi}
= 11.73 + 64.37
= 76.11 N./mm²

Total Stress at short side 1 at Q outer [STS_Qo]:
= S_{ms} + S_{bsQo}
= 11.73 + -64.37
= -52.64 N./mm²

Total Stresses at Short-side 2

Total Stress at short side 2 at N inner [STS_Ni]:
= S_{ms} + S_{bsNi}
= 11.73 + -51.88
= -40.15 N./mm²

Total Stress at short side 2 at N outer [STS_No]:
= S_{ms} + S_{bsNo}
= 11.73 + 51.88
= 63.61 N./mm²

Total Stress at short side 2 at Q inner [STS_Qi]:
= S_{ms} + S_{bsQi}
= 11.73 + 64.37
= 76.11 N./mm²

Total Stress at short side 2 at Q outer [STS_Qo]:
= S_{ms} + S_{bsQo}
= 11.73 + -64.37
= -52.64 N./mm²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 83 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Total Stresses at Long-side 1

Total Stress at long side 1 at M inner [STL_Mi]:
 $= S_{ml} + S_{blMi}$
 $= 24.67 + 32.80$
 $= 57.47 \text{ N./mm}^2$

Total Stress at long side 1 at M outer [STL_Mo]:
 $= S_{ml} + S_{blMo}$
 $= 24.67 + -32.80$
 $= -8.13 \text{ N./mm}^2$

Total Stress at long side 1 at Q inner [STL_Qi]:
 $= S_{ml} + S_{blQi}$
 $= 15.50 + 64.37$
 $= 79.88 \text{ N./mm}^2$

Total Stress at long side 1 at Q outer [STL_Qo]:
 $= S_{ml} + S_{blQo}$
 $= 15.50 + -64.37$
 $= -48.87 \text{ N./mm}^2$

Total Stresses at Long-side 2

Total Stress at long side 2 at M inner [STL_Mi]:
 $= S_{ml} + S_{blMi}$
 $= 27.16 + 37.40$
 $= 64.55 \text{ N./mm}^2$

Total Stress at long side 2 at M outer [STL_Mo]:
 $= S_{ml} + S_{blMo}$
 $= 27.16 + -39.15$
 $= -11.99 \text{ N./mm}^2$

Total Stress at long side 2 at Q inner [STL_Qi]:
 $= S_{ml} + S_{blQi}$
 $= 15.50 + 62.90$
 $= 78.40 \text{ N./mm}^2$

Total Stress at long side 2 at Q outer [STL_Qo]:
 $= S_{ml} + S_{blQo}$
 $= 15.50 + -65.85$
 $= -50.35 \text{ N./mm}^2$

TOTAL STRESSES: Total Stress Calculations per Section 13-9, Equations (20-24). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-40.15	63.61	142.68
at Q	76.11	-52.64	142.68
Short-side 2 at N	-40.15	63.61	142.68
at Q	76.11	-52.64	142.68
Long-side 1 at M	57.47	-8.13	167.86
at Q	79.88	-48.87	142.68
Long-side 2 at M	64.55	-11.99	167.86
at Q	78.40	-50.35	142.68

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 84 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

End Plate Stresses (N./mm²):

	Actual	Allowable
End Plate	68.20	111.91

Required End Plate thickness due to Internal Pressure [trEP]:

$$= d * \sqrt{Z * C * P / (SE)} + ca$$

$$= 100.000 * \sqrt{2.200 * 0.200 * 62.000 / (111.908)} + 0.000$$

$$= 15.614 \text{ mm.}$$

End Plate MAWP at given Thickness [MAWPEP]:

$$= ((T-ca)/d)^2 * ((SE)/(C*Z)) \text{ per UG-34 (c)(3)}$$

$$= ((20.0000-0.0000)/100.0000)^2 * ((111)/(2.20*2.20))$$

$$= 101.728 \text{ bars}$$

where Z is:

$$= \min(3.4 - 2.4(d/D), 2.5)$$

$$= \min(3.4 - 2.4(100.000 / 200.000), 2.5)$$

$$= 2.200$$

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	32.34	N./mm ²
High Stress Percentage	28.27	%
M.A.W.P. for Membrane Stresses	219.31	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-65.85	N./mm ²
High Stress Percentage	46.15	%
M.A.W.P. for Bending Stresses	134.34	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	79.88	N./mm ²
High Stress Percentage	55.98	%
M.A.W.P. for Total Stresses	110.75	bars

Rectangular Vessel Results For Item 1 : A8

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	32.34	N./mm ²
High Stress Percentage	28.27	%
M.A.W.P. for Membrane Stresses	219.31	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-65.85	N./mm ²
High Stress Percentage	46.15	%
M.A.W.P. for Bending Stresses	134.34	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	79.88	N./mm ²
High Stress Percentage	55.98	%
M.A.W.P. for Total Stresses	110.75	bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 85 از 150
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	AA	120	PR	CN	0001	V03	

3.8 FLOATING HEADER CALCULATION @ TEST PRESSURE FOR AE-2102.

Input Echo, COMPONENT 1, Description: FI.AE-2101-Test

Figure Number Analyzed A8

Design Internal Pressure P 80.6000 bars
Design Temperature Temp 25.0000 C

VESSEL MATERIAL DATA:
Material Specification SA-240 316L
Shell Allowable Stress at Design Temp S 155.0000 N./mm²
Shell Allowable Stress at Ambient SA 155.0000 N./mm²
Shell Yield Stress at Design Temperature Sy 172.3750 N./mm²

SHORT-SIDE VESSEL DATA:
Short-side Length Dimension H 100.0000 mm.
Minimum Thickness of Short-side Plates t1 20.0000 mm.
Mid-side Joint Efficiency on Short-side E 0.8500
Corner Joint Efficiency on Short-side EC 0.8500

LONG-SIDE VESSEL DATA:
Long-side Length Dimension h 60.0000 mm.
Minimum Thickness of Long-side Plates t2 20.0000 mm.
Mid-side Joint Efficiency on Long-side E 0.8500

ADDITIONAL VESSEL DATA:
Minimum Thickness of End Plate t5 20.0000 mm.
C-Factor for End Plate Cf_Epl 0.2000

Long-side Plate # 1,
Pitch Distance p 69.0000 mm.
Uniform Hole Diameter d0 25.6500 mm.
Depth of Holes T0 20.0000 mm.
Long-side Plate # 2,
Pitch Distance p 69.0000 mm.
1: Hole Diameter d0 36.3000 mm.
Hole Depth T0 2.7000 mm.
2: Hole Diameter d1 28.5750 mm.
Hole Depth T1 17.3000 mm.

STAY PLATE MATERIAL DATA:
Stay Material Specification SA-240 316L
Stay Allowable Stress at Design Temp Sr 114.3898 N./mm²
Stay Allowable Stress at Ambient SA 115.1465 N./mm²
Stay Yield Stress at Design Temp Sy 129.8699 N./mm²

STAY PLATE DATA:
Minimum Thickness of Stay t3 10.0000 mm.
Minimum Thickness of Stay t4 10.0000 mm.
The Stay(s) Are Not Welded to the End Plate

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 86 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Rectangular Vessel Results, Item number 1, Desc: FI.AE-2101-Test
ASME Code, Section VIII, Division 1, 2019 App. 13

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

Short-side 1 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Short-side 2 Calculations

Membrane Ligament Efficiency [Em]:
= 0.850

Bending Ligament Efficiency [Eb]:
= 0.850

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:
= $-(t_1 - CA) / 2$
= $-(20.000 - 0.000) / 2$
= -10.000 mm.

Long-side 1 Calculations

Effective Diameter [De]: 25.650 mm.

Membrane Ligament Efficiency [Em]:
= $Pitch - De / Pitch$
= $69.000 - 25.650 / 69.000$
= 0.628

Bending Ligament Efficiency [Eb]:
As diameter holes are uniform $Eb = Em$
= 0.628

Dist from Neutral axis of c/s to inside surface of the vessel [Ci]:
= $t_1 - CA / 2$
= $20.000 - 0.000 / 2$
= 10.000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 87 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t_1 - CA) / 2$$

$$= -(20.000 - 0.000) / 2$$

$$= -10.000 \text{ mm.}$$

Long-side 2 Calculations

Effective Diameter [De]:

$$= (d_0 * T_0 + d_1 * T_1 + d_2 * T_2) / (t_1 - CA)$$

$$= (36.30 * 2.70 + 28.57 * 17.30 + 0.00 * 0.00) /$$

$$(20.00 - 0.00)$$

$$= 29.618 \text{ mm.}$$

Membrane Ligament Efficiency [Em]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 69.000 - 29.618 / 69.000$$

$$= 0.571$$

Dist from Neutral axis of c/s to extreme fibers [Ci & Co]:

Calculation of Xbar:

$$= ((b_0 * T_0 * (T_0/2 + T_1 + T_2)) + (b_1 * T_1 * (T_1/2 + T_2))) /$$

$$(b_0 * T_0 + b_1 * T_1 + b_2 * T_2)$$

$$= ((1.29 * 2.70 * (2.70/2 + 17.30 + 0.00)) + (1.59 * 17.30 * (17.30/2 + 0.00))) /$$

$$(1.29 * 2.70 + 1.59 * 17.30 + 2.72 * 0.00)$$

$$= 9.771 \text{ mm.}$$

Dist from Neutral axis of c/s to inside surface of the vesssel [Ci]:

$$Ci = Xbar$$

$$= 9.771 \text{ mm.}$$

Dist from Neutral axis of c/s to extreme outside surface of the section [Co]:

$$= -(t - CA - Xbar)$$

$$= -(20.000 - 0.000 - 9.771)$$

$$= -10.229 \text{ mm.}$$

Moment of Inertia (Section 13-6, Equation (5)) [I]:

$$= 0.100 \text{ cm}^4$$

Effective Diameter [De]:

$$= \text{Pitch} - ((6 * I) / ((t - CA)^2 * (-Co)))$$

$$= 69.00 - ((6 * 0.10) / ((20.00 - 0.00)^2 * (10.23)))$$

$$= 31.848 \text{ mm.}$$

Bending Ligament Efficiency [Eb]:

$$= \text{Pitch} - De / \text{Pitch}$$

$$= 69.000 - 31.848 / 69.000$$

$$= 0.538$$

Ligament Efficiency Calculations (Section 13-6, Equations (1)-(6)):

		Em	Eb	Ci	Co
Short-side	1	0.850	0.850	10.000	-10.000
	2	0.850	0.850	10.000	-10.000
Long-side	1	0.628	0.628	10.000	-10.000
	2	0.571	0.538	9.771	-10.229

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 - 073 - 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 88 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

Moment of Inertia of a Strip of the Vessel Wall:

$$\text{Thickness } t_1, I_1 = 0.0667 \text{ cm}^4$$

$$\text{Thickness } t_2, I_2 = 0.0667 \text{ cm}^4$$

Rectangular Vessel Parameters:

$$\text{Alpha} = H / h = 1.6667$$

$$K = (I_2/I_1) * \text{Alpha} = 1.6667$$

Membrane Stress Calculations per Section 13-9

Membrane Stresses at Short-side 1

Membrane Stress at Short-side 1 [Sms]:

$$= P * h / (2 * t_1) * \{ 3 - [(6 + K * (11 - \alpha^2)) / (3 + 5 * K)] \}$$

$$= 80.60 * 60.00 / (2 * 20.00) * \{ 3 - [(6 + 1.67 * (11 - 1.67^2)) / (3 + 5 * 1.67)] \}$$

$$= 15.25 \text{ N./mm}^2$$

Membrane Stresses at Short-side 2

Membrane Stress at Short-side 2 [Sms]:

$$= P * h / (2 * t_1) * \{ 3 - [(6 + K * (11 - \alpha^2)) / (3 + 5 * K)] \}$$

$$= 80.60 * 60.00 / (2 * 20.00) * \{ 3 - [(6 + 1.67 * (11 - 1.67^2)) / (3 + 5 * 1.67)] \}$$

$$= 15.25 \text{ N./mm}^2$$

Membrane Stresses at Long-side 1

Membrane Stress at Long-side 1 at A [Sml]:

$$= P * H / 2 * t_2$$

$$= 80.60 * 100.00 / 2 * 20.00$$

$$= 20.15 \text{ N./mm}^2$$

If $E_m(0.628) < E(0.850)$ and $E_b(0.628) < E(0.850)$ then

$$S_{ml} = S_{ml} / E_m$$

$$= 20.15 / 0.63$$

$$= 32.07 \text{ N./mm}^2$$

Membrane Stresses at Long-side 2

Membrane Stress at Long-side 2 at A [Sml]:

$$= P * H / 2 * t_2$$

$$= 80.60 * 100.00 / 2 * 20.00$$

$$= 20.15 \text{ N./mm}^2$$

If $E_m(0.571) < E(0.850)$ and $E_b(0.538) < E(0.850)$ then

$$S_{ml} = S_{ml} / E_m$$

$$= 20.15 / 0.57$$

$$= 35.31 \text{ N./mm}^2$$

Membrane Stresses at Stay Plate

Membrane Stress at Stay Plate [t3]:

$$= P * h / (2 * t_3) * [(6 + K * (11 - \alpha^2)) / (3 + 5 * K)]$$

$$= 80.60 * 60.00 / (2 * 10.00) * [(6 + 1.67 * (11 - 1.67^2)) / (3 + 5 * 1.67)]$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 89 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

$$= 1.67^2 / (3 + 5 * 1.67)]$$

$$= 42.04 \text{ N./mm}^2$$

Membrane Stress at Stay Plate [t4]:

$$= P * h / (2 * t4) * [(6 + K * (11 - \alpha^2) / (3 + 5 * K))]$$

$$= 80.60 * 60.00 / (2 * 10.00) * [(6 + 1.67 * (11 - 1.67^2) / (3 + 5 * 1.67))]$$

$$= 42.04 \text{ N./mm}^2$$

MEMBRANE STRESSES: Membrane Stress Calculations per Section 13-9, Equations (13-15). (N./mm²) :

STRESS LOCATIONS	Actual	Allowable
Short-side 1	15.25	131.75
Short-side 2	15.25	131.75
Short-side Corner	15.25	131.75
Long-side 1 at A	32.07	155.00
Long-side 2 at A	35.31	155.00
Long-side Corner	20.15	131.75
Stay Plate (t3)	42.04	114.39
Stay Plate (t4)	42.04	114.39

Bending Stress Calculations per Section 13-9

Bending Stresses at Short-side 1

Bending Stress at Short-side 1 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))]$$

$$= 80.60 * 10.00 / (24 * 0.07) * [-3 * 100.00^2 + 2 * 60.00^2 * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))]$$

$$= -67.45 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))]$$

$$= 80.60 * -10.00 / (24 * 0.07) * [-3 * 100.00^2 + 2 * 60.00^2 * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))]$$

$$= 67.45 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))$$

$$= 80.60 * 60.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))$$

$$= 83.69 \text{ N./mm}^2$$

Bending Stress at Short-side 1 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * \alpha^2 * K) / (3 + 5 * K))$$

$$= 80.60 * 60.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))$$

$$= -83.69 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 90 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Bending Stresses at Short-side 2

Bending Stress at Short-side 2 at N Inner[SbsNi]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 80.60 * 10.00 / (24 * 0.07) * [-3 * 100.00^2 + 2 * 60.00^2 * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))]$$

$$= -67.45 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at N Outer[SbsNo]:

$$= P * c / (24 * I1) * [-3 * H^2 + 2 * h^2 * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))]$$

$$= 80.60 * -10.00 / (24 * 0.07) * [-3 * 100.00^2 + 2 * 60.00^2 * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))]$$

$$= 67.45 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Inner[SbsQi]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))$$

$$= 80.60 * 60.00^2 * 10.00 / (12 * 0.07) * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))$$

$$= 83.69 \text{ N./mm}^2$$

Bending Stress at Short-side 2 at Q Outer[SbsQo]:

$$= P * h^2 * c / (12 * I1) * ((3 + 5 * Alpha^2 * K) / (3 + 5 * K))$$

$$= 80.60 * 60.00^2 * -10.00 / (12 * 0.07) * ((3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67))$$

$$= -83.69 \text{ N./mm}^2$$

Bending Stresses at Long-side 1

Bending Stress at Long-side 1 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I2) * [(3 + K * (6 - Alpha^2)) / (3 + 5 * K)]$$

$$= 80.60 * 60.00^2 * 10.00 / (12 * 0.07) * [(3 + 1.67 * (6 - 1.67^2)) / (3 + 5 * 1.67)]$$

$$= 26.79 \text{ N./mm}^2$$

If $Em(0.628) < E(0.850)$ and $Eb(0.628) < E(0.850)$ then

$$SblMi = SblMi / Eb$$

$$= 26.79 / 0.63$$

$$= 42.64 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I2) * [(3 + K * (6 - Alpha^2)) / (3 + 5 * K)]$$

$$= 80.60 * 60.00^2 * -10.00 / (12 * 0.07) * [(3 + 1.67 * (6 - 1.67^2)) / (3 + 5 * 1.67)]$$

$$= -26.79 \text{ N./mm}^2$$

If $Em(0.628) < E(0.850)$ and $Eb(0.628) < E(0.850)$ then

$$SblMo = SblMo / Eb$$

$$= -26.79 / 0.63$$

$$= -42.64 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I2) * [(3 + 5 * Alpha^2 * K) / (3 + 5 * K)]$$

$$= 80.60 * 60.00^2 * 10.00 / (12 * 0.07) * [(3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67)]$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 91 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

$$= 1.67^2 * 1.67 / (3 + 5 * 1.67)]$$

$$= 83.69 \text{ N./mm}^2$$

Bending Stress at Long-side 1 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 80.60 * 60.00^2 * -10.00 / (12 * 0.07) * [(3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67)]$$

$$= -83.69 \text{ N./mm}^2$$

Bending Stresses at Long-side 2

Bending Stress at Long-side 2 at M Inner[SblMi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 80.60 * 60.00^2 * 9.77 / (12 * 0.07) * [(3 + 1.67 * (6 - 1.67^2)) / (3 + 5 * 1.67)]$$

$$= 26.18 \text{ N./mm}^2$$

If $E_m(0.571) < E(0.850)$ and $E_b(0.538) < E(0.850)$ then

$$\text{SblMi} = \text{SblMi} / E_b$$

$$= 26.18 / 0.54$$

$$= 48.61 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at M Outer[SblMo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + K * (6 - \text{Alpha}^2)) / (3 + 5 * K)]$$

$$= 80.60 * 60.00^2 * -10.23 / (12 * 0.07) * [(3 + 1.67 * (6 - 1.67^2)) / (3 + 5 * 1.67)]$$

$$= -27.40 \text{ N./mm}^2$$

If $E_m(0.571) < E(0.850)$ and $E_b(0.538) < E(0.850)$ then

$$\text{SblMo} = \text{SblMo} / E_b$$

$$= -27.40 / 0.54$$

$$= -50.89 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Inner[SblQi]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 80.60 * 60.00^2 * 9.77 / (12 * 0.07) * [(3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67)]$$

$$= 81.77 \text{ N./mm}^2$$

Bending Stress at Long-side 2 at Q Outer[SblQo]:

$$= P * h^2 * c / (12 * I_2) * [(3 + 5 * \text{Alpha}^2 * K) / (3 + 5 * K)]$$

$$= 80.60 * 60.00^2 * -10.23 / (12 * 0.07) * [(3 + 5 * 1.67^2 * 1.67) / (3 + 5 * 1.67)]$$

$$= -85.60 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 92 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

BENDING STRESSES: Bending Stress Calculations per Section 13-9, Equations (16-19). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-67.45	67.45	197.62
at Q	83.69	-83.69	197.62
Short-side 2 at N	-67.45	67.45	197.62
at Q	83.69	-83.69	197.62
Long-side 1 at M	42.64	-42.64	232.50
at Q	83.69	-83.69	197.62
Long-side 2 at M	48.61	-50.89	232.50
at Q	81.77	-85.60	197.62

Total Stress Calculations per Section 13-9

Total Stresses at Short-side 1

Total Stress at short side 1 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 15.25 + -67.45 \\
 &= -52.20 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 15.25 + 67.45 \\
 &= 82.70 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 15.25 + 83.69 \\
 &= 98.94 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 1 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 15.25 + -83.69 \\
 &= -68.43 \text{ N./mm}^2
 \end{aligned}$$

Total Stresses at Short-side 2

Total Stress at short side 2 at N inner [STS_Ni]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNi} \\
 &= 15.25 + -67.45 \\
 &= -52.20 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at N outer [STS_No]:

$$\begin{aligned}
 &= S_{ms} + S_{bsNo} \\
 &= 15.25 + 67.45 \\
 &= 82.70 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q inner [STS_Qi]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQi} \\
 &= 15.25 + 83.69 \\
 &= 98.94 \text{ N./mm}^2
 \end{aligned}$$

Total Stress at short side 2 at Q outer [STS_Qo]:

$$\begin{aligned}
 &= S_{ms} + S_{bsQo} \\
 &= 15.25 + -83.69 \\
 &= -68.43 \text{ N./mm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 93 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Total Stresses at Long-side 1

Total Stress at long side 1 at M inner [STL_Mi]:
 $= S_{ml} + S_{blMi}$
 $= 32.07 + 42.64$
 $= 74.71 \text{ N./mm}^2$

Total Stress at long side 1 at M outer [STL_Mo]:
 $= S_{ml} + S_{blMo}$
 $= 32.07 + -42.64$
 $= -10.57 \text{ N./mm}^2$

Total Stress at long side 1 at Q inner [STL_Qi]:
 $= S_{ml} + S_{blQi}$
 $= 20.15 + 83.69$
 $= 103.84 \text{ N./mm}^2$

Total Stress at long side 1 at Q outer [STL_Qo]:
 $= S_{mlB} + S_{blQo}$
 $= 20.15 + -83.69$
 $= -63.54 \text{ N./mm}^2$

Total Stresses at Long-side 2

Total Stress at long side 2 at M inner [STL_Mi]:
 $= S_{ml} + S_{blMi}$
 $= 35.31 + 48.61$
 $= 83.92 \text{ N./mm}^2$

Total Stress at long side 2 at M outer [STL_Mo]:
 $= S_{ml} + S_{blMo}$
 $= 35.31 + -50.89$
 $= -15.59 \text{ N./mm}^2$

Total Stress at long side 2 at Q inner [STL_Qi]:
 $= S_{ml} + S_{blQi}$
 $= 20.15 + 81.77$
 $= 101.92 \text{ N./mm}^2$

Total Stress at long side 2 at Q outer [STL_Qo]:
 $= S_{mlB} + S_{blQo}$
 $= 20.15 + -85.60$
 $= -65.45 \text{ N./mm}^2$

TOTAL STRESSES: Total Stress Calculations per Section 13-9, Equations (20-24). (N./mm²) :

STRESS LOCATIONS	Inner	Outer	Allowable
Short-side 1 at N	-52.20	82.70	197.62
at Q	98.94	-68.43	197.62
Short-side 2 at N	-52.20	82.70	197.62
at Q	98.94	-68.43	197.62
Long-side 1 at M	74.71	-10.57	232.50
at Q	103.84	-63.54	197.62
Long-side 2 at M	83.92	-15.59	232.50
at Q	101.92	-65.45	197.62

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 94 از 150
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	AA	120	PR	CN	0001	V03	

End Plate Stresses (N./mm²):

	Actual	Allowable
End Plate	88.67	155.00

Required End Plate thickness due to Internal Pressure [trEP]:

$$= d \cdot \sqrt{Z \cdot C \cdot P / (SE)} + ca$$

$$= 100.000 \cdot \sqrt{2.200 \cdot 0.200 \cdot 80.600 / (155.000)} + 0.000$$

$$= 15.127 \text{ mm.}$$

End Plate MAWP at given Thickness [MAWPEP]:

$$= ((T-ca)/d)^2 \cdot ((SE)/(C \cdot Z)) \text{ per UG-34 (c)(3)}$$

$$= ((20.0000-0.0000)/100.0000)^2 \cdot ((155)/(.20 \cdot 2.20))$$

$$= 140.901 \text{ bars}$$

where Z is:

$$= \min(3.4 - 2.4(d/D), 2.5)$$

$$= \min(3.4 - 2.4(100.000 / 200.000), 2.5)$$

$$= 2.200$$

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	42.04	N./mm ²
High Stress Percentage	36.75	%
M.A.W.P. for Membrane Stresses	219.31	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-85.60	N./mm ²
High Stress Percentage	43.32	%
M.A.W.P. for Bending Stresses	186.07	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	103.84	N./mm ²
High Stress Percentage	52.54	%
M.A.W.P. for Total Stresses	153.40	bars

Rectangular Vessel Results For Item 1 : A8

SUMMARY OF RESULTS:

MEMBRANE STRESS SUMMARY,		
High Stress (Highest % of Allowable)	42.04	N./mm ²
High Stress Percentage	36.75	%
M.A.W.P. for Membrane Stresses	219.31	bars
BENDING STRESS SUMMARY,		
High Stress (Highest % of Allowable)	-85.60	N./mm ²
High Stress Percentage	43.32	%
M.A.W.P. for Bending Stresses	186.07	bars
TOTAL STRESS SUMMARY,		
High Stress (Highest % of Allowable)	103.84	N./mm ²
High Stress Percentage	52.54	%
M.A.W.P. for Total Stresses	153.40	bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 95 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

3.9 FINITE ELEMENT FOR AE-2101

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Tue Oct 01 08:56:40 2024.

- [Model Notes, Tube Results and API Check](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Compressive Stress Summary](#)
- [Graphical Results](#)



Model Notes, Tube Results and API Check
Model Notes, Tube Results and API Check

661PRO 3.0 - API 661 - Air-Cooled Heat Exchanger Nozzle Model

Input Echo:

Notes:

- The centerline of the header box is along the -Z axis.
- Only 1 Nozzle will be modeled at a time. The Nozzle Number Modeled can be seen below.
- User Defined Loads API 661 Check is shown below.
- Sum of ALL Nozzle Loads must not exceed 3*API Allowable Loads shown in paragraph 7.1.10.2 according to API 661 2013 paragraph 7.1.10.3.
- Results are given as: Actual Load, Allowable Load, percentage of allowable for API Check in lbs. and ft-lbs. for English Units and N. and N-m for SI Units.

Nozzle Number Modelled : 1
Top or Bottom Nozzle : Top
Analysis Type : User Defined Loads
Nozzle Type : Straight
Flange Type : Weldneck

Header Box Dimensions:
Centerline on : Centerline on LEFT Side
Height : 323.000 mm.
Width : 200.000 mm.
Length : 1842.000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 96 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Outboard Thickness : 20.000 mm.
Tubesheet Side Thickness : 20.000 mm.
Top Plate Thickness : 20.000 mm.
Free End Plate Thickness : 20.000 mm.

Header Box Pressure : 2.200 MPa

Symmetric Boundary Condition at Centerline

Partition Plates:

Number of Partition Plates : 2

Partition Plate #1

Plate Elevation from Bottom : 91.000 mm.
Plate Thickness : 10.000 mm.

Partition Plate #2

Plate Elevation from Bottom : 223.000 mm.
Plate Thickness : 10.000 mm.

Nozzle Dimensions:

Distance to CenterLine : 921.000 mm.
Nozzle Outside Diameter : 168.300 mm.
Nozzle Thickness : 9.600 mm.
Projection to Face of Flange : 260.000 mm.
Flange Thickness Used : 31.800 mm.
Flange ID : 202.480 mm.
Flange Hub Length Used : 47.700 mm.

Weld Size and SCF : 0.000, 1.350

Engineering Details:

Operating Cycles : 7000
Occasional Cycles : 0
Ambient Temperature : 21.100 deg.
Computation Type : Gauss Average

Material Properties

Nozzle:

Cold Allowable Stress : 115.100 MPa
Hot Allowable Stress : 86.600 MPa
Elastic Modulus : 0.186E+06 MPa
Poissons Ratio : 0.300
Material ID : 4-Austenitic Steels
Density : 0.000E+00 N /cu. mm.
Cold Yield Stress : 172.400 MPa
Hot Yield Stress : 129.900 MPa
Cold Tensile Stress : 482.600 MPa
Density : 0.000E+00 N /cu. mm.

Header Box:

Cold Allowable Stress : 115.100 MPa
Hot Allowable Stress : 86.600 MPa
Elastic Modulus : 0.186E+06 MPa
Poissons Ratio : 0.300
Material ID : 4-Austenitic Steels
Density : 0.000E+00 N /cu. mm.
Cold Yield Stress : 172.400 MPa
Hot Yield Stress : 129.900 MPa
Cold Tensile Stress : 482.600 MPa
Density : 0.000E+00 N /cu. mm.

Tubesheet was not modeled

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 97 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

User Defined Loads:

Forces [N]

	FX	FY	FZ	MX	MY	MZ
Weight	12000	15090	15090	6420000	9150000	4890000
Operating	12000	15090	15090	6420000	9150000	4890000
Occasional	0	0	0	0	0	0

03

No Tube Results

API Check for User Defined Loads and API Evaluation
API 661 2013 paragraph 7.1.10.2 and 7.1.10.3.

Results below are shown as:

Actual Load, Allowable Load, % of Allowable

Allowable Load: 3x API Allowable from para. 7.1.10.2

Total Nozzle Loads per DOF in [N and N.m]

Global FX	:	12000, 15015,	79 %
Global FY	:	15090, 30030,	50 %
Global FZ	:	15090, 25020,	60 %
Global MX	:	6420, 9150,	70 %
Global MY	:	9150, 12195,	75 %
Global MZ	:	4890, 6105,	80 %

API 661 para. 7.1.10.3 check PASSED. The summation of
all nozzle loads did NOT exceed the 1.5x API value from
para. 7.1.10.2.

Symmetric boundary condition applied at the center of the
headerbox, the API multiplier from paragraph 7.1.10.3 will
be 1.5 since total loads will be 2x larger due to symmetry.

[Table of Contents](#)

Load Case Report
FEPipe Version 15.0
Released Jan. 2021

Jobname: setup2
8:55am OCT 1, 2024

\$P

Load Case Report

\$X

Inner and outer element temperatures are the same
throughout the model. No thermal ratcheting
calculations will be performed.

THE 4 LOAD CASES ANALYZED ARE:

1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range
between the installed and the operating states.

/----- Loads in Case 1
Loads due to Weight

2 SUSTAINED (Wgt+Pr)

Sustained case run to satisfy local primary
membrane and bending stress limits.

/----- Loads in Case 2
Loads due to Weight

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 98 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Pressure Case 1

3 OPERATING

Case run to compute the operating stresses used in secondary, peak and range calculations as needed.

/----- Loads in Case 3
Pressure Case 1
Loads from (Operating)

4 RANGE (Fatigue Calc Performed)

Case run to get the RANGE of stresses.
as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case 4
Plus Stress Results from CASE 3
Minus Stress Results from CASE 1

[Table of Contents](#)

Solution Data
FEPipe Version 15.0 Jobname: setup2 \$P
Released Jan. 2021 8:55am OCT 1,2024

Solution Data

Maximum Solution Row Size = 1758
Number of Nodes = 8591
Number of Elements = 2923
Number of Solution Cases = 3

Summation of Loads per Case

Case #	FX	FY	FZ
1	12000.	53502.	15090.
2	12000.	-44684.	-104898.
3	12000.	-44684.	-104898.

[Table of Contents](#)

ASME Code Stress Output Plots
FEPipe Version 15.0 Jobname: setup2 \$P
Released Jan. 2021 8:56am OCT 1,2024

ASME Code Stress Output Plots \$X

- 1) PL < SPL (SUS,Membrane) Case 2
- 2) Qb < SPS (SUS,Bending) Case 2
- 3) PL+Pb+Q < SPS (SUS,Inside) Case 2
- 4) PL+Pb+Q < SPS (SUS,Outside) Case 2

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 99 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

- 5) $S1+S2+S3 < 4S$ (SUS,S1+S2+S3) Case 2
- 6) $Pl+Pb+Q < SPS$ (OPE,Inside) Case 3
- 7) $Pl+Pb+Q < SPS$ (OPE,Outside) Case 3
- 8) $Membrane < User$ (OPE,Membrane) Case 3
- 9) $Bending < User$ (OPE,Bending) Case 3
- 10) $Pl+Pb+Q < SPS$ (EXP,Inside) Case 4
- 11) $Pl+Pb+Q < SPS$ (EXP,Outside) Case 4
- 12) $Pl+Pb+Q+F < 2Sa$ (EXP,Inside) Case 4
- 13) $Pl+Pb+Q+F < 2Sa$ (EXP,Outside) Case 4

03

[Table of Contents](#)

Stress Results - Notes
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: setup2
 8:56am OCT 1,2024

\$P

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = 1.000000
Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. (Pb=0)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
S1+S2+S3 evaluation omitted from operating stress.
Include S1+S2+S3 evaluation in primary case evaluation.
Bending stress NOT included for all S1+S2+S3 calculations.
- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: setup2
 8:56am OCT 1,2024

\$P

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 100 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

ASME Overstressed Areas

\$X

03

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios
FEPipe Version 15.0
Released Jan. 2021

Jobname: setup2
8:56am OCT 1, 2024

\$P

Highest Primary Stress Ratios \$X

Circ Plate for Plate # 1

PL	SPL	Primary Membrane Load Case 2
43	130	Min Prin. Stress = -65. (51% Neg, 8% NegHi)
MPa	MPa	Plot Reference:
		1) PL < SPL (SUS,Membrane) Case 2

33%

Long Plate for Plate # 1

PL	SPL	Primary Membrane Load Case 2
103	130	Min Prin. Stress = -107. (97% Neg, 19% NegHi)
MPa	MPa	Plot Reference:
		1) PL < SPL (SUS,Membrane) Case 2

79%

Circ Plate for Plate # 2

PL	SPL	Primary Membrane Load Case 2
50	130	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
		1) PL < SPL (SUS,Membrane) Case 2

38%

Circ Plate for Plate # 3

PL	SPL	Primary Membrane Load Case 2
122	130	Min Prin. Stress = -175. (89% Neg, 49% NegHi)
MPa	MPa	Plot Reference:
		1) PL < SPL (SUS,Membrane) Case 2

93%

Circ Plate for Plate # 4

PL	SPL	Primary Membrane Load Case 2
93	130	Min Prin. Stress = -113. (76% Neg, 20% NegHi)
MPa	MPa	Plot Reference:
		1) PL < SPL (SUS,Membrane) Case 2

71%

Long Plate for Plate # 4

PL	SPL	Primary Membrane Load Case 2
----	-----	------------------------------

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 101 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

22 MPa 130 MPa Min Prin. Stress = -15. (79% Neg, 12% NegHi)
Plot Reference:
1) Pl < SPL (SUS,Membrane) Case 2

Circ Plate for Plate # 5

Pl 35 MPa SPL 130 MPa Primary Membrane Load Case 2
Min Prin. Stress = -10. (42% Neg, 11% NegHi)
Plot Reference:
1) Pl < SPL (SUS,Membrane) Case 2



[Table of Contents](#)

Highest Secondary Stress Ratios
FEPIPE Version 15.0 Jobname: setup2 \$P
Released Jan. 2021 8:56am OCT 1,2024

Highest Secondary Stress Ratios \$X

In combination case 4 the max range stress divided by the max component stress is 1.99. The case tensor components are in some directions additive and so the combination case will have HIGHER stresses than the largest of any of the individual cases by more than 50%.

Load Case	Combined/Max (Inside)	Combined/Max (Outside)
4	1.993	1.970

Circ Plate for Plate # 1

Pl+Pb+Q 88 MPa SPS 303 MPa Primary+Secondary (Inner) Load Case 2
Min Prin. Stress = -65. (51% Neg, 8% NegHi)
Plot Reference:
3) Pl+Pb+Q < SPS (SUS,Inside) Case 2

Pl+Pb+Q 88 MPa SPS 303 MPa Primary+Secondary (Inner) Load Case 3
Min Prin. Stress = -65. (51% Neg, 8% NegHi)
Plot Reference:
6) Pl+Pb+Q < SPS (OPE,Inside) Case 3

Long Plate for Plate # 1

Pl+Pb+Q 190 MPa SPS 303 MPa Primary+Secondary (Outer) Load Case 2
Min Prin. Stress = -107. (97% Neg, 19% NegHi)
Plot Reference:
4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

Pl+Pb+Q 190 MPa SPS 303 MPa Primary+Secondary (Outer) Load Case 3
Min Prin. Stress = -107. (97% Neg, 19% NegHi)
Plot Reference:
7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

Circ Plate for Plate # 2

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان:	Thermal/Mechanical Calculation Book							شماره صفحه : 102 از 150	
053 – 073 – 9184	پروژه	بسته کاری	صادرکننده	تجهیزات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001		V03

Pl+Pb+Q 75 MPa SPS 303 MPa Primary+Secondary (Outer) Load Case 2
Min Prin. Stress = -27. (58% Neg, 9% NegHi)
Plot Reference:
4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

24%

Pl+Pb+Q 75 MPa SPS 303 MPa Primary+Secondary (Outer) Load Case 3
Min Prin. Stress = -27. (58% Neg, 9% NegHi)
Plot Reference:
7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

24%

Circ Plate for Plate # 3

Pl+Pb+Q 245 MPa SPS 303 MPa Primary+Secondary (Inner) Load Case 2
Min Prin. Stress = -175. (89% Neg, 49% NegHi)
Plot Reference:
3) Pl+Pb+Q < SPS (SUS,Inside) Case 2

80%

Pl+Pb+Q 245 MPa SPS 303 MPa Primary+Secondary (Inner) Load Case 3
Min Prin. Stress = -175. (89% Neg, 49% NegHi)
Plot Reference:
6) Pl+Pb+Q < SPS (OPE,Inside) Case 3

80%

Circ Plate for Plate # 4

Pl+Pb+Q 157 MPa SPS 303 MPa Primary+Secondary (Inner) Load Case 2
Min Prin. Stress = -113. (76% Neg, 20% NegHi)
Plot Reference:
3) Pl+Pb+Q < SPS (SUS,Inside) Case 2

52%

Pl+Pb+Q 157 MPa SPS 303 MPa Primary+Secondary (Inner) Load Case 3
Min Prin. Stress = -113. (76% Neg, 20% NegHi)
Plot Reference:
6) Pl+Pb+Q < SPS (OPE,Inside) Case 3

52%

Long Plate for Plate # 4

Pl+Pb+Q 39 MPa SPS 303 MPa Primary+Secondary (Outer) Load Case 2
Min Prin. Stress = -15. (79% Neg, 12% NegHi)
Plot Reference:
4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

12%

Pl+Pb+Q 39 MPa SPS 303 MPa Primary+Secondary (Outer) Load Case 3
Min Prin. Stress = -15. (79% Neg, 12% NegHi)
Plot Reference:
7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

12%

Circ Plate for Plate # 5

Pl+Pb+Q 56 MPa SPS 302 MPa Primary+Secondary (Outer) Load Case 2
Min Prin. Stress = -10. (42% Neg, 11% NegHi)
Plot Reference:
4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

18%

Pl+Pb+Q 56 MPa SPS 302 MPa Primary+Secondary (Outer) Load Case 3
Min Prin. Stress = -10. (42% Neg, 11% NegHi)
Plot Reference:
7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

18%

03

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 103 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

[Table of Contents](#)

03

Highest Fatigue Stress Ratios
FEPipe Version 15.0
Released Jan. 2021

Jobname: setup2
8:56am OCT 1, 2024

\$P

Highest Fatigue Stress Ratios \$X

Circ Plate for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
40	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.052 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 504.2
777.2		Markl Fatigue Stress Allowable = 659.5
MPa		WRC 474 Mean Cycles to Failure = 53,800,080.
		WRC 474 99% Probability Cycles = 12,498,247.
		WRC 474 95% Probability Cycles = 17,352,244.
5%		BS5500 Allowed Cycles(Curve F) = 17,406,096.
		Membrane-to-Bending Ratio = 0.287
		Bending-to-PL+PB+Q Ratio = 0.777
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Long Plate for Plate # 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
67	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.087 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 504.2
777.2		Markl Fatigue Stress Allowable = 659.5
MPa		WRC 474 Mean Cycles to Failure = 12,005,280.
		WRC 474 99% Probability Cycles = 2,788,933.
		WRC 474 95% Probability Cycles = 3,872,082.
8%		BS5500 Allowed Cycles(Curve F) = 2,956,780.
		Membrane-to-Bending Ratio = 0.249
		Bending-to-PL+PB+Q Ratio = 0.800
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

Circ Plate for Plate # 2

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
40	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.052 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 504.2
777.2		Markl Fatigue Stress Allowable = 659.5
MPa		WRC 474 Mean Cycles to Failure = 53,800,080.
		WRC 474 99% Probability Cycles = 12,498,247.
		WRC 474 95% Probability Cycles = 17,352,244.
5%		BS5500 Allowed Cycles(Curve F) = 17,406,096.
		Membrane-to-Bending Ratio = 0.287
		Bending-to-PL+PB+Q Ratio = 0.777
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Circ Plate for Plate # 3

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 104 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Inner) Load Case 4
62 0.000 Life Stress Concentration Factor = 1.000
MPa 0.079 Stress Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11
Allowable "B31" Fatigue Stress Allowable = 504.2
777.2 MPa Markl Fatigue Stress Allowable = 659.5
WRC 474 Mean Cycles to Failure = 22,928,718.
WRC 474 99% Probability Cycles = 5,326,544.
WRC 474 95% Probability Cycles = 7,395,236.
BS5500 Allowed Cycles(Curve F) = 3,877,636.
Membrane-to-Bending Ratio = 0.577
Bending-to-PL+PB+Q Ratio = 0.634
Plot Reference:
12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

03

Circ Plate for Plate # 4

Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Inner) Load Case 4
29 0.000 Life Stress Concentration Factor = 1.000
MPa 0.038 Stress Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11
Allowable "B31" Fatigue Stress Allowable = 504.2
777.2 MPa Markl Fatigue Stress Allowable = 659.5
WRC 474 Mean Cycles to Failure = 2.2774E8
WRC 474 99% Probability Cycles = 52,906,380.
WRC 474 95% Probability Cycles = 73,453,848.
BS5500 Allowed Cycles(Curve F) = 86,924,216.
Membrane-to-Bending Ratio = 0.912
Bending-to-PL+PB+Q Ratio = 0.523
Plot Reference:
12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Long Plate for Plate # 4

Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Inner) Load Case 4
10 0.000 Life Stress Concentration Factor = 1.000
MPa 0.013 Stress Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11
Allowable "B31" Fatigue Stress Allowable = 504.2
777.2 MPa Markl Fatigue Stress Allowable = 659.5
WRC 474 Mean Cycles to Failure = 2.2647E9
WRC 474 99% Probability Cycles = 5.2612E8
WRC 474 95% Probability Cycles = 7.3045E8
BS5500 Allowed Cycles(Curve F) = 7.5188E9
Membrane-to-Bending Ratio = 0.919
Bending-to-PL+PB+Q Ratio = 0.521
Plot Reference:
12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Circ Plate for Plate # 5

Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Inner) Load Case 4
29 0.000 Life Stress Concentration Factor = 1.000
MPa 0.054 Stress Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11
Allowable "B31" Fatigue Stress Allowable = 0.0
530.5 MPa Markl Fatigue Stress Allowable = 575.0
WRC 474 Mean Cycles to Failure = 2.1487E8
WRC 474 99% Probability Cycles = 49,916,348.
WRC 474 95% Probability Cycles = 69,302,576.
BS5500 Allowed Cycles(Curve F) = 91,314,408.
Membrane-to-Bending Ratio = 9.370
Bending-to-PL+PB+Q Ratio = 0.096
Plot Reference:
12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 105 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Highest Stress Ratios Per Region
FEPIPE Version 15.0 Jobname: setup2 \$P
Released Jan. 2021 8:56am OCT 1,2024



Highest Stress Ratios Per Region \$X

Circ Plate for Plate # 1

PL 43 MPa	SPL 130 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 1) PL < SPL (SUS,Membrane) Case 2
33%		
Qb 59 MPa	SPS 303 MPa	Primary Bending Load Case 2 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
19%		
PL+Pb+Q 88 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 3) PL+Pb+Q < SPS (SUS,Inside) Case 2
29%		
PL+Pb+Q 72 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 4) PL+Pb+Q < SPS (SUS,Outside) Case 2
23%		
S1+S2+S3 46 MPa	4S 346 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
13%		
PL+Pb+Q 88 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 6) PL+Pb+Q < SPS (OPE,Inside) Case 3
29%		
PL+Pb+Q 72 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 7) PL+Pb+Q < SPS (OPE,Outside) Case 3
23%		
Membrane 43 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
14%		
Bending 59 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -65. (51% Neg, 8% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
19%		
PL+Pb+Q 40	SPS 303	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -16. (49% Neg, 7% NegHi)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 106 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

MPa	MPa	Plot Reference:
13%		10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
35	303	Min Prin. Stress = -16. (49% Neg, 7% NegHi)
MPa	MPa	Plot Reference:
11%		11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
40	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.052 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
777.2		"B31" Fatigue Stress Allowable = 504.2
MPa		Markl Fatigue Stress Allowable = 659.5
5%		WRC 474 Mean Cycles to Failure = 53,800,080.
		WRC 474 99% Probability Cycles = 12,498,247.
		WRC 474 95% Probability Cycles = 17,352,244.
		BS5500 Allowed Cycles(Curve F) = 17,406,096.
		Membrane-to-Bending Ratio = 0.287
		Bending-to-PL+PB+Q Ratio = 0.777
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
35	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.045 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
777.2		"B31" Fatigue Stress Allowable = 504.2
MPa		Markl Fatigue Stress Allowable = 659.5
4%		WRC 474 Mean Cycles to Failure = 80,855,728.
		WRC 474 99% Probability Cycles = 18,783,518.
		WRC 474 95% Probability Cycles = 26,078,552.
		BS5500 Allowed Cycles(Curve F) = 34,168,636.
		Membrane-to-Bending Ratio = 0.359
		Bending-to-PL+PB+Q Ratio = 0.736
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Long Plate for Plate # 1		
PL	SPL	Primary Membrane Load Case 2
103	130	Min Prin. Stress = -107. (97% Neg, 19% NegHi)
MPa	MPa	Plot Reference:
79%		1) PL < SPL (SUS,Membrane) Case 2
Qb	SPS	Primary Bending Load Case 2
139	303	Min Prin. Stress = -107. (97% Neg, 19% NegHi)
MPa	MPa	Plot Reference:
45%		2) Qb < SPS (SUS,Bending) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
138	303	Min Prin. Stress = -107. (97% Neg, 19% NegHi)
MPa	MPa	Plot Reference:
45%		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
190	303	Min Prin. Stress = -107. (97% Neg, 19% NegHi)
MPa	MPa	Plot Reference:
62%		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2
122	346	Min Prin. Stress = -107. (97% Neg, 19% NegHi)
MPa	MPa	Plot Reference:
35%		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 107 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Pl+Pb+Q 138 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -107. (97% Neg, 19% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
45%		
Pl+Pb+Q 190 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -107. (97% Neg, 19% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
62%		
Membrane 103 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -107. (97% Neg, 19% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
33%		
Bending 139 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -107. (97% Neg, 19% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
45%		
Pl+Pb+Q 67 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -32. (91% Neg, 15% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
22%		
Pl+Pb+Q 67 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -32. (91% Neg, 15% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
22%		
Pl+Pb+Q+F 67 MPa	Damage Ratio 0.000 Life 0.086 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 504.2 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 12,298,224. WRC 474 99% Probability Cycles = 2,856,986. WRC 474 95% Probability Cycles = 3,966,566. BS5500 Allowed Cycles(Curve F) = 3,014,588. Membrane-to-Bending Ratio = 0.248 Bending-to-PL+PB+Q Ratio = 0.802 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Allowable 777.2 MPa		
8%		
Pl+Pb+Q+F 67 MPa	Damage Ratio 0.000 Life 0.087 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 504.2 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 12,005,280. WRC 474 99% Probability Cycles = 2,788,933. WRC 474 95% Probability Cycles = 3,872,082. BS5500 Allowed Cycles(Curve F) = 2,956,780. Membrane-to-Bending Ratio = 0.249 Bending-to-PL+PB+Q Ratio = 0.800 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Allowable 777.2 MPa		
8%		

Circ Plate for Plate # 2

PL 50	SPL 130	Primary Membrane Load Case 2 Min Prin. Stress = -27. (58% Neg, 9% NegHi)
----------	------------	---

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)										
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 108 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			

MPa	MPa	Plot Reference:
38%		1) Pl < SPL (SUS,Membrane) Case 2
Qb	SPS	Primary Bending Load Case 2
54	303	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
17%		2) Qb < SPS (SUS,Bending) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
57	303	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
18%		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
75	303	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
24%		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2
28	346	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
8%		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3
57	303	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
18%		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3
75	303	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
24%		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
Membrane	User	Component Evaluation Load Case 3
50	303	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
16%		8) Membrane < User (OPE,Membrane) Case 3
Bending	User	Component Evaluation Load Case 3
54	303	Min Prin. Stress = -27. (58% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
17%		9) Bending < User (OPE,Bending) Case 3
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
40	303	Min Prin. Stress = -16. (52% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
13%		10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
35	303	Min Prin. Stress = -16. (52% Neg, 9% NegHi)
MPa	MPa	Plot Reference:
11%		11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
40	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.052 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
777.2		"B31" Fatigue Stress Allowable = 504.2
MPa		Markl Fatigue Stress Allowable = 659.5
		WRC 474 Mean Cycles to Failure = 53,800,080.
		WRC 474 99% Probability Cycles = 12,498,247.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 109 از 150
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	AA	120	PR	CN	0001	V03	

5%		WRC 474 95% Probability Cycles = 17,352,244. BS5500 Allowed Cycles(Curve F) = 17,406,096. Membrane-to-Bending Ratio = 0.287 Bending-to-PL+PB+Q Ratio = 0.777 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Pl+Pb+Q+F 35 MPa	Damage Ratio 0.000 Life 0.045 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 504.2 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 80,855,760. WRC 474 99% Probability Cycles = 18,783,526. WRC 474 95% Probability Cycles = 26,078,564. BS5500 Allowed Cycles(Curve F) = 34,168,652. Membrane-to-Bending Ratio = 0.359 Bending-to-PL+PB+Q Ratio = 0.736 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Allowable 777.2 MPa		
4%		
Circ Plate for Plate # 3		
PL 122 MPa	SPL 130 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 1) PL < SPL (SUS,Membrane) Case 2
93%		
Qb 203 MPa	SPS 303 MPa	Primary Bending Load Case 2 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
67%		
Pl+Pb+Q 245 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
80%		
Pl+Pb+Q 185 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
61%		
S1+S2+S3 170 MPa	4S 346 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
49%		
Pl+Pb+Q 245 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
80%		
Pl+Pb+Q 185 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
61%		
Membrane 122 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
40%		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 110 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Bending 203 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -175. (89% Neg, 49% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
67%		
Pl+Pb+Q 62 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -40. (99% Neg, 28% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
20%		
Pl+Pb+Q 34 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -40. (99% Neg, 28% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
11%		
Pl+Pb+Q+F 62 MPa	Damage Ratio 0.000 Life 0.079 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 504.2 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 22,928,718. WRC 474 99% Probability Cycles = 5,326,544. WRC 474 95% Probability Cycles = 7,395,236. BS5500 Allowed Cycles(Curve F) = 3,877,636. Membrane-to-Bending Ratio = 0.577 Bending-to-PL+PB+Q Ratio = 0.634 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Allowable 777.2 MPa		
7%		
Pl+Pb+Q+F 34 MPa	Damage Ratio 0.000 Life 0.044 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 504.2 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 1.3199E8 WRC 474 99% Probability Cycles = 30,662,112. WRC 474 95% Probability Cycles = 42,570,488. BS5500 Allowed Cycles(Curve F) = 39,697,960. Membrane-to-Bending Ratio = 4.769 Bending-to-PL+PB+Q Ratio = 0.173 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Allowable 777.2 MPa		
4%		
Circ Plate for Plate # 4		
Pl 93 MPa	SPL 130 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -113. (76% Neg, 20% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
71%		
Qb 100 MPa	SPS 303 MPa	Primary Bending Load Case 2 Min Prin. Stress = -113. (76% Neg, 20% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
32%		
Pl+Pb+Q 157 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -113. (76% Neg, 20% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
52%		
Pl+Pb+Q 113	SPS 303	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -113. (76% Neg, 20% NegHi)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 111 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

MPa	MPa	Plot Reference:
37%		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
S1+S2+S3 148 MPa	4S 346 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -113. (76% Neg, 20% NegHi) Plot Reference:
42%		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
Pl+Pb+Q 157 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -113. (76% Neg, 20% NegHi) Plot Reference:
52%		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
Pl+Pb+Q 113 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -113. (76% Neg, 20% NegHi) Plot Reference:
37%		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
Membrane 93 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -113. (76% Neg, 20% NegHi) Plot Reference:
30%		8) Membrane < User (OPE,Membrane) Case 3
Bending 100 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -113. (76% Neg, 20% NegHi) Plot Reference:
32%		9) Bending < User (OPE,Bending) Case 3
Pl+Pb+Q 29 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -19. (60% Neg, 11% NegHi) Plot Reference:
9%		10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
Pl+Pb+Q 28 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -19. (60% Neg, 11% NegHi) Plot Reference:
9%		11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
Pl+Pb+Q+F 29 MPa	Damage Ratio 0.000 Life 0.038 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 504.2 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 2.2774E8 WRC 474 99% Probability Cycles = 52,906,380. WRC 474 95% Probability Cycles = 73,453,848. BS5500 Allowed Cycles(Curve F) = 86,924,216. Membrane-to-Bending Ratio = 0.912 Bending-to-PL+PB+Q Ratio = 0.523 Plot Reference:
Allowable 777.2 MPa		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
3%		
Pl+Pb+Q+F 28 MPa	Damage Ratio 0.000 Life 0.036 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 504.2 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 2.5213E8 WRC 474 99% Probability Cycles = 58,572,912. WRC 474 95% Probability Cycles = 81,321,112. BS5500 Allowed Cycles(Curve F) = 1.0450E8 Membrane-to-Bending Ratio = 1.230
Allowable 777.2 MPa		
3%		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 112 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Bending-to-PL+PB+Q Ratio = 0.448

Plot Reference:

13) PL+PB+Q+F < 2Sa (EXP,Outside) Case 4

03

Long Plate for Plate # 4

PL 22 MPa	SPL 130 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 1) PL < SPL (SUS,Membrane) Case 2
16%		
Qb 26 MPa	SPS 303 MPa	Primary Bending Load Case 2 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
8%		
PL+PB+Q 24 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 3) PL+PB+Q < SPS (SUS,Inside) Case 2
7%		
PL+PB+Q 39 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 4) PL+PB+Q < SPS (SUS,Outside) Case 2
12%		
S1+S2+S3 17 MPa	4S 346 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
5%		
PL+PB+Q 24 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 6) PL+PB+Q < SPS (OPE,Inside) Case 3
7%		
PL+PB+Q 39 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 7) PL+PB+Q < SPS (OPE,Outside) Case 3
12%		
Membrane 22 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
7%		
Bending 26 MPa	User 303 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -15. (79% Neg, 12% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
8%		
PL+PB+Q 10 MPa	SPS 303 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -4. (51% Neg, 8% NegHi) Plot Reference: 10) PL+PB+Q < SPS (EXP,Inside) Case 4
3%		
PL+PB+Q 7 MPa	SPS 303 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -4. (51% Neg, 8% NegHi) Plot Reference: 11) PL+PB+Q < SPS (EXP,Outside) Case 4
2%		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 113 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Inner) Load Case 4
10 0.000 Life Stress Concentration Factor = 1.000
MPa 0.013 Stress Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11
Allowable "B31" Fatigue Stress Allowable = 504.2
777.2 Markl Fatigue Stress Allowable = 659.5
MPa WRC 474 Mean Cycles to Failure = 2.2647E9
1% WRC 474 99% Probability Cycles = 5.2612E8
WRC 474 95% Probability Cycles = 7.3045E8
BS5500 Allowed Cycles(Curve F) = 7.5188E9
Membrane-to-Bending Ratio = 0.919
Bending-to-PL+PB+Q Ratio = 0.521
Plot Reference:
12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4



Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Outer) Load Case 4
7 0.000 Life Stress Concentration Factor = 1.000
MPa 0.008 Stress Strain Concentration Factor = 1.000
Cycles Allowed for this Stress = 1.0000E11
Allowable "B31" Fatigue Stress Allowable = 504.2
777.2 Markl Fatigue Stress Allowable = 659.5
MPa WRC 474 Mean Cycles to Failure = 9.5210E9
0% WRC 474 99% Probability Cycles = 2.2118E9
WRC 474 95% Probability Cycles = 3.0708E9
BS5500 Allowed Cycles(Curve F) = 5.9365E10
Membrane-to-Bending Ratio = 0.913
Bending-to-PL+PB+Q Ratio = 0.523
Plot Reference:
13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

Circ Plate for Plate # 5

Pl	SPL	Primary Membrane Load Case 2
35	130	Min Prin. Stress = -10. (42% Neg, 11% NegHi)
MPa	MPa	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
26%		
Qb	SPS	Primary Bending Load Case 2
23	302	Min Prin. Stress = -10. (42% Neg, 11% NegHi)
MPa	MPa	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 2
7%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
47	302	Min Prin. Stress = -10. (42% Neg, 11% NegHi)
MPa	MPa	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
15%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
56	302	Min Prin. Stress = -10. (42% Neg, 11% NegHi)
MPa	MPa	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
18%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3
47	302	Min Prin. Stress = -10. (42% Neg, 11% NegHi)
MPa	MPa	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
15%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3
56	302	Min Prin. Stress = -10. (42% Neg, 11% NegHi)
MPa	MPa	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
18%		
Membrane	User	Component Evaluation Load Case 3
35	302	Min Prin. Stress = -10. (42% Neg, 11% NegHi)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 114 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

MPa	MPa	Plot Reference:
11%		8) Membrane < User (OPE,Membrane) Case 3
Bending	User	Component Evaluation Load Case 3
23	302	Min Prin. Stress = -10. (42% Neg, 11% NegHi)
MPa	MPa	Plot Reference:
7%		9) Bending < User (OPE,Bending) Case 3
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
29	302	Min Prin. Stress = -3. (17% Neg, 5% NegHi)
MPa	MPa	Plot Reference:
9%		10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
29	302	Min Prin. Stress = -3. (17% Neg, 5% NegHi)
MPa	MPa	Plot Reference:
9%		11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
29	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.054 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
530.5		"B31" Fatigue Stress Allowable = 0.0
MPa		Markl Fatigue Stress Allowable = 575.0
5%		WRC 474 Mean Cycles to Failure = 2.1487E8
		WRC 474 99% Probability Cycles = 49,916,348.
		WRC 474 95% Probability Cycles = 69,302,576.
		BS5500 Allowed Cycles(Curve F) = 91,314,408.
		Membrane-to-Bending Ratio = 9.370
		Bending-to-PL+PB+Q Ratio = 0.096
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
29	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.054 Stress	Strain Concentration Factor = 1.000
Allowable		Cycles Allowed for this Stress = 1.0000E11
530.5		"B31" Fatigue Stress Allowable = 0.0
MPa		Markl Fatigue Stress Allowable = 575.0
5%		WRC 474 Mean Cycles to Failure = 2.2377E8
		WRC 474 99% Probability Cycles = 51,982,772.
		WRC 474 95% Probability Cycles = 72,171,536.
		BS5500 Allowed Cycles(Curve F) = 97,284,968.
		Membrane-to-Bending Ratio = 7.767
		Bending-to-PL+PB+Q Ratio = 0.114
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4



Table of Contents

Compressive Stress Summary
FEPipe Version 15.0
Released Jan. 2021

Jobname: setup2
8:56am OCT 1,2024

\$P

Compressive Stress Summary (MPa) \$X

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress
Pts in Region - No. of nodes in the model region
>5% Compression - 5% or more of Compressive Stress Limit

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 115 از 150	
	پروژه	بسته کاری	صادرکننده	تجهیزات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

>50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = $-0.55 \text{ Min}(S_y, kE_t/R)$, Section slenderness ratio (elastic buckling) not considered.


#	Load Type	Case	Min Stress	Pts in Region	>5% Compression and Bending	>50% Region
1	SUSTAINED	2	-65.	1856	51%	8% Circ Plate for Plate # 1
2	OPERATING	3	-65.	1856	51%	8% Circ Plate for Plate # 1
3	EXPANSION	4	-16.	1856	49%	7% Circ Plate for Plate # 1
4	SUSTAINED	2	-107.	8072	97%	19% Long Plate for Plate # 1
5	OPERATING	3	-107.	8072	97%	19% Long Plate for Plate # 1
6	EXPANSION	4	-32.	8072	91%	15% Long Plate for Plate # 1
7	SUSTAINED	2	-27.	1504	58%	9% Circ Plate for Plate # 2
8	OPERATING	3	-27.	1504	58%	9% Circ Plate for Plate # 2
9	EXPANSION	4	-16.	1504	52%	9% Circ Plate for Plate # 2
10	SUSTAINED	2	-175.	1600	89%	49% Circ Plate for Plate # 3
11	OPERATING	3	-175.	1600	89%	49% Circ Plate for Plate # 3
12	EXPANSION	4	-40.	1600	99%	28% Circ Plate for Plate # 3
13	SUSTAINED	2	-113.	1440	76%	20% Circ Plate for Plate # 4
14	OPERATING	3	-113.	1440	76%	20% Circ Plate for Plate # 4
15	EXPANSION	4	-19.	1440	60%	11% Circ Plate for Plate # 4
16	SUSTAINED	2	-15.	640	79%	12% Long Plate for Plate # 4
17	OPERATING	3	-15.	640	79%	12% Long Plate for Plate # 4
18	EXPANSION	4	-4.	640	51%	8% Long Plate for Plate # 4
19	SUSTAINED	2	-10.	8272	42%	11% Circ Plate for Plate # 5
20	OPERATING	3	-10.	8272	42%	11% Circ Plate for Plate # 5
21	EXPANSION	4	-3.	8272	17%	5% Circ Plate for Plate # 5

[Table of Contents](#)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 116 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	


Finite Element Model

03



3d

1) $P1 < SPL$ (SUS Membrane) Case 2



3d(Deformed)

3d



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0015_02)



شماره پیمان:


053-073-9184

Thermal/Mechanical Calculation Book


پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	GCS	AA	120	PR	CN	0001	V03

شماره صفحه : 117 از 150

2) $Q_b < SPS$ (SUS Bending) Case 2





03



3d(Deformed)

3d

3) $P1+Pb+Q < SPS$ (SUS Inside) Case 2




3d(Deformed)

3d

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 118 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

4) P1+Pb+Q < SPS (SUS Outside) Case 2




03

3d(Deformed)

3d

5) S1+S2+S3 < 4S (SUS S1+S2+S3) Case 2




3d(Deformed)

3d

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 119 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	


6) P1+Pb+Q < SPS (OPE Inside) Case 3



03

3d(Deformed) 3d


7) P1+Pb+Q < SPS (OPE Outside) Case 3



3d(Deformed) 3d


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 120 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

8) Membrane < User (OPE Membrane) Case 3





03

9) Bending < User (OPE Bending) Case 3



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 121 از 150
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	AA	120	PR	CN	0001	V03	



10) P1+Pb+Q < SPS (EXP Inside) Case 4



3d

03


11) P1+Pb+Q < SPS (EXP Outside) Case 4



3d

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)										
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 122 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			


12) P1+Pb+Q+F < 2Sa (EXP Inside) Case 4



3d

03

13) P1+Pb+Q+F < 2Sa (EXP Outside) Case 4



3d

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 123 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

3.10 FINITE ELEMENT FOR AE-2102

Tabular Results

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Wed Oct 02 11:48:52 2024.

- [Model Notes, Tube Results and API Check](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Compressive Stress Summary](#)
- [Graphical Results](#)



Model Notes, Tube Results and API Check
Model Notes, Tube Results and API Check

661PR0 3.0 - API 661 - Air-Cooled Heat Exchanger Nozzle Model

Input Echo:

Notes:

- The centerline of the header box is along the -Z axis.
- Only 1 Nozzle will be modeled at a time. The Nozzle Number Modeled can be seen below.
- User Defined Loads API 661 Check is shown below.
- Sum of ALL Nozzle Loads must not exceed 3*API Allowable Loads shown in paragraph 7.1.10.2 according to API 661 2013 paragraph 7.1.10.3.
- Results are given as: Actual Load, Allowable Load, percentage of allowable for API Check in lbs. and ft-lbs. for English Units and N. and N-m for SI Units.

Nozzle Number Modelled : 1
Top or Bottom Nozzle : Top

Analysis Type : User Defined Loads

Nozzle Type : Straight
Flange Type : Weldneck

Header Box Dimensions:
Centerline on :Centerline on LEFT Side
Height : 485.000 mm.
Width : 166.000 mm.
Length : 2065.000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)										
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 124 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			

Outboard Thickness : 28.000 mm.
Tubesheet Side Thickness : 28.000 mm.
Top Plate Thickness : 20.000 mm.
Free End Plate Thickness : 20.000 mm.

Header Box Pressure : 6.200 MPa

Symmetric Boundary Condition at Centerline

Partition Plates:

Number of Partition Plates : 2

Partition Plate #1

Plate Elevation from Bottom : 165.000 mm.

Plate Thickness : 10.000 mm.

Partition Plate #2

Plate Elevation from Bottom : 305.000 mm.

Plate Thickness : 10.000 mm.

Nozzle Dimensions:

Distance to CenterLine : 1032.500 mm.

Nozzle Outside Diameter : 114.300 mm.

Nozzle Thickness : 7.500 mm.

Projection to Face of Flange : 270.000 mm.

Flange Thickness Used : 27.300 mm.

Flange ID : 154.059 mm.

Flange Hub Length Used : 40.950 mm.

Weld Size and SCF : 0.000, 1.350

Engineering Details:

Operating Cycles : 7000

Occasional Cycles : 0

Ambient Temperature : 21.100 deg.

Computation Type : Gauss Average

Material Properties

Nozzle:

Cold Allowable Stress : 115.100 MPa

Hot Allowable Stress : 111.900 MPa

Elastic Modulus : 0.184E+06 MPa

Poissons Ratio : 0.300

Material ID : 4-Austenitic Steels

Density : 0.000E+00 N /cu. mm.

Cold Yield Stress : 172.400 MPa

Hot Yield Stress : 126.100 MPa

Cold Tensile Stress : 482.700 MPa

Density : 0.000E+00 N /cu. mm.

Header Box:

Cold Allowable Stress : 115.100 MPa

Hot Allowable Stress : 111.900 MPa

Elastic Modulus : 0.184E+06 MPa

Poissons Ratio : 0.300

Material ID : 4-Austenitic Steels

Density : 0.000E+00 N /cu. mm.

Cold Yield Stress : 172.400 MPa

Hot Yield Stress : 126.100 MPa

Cold Tensile Stress : 482.700 MPa

Density : 0.000E+00 N /cu. mm.

Tubesheet was not modeled

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 125 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

User Defined Loads:

Forces [N]

	FX	FY	FZ	MX	MY	MZ
Weight	10020	8010	10020	2430000	3660000	2430000
Operating	10020	8010	10020	2430000	3660000	2430000
Occasional	0	0	0	0	0	0

03

No Tube Results

API Check for User Defined Loads and API Evaluation
API 661 2013 paragraph 7.1.10.2 and 7.1.10.3.

Results below are shown as:

Actual Load, Allowable Load, % of Allowable

Allowable Load: 3x API Allowable from para. 7.1.10.2

Total Nozzle Loads per DOF in [N and N.m]

Global FX	:	10020, 15015,	66 %
Global FY	:	8010, 30030,	26 %
Global FZ	:	10020, 25020,	40 %
Global MX	:	2430, 9150,	26 %
Global MY	:	3660, 12195,	30 %
Global MZ	:	2430, 6105,	39 %

API 661 para. 7.1.10.3 check PASSED. The summation of
all nozzle loads did NOT exceed the 1.5x API value from
para. 7.1.10.2.

Symmetric boundary condition applied at the center of the
headerbox, the API multiplier from paragraph 7.1.10.3 will
be 1.5 since total loads will be 2x larger due to symmetry.

[Table of Contents](#)

Load Case Report
FEPIPE Version 15.0
Released Jan. 2021

Jobname: setup2
11:46am OCT 2, 2024

\$P

Load Case Report

\$X

Inner and outer element temperatures are the same
throughout the model. No thermal ratcheting
calculations will be performed.

THE 4 LOAD CASES ANALYZED ARE:

1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range
between the installed and the operating states.

/----- Loads in Case 1
Loads due to Weight

2 SUSTAINED (Wgt+Pr)

Sustained case run to satisfy local primary
membrane and bending stress limits.

/----- Loads in Case 2
Loads due to Weight

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 126 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Pressure Case 1

3 OPERATING

Case run to compute the operating stresses used in secondary, peak and range calculations as needed.

/----- Loads in Case 3
Pressure Case 1
Loads from (Operating)

4 RANGE (Fatigue Calc Performed)

Case run to get the RANGE of stresses.
as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case 4
Plus Stress Results from CASE 3
Minus Stress Results from CASE 1

[Table of Contents](#)

Solution Data
FEPipe Version 15.0 Jobname: setup2 \$P
Released Jan. 2021 11:46am OCT 2, 2024

Solution Data

Maximum Solution Row Size = 2466
Number of Nodes = 13117
Number of Elements = 4421
Number of Solution Cases = 3

Summation of Loads per Case

Case #	FX	FY	FZ
1	10020.	56025.	10020.
2	10020.	-119625.	-387834.
3	10020.	-119625.	-387834.

[Table of Contents](#)

ASME Code Stress Output Plots
FEPipe Version 15.0 Jobname: setup2 \$P
Released Jan. 2021 11:48am OCT 2, 2024

ASME Code Stress Output Plots \$X

- 1) PL < SPL (SUS,Membrane) Case 2
- 2) Qb < SPS (SUS,Bending) Case 2
- 3) PL+Pb+Q < SPS (SUS,Inside) Case 2
- 4) PL+Pb+Q < SPS (SUS,Outside) Case 2

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 127 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

- 5) $S1+S2+S3 < 4S$ (SUS,S1+S2+S3) Case 2
- 6) $Pl+Pb+Q < SPS$ (OPE,Inside) Case 3
- 7) $Pl+Pb+Q < SPS$ (OPE,Outside) Case 3
- 8) $Membrane < User$ (OPE,Membrane) Case 3
- 9) $Bending < User$ (OPE,Bending) Case 3
- 10) $Pl+Pb+Q < SPS$ (EXP,Inside) Case 4
- 11) $Pl+Pb+Q < SPS$ (EXP,Outside) Case 4
- 12) $Pl+Pb+Q+F < 2Sa$ (EXP,Inside) Case 4
- 13) $Pl+Pb+Q+F < 2Sa$ (EXP,Outside) Case 4

03

[Table of Contents](#)

Stress Results - Notes
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: setup2
 11:48am OCT 2,2024

\$P

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = 1.000000
Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. ($Pb=0$)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
S1+S2+S3 evaluation omitted from operating stress.
Include S1+S2+S3 evaluation in primary case evaluation.
Bending stress NOT included for all S1+S2+S3 calculations.
- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: setup2
 11:48am OCT 2,2024

\$P

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 128 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		
	BK	GCS	AA	120	PR	CN	0001	V03	

ASME Overstressed Areas

\$X

03

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios

FEPipe Version 15.0

Released Jan. 2021

Jobname: setup2

11:48am OCT 2, 2024

\$P

Highest Primary Stress Ratios

\$X

Circ Plate for Plate # 1

Pl+Pb+Q SPS
120 340
MPa MPa

Primary+Secondary (Outer) Load Case 2
Min Prin. Stress = -49. (59% Neg, 5% NegHi)
Plot Reference:
4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

35%

Long Plate for Plate # 1

Pl+Pb+Q SPS
237 340
MPa MPa

Primary+Secondary (Outer) Load Case 2
Min Prin. Stress = -121. (91% Neg, 29% NegHi)
Plot Reference:
4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

69%

Circ Plate for Plate # 2

Pl+Pb+Q SPS
102 340
MPa MPa

Primary+Secondary (Outer) Load Case 2
Min Prin. Stress = -28. (59% Neg, 4% NegHi)
Plot Reference:
4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

30%

Circ Plate for Plate # 3

Pl SPL
143 168
MPa MPa

Primary Membrane Load Case 2
Min Prin. Stress = -192. (77% Neg, 47% NegHi)
Plot Reference:
1) Pl < SPL (SUS,Membrane) Case 2

84%

Circ Plate for Plate # 4

Pl SPL
121 168
MPa MPa

Primary Membrane Load Case 2
Min Prin. Stress = -175. (68% Neg, 22% NegHi)
Plot Reference:
1) Pl < SPL (SUS,Membrane) Case 2

72%

Long Plate for Plate # 4

Pl SPL

Primary Membrane Load Case 2

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 129 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

27 MPa 168 MPa Min Prin. Stress = -17. (75% Neg, 4% NegHi)
 Plot Reference:
 1) Pl < SPL (SUS,Membrane) Case 2

Circ Plate for Plate # 5

PL SPL Primary Membrane Load Case 2
 104 126 Min Prin. Stress = -7. (10% Neg, 3% NegHi)
 MPa MPa Plot Reference:
 1) Pl < SPL (SUS,Membrane) Case 2

[Table of Contents](#)

Highest Secondary Stress Ratios
 FEPipe Version 15.0 Jobname: setup2 \$P
 Released Jan. 2021 11:48am OCT 2,2024

Highest Secondary Stress Ratios \$X

In combination case 4 the max range stress divided by the max component stress is 1.84. The case tensor components are in some directions additive and so the combination case will have HIGHER stresses than the largest of any of the individual cases by more than 50%.

Load Case	Combined/Max (Inside)	Combined/Max (Outside)
4	1.838	1.691

Circ Plate for Plate # 1

Pl+Pb+Q SPS Primary+Secondary (Outer) Load Case 2
 120 340 Min Prin. Stress = -49. (59% Neg, 5% NegHi)
 MPa MPa Plot Reference:
 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

Pl+Pb+Q SPS Primary+Secondary (Outer) Load Case 3
 120 340 Min Prin. Stress = -49. (59% Neg, 5% NegHi)
 MPa MPa Plot Reference:
 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

Long Plate for Plate # 1

Pl+Pb+Q SPS Primary+Secondary (Outer) Load Case 2
 237 340 Min Prin. Stress = -121. (91% Neg, 29% NegHi)
 MPa MPa Plot Reference:
 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

Pl+Pb+Q SPS Primary+Secondary (Outer) Load Case 3
 237 340 Min Prin. Stress = -121. (91% Neg, 29% NegHi)
 MPa MPa Plot Reference:
 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 130 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

69%

Circ Plate for Plate # 2

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
102	340	Min Prin. Stress = -28. (59% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

30%

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3
102	340	Min Prin. Stress = -28. (59% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

30%

Circ Plate for Plate # 3

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
271	340	Min Prin. Stress = -192. (77% Neg, 47% NegHi)
MPa	MPa	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2

79%

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3
271	340	Min Prin. Stress = -192. (77% Neg, 47% NegHi)
MPa	MPa	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3

79%

Circ Plate for Plate # 4

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
210	340	Min Prin. Stress = -175. (68% Neg, 22% NegHi)
MPa	MPa	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2

61%

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3
210	340	Min Prin. Stress = -175. (68% Neg, 22% NegHi)
MPa	MPa	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3

61%

Long Plate for Plate # 4

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
47	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

13%

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3
47	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

13%

Circ Plate for Plate # 5

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
115	298	Min Prin. Stress = -7. (10% Neg, 3% NegHi)
MPa	MPa	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2

38%

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 132 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Plot Reference:

12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

03

Circ Plate for Plate # 3

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
153	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.198 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 567.5
770.9		Markl Fatigue Stress Allowable = 659.5
MPa		WRC 474 Mean Cycles to Failure = 1,478,924.
		WRC 474 99% Probability Cycles = 343,567.
19%		WRC 474 95% Probability Cycles = 477,000.
		BS5500 Allowed Cycles(Curve F) = 258,260.
		Membrane-to-Bending Ratio = 0.914
		Bending-to-PL+PB+Q Ratio = 0.523
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Circ Plate for Plate # 4

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
108	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.140 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 567.5
770.9		Markl Fatigue Stress Allowable = 659.5
MPa		WRC 474 Mean Cycles to Failure = 4,459,746.
		WRC 474 99% Probability Cycles = 1,036,040.
13%		WRC 474 95% Probability Cycles = 1,438,410.
		BS5500 Allowed Cycles(Curve F) = 735,938.
		Membrane-to-Bending Ratio = 0.790
		Bending-to-PL+PB+Q Ratio = 0.559
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Long Plate for Plate # 4

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
33	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.042 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 567.5
770.9		Markl Fatigue Stress Allowable = 659.5
MPa		WRC 474 Mean Cycles to Failure = 61,483,976.
		WRC 474 99% Probability Cycles = 14,283,285.
4%		WRC 474 95% Probability Cycles = 19,830,544.
		BS5500 Allowed Cycles(Curve F) = 26,126,478.
		Membrane-to-Bending Ratio = 0.826
		Bending-to-PL+PB+Q Ratio = 0.548
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Circ Plate for Plate # 5

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
108	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.205 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0145E9
Allowable		"B31" Fatigue Stress Allowable = 0.0
526.2		Markl Fatigue Stress Allowable = 575.0
MPa		WRC 474 Mean Cycles to Failure = 3,397,071.
		WRC 474 99% Probability Cycles = 789,170.
20%		WRC 474 95% Probability Cycles = 1,095,664.
		BS5500 Allowed Cycles(Curve F) = 734,195.
		Membrane-to-Bending Ratio = 25.637
		Bending-to-PL+PB+Q Ratio = 0.038

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 133 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Plot Reference:
13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

[Table of Contents](#)

03

Highest Stress Ratios Per Region
FEPipe Version 15.0 Jobname: setup2 \$P
Released Jan. 2021 11:48am OCT 2, 2024

Highest Stress Ratios Per Region \$X

Circ Plate for Plate # 1

Pl 40 MPa	SPL 168 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
23%		
Qb 99 MPa	SPS 340 MPa	Primary Bending Load Case 2 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
28%		
Pl+Pb+Q 92 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
27%		
Pl+Pb+Q 120 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
35%		
S1+S2+S3 65 MPa	4S 448 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
14%		
Pl+Pb+Q 92 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
27%		
Pl+Pb+Q 120 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
35%		
Membrane 40 MPa	User 340 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
11%		
Bending 99 MPa	User 340 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -49. (59% Neg, 5% NegHi) Plot Reference:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 134 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

9) Bending < User (OPE,Bending) Case 3		
28%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
89	340	Min Prin. Stress = -33. (61% Neg, 5% NegHi)
MPa	MPa	Plot Reference:
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
26%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4
120	340	Min Prin. Stress = -33. (61% Neg, 5% NegHi)
MPa	MPa	Plot Reference:
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
35%		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
89	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.115 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 567.5
771.0		Markl Fatigue Stress Allowable = 659.5
MPa		WRC 474 Mean Cycles to Failure = 5,583,941.
		WRC 474 99% Probability Cycles = 1,297,200.
11%		WRC 474 95% Probability Cycles = 1,800,999.
		BS5500 Allowed Cycles(Curve F) = 1,320,867.
		Membrane-to-Bending Ratio = 0.385
		Bending-to-PL+PB+Q Ratio = 0.722
		Plot Reference:
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
120	0.000 Life	Stress Concentration Factor = 1.000
MPa	0.155 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 567.5
771.0		Markl Fatigue Stress Allowable = 659.5
MPa		WRC 474 Mean Cycles to Failure = 1,771,558.
		WRC 474 99% Probability Cycles = 411,549.
15%		WRC 474 95% Probability Cycles = 571,384.
		BS5500 Allowed Cycles(Curve F) = 537,311.
		Membrane-to-Bending Ratio = 0.385
		Bending-to-PL+PB+Q Ratio = 0.722
		Plot Reference:
		13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Long Plate for Plate # 1		
Pl	SPL	Primary Membrane Load Case 2
107	168	Min Prin. Stress = -121. (91% Neg, 29% NegHi)
MPa	MPa	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
63%		
Qb	SPS	Primary Bending Load Case 2
190	340	Min Prin. Stress = -121. (91% Neg, 29% NegHi)
MPa	MPa	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 2
55%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
165	340	Min Prin. Stress = -121. (91% Neg, 29% NegHi)
MPa	MPa	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
48%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
237	340	Min Prin. Stress = -121. (91% Neg, 29% NegHi)
MPa	MPa	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
69%		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 135 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

S1+S2+S3 124 MPa	4S 448 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -121. (91% Neg, 29% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
27%		
Pl+Pb+Q 165 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -121. (91% Neg, 29% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
48%		
Pl+Pb+Q 237 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -121. (91% Neg, 29% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
69%		
Membrane 107 MPa	User 340 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -121. (91% Neg, 29% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
31%		
Bending 190 MPa	User 340 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -121. (91% Neg, 29% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
55%		
Pl+Pb+Q 125 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -71. (89% Neg, 24% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
36%		
Pl+Pb+Q 169 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -71. (89% Neg, 24% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
49%		
Pl+Pb+Q+F 125 MPa	Damage Ratio 0.000 Life 0.162 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 567.5 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 1,988,003. WRC 474 99% Probability Cycles = 461,831. WRC 474 95% Probability Cycles = 641,194. BS5500 Allowed Cycles(Curve F) = 474,054. Membrane-to-Bending Ratio = 0.303 Bending-to-PL+PB+Q Ratio = 0.768 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Allowable 771.0 MPa		
16%		
Pl+Pb+Q+F 169 MPa	Damage Ratio 0.000 Life 0.220 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 567.5 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 607,122. WRC 474 99% Probability Cycles = 141,040. WRC 474 95% Probability Cycles = 195,816. BS5500 Allowed Cycles(Curve F) = 190,383. Membrane-to-Bending Ratio = 0.303 Bending-to-PL+PB+Q Ratio = 0.768 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Allowable 771.0 MPa		
21%		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 136 از 150	
	پروژه	بسته کاری	صادرکننده	تجهیزات	رشته	نوع مدرک	سریال		
	BK	GCS	AA	120	PR	CN	0001	V03	

Circ Plate for Plate # 2

Pl 38 MPa	SPL 168 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
22%		
Qb 87 MPa	SPS 340 MPa	Primary Bending Load Case 2 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
25%		
Pl+Pb+Q 86 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
25%		
Pl+Pb+Q 102 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
30%		
S1+S2+S3 63 MPa	4S 448 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
14%		
Pl+Pb+Q 86 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
25%		
Pl+Pb+Q 102 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
30%		
Membrane 38 MPa	User 340 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
11%		
Bending 87 MPa	User 340 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -28. (59% Neg, 4% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
25%		
Pl+Pb+Q 84 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -31. (57% Neg, 4% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
24%		
Pl+Pb+Q 79 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -31. (57% Neg, 4% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
23%		
Pl+Pb+Q+F 84 MPa	Damage Ratio 0.000 Life 0.109 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 137 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Allowable 770.9 MPa 10%		Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 567.5 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 4,542,684. WRC 474 99% Probability Cycles = 1,055,307. WRC 474 95% Probability Cycles = 1,465,161. BS5500 Allowed Cycles(Curve F) = 1,316,472. Membrane-to-Bending Ratio = 0.150 Bending-to-PL+PB+Q Ratio = 0.869 Plot Reference: 12) PL+PB+Q+F < 2Sa (EXP,Inside) Case 4
Pl+Pb+Q+F 79 MPa 10%	Damage Ratio 0.000 Life 0.102 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 567.5 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 5,778,046. WRC 474 99% Probability Cycles = 1,342,292. WRC 474 95% Probability Cycles = 1,863,604. BS5500 Allowed Cycles(Curve F) = 1,577,694. Membrane-to-Bending Ratio = 0.108 Bending-to-PL+PB+Q Ratio = 0.903 Plot Reference: 13) PL+PB+Q+F < 2Sa (EXP,Outside) Case 4
Circ Plate for Plate # 3		
Pl 143 MPa 84%	SPL 168 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
Qb 184 MPa 54%	SPS 340 MPa	Primary Bending Load Case 2 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
Pl+Pb+Q 271 MPa 79%	SPS 340 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
Pl+Pb+Q 159 MPa 46%	SPS 340 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
S1+S2+S3 148 MPa 33%	4S 448 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
Pl+Pb+Q 271 MPa 79%	SPS 340 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
Pl+Pb+Q 159 MPa 46%	SPS 340 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)								
شماره پیمان: 053-073-9184	Thermal/Mechanical Calculation Book							شماره صفحه : 138 از 150	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	AA	120	PR	CN	0001	V03	

Membrane 143 MPa	User 340 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
41%		
Bending 184 MPa	User 340 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -192. (77% Neg, 47% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
54%		
Pl+Pb+Q 153 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -119. (99% Neg, 68% NegHi) Plot Reference: 10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
44%		
Pl+Pb+Q 103 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -119. (99% Neg, 68% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
30%		
Pl+Pb+Q+F 153 MPa	Damage Ratio 0.000 Life 0.198 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 567.5 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 1,478,924. WRC 474 99% Probability Cycles = 343,567. WRC 474 95% Probability Cycles = 477,000. BS5500 Allowed Cycles(Curve F) = 258,260. Membrane-to-Bending Ratio = 0.914 Bending-to-PL+PB+Q Ratio = 0.523 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Allowable 770.9 MPa		
19%		
Pl+Pb+Q+F 103 MPa	Damage Ratio 0.000 Life 0.134 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 567.5 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 4,763,216. WRC 474 99% Probability Cycles = 1,106,538. WRC 474 95% Probability Cycles = 1,536,289. BS5500 Allowed Cycles(Curve F) = 837,188. Membrane-to-Bending Ratio = 13.210 Bending-to-PL+PB+Q Ratio = 0.070 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Allowable 770.9 MPa		
13%		
Circ Plate for Plate # 4		
Pl 121 MPa	SPL 168 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -175. (68% Neg, 22% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
72%		
Qb 128 MPa	SPS 340 MPa	Primary Bending Load Case 2 Min Prin. Stress = -175. (68% Neg, 22% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
37%		
Pl+Pb+Q 210 MPa	SPS 340 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -175. (68% Neg, 22% NegHi) Plot Reference:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)							
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book							شماره صفحه : 139 از 150
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	
	V03	0001	CN	PR	120	AA	GCS	BK

		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2	
61%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2	
149	340	Min Prin. Stress = -175. (68% Neg, 22% NegHi)	
MPa	MPa	Plot Reference:	
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2	
43%			
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2	
151	448	Min Prin. Stress = -175. (68% Neg, 22% NegHi)	
MPa	MPa	Plot Reference:	
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2	
33%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3	
210	340	Min Prin. Stress = -175. (68% Neg, 22% NegHi)	
MPa	MPa	Plot Reference:	
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3	
61%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3	
149	340	Min Prin. Stress = -175. (68% Neg, 22% NegHi)	
MPa	MPa	Plot Reference:	
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3	
43%			
Membrane	User	Component Evaluation Load Case 3	
121	340	Min Prin. Stress = -175. (68% Neg, 22% NegHi)	
MPa	MPa	Plot Reference:	
		8) Membrane < User (OPE,Membrane) Case 3	
35%			
Bending	User	Component Evaluation Load Case 3	
128	340	Min Prin. Stress = -175. (68% Neg, 22% NegHi)	
MPa	MPa	Plot Reference:	
		9) Bending < User (OPE,Bending) Case 3	
37%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
108	340	Min Prin. Stress = -73. (78% Neg, 22% NegHi)	
MPa	MPa	Plot Reference:	
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 4	
31%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4	
106	340	Min Prin. Stress = -73. (78% Neg, 22% NegHi)	
MPa	MPa	Plot Reference:	
		11) Pl+Pb+Q < SPS (EXP,Outside) Case 4	
31%			
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4	
108	0.000 Life	Stress Concentration Factor = 1.000	
MPa	0.140 Stress	Strain Concentration Factor = 1.000	
		Cycles Allowed for this Stress = 1.0000E11	
Allowable		"B31" Fatigue Stress Allowable = 567.5	
770.9		Markl Fatigue Stress Allowable = 659.5	
MPa		WRC 474 Mean Cycles to Failure = 4,459,746.	
		WRC 474 99% Probability Cycles = 1,036,040.	
13%		WRC 474 95% Probability Cycles = 1,438,410.	
		BS5500 Allowed Cycles(Curve F) = 735,938.	
		Membrane-to-Bending Ratio = 0.790	
		Bending-to-PL+PB+Q Ratio = 0.559	
		Plot Reference:	
		12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4	
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4	
106	0.000 Life	Stress Concentration Factor = 1.000	
MPa	0.138 Stress	Strain Concentration Factor = 1.000	
		Cycles Allowed for this Stress = 1.0000E11	
Allowable		"B31" Fatigue Stress Allowable = 567.5	
770.9		Markl Fatigue Stress Allowable = 659.5	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 140 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

MPa WRC 474 Mean Cycles to Failure = 4,608,486.
 13% WRC 474 99% Probability Cycles = 1,070,593.
 WRC 474 95% Probability Cycles = 1,486,384.
 BS5500 Allowed Cycles(Curve F) = 770,017.
 Membrane-to-Bending Ratio = 1.090
 Bending-to-PL+PB+Q Ratio = 0.478
 Plot Reference:
 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

03

Long Plate for Plate # 4

Pl	SPL	Primary Membrane Load Case 2
27	168	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		1) Pl < SPL (SUS,Membrane) Case 2
15%		
Qb	SPS	Primary Bending Load Case 2
37	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		2) Qb < SPS (SUS,Bending) Case 2
10%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
38	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
11%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
47	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
13%		
S1+S2+S3	4S	Part 5 (5.3.2) Load Case 2
21	448	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
4%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3
38	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
11%		
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3
47	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
13%		
Membrane	User	Component Evaluation Load Case 3
27	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		8) Membrane < User (OPE,Membrane) Case 3
7%		
Bending	User	Component Evaluation Load Case 3
37	340	Min Prin. Stress = -17. (75% Neg, 4% NegHi)
MPa	MPa	Plot Reference:
		9) Bending < User (OPE,Bending) Case 3
10%		
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
33	340	Min Prin. Stress = -14. (88% Neg, 5% NegHi)
MPa	MPa	Plot Reference:
		10) Pl+Pb+Q < SPS (EXP,Inside) Case 4
9%		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 141 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Pl+Pb+Q 20 MPa	SPS 340 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -14. (88% Neg, 5% NegHi) Plot Reference: 11) Pl+Pb+Q < SPS (EXP,Outside) Case 4
5%		
Pl+Pb+Q+F 33 MPa	Damage Ratio 0.000 Life 0.042 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 567.5 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 61,483,976. WRC 474 99% Probability Cycles = 14,283,285. WRC 474 95% Probability Cycles = 19,830,544. BS5500 Allowed Cycles(Curve F) = 26,126,478. Membrane-to-Bending Ratio = 0.826 Bending-to-PL+PB+Q Ratio = 0.548 Plot Reference: 12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Allowable 770.9 MPa		
4%		
Pl+Pb+Q+F 20 MPa	Damage Ratio 0.000 Life 0.026 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.000 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 567.5 Markl Fatigue Stress Allowable = 659.5 WRC 474 Mean Cycles to Failure = 3.3834E8 WRC 474 99% Probability Cycles = 78,598,464. WRC 474 95% Probability Cycles = 1.0912E8 BS5500 Allowed Cycles(Curve F) = 2.9743E8 Membrane-to-Bending Ratio = 0.854 Bending-to-PL+PB+Q Ratio = 0.539 Plot Reference: 13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Allowable 770.9 MPa		
2%		
Circ Plate for Plate # 5		
Pl 104 MPa	SPL 126 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -7. (10% Neg, 3% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
82%		
Qb 37 MPa	SPS 298 MPa	Primary Bending Load Case 2 Min Prin. Stress = -7. (10% Neg, 3% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
12%		
Pl+Pb+Q 107 MPa	SPS 298 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -7. (10% Neg, 3% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
35%		
Pl+Pb+Q 115 MPa	SPS 298 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -7. (10% Neg, 3% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
38%		
Pl+Pb+Q 107 MPa	SPS 298 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -7. (10% Neg, 3% NegHi) Plot Reference: 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
35%		
Pl+Pb+Q 115 MPa	SPS 298 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -7. (10% Neg, 3% NegHi) Plot Reference:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)										
شماره پیمان: 053 – 073 – 9184	Thermal/Mechanical Calculation Book								شماره صفحه : 142 از 150		
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه			
	BK	GCS	AA	120	PR	CN	0001	V03			

38%			7) Pl+Pb+Q < SPS (OPE,Outside) Case 3		
Membrane	User	Component Evaluation Load Case 3			
104	298	Min Prin. Stress = -7. (10% Neg, 3% NegHi)			
MPa	MPa	Plot Reference:			
			8) Membrane < User (OPE,Membrane) Case 3		
34%					
Bending	User	Component Evaluation Load Case 3			
37	298	Min Prin. Stress = -7. (10% Neg, 3% NegHi)			
MPa	MPa	Plot Reference:			
			9) Bending < User (OPE,Bending) Case 3		
12%					
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4			
100	298	Min Prin. Stress = -5. (8% Neg, 1% NegHi)			
MPa	MPa	Plot Reference:			
			10) Pl+Pb+Q < SPS (EXP,Inside) Case 4		
33%					
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4			
108	298	Min Prin. Stress = -5. (8% Neg, 1% NegHi)			
MPa	MPa	Plot Reference:			
			11) Pl+Pb+Q < SPS (EXP,Outside) Case 4		
36%					
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4			
100	0.000 Life	Stress Concentration Factor = 1.000			
MPa	0.191 Stress	Strain Concentration Factor = 1.000			
			Cycles Allowed for this Stress = 4.8949E9		
			"B31" Fatigue Stress Allowable = 0.0		
			Markl Fatigue Stress Allowable = 575.0		
			WRC 474 Mean Cycles to Failure = 4,277,923.		
			WRC 474 99% Probability Cycles = 993,800.		
			WRC 474 95% Probability Cycles = 1,379,767.		
			BS5500 Allowed Cycles(Curve F) = 915,978.		
			Membrane-to-Bending Ratio = 25.639		
			Bending-to-PL+PB+Q Ratio = 0.038		
			Plot Reference:		
			12) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4		
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4			
108	0.000 Life	Stress Concentration Factor = 1.000			
MPa	0.205 Stress	Strain Concentration Factor = 1.000			
			Cycles Allowed for this Stress = 1.0145E9		
			"B31" Fatigue Stress Allowable = 0.0		
			Markl Fatigue Stress Allowable = 575.0		
			WRC 474 Mean Cycles to Failure = 3,397,071.		
			WRC 474 99% Probability Cycles = 789,170.		
			WRC 474 95% Probability Cycles = 1,095,664.		
			BS5500 Allowed Cycles(Curve F) = 734,195.		
			Membrane-to-Bending Ratio = 25.637		
			Bending-to-PL+PB+Q Ratio = 0.038		
			Plot Reference:		
			13) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4		

Table of Contents

Compressive Stress Summary
FEPipe Version 15.0
Released Jan. 2021

Jobname: setup2
11:48am OCT 2,2024

\$P

Compressive Stress Summary (MPa)

\$X

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0015_02)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">Thermal/Mechanical Calculation Book</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V03</td><td>0001</td><td>CN</td><td>PR</td><td>120</td><td>AA</td><td>GCS</td><td>BK</td></tr></table>	Thermal/Mechanical Calculation Book								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V03	0001	CN	PR	120	AA	GCS	BK	شماره صفحه : 143 از 150
Thermal/Mechanical Calculation Book																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V03	0001	CN	PR	120	AA	GCS	BK																			

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress
 Pts in Region - No. of nodes in the model region
 >5% Compression - 5% or more of Compressive Stress Limit
 >50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = $-0.55 \text{ Min}(S_y, kEt/R)$, Section slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	>5% Compression	>50% Compression and Bending	Region
1	SUSTAINED	2	-49.	3024	59%	5%	Circ Plate for Plate # 1
2	OPERATING	3	-49.	3024	59%	5%	Circ Plate for Plate # 1
3	EXPANSION	4	-33.	3024	61%	5%	Circ Plate for Plate # 1
4	SUSTAINED	2	-121.	13176	91%	29%	Long Plate for Plate # 1
5	OPERATING	3	-121.	13176	91%	29%	Long Plate for Plate # 1
6	EXPANSION	4	-71.	13176	89%	24%	Long Plate for Plate # 1
7	SUSTAINED	2	-28.	2112	59%	4%	Circ Plate for Plate # 2
8	OPERATING	3	-28.	2112	59%	4%	Circ Plate for Plate # 2
9	EXPANSION	4	-31.	2112	57%	4%	Circ Plate for Plate # 2
10	SUSTAINED	2	-192.	1600	77%	47%	Circ Plate for Plate # 3
11	OPERATING	3	-192.	1600	77%	47%	Circ Plate for Plate # 3
12	EXPANSION	4	-119.	1600	99%	68%	Circ Plate for Plate # 3
13	SUSTAINED	2	-175.	1440	68%	22%	Circ Plate for Plate # 4
14	OPERATING	3	-175.	1440	68%	22%	Circ Plate for Plate # 4
15	EXPANSION	4	-73.	1440	78%	22%	Circ Plate for Plate # 4
16	SUSTAINED	2	-17.	640	75%	4%	Long Plate for Plate # 4
17	OPERATING	3	-17.	640	75%	4%	Long Plate for Plate # 4
18	EXPANSION	4	-14.	640	88%	5%	Long Plate for Plate # 4
19	SUSTAINED	2	-7.	13376	10%	3%	Circ Plate for Plate # 5
20	OPERATING	3	-7.	13376	10%	3%	Circ Plate for Plate # 5
21	EXPANSION	4	-5.	13376	8%	1%	Circ Plate for Plate # 5

[Table of Contents](#)



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0015_02)



شماره پیمان:

053-073-9184


Thermal/Mechanical Calculation Book

پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	GCS	AA	120	PR	CN	0001	V03

شماره صفحه : 144 از 150



Finite Element Model

03



3d

1) P1 < SPL (SUS Membrane) Case 2



3d(Deformed)

3d



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0015_02)



شماره پیمان:


053-073-9184

Thermal/Mechanical Calculation Book


پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	GCS	AA	120	PR	CN	0001	V03

شماره صفحه : 145 از 150

2) $Q_b < SPS$ (SUS Bending) Case 2



3) $P1+Pb+Q < SPS$ (SUS Inside) Case 2





نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0015_02)



شماره پیمان:


053-073-9184

Thermal/Mechanical Calculation Book

پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	GCS	AA	120	PR	CN	0001	V03

شماره صفحه : 146 از 150

4) P1+Pb+Q < SPS (SUS Outside) Case 2




03

3d(Deformed)

3d

5) S1+S2+S3 < 4S (SUS S1+S2+S3) Case 2



3d(Deformed)

3d



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0015_02)



شماره پیمان:


053-073-9184

Thermal/Mechanical Calculation Book

پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	GCS	AA	120	PR	CN	0001	V03

شماره صفحه : 147 از 150

6) P1+Pb+Q < SPS (OPE Inside) Case 3




3d(Deformed)

3d

03

7) P1+Pb+Q < SPS (OPE Outside) Case 3



3d(Deformed)

3d



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0015_02)



شماره پیمان:


053-073-9184

Thermal/Mechanical Calculation Book

پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه
BK	GCS	AA	120	PR	CN	0001	V03

شماره صفحه : 148 از 150

8) Membrane < User (OPE Membrane) Case 3




03

3d(Deformed)

3d

9) Bending < User (OPE Bending) Case 3



3d(Deformed)

3d



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0015_02)



شماره پیمان:


053-073-9184

Thermal/Mechanical Calculation Book

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
V03	0001	CN	PR	120	AA	GCS	BK

شماره صفحه : 149 از 150


10) P1+Pb+Q < SPS (EXP Inside) Case 4



3d

03

11) P1+Pb+Q < SPS (EXP Outside) Case 4



3d



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید پکیج کولرهای هوایی ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0015_02)



شماره پیمان:


053-073-9184

Thermal/Mechanical Calculation Book

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
V03	0001	CN	PR	120	AA	GCS	BK

شماره صفحه : 150 از 150


12) $P1+Pb+Q+F < 2Sa$ (EXP Inside) Case 4



3d

03

13) $P1+Pb+Q+F < 2Sa$ (EXP Outside) Case 4



3d