

|                                                                                           |                                                                                                                                                                                         |       |          |      |        |            |           |                                                                                     |
|-------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------|----------|------|--------|------------|-----------|-------------------------------------------------------------------------------------|
| <br>NISOC | <p>تکهداشت و افزایش تولید میدان نفتی بینک</p> <p>سطح الارض و ابنیه تحت الارض</p> <p>خرید پکیج پمپ های آب آتشنشانی ایستگاه تقویت فشار گاز بینک</p> <p>(قرارداد ۰۰۲۳-۰۰-BK-HD-GCS-CO)</p> |       |          |      |        |            |           |  |
| شماره پیمان:<br><br>۰۵۳-۰۰۷۳-۹۱۸۴                                                         | DATA SHEETS (W/PERFORMANCE CURVE) FOR FIRE WATER JOCKEY PUMPS                                                                                                                           |       |          |      |        |            |           |                                                                                     |
|                                                                                           | نسخه                                                                                                                                                                                    | سریال | نوع مدرک | رشته | تهیلات | صادر کننده | بسته کاری | پروژه                                                                               |
|                                                                                           | V00                                                                                                                                                                                     | 0003  | DS       | ME   | 120    | KP         | GCS       | BK                                                                                  |
| شماره صفحه: ۱ از ۱۰                                                                       |                                                                                                                                                                                         |       |          |      |        |            |           |                                                                                     |

طرح نگهداشت و افزایش تولید ۲۷ مخزن

DATA SHEETS (W/PERFORMANCE CURVE) FOR FIRE WATER JOCKEY PUMPS

نگهداشت و افزایش تولید میدان نفتی بینک

|      |          |                           |              |             |              |                 |
|------|----------|---------------------------|--------------|-------------|--------------|-----------------|
|      |          |                           |              |             |              |                 |
|      |          |                           |              |             |              |                 |
|      |          |                           |              |             |              |                 |
|      |          |                           |              |             |              |                 |
|      |          |                           |              |             |              |                 |
| V00  | Nov-2024 | IFA                       | KP           | M.Fakharian | M.Sadeghian  |                 |
| Rev. | Date     | Purpose of Issue / Status | Prepared by: | Checked by: | Approved by: | CLIENT Approval |

status:

- IFA: Issued For Approval
- AFC: Approved For Construction
- IFI: Issued For Information



NISOC

نگهداشت و افزایش تولید میدان نفتی بینک  
سطح الارض و ابنیه تحت الارض  
خرید پکیج پمپ های آب آتشنشانی ایستگاه تقویت فشار گاز بینک  
(قرارداد ۰۰۲۳-۰۰۰۰-BK-HD-GCS-CO)



شماره پیمان:

DATA SHEETS (W/PERFORMANCE CURVE) FOR FIRE WATER JOCKEY PUMPS

۰۵۳-۰۷۳-۹۱۸۴

| نسخه | سریال | نوع مدرک | رشته | تجهیزات | صادر کننده | بسته کاری | پروژه |
|------|-------|----------|------|---------|------------|-----------|-------|
| V00  | 0003  | DS       | ME   | 120     | KP         | GCS       | BK    |

شماره صفحه: ۲ از ۱۰

## REVISION RECORD SHEET

| page | 00 | 01 | 02 | 03 | 04 | 05 |
|------|----|----|----|----|----|----|
| 1    | x  |    |    |    |    |    |
| 2    | x  |    |    |    |    |    |
| 3    | x  |    |    |    |    |    |
| 4    | x  |    |    |    |    |    |
| 5    | x  |    |    |    |    |    |
| 6    | x  |    |    |    |    |    |
| 7    | x  |    |    |    |    |    |
| 8    | x  |    |    |    |    |    |
| 9    | x  |    |    |    |    |    |
| 10   | x  |    |    |    |    |    |
| 11   |    |    |    |    |    |    |
| 12   |    |    |    |    |    |    |
| 13   |    |    |    |    |    |    |
| 14   |    |    |    |    |    |    |
| 15   |    |    |    |    |    |    |
| 16   |    |    |    |    |    |    |
| 17   |    |    |    |    |    |    |
| 18   |    |    |    |    |    |    |
| 19   |    |    |    |    |    |    |
| 20   |    |    |    |    |    |    |
| 21   |    |    |    |    |    |    |
| 22   |    |    |    |    |    |    |
| 23   |    |    |    |    |    |    |
| 24   |    |    |    |    |    |    |
| 25   |    |    |    |    |    |    |
| 26   |    |    |    |    |    |    |
| 27   |    |    |    |    |    |    |
| 28   |    |    |    |    |    |    |
| 29   |    |    |    |    |    |    |
| 30   |    |    |    |    |    |    |
| 31   |    |    |    |    |    |    |
| 32   |    |    |    |    |    |    |
| 33   |    |    |    |    |    |    |
| 34   |    |    |    |    |    |    |
| 35   |    |    |    |    |    |    |
| 36   |    |    |    |    |    |    |
| 37   |    |    |    |    |    |    |
| 38   |    |    |    |    |    |    |
| 39   |    |    |    |    |    |    |
| 40   |    |    |    |    |    |    |
| 41   |    |    |    |    |    |    |
| 42   |    |    |    |    |    |    |
| 43   |    |    |    |    |    |    |
| 44   |    |    |    |    |    |    |
| 45   |    |    |    |    |    |    |
| 46   |    |    |    |    |    |    |
| 47   |    |    |    |    |    |    |
| 48   |    |    |    |    |    |    |
| 49   |    |    |    |    |    |    |
| 50   |    |    |    |    |    |    |
| 51   |    |    |    |    |    |    |
| 52   |    |    |    |    |    |    |
| 53   |    |    |    |    |    |    |
| 54   |    |    |    |    |    |    |
| 55   |    |    |    |    |    |    |
| 56   |    |    |    |    |    |    |
| 57   |    |    |    |    |    |    |
| 58   |    |    |    |    |    |    |
| 59   |    |    |    |    |    |    |
| 60   |    |    |    |    |    |    |
| 61   |    |    |    |    |    |    |
| 62   |    |    |    |    |    |    |
| 63   |    |    |    |    |    |    |
| 64   |    |    |    |    |    |    |


| page | 00 | 01 | 02 | 03 | 04 | 05 |
|------|----|----|----|----|----|----|
| 65   |    |    |    |    |    |    |
| 66   |    |    |    |    |    |    |
| 67   |    |    |    |    |    |    |
| 68   |    |    |    |    |    |    |
| 69   |    |    |    |    |    |    |
| 70   |    |    |    |    |    |    |
| 71   |    |    |    |    |    |    |
| 72   |    |    |    |    |    |    |
| 73   |    |    |    |    |    |    |
| 74   |    |    |    |    |    |    |
| 75   |    |    |    |    |    |    |
| 76   |    |    |    |    |    |    |
| 77   |    |    |    |    |    |    |
| 78   |    |    |    |    |    |    |
| 79   |    |    |    |    |    |    |
| 80   |    |    |    |    |    |    |
| 81   |    |    |    |    |    |    |
| 82   |    |    |    |    |    |    |
| 83   |    |    |    |    |    |    |
| 84   |    |    |    |    |    |    |
| 85   |    |    |    |    |    |    |
| 86   |    |    |    |    |    |    |
| 87   |    |    |    |    |    |    |
| 88   |    |    |    |    |    |    |
| 89   |    |    |    |    |    |    |
| 90   |    |    |    |    |    |    |
| 91   |    |    |    |    |    |    |
| 92   |    |    |    |    |    |    |
| 93   |    |    |    |    |    |    |
| 94   |    |    |    |    |    |    |
| 95   |    |    |    |    |    |    |
| 96   |    |    |    |    |    |    |
| 97   |    |    |    |    |    |    |
| 98   |    |    |    |    |    |    |
| 99   |    |    |    |    |    |    |
| 100  |    |    |    |    |    |    |
| 101  |    |    |    |    |    |    |
| 102  |    |    |    |    |    |    |
| 103  |    |    |    |    |    |    |
| 104  |    |    |    |    |    |    |
| 105  |    |    |    |    |    |    |
| 106  |    |    |    |    |    |    |
| 107  |    |    |    |    |    |    |
| 108  |    |    |    |    |    |    |
| 109  |    |    |    |    |    |    |
| 110  |    |    |    |    |    |    |
| 111  |    |    |    |    |    |    |
| 112  |    |    |    |    |    |    |
| 113  |    |    |    |    |    |    |
| 114  |    |    |    |    |    |    |
| 115  |    |    |    |    |    |    |
| 116  |    |    |    |    |    |    |
| 117  |    |    |    |    |    |    |
| 118  |    |    |    |    |    |    |
| 119  |    |    |    |    |    |    |
| 120  |    |    |    |    |    |    |
| 121  |    |    |    |    |    |    |
| 122  |    |    |    |    |    |    |
| 123  |    |    |    |    |    |    |
| 124  |    |    |    |    |    |    |
| 125  |    |    |    |    |    |    |
| 126  |    |    |    |    |    |    |
| 127  |    |    |    |    |    |    |
| 128  |    |    |    |    |    |    |

|                                                                                              |                                                                                                                                                                                |           |            |        |      |          |                                                                                    |      |
|----------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------|------------|--------|------|----------|------------------------------------------------------------------------------------|------|
|  <p>NISOC</p> | <p>نگهداشت و افزایش تولید میدان نفتی بینک<br/>سطح الارض و ابنیه تحت الارض<br/>خرید پکیج پمپ های آب آتشنشانی ایستگاه تقویت فشار گاز بینک<br/>(قرارداد ۰۰۲۳-۰۰-BK-HD-GCS-CO)</p> |           |            |        |      |          |  |      |
| شماره پیمان: ۰۵۳-۰۲۳-۹۱۸۴                                                                    | DATA SHEETS (W/PERFORMANCE CURVE) FOR FIRE WATER JOCKEY PUMPS                                                                                                                  |           |            |        |      |          | شماره صفحه: ۳ از ۱۰                                                                |      |
|                                                                                              | پروژه                                                                                                                                                                          | بسته کاری | صادر کننده | تهیهات | رشته | نوع مدرک | سریال                                                                              | نسخه |
|                                                                                              | BK                                                                                                                                                                             | GCS       | KP         | 120    | ME   | DS       | 0003                                                                               | V00  |

| GENERAL NOTES                                                                                                                                                                                                                                                                                                                                                                                                                                            |                                                                                                 |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------|
| 1 Vendor shall fill in the blanks and return the completed data sheet along with Motor data sheet, "DOC NO.: BK-GCS-PEDCO-120-EL-DT-0008 & 0009 with his proposal.                                                                                                                                                                                                                                                                                       | KPC : Confirmed                                                                                 |
| 2 Vendor shall submit ITP (Inspection & Testing Plan) with his proposal.                                                                                                                                                                                                                                                                                                                                                                                 | KPC : Confirmed                                                                                 |
| 3 Vendor is requested to confirm the material, or propose appropriate alternative.                                                                                                                                                                                                                                                                                                                                                                       | KPC : Confirmed                                                                                 |
| 4 For Instrumentation, Project specification 'Specification For Instrument and Control of package Unit System (PU)' Doc. No. BK-GNRAL-PEDCO-000-IN-SP-0004, shall be followed.                                                                                                                                                                                                                                                                           | KPC : Confirmed                                                                                 |
| 5 Mechanical seal data sheet shall fill in by vendor as per API 682, 4th edition.                                                                                                                                                                                                                                                                                                                                                                        | KPC : Confirmed                                                                                 |
| 6 NPSH test shall be done & witnessed if the margin of NPSHr & NPSHa is less than 1.                                                                                                                                                                                                                                                                                                                                                                     | KPC : Confirmed                                                                                 |
| 7 The Tie-in flanges shall conform to ASME B-16.1.                                                                                                                                                                                                                                                                                                                                                                                                       | KPC : Confirmed                                                                                 |
| 8 Pump drain shall be terminated at skid edge with flange connection and valved.                                                                                                                                                                                                                                                                                                                                                                         | KPC : Confirmed                                                                                 |
| 9 Supplier to indicate which minimum flow pumps can achieve.                                                                                                                                                                                                                                                                                                                                                                                             | KPC : Confirmed                                                                                 |
| 10 Nozzle loads shall be 2 times the loads shown in API 610 11th Edition.                                                                                                                                                                                                                                                                                                                                                                                | KPC : Confirmed                                                                                 |
| 11 Electrical motor shall be rated for the end of curve.                                                                                                                                                                                                                                                                                                                                                                                                 | KPC : Confirmed                                                                                 |
| 12 The Suction line size is 2 " and discharge line is 2 ".                                                                                                                                                                                                                                                                                                                                                                                               | KPC : Confirmed                                                                                 |
| 13 Pump Manufacturer shall supply all instrumentation for mechanical seals as per API 682 4th Edition and project requirements.                                                                                                                                                                                                                                                                                                                          | KPC : Confirmed                                                                                 |
| 14 Based on project instrumentation specification, these equipments are classified as Type C. Electro pump shall include a dedicated controller/ starter panel installed on pump skid as per NFPA 20 (2019). Pressure switch and pressure sensing line and its accessories are in vendor scope of work and supply. As per NFPA 20 dedicated sensing line and control panel for jockey pumps and separated from main pumps shall be considered by vendor. | KPC : Based on project instrumentation specification, these equipments are classified as Type A |
| 15 Welding repair procedures shall be submitted for approval.                                                                                                                                                                                                                                                                                                                                                                                            | KPC : Confirmed                                                                                 |
| 16 If pump is self venting there is no need for vent .                                                                                                                                                                                                                                                                                                                                                                                                   | KPC : Confirmed                                                                                 |
| 17 For information on site conditions refer to Process Basis of Design document; Doc.No: BK-GNRAL-PEDCO-000-PR-DB-0001., electrical motor shall be rated according to project site condition. any required protection for pumps in this regard shall be considered by pump manufacturer.                                                                                                                                                                 | KPC : Confirmed                                                                                 |
| 18 Ultrasonic Test shall be performed for forged shaft.                                                                                                                                                                                                                                                                                                                                                                                                  | KPC : Confirmed                                                                                 |
| 19 Couplings shall be dry, flexible and spacer type.                                                                                                                                                                                                                                                                                                                                                                                                     | KPC : Confirmed                                                                                 |
| 20 For electrical motor descriptions, refer to 'Specification For LV Induction Motors' Doc. No. BK-GNRAL-PEDCO-000-EL-SP-0010.                                                                                                                                                                                                                                                                                                                           | KPC : Confirmed                                                                                 |
| 21 A local control panel shall be considered by vendor to be located next to the pumps as per "Specification For Fire Water Network", Doc.No.BK-GCS-PEDCO-120-SA-PI-0001. Pump LCP shall be designed to manage all required monitoring and control signals , as minimum in accordance with "P&ID For Fire Water Network", Doc.No.BK-GCS-PEDCO-120-SA-PI-0001.                                                                                            | KPC : Confirmed                                                                                 |
| 22 Pressure sensing lines are in the vendor's scope of supply.                                                                                                                                                                                                                                                                                                                                                                                           | KPC : Confirmed                                                                                 |
| 23 For technical requirements of electrical lv motors refer to "Data sheets "for lv induction motors: DOC NO:BK-GCS-PEDCO-120-EL-DT-0008". Power Factor, efficeincy, frequent, voltage, frequent variation and voltage variation of motor shall be specified by vendor in data sheet.                                                                                                                                                                    | KPC : Confirmed                                                                                 |





**شماره پیمان:**

## DATA SHEETS (W/PERFORMANCE CURVE) FOR FIRE WATER JOCKEY PUMPS

• 03-073-9184

شماره صفحه: ۵ از ۱۰

| نسخه | سرمال | نوع مدرک | رشته | تسهیلات | صادرکننده | بسته کاری | پروژه |
|------|-------|----------|------|---------|-----------|-----------|-------|
| V00  | 0003  | DS       | ME   | 120     | KP        | GCS       | BK    |

## CENTRIFUGAL PUMP DATA SHEET (SI UNIT) - P-2302 A/B (Sheet 2 of 6)

|                |                              |                   |
|----------------|------------------------------|-------------------|
| APPLICABLE TO: | PROPOSAL                     |                   |
| FOR            | NISOC                        |                   |
| SITE           | BINAK Gas Compressor Station |                   |
| NO. REQ        | 2 (1+1)                      | PUMP SIZE 2 "x 1" |
| MANUFACTURER   | KALAYE PUMP CO.              |                   |

|                                    |                      |                              |        |
|------------------------------------|----------------------|------------------------------|--------|
| APPLICABLE NTL/INTNTL STANDARD:    |                      | NFPA20 (2019) & IPS-M-PM-125 |        |
| UNIT                               |                      |                              |        |
| SERVICE<br>Fire Water Jockey Pumps |                      |                              |        |
| TYPE                               | OH2 (V.T.A.)         | No. STAGES                   | 1      |
| MODEL                              | V.T.A. <b>RP2532</b> | SERIAL NO.                   | V.T.A. |

## LIQUID CHARACTERISTICS

|                              |        |               |         |                                                                |                                       |                                   |
|------------------------------|--------|---------------|---------|----------------------------------------------------------------|---------------------------------------|-----------------------------------|
|                              | Units  | Maximum       | Minimum | Note                                                           | SERVICE :                             | INTERMITTENT                      |
| LIQUID TYPE OR NAME :        | Water  |               |         | Max & min<br>values refer<br>only to the<br>property<br>listed | • IF INTERMITTENT NO. OF STARTS :     |                                   |
| VAPOR PRESSURE :             | bara   | 0.0087        | 0.1219  |                                                                | PUMPS OPERATE IN:                     |                                   |
| DENSITY :                    | kg/m³  | 997           |         |                                                                | CORROSION DUE TO : (6.12.1.9)         |                                   |
| SPECIFIC HEAT :              | kJ/kgC | 4.186         |         |                                                                | EROSION DUE TO : (6.12.1.9)           |                                   |
| VISCOSITY :                  | cP     | 1             |         |                                                                | H2S CONCENTRATION (ppm) : (6.12.1.12) | N.A.                              |
| OPERATING CONDITIONS (6.1.2) |        |               |         |                                                                | CHLORIDE CONCENTRATION (ppm) :        |                                   |
|                              | Units  | Maximum       | Rated   | Normal                                                         | Min                                   | PARTICULATE SIZE (DIA IN MICRONS) |
| NPSH <sub>A</sub> Datum:     |        | C.L. Impeller |         |                                                                |                                       | PARTICULATE CONCENTRATION (PPM)   |
| PUMPING TEMPERATURE :        | °C     | 50            |         |                                                                | 5                                     |                                   |
| FLOW :                       | m³/hr  |               | 15.0    |                                                                |                                       |                                   |
| DISCHARGE PRESSURE :(6.3.2)  | barg   |               | 10.4    |                                                                |                                       |                                   |
| SUCTION PRESSURE :           | barg   | 0.83          | 0.81    |                                                                | 0.08                                  |                                   |
| DIFFERENTIAL PRESSURE :      | bar    |               | 10.3    |                                                                |                                       |                                   |
| DIFFERENTIAL HEAD :          | m      |               | 105.0   |                                                                |                                       |                                   |
| NPSH <sub>A</sub> :          | m      |               | 8.8     |                                                                |                                       |                                   |
| HYDRAULIC POWER:             | KW     |               | 4.50    |                                                                |                                       |                                   |

## SITE AND UTILITY DATA

|                                  |               |                         |                          |
|----------------------------------|---------------|-------------------------|--------------------------|
| LOCATION:                        |               |                         |                          |
| OUTDOOR                          | UNHEATED      | UNDER ROOF              |                          |
| MOUNTED AT:                      |               | ● TROPICALISATION REQ'D |                          |
| ELECTRIC AREA CLASSIFICATION:    |               | (6.1.22)                | ZONE <u>SAFE</u>         |
| GROUP                            |               | TEMP CLASS              |                          |
| SITE DATA:                       |               |                         |                          |
| ELEVATION (MSL):                 | <u>12.5</u> m | BAROMETER:              | <u>990.77</u> mBar       |
| RANGE OF DESIGN TEMPS: MIN / MAX |               | <u>5</u>                | <u>85</u> °C             |
| RELATIVE HUMIDITY: MIN / MAX     |               | <u>0</u>                | <u>100</u> % (@ 25.6 °C) |
| UNUSUAL CONDITIONS:              |               | <u>NA</u>               |                          |
| UTILITY CONDITIONS:              |               |                         |                          |
| ELECTRICITY:                     | DRIVERS       | HEATING                 | CONTROL                  |
| VOLTAGE                          | <u>400</u>    |                         | SHUTDOWN                 |
| PHASE                            | <u>3</u>      |                         |                          |
| HERTZ                            | <u>50</u>     |                         |                          |

|                                       |  |         |         |
|---------------------------------------|--|---------|---------|
| COOLING WATER :                       |  | RETURN  | DESIGN  |
| TEMP                                  |  |         |         |
| PRESS.                                |  |         |         |
| SOURCE                                |  |         |         |
| COOLING WATER CHLORIDE CONCENTRATION: |  |         |         |
| INSTRUMENT AIR :                      |  | kg      | MIN     |
| STEAM                                 |  |         | kg      |
|                                       |  | DRIVERS | HEATING |
| TEMP                                  |  |         |         |
| PRESS.                                |  |         |         |

## PERFORMANCE


|                                              |       |         |      |            |      |      |       |             |
|----------------------------------------------|-------|---------|------|------------|------|------|-------|-------------|
| PROPOSAL CURVE NO.                           |       | KP 2532 | RPM  | 2950       |      |      |       |             |
| As Tested Curve No.                          |       |         |      | KP 2532    |      |      |       |             |
| IMPELLER DIA.:                               | RATED | 286     | MAX. | 324        | MIN. | 250  | mm    |             |
| RATED POWER                                  |       | 14.8    | Kw   | EFFICIENCY |      | 29   | (%)   |             |
| RATED CURVE BEP FLOW (at rated impeller dia) |       |         |      |            |      |      | m³/hr |             |
| MIN FLOW :                                   |       |         |      |            |      |      | 5.7   | m³/hr       |
| PREFERRED OPERATING REGION (6.1.11)          |       |         |      | 13.3       | to   | 22.8 | m³/hr |             |
| ALLOWABLE OPERATING REGION                   |       |         |      | 5.7        | to   | 22.8 | m³/hr |             |
| MAX HEAD @ RATED IMPELLER                    |       |         |      | 119        |      |      |       | m           |
| MAX POWER @ RATED IMPELLER                   |       |         |      | 16.8       |      |      |       | kW          |
| NPSH3 AT RATED FLOW :                        |       |         |      | 1.5        |      |      |       | m           |
| CL PUMP TO U/S BASEPLATE                     |       |         |      |            |      |      |       | m           |
| NPSH MARGIN AT RATED FLOW :                  |       |         |      | 7.3        |      |      |       | m           |
| SPECIFIC SPEED (6.1.9)                       |       |         |      |            |      |      |       |             |
| SUCTION SPECIFIC SPEED LIMIT                 |       |         |      |            |      |      |       |             |
| SUCTION SPECIFIC SPEED                       |       |         |      | 9502       |      |      |       |             |
| MAX. ALLOW. SOUND PRESS. LEVEL REQD (6.1.14) |       |         |      | 85         |      |      |       | (dBA) @ 1 m |
| EST MAX SOUND PRESS. LEVEL                   |       |         |      | 85         |      |      |       | (dBA)       |
| MAX. SOUND POWER LEVEL REQD (6.1.14)         |       |         |      |            |      |      |       |             |
| EST MAX SOUND POWER LEVEL                    |       |         |      |            |      |      |       |             |

**DRIVER (7.1.5) (NOTES 11,20,17)**

|                                              |                 |                                   |               |
|----------------------------------------------|-----------------|-----------------------------------|---------------|
| Driver Type                                  |                 | <b>INDUCTION MOTOR</b>            |               |
| GEAR                                         |                 | <b>NO</b>                         |               |
| VARIABLE SPEED REQUIRED                      |                 | <b>NO</b>                         |               |
| SOURCE OF VARIABLE SPEED                     |                 |                                   |               |
| OTHER                                        |                 |                                   |               |
| MANUFACTURER                                 |                 |                                   |               |
| NAMEPLATE POWER                              | @Site Condition | <b>18.5</b>                       | KW            |
| Nominal RPM                                  |                 | <b>2950</b>                       |               |
| RATED LOAD RPM                               |                 |                                   |               |
| FRAME OR MODEL                               |                 |                                   |               |
| ORIENTATION                                  |                 | <b>HORIZONTAL</b>                 |               |
| LUBE                                         |                 | <b>Grease</b>                     |               |
| BEARING TYPE:                                |                 |                                   |               |
| RADIAL                                       |                 | <b>Ball / 1</b>                   |               |
| THRUST                                       |                 | <b>Ball / 1</b>                   |               |
| STARTING METHOD                              |                 | <b>D.O.L /Open delivery valve</b> |               |
| SEE DRIVER DATA SHEET                        |                 |                                   | <b>Note 1</b> |
| Max Voltage Variation                        |                 | <b>±5%</b>                        |               |
| Max Frequency Variation                      |                 | <b>±2%</b>                        |               |
| Max Voltage and Frequency Variation together |                 | <b>±5%</b>                        |               |







DATA SHEETS (W/PERFORMANCE CURVE) FOR FIRE WATER JOCKEY PUMPS

• 03-073-9184


شماره صفحه: ۸ از ۱۰

CENTRIFUGAL PUMP DATA SHEET (SI UNIT) - P-2302 A/B (Sheet 5 of 6)

| SURFACE PREPARATION AND PAINT                                                 |  |  |  |  |  | TEST                                                                     |  |  |  |                 |
|-------------------------------------------------------------------------------|--|--|--|--|--|--------------------------------------------------------------------------|--|--|--|-----------------|
| MANUFACTURER'S STANDARD                                                       |  |  |  |  |  | SHOP INSPECTION (8.1.1)                                                  |  |  |  | YES             |
| OTHER (SEE BELOW)                                                             |  |  |  |  |  | PERFORMANCE CURVE                                                        |  |  |  |                 |
| SPECIFICATION NO. BK-GNRAL-PEDCO-000-PI-SP-0006, "Specification for Painting" |  |  |  |  |  | & DATA APPROVAL PRIOR TO SHIPMENT.                                       |  |  |  | YES             |
| PUMP:                                                                         |  |  |  |  |  | TEST WITH SUBSTITUTE SEAL (8.3.3.2.b)                                    |  |  |  |                 |
| PUMP SURFACE PREPARATION SA 2 1/2                                             |  |  |  |  |  | MATERIAL CERTIFICATION REQUIRED CASING                                   |  |  |  | YES             |
| PRIMER AS PER PROJECT PAINTING SPEC.                                          |  |  |  |  |  | SHAFT YES (6.12.1.8) IMPELLER                                            |  |  |  | YES             |
| FINISH COAT AS PER PROJECT PAINTING SPEC.                                     |  |  |  |  |  | OTHER YES Casing and impeller Wear ring                                  |  |  |  |                 |
| BASEPLATE:                                                                    |  |  |  |  |  | CASTING REPAIR WELD PROCEDURE APPR REQD                                  |  |  |  | YES             |
| BASEPLATE SURFACE PREPARATION SA 2 1/2                                        |  |  |  |  |  | INSPECTION REQUIRED FOR CONNECTION WELDS (6.12.3.4.d) KPC:NOT APPLICABLE |  |  |  |                 |
| PRIMER: AS PER PROJECT PAINTING SPEC.                                         |  |  |  |  |  | LIQUID PENETRANT YES                                                     |  |  |  | MAG PARTICLE    |
| FINISH COAT AS PER PROJECT PAINTING SPEC.                                     |  |  |  |  |  | ULTRASONIC                                                               |  |  |  | RADIOGRAPHY YES |
| DETAILS OF LIFTING DEVICES                                                    |  |  |  |  |  | INSPECTION REQUIRED FOR CASTINGS                                         |  |  |  |                 |
| SHIPMENT: (8.4.1) EXPORT                                                      |  |  |  |  |  | LIQUID PENETRANT YES                                                     |  |  |  | MAG PARTICLE NO |
| EXPORT BOXING REQUIRED YES                                                    |  |  |  |  |  | ULTRASONIC (NOTE 18) YES                                                 |  |  |  | RADIOGRAPHY     |
| OUTDOOR STORAGE MORE THAN 6 MONTHS YES                                        |  |  |  |  |  | HARDNESS TEST REQUIRED (8.2.2.7)                                         |  |  |  |                 |
| SPARE ROTOR ASSEMBLY PACKAGED FOR:                                            |  |  |  |  |  | ADDNL SUBSURFACE EXAMINATION (6.12.1.5) (8.2.1.3)                        |  |  |  |                 |
| ROTOR STORAGE ORIENTATION (9.2.8.2)                                           |  |  |  |  |  |                                                                          |  |  |  | FOR             |
| SHIPPING & STORAGE CONTAINER FOR VERT STORAGE (9.2.8.3)                       |  |  |  |  |  |                                                                          |  |  |  | METHOD          |
| N <sub>2</sub> PURGE (9.2.8.4)                                                |  |  |  |  |  |                                                                          |  |  |  |                 |
| SPARE PARTS                                                                   |  |  |  |  |  | PMI TESTING REQUIRED (8.2.2.8)                                           |  |  |  |                 |
| START-UP YES                                                                  |  |  |  |  |  | COMPONENTS TO BE TESTED                                                  |  |  |  |                 |
| NORMAL MAINTENANCE YES                                                        |  |  |  |  |  | RESIDUAL UNBALANCE TEST (J.4.1.2)                                        |  |  |  |                 |
|                                                                               |  |  |  |  |  | NOTIFICATION OF SUCCESSFUL SHOP                                          |  |  |  | YES             |
|                                                                               |  |  |  |  |  | PERFORMANCE TEST (8.1.1.c) (8.3.3.5)                                     |  |  |  | YES             |
|                                                                               |  |  |  |  |  | BASEPLATE TEST (7.3.21)                                                  |  |  |  |                 |
|                                                                               |  |  |  |  |  | HYDROSTATIC                                                              |  |  |  | WIT             |
|                                                                               |  |  |  |  |  | HYDROSTATIC TEST OF BOWLS & COLUMN (9.3.13.2)                            |  |  |  |                 |
|                                                                               |  |  |  |  |  | PERFORMANCE TEST                                                         |  |  |  | WIT             |
|                                                                               |  |  |  |  |  | TEST IN COMPLIANCE WITH (8.3.3.2)                                        |  |  |  | NFPA 20         |
|                                                                               |  |  |  |  |  | TEST DATA POINTS TO (8.3.3.3)                                            |  |  |  | NFPA 20         |
|                                                                               |  |  |  |  |  | TEST TOLERANCES TO (8.3.3.4)                                             |  |  |  | TABLE 16        |
|                                                                               |  |  |  |  |  | NPSH (8.3.4.3.1) (8.3.4.3.4) (NOTE 6)                                    |  |  |  | WIT             |
|                                                                               |  |  |  |  |  | NPSH-1ST STG ONLY (8.3.4.3.2)                                            |  |  |  |                 |
|                                                                               |  |  |  |  |  | NPSH TESTING TO HI 1.6 OR ISO 9906 (8.3.4.3.3)                           |  |  |  |                 |
|                                                                               |  |  |  |  |  | TEST NPSHA LIMITED TO 110% SITE NPSHA (8.3.3.6)                          |  |  |  |                 |
|                                                                               |  |  |  |  |  | RETEST ON SEAL LEAKAGE (8.3.3.2.d)                                       |  |  |  | OBSERVE         |
|                                                                               |  |  |  |  |  | RETEST REQUIRED AFTER FINAL HEAD ADJ (8.3.3.7.b)                         |  |  |  |                 |
|                                                                               |  |  |  |  |  | COMPLETE UNIT TEST (8.3.4.4.1)                                           |  |  |  | WIT             |
|                                                                               |  |  |  |  |  | SOUND LEVEL TEST (8.3.4.5)                                               |  |  |  | WIT             |
|                                                                               |  |  |  |  |  | CLEANLINESS PRIOR TO FINAL ASSEMBLY (8.2.2.6)                            |  |  |  | OBSERVE         |
|                                                                               |  |  |  |  |  | LOCATION OF CLEANLINESS INSPECTION                                       |  |  |  |                 |
|                                                                               |  |  |  |  |  | NOZZLE LOAD TEST                                                         |  |  |  |                 |
|                                                                               |  |  |  |  |  | CHECK FOR CO-PLANAR MOUNTING PAD SURFACES                                |  |  |  |                 |
|                                                                               |  |  |  |  |  | MECHANICAL RUN TEST UNTIL OIL TEMP STABLE                                |  |  |  |                 |
|                                                                               |  |  |  |  |  | 4 HR. MECH RUN AFTER OIL TEMP STABLE (8.3.4.2.1)                         |  |  |  | WIT             |
|                                                                               |  |  |  |  |  | 4 HR. MECH RUN TEST (8.3.4.2.2)                                          |  |  |  |                 |
|                                                                               |  |  |  |  |  | BRG HSG RESONANCE TEST (8.3.4.7)                                         |  |  |  |                 |
|                                                                               |  |  |  |  |  | STRUCTURAL RESONANCE TEST (9.3.9.2)                                      |  |  |  |                 |
|                                                                               |  |  |  |  |  | REMOVE / INSPECT HYDRODYNAMIC BEARINGS AFTER TEST (9.2.7.5)              |  |  |  |                 |
|                                                                               |  |  |  |  |  | AUXILIARY EQUIPMENT TEST (8.3.4.6)                                       |  |  |  |                 |
|                                                                               |  |  |  |  |  | EQUIPMENT TO BE INCLUDED IN AUXILIARY TESTS                              |  |  |  |                 |
|                                                                               |  |  |  |  |  | LOCATION OF AUXILIARY EQUIPMENT TEST                                     |  |  |  |                 |
|                                                                               |  |  |  |  |  | IMPACT TEST PER EN 13445                                                 |  |  |  |                 |
|                                                                               |  |  |  |  |  | REMOVE CASING AFTER TEST PER ASME SECTION VIII                           |  |  |  |                 |

| ITEM No | PUMP | DRIVER | GEAR | BASE | TOTAL |
|---------|------|--------|------|------|-------|
|         |      |        |      |      |       |
|         |      |        |      |      |       |
|         |      |        |      |      |       |

| OTHER PURCHASER REQUIREMENTS                               |  |  |  |  |  |
|------------------------------------------------------------|--|--|--|--|--|
| COORDINATION MEETING REQUIRED (10.1.3) YES                 |  |  |  |  |  |
| MAXIMUM DISCHARGE PRESSURE TO INCLUDE                      |  |  |  |  |  |
| OPERATION TO TRIP SPEED                                    |  |  |  |  |  |
| MAX DIA. IMPELLERS AND/OR NO OF STAGES YES                 |  |  |  |  |  |
| CONNECTION DESIGN APPROVAL (9.2.1.4) YES                   |  |  |  |  |  |
| TORSIONAL ANALYSIS / REPORT (6.9.2.10) NO                  |  |  |  |  |  |
| PROGRESS REPORTS YES                                       |  |  |  |  |  |
| OUTLINE OF PROC FOR OPTIONAL TESTS (10.2.5)                |  |  |  |  |  |
| ADDITIONAL DATA REQUIRING 20 YEARS RETENTION (8.2.1.1) YES |  |  |  |  |  |
| LATERAL ANALYSIS REQUIRED (9.1.3.4) (9.2.4.1.3) NO         |  |  |  |  |  |
| MODAL ANALYSIS REQUIRED (9.3.9.2)                          |  |  |  |  |  |
| DYNAMIC BALANCE ROTOR (6.9.4.4) YES                        |  |  |  |  |  |
| INSTALLATION LIST IN PROPOSAL (10.2.3.1) YES               |  |  |  |  |  |
| VFD STEADY STATE DAMPED RESPONSE ANALYSIS (6.9.2.3) NO     |  |  |  |  |  |
| TRANSIENT TORSIONAL RESPONSE NO                            |  |  |  |  |  |
| BEARING LIFE CALCULATIONS REQUIRED (6.10.1.6)              |  |  |  |  |  |
| IGNITION HAZARD ASSMT TO EN 13463-1 (7.2.13.e)             |  |  |  |  |  |
| CASING RETIREMENT THICKNESS DRAWING (10.3.2.3)             |  |  |  |  |  |
| FLANGES RQD IN PLACE OF SKT WELD UNIONS (7.5.2.8)          |  |  |  |  |  |
| INCLUDE PLOTTED VIBRATION SPECTRA (6.9.3.3)                |  |  |  |  |  |
| CONNECTION BOLTING (7.5.1.7)                               |  |  |  |  |  |
| CADMIUM PLATED BOLTS PROHIBITED                            |  |  |  |  |  |
| VENDOR TO KEEP REPAIR AND HT RCDS (8.2.1.1.c)              |  |  |  |  |  |
| VENDOR SUBMIT TEST PROCEDURES (8.3.1.1) YES                |  |  |  |  |  |
| SUBMIT INSPECTION CHECK LIST (8.1.5) NOTE 2 YES            |  |  |  |  |  |



شماره پیمان:

• 03-073-9184

## DATA SHEETS (W/PERFORMANCE CURVE) FOR FIRE WATER JOCKEY PUMPS

| نسخه | سریال | نوع مدرک | رشته | تسهیلات | صادرکننده | بسته کاری | پروژه |
|------|-------|----------|------|---------|-----------|-----------|-------|
| V00  | 0003  | DS       | ME   | 120     | KP        | GCS       | BK    |

شماره صفحه: ۹ از ۱۰

## CENTRIFUGAL PUMP DATA SHEET (SI UNIT) - P-2302 A/B (Sheet 6 of 6)

## PRESSURE VESSEL DESIGN CODE REFERENCES

THESE REFERENCES MUST BE LISTED BY THE MANUFACTURER

CASTING FACTORS USED IN DESIGN ( TABLE 3)

SOURCE OF MATERIAL PROPERTIES

## WELDING AND REPAIRS (NOTE 15)

THESE REFERENCES MUST BE LISTED BY THE PURCHASER. (DEFAULT TO TABLE 11 IF NO PURCHASER PREFERENCE IS STATED)

## ALTERNATE WELDING CODES AND STANDARDS

WELDING REQUIREMENT (APPLICABLE CODE OR STANDARD)

DEFAULT PER TABLE 11

WELDER/OPERATOR QUALIFICATION

DEFAULT PER TABLE 11

WELDING PROCEDURE QUALIFICATION

DEFAULT PER TABLE 11

#### NON-PRESSURE RETAINING STRUCTURAL WELDING SUCH AS BASEPLATES OR SUPPORTS

DEFAULT PER TABLE 11

MAGNETIC PARTICLE OR LIQUID PENETRANT EXAMINATION OF PLATE EDGES

DEFAULT PER TABLE 11

#### POSTWELD HEAT TREATMENT

DEFAULT PER TABLE 11

POSTWELD HEAT TREATMENT OF CASING FABRICATION WELDS

DEFAULT PER TABLE 11

## MATERIAL INSPECTION

THESE REFERENCES MUST BE LISTED BY THE PURCHASER

DEFAULT TO TABLE 14

**YES**

ALTERNATIVE MATERIAL INSPECTIONS AND ACCEPTANCE CRITERIA (SEE TABLE 15) (8.2.2.5)

| TYPE OF INSPECTION               | METHOD | FOR FABRICATIONS | FOR CASTINGS |
|----------------------------------|--------|------------------|--------------|
| RADIOGRAPHY                      |        |                  |              |
| ULTRASONIC INSPECTION            |        |                  |              |
| MAGNETIC PARTICLE INSPECTION     |        |                  |              |
| LIQUID PENETRANT INSPECTION      |        |                  |              |
| VISUAL INSPECTION (all surfaces) |        |                  |              |

REMARKS :



# KALAYE PUMP CO.

## Performance curve



|                       |            |                     |        |                         |      |
|-----------------------|------------|---------------------|--------|-------------------------|------|
| Item No.              | P-2302 A/B | Pump Model          | KP2532 | Flow, Rated ( $m^3/h$ ) | 15   |
| Liquid                | WATER      | Speed (rpm)         | 2950   | Head (m)                | 105  |
| Temp. ( $^{\circ}C$ ) | 50         | Rated Imp.Dia. (mm) | 286    | Efficiency (%)          | 29   |
| Density( $kg/m^3$ )   | 997        | Suction Size (Inch) | 2      | NPSHR (m)               | 1.5  |
| Viscosity (cp)        | 1          | Disch. Size (Inch)  | 1      | Rated Power (kw)        | 14.8 |
| NPSHA (m)             | 8.8        | NSS (m /h,m,rpm)    | 9502   | Motor Power (kw)        | 18.5 |

