



خرید پکیج پمپ های آب آتشنشانی ایستگاه تقویت فشار گاز بینک (BK-HD-GCS-CO-0023_00

شماره پیمان:

· ۵۳ - · ۷۳ - 9114

	MECHANICAL RUNNING TEST PROCEDURE							
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه	
BK	GCS	KP	120	QC	PR	0006	V00	

شماره صفحه: 1 از **5**

طرح نگهداشت و افزایش تولید ۲۷ مخزن

MECHANICAL RUNNING TEST PROCEDURE

نگهداشت و افزایش تولید میدان نفتی بینک

Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval
V00	NOV. 2024	IFA	Kalaye Pump	M.Fakharian	M.Sadeghian	

Status:

IFA: Issued for Approval
IFI: Issued for Information
AFC: Approved for Construction



ّ خرید



خرید پکیج پمپ های آب آتشنشانی ایستگاه تقویت فشار گاز بینک (BK-HD-GCS-CO-0023_00

Value Brow Co

پیمان:	شماره
.0414 - 114	

MECHANICAL RUNNING TEST PROCEDURE							
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سر يال	نسخه
BK	GCS	KP	120	QC	PR	0006	V00

شماره صفحه: 2 از 5

REVISION RECORD SHEET

REVIS							
PAGE	V00	V01	V02	V03	V04		
1	Х						
2	X						
3	X						
<u>4</u> 5	X						
6							
7							
8							
9 10							
11							
12							
13							
14							
15 16							
17							
18							
19							
20							
21 22							
23							
24							
25							
26							
27							
28 29							
30							
31							
32							
33							
34							
35 36							
37							
38							
39							
40							
41							
42 43							
44							
45							
46	 						
47	 						
<u>48</u>	<u> </u>						
<u>49</u> 50							
51							
52							
53	1						
54 55	+						
55 56							
57							
58							
59							
60	1						
61	+						
62 63							
64							
65							

66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 108 109 110 111	
68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
69 70 71 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
70 71 71 72 73 74 75 76 77 78 79 80 81 81 82 83 84 85 86 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
71 72 73 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
72 73 74 75 76 77 78 79 80 80 81 81 82 83 84 85 86 87 88 89 90 91 92 93 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111	
73 74 75 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111	
74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 91 92 93 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
78 79 80 81 81 82 83 84 85 86 87 88 89 90 91 91 92 93 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
79 80 81 81 82 83 84 85 86 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
80 81 82 83 84 85 86 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
84 85 86 87 88 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
86 87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
87 88 89 90 91 91 92 93 94 95 96 97 98 99 100 101 101 102 103 104 105 106 107 108 109 110	
88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
96 97 98 99 100 101 102 103 104 105 106 107 108 109 110	
97 98 99 100 101 102 103 104 105 106 107 108 109 110	
98 99 100 101 102 103 104 105 106 107 108 109 110	
99 100 101 102 103 104 105 106 107 108 109 110	
100 101 102 103 104 105 106 107 108 109 110	
101 102 103 104 105 106 107 108 109 110	
102 103 104 105 106 107 108 109 110	
103 104 105 106 107 108 109 110	
104 105 106 107 108 109 110	
105 106 107 108 109 110	
106 107 108 109 110 111	
107 108 109 110 111	
108 109 110 111	
109 110 111	
110	
111	
112	
113	
114	
115	
116	
117	
118	
119	
120	
121	
122	
123	
124	
125	
126	
127	
128	
129	
130	







، پیمان:	شمارد
----------	-------

. 22 - . 22 - 174

MECHANICAL RUNNING TEST PROCEDURE									
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه		
BK	GCS	KP	120	QC	PR	0006	V00		

 شماره صفحه: 3 از 5

1.0 INTRODUCTION

Binak oilfield in Bushehr province is a part of the southern oilfields of Iran, is located 20 km northwest of Genaveh city.

With the aim of increasing production of oil from Binak oilfield, an EPC/EPD Project has been defined by NIOC/NISOC and awarded to Petro Iran Development Company (PEDCO). Also, PEDCO (as General Contractor) has assigned the EPC-packages of the Project to "Hirgan Energy - Design and Inspection" JV.

2.0 GENERAL DEFINITION

The following terms shall be used in this document.

CLIENT: National Iranian South Oilfields Company

(NISOC)

PROJECT: Binak Oilfield Development – Supply Of Fire

Water Pumps

EPD/EPC CONTRACTOR (GC): Petro Iran Development Company (PEDCO)

EPC CONTRACTOR/PURCHASER: Joint Venture of: Hirgan Energy - Design &

Inspection (D&I) Companies

VENDOR: Kalaye Pump Company

EXECUTOR: Executor is the party which carries out all or part

of construction and/or commissioning for the

project.

TPI: Third Party Inspector.

SHALL: Is used where a provision is mandatory.

SHOULD: Is used where a provision is advisory only.

WILL: Is normally used in connection with the action by

CLIENT rather than by an EPC/EPD

CONTRACTOR, supplier or VENDOR.

MAY: Is used where a provision is completely

discretionary.

3.0 SCOPE

This executive method aims to illustrate the way of the test and testing manufactured/repaired pumps in the factory to achieve assurance about their alignment to those determined characteristics as well as their quality.



خرید پکیج پمپ های آب آتشنشانی ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0023_00)



ىىمان:	شماده
ييس .	سسارت

· 24 - · 74 - 4114

MECHANICAL RUNNING TEST PROCEDURE								
پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه	
BK	GCS	KP	120	QC	PR	0006	V00	

 شماره صفحه : 4 از 5

4.0 USAGE DOMAIN

The usage domain of this executive instruction includes all projects of Kalay-E-Pump Company and other common productions.

5.0 LIABILITIES

The quality control director is responsible for executing this instruction, furthermore product supervisor and technical office representative are present in the examination (Test) steps entirely, as auditors.

6.0 REFERENCES

The testing operation of pumps/Electro pumps/Diesel Pumps belonging to Kalay-E-Pump Company is accomplished based on derivate tests of creditable global collected standards for centrifugal and firefighting pumps and gathered movements. (API 610, NFPA 20)

7.0 PROCEEDING DESCRIPTION

The running test (including bearing temperature test, vibration test, noise level test) for all project pumps is carried out according to API 610 and this procedure as well as customer project documents."

8.0 MECHANICAL RUNNING TEST

This provides a unified test procedure for each mechanical running test. After the test, a report shall be issued by the testbed and controlled by this procedure.

- 8.1.1. The pump shall be mechanically run for 4 hours unless otherwise specified or agreed, this run shall be performed at rated flow.
- 8.1.2. The pump shall be run on the test stand until oil temperature stabilization has been achieved. (if any)
- 8.1.3. Test Condition
- 8.1.3.1. Test fluid is clean water.
- 8.1.3.2. The following meters can be used for testing.

Flowmeter, laser thermometer, digital photo-optical speed counter, vibration meter in mm/s RMS unit, photometer for noise level.

- 8.1.3.3. Unless otherwise specified, the seal specified in the contract shall be used in the pump for testing. (for mechanical seal pumps)
- 8.1.4. Test items are :







.04 - .14 - 114

MECHANICAL RUNNING TEST PROCEDURE								
پروژه	بسته کاری	صادركننده	تسهيلات	رشته	نوع مدرك	سريال	نسخه	
BK	GCS	KP	120	QC	PR	0006	V00	

5 : از 5 از 5

8.1.4.1. Vibration of pump bearing in horizontal & vertical direction. Vibration must be according to Table 8 of API 610, 11th edition.

Note: For diesel pumps, the vibration test is not applicable.

- 8.1.4.2. Temperature of pump bearings.
- 8.1.4.3. Speed of pump shaft.
- 8.1.4.4. Noise level at 1meter distance around of package.
- 8.1.4.5. Leakage by visual checking from the mechanical seal.

Mentioned items shall be recorded each 1 hour.

Note: For diesel pumps, the sound level test is not applicable.

- 8.1.5 . Acceptable Factors
- 8.1.5.1 .If it is no leakage by visual checking, a mechanical seal is acceptable. Dripping leakage is acceptable for a soft packing seal.
- 8.1.5.2 .Noise level of pump set shall be lower than 85dB under rated flow in 1 meter distance and 1.5 m above ground.
- 8.1.5.3. Vibration must be according to table 8 of API 610 11th edition.
- 8.1.5.4 .For ring-oiled or splash systems and grease lubricated bearings, an oil temperature below 82°C (180°F) during shop testing is acceptable. The sump oil temperature rise shall not exceed 40°K (70°R) above the ambient temperature in the test cell measured at the time of each reading and if bearing temperature sensors are supplied outer ring temperature shall not exceed 93°C (200° F).