

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							 	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 1 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009	V00	

طرح نگهداشت و افزایش تولید 27 مخزن

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

نگهداشت و افزایش تولید میدان نفتی بینک

V00	DEC. 2024	IFI	MFS	M.Fakharian	S.Faramarzpour	
Rev.	Date	Purpose of Issue/Status	Prepared by:	Checked by:	Approved by:	CLIENT Approval

Status:

IFA: Issued For Approval
IFI: Issued For Information
AFC: Approved For Construction

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 - 073 - 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 2 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	V00

REVISION RECORD SHEET

PAGE	V00	V01	V02	V03	V04
1	X				
2	X				
3	X				
4	X				
5	X				
6	X				
7	X				
8	X				
9	X				
10	X				
11	X				
12	X				
13	X				
14	X				
15	X				
16	X				
17	X				
18	X				
19	X				
20	X				
21	X				
22	X				
23	X				
24	X				
25	X				
26	X				
27	X				
28	X				
29	X				
30	X				
31	X				
32	X				
33	X				
34	X				
35	X				
36	X				
37	X				
38	X				
39	X				
40	X				
41	X				
42	X				
43	X				
44	X				
45	X				
46	X				
47	X				
48	X				
49	X				
50	X				
51	X				
52	X				
53	X				
54	X				
55	X				
56	X				
57	X				
58	X				
59	X				
60	X				
61	X				
62	X				
63	X				
64	X				
65	X				

PAGE	V00	V01	V02	V03	V04
66	X				
67	X				
68	X				
69	X				
70	X				
71	X				
72	X				
73	X				
74	X				
75	X				
76	X				
77	X				
78	X				
79	X				
80	X				
81	X				
82	X				
83	X				
84	X				
85	X				
86	X				
87	X				
88	X				
89	X				
90	X				
91	X				
92	X				
93	X				
94	X				
95	X				
96	X				
97	X				
98	X				
99	X				
100	X				
101	X				
102	X				
103	X				
104	X				
105	X				
106	X				
107	X				
108	X				
109	X				
110	X				
111	X				
112	X				
113	X				
114	X				
115	X				
116	X				
117	X				
118	X				
119	X				
120	X				
121	X				
122	X				
123	X				
124	X				
125	X				
126	X				
127	X				
128	X				
129	X				
130	X				

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 - 073 - 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 3 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	V00

PAGE	V00	V01	V02	V03	V04
131	X				
132	X				
133	X				
134	X				
135	X				
136	X				
137	X				
138	X				
139	X				
140	X				
141	X				
142	X				
143	X				
144	X				
145	X				
146	X				
147	X				
148	X				
149	X				
150	X				
151	X				
152	X				
153	X				
154	X				
155	X				
156	X				
157	X				
158	X				
159	X				
160	X				
161	X				
162	X				
163	X				
164	X				
165	X				
166	X				
167	X				
168	X				
169	X				
170	X				
171	X				
172	X				
173	X				
174	X				
175	X				
176	X				
177	X				
178	X				
179	X				
180	X				
181	X				
182	X				
183	X				
184	X				
185	X				
186	X				
187	X				
188	X				
189	X				
190	X				
191	X				
192	X				
193	X				
194	X				
195	X				

PAGE	V00	V01	V02	V03	V04
196	X				
197	X				
198	X				
199	X				
200	X				
201	X				
202	X				
203	X				
204	X				
205	X				
206	X				
207	X				
208	X				
209	X				
210	X				
211	X				
212	X				
213	X				
214	X				
215	X				
216	X				
217	X				
218	X				
219	X				
220	X				
221	X				
222	X				
223	X				
224	X				
225	X				
226	X				
227	X				
228	X				
229	X				
230	X				
231	X				
232	X				
233	X				
234	X				
235	X				
236	X				
237	X				
238	X				
239	X				
240	X				
241	X				
242	X				
243	X				
244	X				
245	X				
246	X				
247	X				
248	X				
249	X				
250	X				
251	X				
252	X				
253	X				
254	X				
255	X				
256	X				
257	X				
258	X				
259	X				
260	X				

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 - 073 - 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 4 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	V00

PAGE	V00	V01	V02	V03	V04
261	X				
262	X				
263	X				
264	X				
265	X				
266	X				
267	X				
268	X				
269	X				
270	X				
271	X				
272	X				
273	X				
274	X				
275	X				
276	X				
277	X				
278	X				
279	X				
280	X				
281	X				
282	X				
283	X				
284	X				
285	X				
286	X				
287	X				
288	X				
289	X				
290	X				
291	X				
292	X				
293	X				
294	X				
295	X				
296	X				
297	X				
298	X				
299	X				
300	X				
301	X				
302	X				
303	X				
304	X				
305	X				
306	X				
307	X				
308	X				
309	X				
310	X				
311	X				
312	X				
313	X				
314	X				
315	X				
316	X				
317	X				
318	X				
319	X				
320	X				
321	X				
322	X				
323	X				
324	X				
325	X				

PAGE	V00	V01	V02	V03	V04
326	X				
327	X				
328	X				
329	X				
330	X				
331	X				
332	X				
333	X				
334	X				
335	X				
336	X				
337	X				
338	X				
339	X				
340	X				
341	X				
342	X				
343	X				
344	X				
345	X				
346	X				
347	X				
348	X				
349	X				
350	X				
351	X				
352	X				
353	X				
354	X				
355	X				
356	X				
357	X				
358	X				
359	X				
360	X				
361	X				
362	X				
363	X				
364	X				
365	X				
366	X				
367	X				
368	X				
369	X				
370	X				
371	X				
372	X				
373	X				
374	X				
375	X				
376	X				
377	X				
378	X				
379	X				
380	X				
381	X				
382	X				
383	X				
384	X				
385	X				
386	X				
387	X				
388	X				
389	X				
390	X				

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 6 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه										
	BK	GCS	MF	120	ME	CN	0009	V00										

Table of Contents

Cover Sheet.....	8
Vessel Design Summary:.....	9
Nozzle Summary:.....	13
Nozzle Schedule & BOM:.....	16
MDMT Summary:.....	20
Warnings and Errors:.....	23
Input Echo:.....	24
XY Coordinate Calculations:.....	41
Flg Calc [Int P]: FLANGE.....	42
Flg Calc [Int P]: FLANGE.....	48
Internal Pressure Calculations:.....	52
External Pressure Calculations:.....	60
Element and Detail Weights:.....	66
Nozzle Flange MAWP:.....	69
Wind Load Calculation:.....	70
Earthquake Load Calculation:.....	73
Center of Gravity Calculation:.....	75
Saddle Calcs: Operating Case:.....	76
Saddle Calcs: Test Case:.....	96
Nozzle Calcs.: N08 (1in)	113
Nozzle Calcs.: N02 (2in)	121
Nozzle Calcs.: N12 (1in)	130
Nozzle Calcs.: M1 (24in)	136
Nozzle Calcs.: N07C (2in)	143
Nozzle Calcs.: N07B (2in)	149
Nozzle Calcs.: K9B (3in)	155
Nozzle Calcs.: K9A (3in)	165
Nozzle Calcs.: K10A (2in)	175
Nozzle Calcs.: K10B (2in)	183
Nozzle Calcs.: K11A (2in)	191
Nozzle Calcs.: K11B (2in)	199
Nozzle Calcs.: K7A (3in)	207
Nozzle Calcs.: K7B (3in)	217
Nozzle Calcs.: N05 (2in)	227
Nozzle Calcs.: K2B (2in)	236
Nozzle Calcs.: K2A (2in)	244
Nozzle Calcs.: K3A (3in)	252
Nozzle Calcs.: K3B (3in)	262
Nozzle Calcs.: N11 (1in)	272
Nozzle Calcs.: M2 (24in)	278

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 7 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Nozzle Calcs.: K8 (2in)	285
Nozzle Calcs.: N04 (6in)	291
Nozzle Calcs.: K1B (2in)	298
Nozzle Calcs.: N07A (2in)	304
Nozzle Calcs.: N09A (1.5in)	310
Nozzle Calcs.: N09B (1.5in)	318
Nozzle Calcs.: K4A (2in)	326
Nozzle Calcs.: K6 (2in)	334
Nozzle Calcs.: K1 (2in)	340
Nozzle Calcs.: N01 (10in)	348
Nozzle Calcs.: N03 (10in)	360
Nozzle Calcs.: Chimney Nozzle.....	367
FEA N03 10INCH:.....	374

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 8 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

DESIGN CALCULATION

In Accordance with ASME Section VIII Division 1

ASME Code Version : 2019

Analysis Performed by :

Job File : C:\USERS\TECHNICAL2\DESKTOP\BINAK\DESIGN\R-100\R

Date of Analysis : Dec 28,2024 10:31am

PV Elite 2020, January 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 9 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

ASME Code, Section VIII Division 1, 2019

Diameter Spec : 1200.000 mm. ID	
Vessel Design Length, Tangent to Tangent	6479.52 mm.
Specified Datum Line Distance	0.00 mm.
Internal Design Temperature	234 °C
Internal Design Pressure	4.100 bars
External Design Temperature	100 °C
External Design Pressure	1.034 bars
Maximum Allowable Working Pressure	5.406 bars
External Max. Allowable Working Pressure	1.404 bars
Hydrostatic Test Pressure	5.330 bars
Required Minimum Design Metal Temperature	5.0 °C
Warmest Computed Minimum Design Metal Temperature	-14.0 °C
Wind Design Code	ASCE-2010
Earthquake Design Code	ASCE 7-2010

Materials of Construction:

Component Type	Material	Class	Thickness	UNS #	Normal ized	Impact Tested
Shell	SA-516 70	...	...	K02700	No	No
Head	SA-516 70	...	...	K02700	No	No
Flange	SA-105	...	...	K03504	No	No
Nozzle	SA-105	...	...	K03504	No	No
Nozzle	SA-516 70	...	...	K02700	No	No
Nozzle	SA-106 B	...	...	K03006	No	No
Re-Pad	SA-516 70	...	...	K02700	No	No
Nozzle Flg	SA-105	...	...	K03504	No	No
Rings	SA-516 70	...	...	K02700	No	No
Flg Bolting	SA-193 B7	...	<= 2 1/2	G41400	No	No
Hrz Bolting	SA-193 B7	...	2 1/2 < t <= 4	G41400	No	No

Normalized is determined based on the UCS-66 material curve selection and Figure UCS-66.

Impact Tested is based on material selection and material data properties.

Element Pressures and MAWP (bars & mm.):

Element Description or Type	Design Pressure + Stat. head	Ext. Press.	Element M.A.W.P	Corrosion Allowance	Str. Flg. Gov.	In Creep Range
Ellipse	4.155	1.03	16.000	3.0000	No	No
Cylinder	4.100	1.03	16.000	3.0000	N/A	No
Cylinder	4.100	1.03	16.000	3.0000	N/A	No
Cylinder	4.100	1.03	16.000	3.0000	N/A	No

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 10 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Cylinder		4.100		1.03		16.000		3.0000		N/A		No	
Body Flg		4.100		1.03		16.000		3.0000		N/A		No	
Body Flg		4.100		1.03		8.000		3.0000		N/A		No	

Liquid Level: 550.00 mm. Dens.: 1019.530 kg/m³ Sp. Gr.: 1.020

Stiffener Ring Specifications:

Elevation mm. Selected Type User Description
3600.00 Bar 100.0 x 15. Ring R1 Fr40

Element Types and Properties:

Element Type	"To" Elev mm.	Element Length mm.	Nominal Thickness mm.	Finished Thickness mm.	Reqd Thk Internal mm.	Reqd Thk External mm.	Long Eff	Circ Eff
Ellipse	50.0	50.0	12.0	10.0	4.8	...	1.00	1.00
Cylinder	1550.0	1500.0	...	10.0	4.8	...	1.00	1.00
Cylinder	3550.0	2000.0	...	10.0	4.8	...	1.00	1.00
Cylinder	5550.0	2000.0	...	10.0	4.8	...	1.00	1.00
Cylinder	6250.0	700.0	...	10.0	4.8	...	1.00	1.00
Body Flg	6410.0	160.0	...	130.0	129.6	...	1.00	1.00
Body Flg	6479.5	60.0	...	60.0	49.9	...	1.00	1.00

External Pressure Calculations:

From	To	External Actual T. mm.	External Required T. mm.	External Design Pressure bars	External M.A.W.P. bars
10	20	10	6.15855	1.034	4.97328
20	30	10	9.22129	1.034	1.4041
30	40	10	9.22129	1.034	1.4041
40	Ring	10	9.22129	1.034	1.4041
Ring	50	10	8.39371	1.034	1.99374
50	60	10	8.39371	1.034	1.99374
60	70	130	129.565	1.034	No Calc
70	80	60	49.8856	1.034	No Calc

External Pressure Calculations:

From	To	Actual Length Bet. Stiffeners mm.	Allowable Length Bet. Stiffeners mm.	Ring Inertia Required cm**4	Ring Inertia Available cm**4
10	20	No Calc	No Calc	No Calc	No Calc
20	30	3700	4945.73	No Calc	No Calc
30	40	3700	4945.73	No Calc	No Calc
40	Ring	3700	4945.73	No Calc	No Calc
Ring	50	2650	4945.66	41.1436	263.43
50	60	2650	4945.66	No Calc	No Calc
60	70	No Calc	No Calc	No Calc	No Calc
70	80	No Calc	No Calc	No Calc	No Calc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 11 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Saddle Parameters:

Saddle Width	150.000	mm.
Saddle Bearing Angle	120.000	deg.
Centerline Dimension	1200.000	mm.
Wear Pad Width	260.000	mm.
Wear Pad Thickness	10.000	mm.
Wear Pad Bearing Angle	145.000	deg.
Distance from Saddle to Tangent	850.000	mm.
Baseplate Length	1200.000	mm.
Baseplate Thickness	15.000	mm.
Baseplate Width	170.000	mm.
Number of Ribs (including outside ribs)	4	
Rib Thickness	15.000	mm.
Web Thickness	15.000	mm.
Height of Center Web	585.000	mm.
Number of Bolts in Baseplate	4	

Baseplate Sketch

----- 1200.000 mm. -----	
	170.000 mm.
-----	-----
Baseplate Plan View	
-----	-----
	15.000 mm.
-----	-----
Baseplate Side View	

Maximum Tensile Bolt Load 2. kN

Summary of Maximum Saddle Loads, Operating Case:

Maximum Vertical Saddle Load	123.00	kN
Maximum Transverse Saddle Shear Load	17.52	kN
Maximum Longitudinal Saddle Shear Load	35.04	kN

Summary of Maximum Saddle Loads, Operating Case, Un-Factored:

Maximum Vertical Saddle Load	148.17	kN
Maximum Transverse Saddle Shear Load	58.73	kN
Maximum Longitudinal Saddle Shear Load	50.05	kN

Summary of Maximum Saddle Loads, Hydrotest Case :

Maximum Vertical Saddle Load	91.95	kN
Maximum Transverse Saddle Shear Load	0.65	kN
Maximum Longitudinal Saddle Shear Load	0.52	kN

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053-073-9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 12 از 411
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Local Stress Analysis Results:

Description	Analysis Type	Max Stress Ratio	High Stress Location	Pass Fail
N02 (2in)	WRC-107/537	0.390	n/a	Passed
N05 (2in)	WRC-107/537	0.390	n/a	Passed
N01 (10in)	WRC-107/537	0.883	n/a	Passed

Weights:

Fabricated - Bare W/O Removable Internals	7113.8	kg.
Shop Test - Fabricated + Water (Full)	14587.8	kg.
Shipping - Fab. + Rem. Intls.+ Shipping App.	9516.8	kg.
Erected - Fab. + Rem. Intls.+ Insul. (etc)	10516.8	kg.
Empty - Fab. + Intls. + Details + Wghts.	10516.8	kg.
Operating - Empty + Operating Liquid (No CA)	10643.0	kg.
Field Test - Empty Weight + Water (Full)	16431.0	kg.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 13 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Nozzle Calculation Summary:

Description	MAWP bars	Ext	MAPNC bars	UG-45	[tr] mm.	Weld Path	Areas or Stresses
N08 (1in)	16	OK	...	OK	4.80	OK	Passed
N08 (1in)	16	OK	...	OK	4.80	OK	Passed
N02 (2in)	16	OK	...	OK	4.80	OK	Passed
N12 (1in)	16	OK	...	OK	4.80	OK	Passed
M1 (24in)	11	OK	...	...		OK	Passed
N07C (2in)	16	OK	...	OK	4.80	OK	Passed
N07B (2in)	16	OK	...	OK	4.80	OK	Passed
K9B (3in)	8	OK	...	OK	4.80	OK	Passed
K9B (3in)	8	OK	...	OK	4.80	OK	Passed
K9A (3in)	8	OK	...	OK	4.80	OK	Passed
K9A (3in)	8	OK	...	OK	4.80	OK	Passed
K10A (2in)	16	OK	...	OK	4.80	OK	Passed
K10A (2in)	16	OK	...	OK	4.80	OK	Passed
K10B (2in)	16	OK	...	OK	4.80	OK	Passed
K10B (2in)	16	OK	...	OK	4.80	OK	Passed
K11A (2in)	16	OK	...	OK	4.80	OK	Passed
K11A (2in)	16	OK	...	OK	4.80	OK	Passed
K11B (2in)	16	OK	...	OK	4.80	OK	Passed
K11B (2in)	16	OK	...	OK	4.80	OK	Passed
K7A (3in)	8	OK	...	OK	4.80	OK	Passed
K7A (3in)	8	OK	...	OK	4.80	OK	Passed
K7B (3in)	8	OK	...	OK	4.80	OK	Passed
K7B (3in)	8	OK	...	OK	4.80	OK	Passed
N05 (2in)	16	OK	...	OK	4.80	OK	Passed
K2B (2in)	16	OK	...	OK	4.80	OK	Passed
K2B (2in)	16	OK	...	OK	4.80	OK	Passed
K2A (2in)	16	OK	...	OK	4.80	OK	Passed
K2A (2in)	16	OK	...	OK	4.80	OK	Passed
K3A (3in)	8	OK	...	OK	4.80	OK	Passed
K3A (3in)	8	OK	...	OK	4.80	OK	Passed
K3B (3in)	8	OK	...	OK	4.80	OK	Passed
K3B (3in)	8	OK	...	OK	4.80	OK	Passed
N11 (1in)	16	OK	...	OK	4.80	OK	Passed
M2 (24in)	11	OK	...	...		OK	Passed
K8 (2in)	16	OK	...	OK	4.80	OK	Passed
N04 (6in)	16	OK	...	OK	4.80	OK	Passed
K1B (2in)	16	OK	...	OK	4.80	OK	Passed
N07A (2in)	16	OK	...	OK	4.80	OK	Passed
N09A (1.5in)	16	OK	...	OK	4.80	OK	Passed
N09A (1.5in)	16	OK	...	OK	4.80	OK	Passed
N09B (1.5in)	16	OK	...	OK	4.80	OK	Passed
N09B (1.5in)	16	OK	...	OK	4.80	OK	Passed
K4A (2in)	16	OK	...	OK	4.80	OK	Passed
K4A (2in)	16	OK	...	OK	4.80	OK	Passed
K6 (2in)	16	OK	...	OK	7.50	OK	Passed
K1 (2in)	16	OK	...	OK	4.80	OK	Passed
K1 (2in)	16	OK	...	OK	4.80	OK	Passed
N01 (10in)	12	OK	...	OK	4.80	OK	Passed
N03 (10in)	5	OK	...	OK	11.10	OK	Passed

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 14 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Chimney Nozzle | 5 | OK | ... | OK | 11.10 | OK | Passed |

Nozzle MAWP Summary:

Minimum MAWP Nozzles : 5 Nozzle : Chimney Nozzle
Minimum MAWP Shells/Flanges : 8 Element :
Minimum MAPnc Shells/Flanges : 9 Element :

Computed Vessel M.A.W.P. : 5 bars

Note: MAWPs (Internal Case) shown above are at the High Point.

Check the Spatial Relationship between the Nozzles:

From Node	Nozzle Description	X Coordinate	Layout Angle	Dia. Limit
		mm.	deg	mm.
10	N08 (1in)	0.000	270.000	113.600
20	N02 (2in)	200.000	270.000	113.600
20	N12 (1in)	250.000	90.000	65.000
20	M1 (24in)	950.000	90.000	920.000
20	N07C (2in)	450.000	270.000	113.600
20	N07B (2in)	1150.000	270.000	113.600
20	K9B (3in)	200.000	-55.052	163.130
20	K9A (3in)	200.000	55.052	163.130
20	K10A (2in)	450.000	-21.342	113.600
20	K10B (2in)	450.000	-51.592	113.600
20	K11A (2in)	600.000	21.342	113.600
20	K11B (2in)	600.000	51.592	90.000
20	K7A (3in)	1250.000	4.702	163.130
20	K7B (3in)	1250.000	-35.014	163.130
20	N05 (2in)	1415.000	270.000	113.600
30	K2B (2in)	2200.000	-21.948	113.600
30	K2A (2in)	2200.000	2.631	113.600
30	K3A (3in)	2450.000	40.976	163.130
30	K3B (3in)	2450.000	-19.139	163.130
30	N11 (1in)	1750.000	90.000	65.000
30	M2 (24in)	3050.000	0.000	1000.000
30	K8 (2in)	1747.400	0.000	113.600
40	N04 (6in)	4550.000	90.000	310.145
40	K1B (2in)	5400.000	90.000	113.600
40	N07A (2in)	4550.000	270.000	113.600
40	N09A (1.5in)	3750.000	289.139	88.200
40	N09B (1.5in)	3750.000	250.861	88.200
40	K4A (2in)	4650.000	40.976	113.600
40	K6 (2in)	5000.000	90.000	125.600
40	K1 (2in)	5200.000	40.976	113.600
50	N01 (10in)	5900.000	90.000	525.651
70	N03 (10in)	0.000	320.000	450.000
70	Chimney Nozzle	0.000	220.000	450.000

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 15 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

The nozzle spacing is computed by the following:

$$= \text{Sqrt}(l_l^2 + l_c^2) \text{ where}$$

l_l - Arc length along the inside vessel surface in the long. direction.

l_c - Arc length along the inside vessel surface in the circ. direction

If any interferences/violations are found, they will be noted below.

No interference violations have been detected !

Checking Multiple Nozzles on Flat Head per ASME Sec. VIII Div. 1 UG-39

Comparing Nozzles on Element from Node: 70 to: 80

UG-39 Average Nozzle Diameter and Ligament Checks:

Nozzle	Avg.	Head Dia.	Ligament	Min. dn
Pair Description	dia.	/4	Width	/4
	mm.	mm.	mm.	mm.
N03 (10in) & Chimney	252.65	312.02	217.22	63.162

UG-39 Nozzle Spacing and Average Area Checks:

Nozzle	Center	Avg. dia.	Avg. Area	Avg. Area
Pair Description	Spacing	* 1.25	Available	Reqd.
	mm.	mm.	cm ²	cm ²
N03 (10in) & Chimney	490.27	315.81	60.676	59.876

UG-39 Nozzle Diameter and Distance to Edge Checks:

Nozzle	Nozzle	Head Dia.	Distance	Nozzle
Description	dia.	/2	from Edge	dia./4
	mm.	mm.	mm.	mm.
N03 (10in)	252.65	624.05	253.48	63.162
Chimney Nozzle	252.65	624.05	253.48	63.162

No Multiple Nozzle spacing violations detected!

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 16 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Bill of Materials:

QTY	DESCRIPTION	MATERIAL
1	ELLIPTICAL HEAD: 2.0 X 1, 12.0mm. THK X 1200.0mm. ID X 50.0mm.	SA-516 70
1	CYLINDER: 10.0mm. THK X 1200.0mm. ID X 1500.0mm.	SA-516 70
2	CYLINDER: 10.0mm. THK X 1200.0mm. ID X 2000.0mm.	SA-516 70
1	CYLINDER: 10.0mm. THK X 1200.0mm. ID X 700.0mm.	SA-516 70
1	BODY FLANGE: 130.0mm. THK X 1200.0mm. OD	SA-105
1	BODY FLANGE: 60.0mm. THK X 1420.0mm. OD	SA-105
1	PLATFORM: 1100mm X 1200mm WIDE	
1	LADDER: 2000mm	...
1	INSULATION: 350mm X 90mm THK	
2	SADDLE: 150mm X 120 DEG	
1	INSULATION: 1500mm X 90mm THK	
2	INSULATION: 2000mm X 90mm THK	
1	BAR RING STIFFENER: 1200mm ID X 1400mm OD X 15mm	SA-516 70
1	INSULATION: 700mm X 90mm THK	
1	INSULATION: 188mm X 90mm THK	
1	INSULATION: 106mm X 90mm THK	
2	CLASS 150 GR 1.1, 24.0" BLIND FLANGE(S)	SA-516 70
1	GASKET: 1265mm. OD X 1220mm. ID	...
44	BODY FLANGE BOLTS: 38mm. DIA	SA-193 B7
88	NUTS FOR BODY FLANGE BOLTS: 38mm. DIA	...
1	NAMEPLATE	...

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 17 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Nozzle Schedule:

Description	Nominal or Actual Size	Schd or FVC Type	Flg Type	Nozzle O/Dia in	Wall Thk mm	Reinforcing Diameter	Pad Thk mm	Cut Length in	Flg Class
N12 (1in)	1.000 in	Actual	LW	2.008	12.800	...	...	160.5	150
N11 (1in)	1.000 in	Actual	LW	2.008	12.800	...	...	160.5	150
N09A (1.5in)	1.500 in	Actual	LW	2.638	14.450	...	...	173.5	150
N09B (1.5in)	1.500 in	Actual	LW	2.638	14.450	...	...	173.5	150
N08 (1in)	2.000 in	Actual	LW	3.248	15.850	...	...	178.0	150
N02 (2in)	2.000 in	Actual	LW	3.248	15.850	...	...	161.4	150
N07C (2in)	2.000 in	Actual	LW	3.248	15.850	...	...	161.4	150
N07B (2in)	2.000 in	Actual	LW	3.248	15.850	...	...	161.4	150
K10A (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	179.3	300
K10B (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	379.6	300
K11A (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	179.3	300
K11B (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	379.6	300
N05 (2in)	2.000 in	Actual	LW	3.248	15.850	...	...	161.4	150
K2B (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	179.9	300
K2A (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	163.4	300
K8 (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	211.4	300
K1B (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	161.4	300
N07A (2in)	2.000 in	Actual	LW	3.248	15.850	...	...	161.4	150
K4A (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	254.7	300
K6 (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	161.4	300
K1 (2in)	2.000 in	Actual	LW	3.307	16.600	...	...	254.7	300
K9B (3in)	3.000 in	80	WN	3.500	7.620	200.00	10.00	397.2	300
K9A (3in)	3.000 in	80	WN	3.500	7.620	200.00	10.00	397.2	300
K7A (3in)	3.000 in	80	WN	3.500	7.620	200.00	10.00	215.4	300
K7B (3in)	3.000 in	80	WN	3.500	7.620	200.00	10.00	297.4	300
K3A (3in)	3.000 in	80	WN	3.500	7.620	200.00	10.00	307.4	300
K3B (3in)	3.000 in	80	WN	3.500	7.620	200.00	10.00	228.3	300
N04 (6in)	6.000 in	80	WN	6.625	10.973	300.00	10.00	165.9	150
N01 (10in)	10.000 in	40	WN	10.750	9.271	450.00	10.00	175.7	150
N03 (10in)	10.000 in	80	WN	10.750	15.088	450.00	15.00	4260.0	150
Chimney Nozzle	10.000 in	80	Non	10.750	15.088	450.00	15.00	4260.0	150
M1 (24in)	24.000 in	Actual	WN	24.000	10.000	800.00	10.00	243.1	150
M2 (24in)	24.000 in	Actual	WN	24.000	10.000	800.00	10.00	243.1	150

General Notes for the above table:

The Cut Length is the Outside Projection + Inside Projection + Drop + In Plane Shell Thickness. This value does not include weld gaps, nor does it account for shrinkage.

In the case of Oblique Nozzles, the Outside Diameter must be increased. The Re-Pad WIDTH around the nozzle is calculated as follows:
Width of Pad = (Pad Outside Dia. (per above) - Nozzle Outside Dia.)/2

For hub nozzles, the thickness and diameter shown are those of the smaller and thinner section.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 18 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Nozzle Material and Weld Fillet Leg Size Details (mm.):

Description	Material	Shl Grve Weld	Noz Shl/Pad Weld	Pad OD Weld	Pad Grve Weld	Inside Weld
N12 (1in)	SA-105	10.000	10.000	...	...	...
N11 (1in)	SA-105	10.000	8.000	...	...	...
N09A (1.5in)	SA-105	10.000	10.000	...	...	...
N09B (1.5in)	SA-105	10.000	10.000	...	...	...
N08 (1in)	SA-105	10.000	10.000	...	...	...
N02 (2in)	SA-105	10.000	10.000	...	...	...
N07C (2in)	SA-105	10.000	10.000	...	...	...
N07B (2in)	SA-105	10.000	10.000	...	...	...
K10A (2in)	SA-105	10.000	10.000	...	...	...
K10B (2in)	SA-105	10.000	10.000	...	...	...
K11A (2in)	SA-105	10.000	10.000	...	...	...
K11B (2in)	SA-105	10.000	10.000	...	...	...
N05 (2in)	SA-105	10.000	10.000	...	...	...
K2B (2in)	SA-105	10.000	10.000	...	...	...
K2A (2in)	SA-105	10.000	10.000	...	...	...
K8 (2in)	SA-105	10.000	10.000	...	...	...
K1B (2in)	SA-105	10.000	10.000	...	...	...
N07A (2in)	SA-105	10.000	10.000	...	...	...
K4A (2in)	SA-105	10.000	10.000	...	...	...
K6 (2in)	SA-105	10.000	10.000	...	...	...
K1 (2in)	SA-105	10.000	10.000	...	...	...
K9B (3in)	SA-106 B	10.000	10.000	8.000	10.000	...
K9A (3in)	SA-106 B	10.000	10.000	8.000	10.000	...
K7A (3in)	SA-106 B	10.000	10.000	8.000	10.000	...
K7B (3in)	SA-106 B	10.000	10.000	8.000	10.000	...
K3A (3in)	SA-106 B	10.000	10.000	8.000	10.000	...
K3B (3in)	SA-106 B	10.000	10.000	8.000	10.000	...
N04 (6in)	SA-106 B	10.000	8.000	6.000	10.000	...
N01 (10in)	SA-106 B	10.000	10.000	10.000	10.000	...
N03 (10in)	SA-106 B	26.000	20.000	12.000	15.000	20.000
Chimney Noz	SA-106 B	26.000	20.000	12.000	15.000	20.000
M1 (24in)	SA-516 70	10.000	10.000	8.000	10.000	...
M2 (24in)	SA-516 70	10.000	10.000	8.000	10.000	...

Note: The Outside projections below do not include the flange thickness.

Nozzle Miscellaneous Data:

Description	Elev/Distance From Datum mm.	Layout Angle deg	Proj Outside mm.	Proj Inside mm.	Installed in Component
N12 (1in)	250.000	90.0	150.00	0.00	Node: 20
N11 (1in)	1750.000	90.0	150.00	0.00	Node: 30
N09A (1.5in)	3750.000	289.1	150.00	0.00	Node: 40
N09B (1.5in)	3750.000	250.9	150.00	0.00	Node: 40
N08 (1in)	...	270.0	150.00	0.00	Node: 10
N02 (2in)	200.000	270.0	150.00	0.00	Node: 20
N07C (2in)	450.000	270.0	150.00	0.00	Node: 20
N07B (2in)	1150.000	270.0	150.00	0.00	Node: 20

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 19 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

K10A (2in)	450.000	-21.3	150.00	0.00	Node: 20
K10B (2in)	450.000	-51.6	300.00	0.00	Node: 20
K11A (2in)	600.000	21.3	150.00	0.00	Node: 20
K11B (2in)	600.000	51.6	300.00	0.00	Node: 20
N05 (2in)	1415.000	270.0	150.00	0.00	Node: 20
K2B (2in)	2200.000	-21.9	150.00	0.00	Node: 30
K2A (2in)	2200.000	2.6	150.00	0.00	Node: 30
K8 (2in)	1747.400	0.0	200.00	0.00	Node: 30
K1B (2in)	5400.000	90.0	150.00	0.00	Node: 40
N07A (2in)	4550.000	270.0	150.00	0.00	Node: 40
K4A (2in)	4650.000	41.0	200.00	0.00	Node: 40
K6 (2in)	5000.000	90.0	150.00	0.00	Node: 40
K1 (2in)	5200.000	41.0	200.00	0.00	Node: 40
K9B (3in)	200.000	-55.1	300.00	0.00	Node: 20
K9A (3in)	200.000	55.1	300.00	0.00	Node: 20
K7A (3in)	1250.000	4.7	200.00	0.00	Node: 20
K7B (3in)	1250.000	-35.0	250.00	0.00	Node: 20
K3A (3in)	2450.000	41.0	250.00	0.00	Node: 30
K3B (3in)	2450.000	-19.1	200.00	0.00	Node: 30
N04 (6in)	4550.000	90.0	150.00	0.00	Node: 40
N01 (10in)	5900.000	90.0	150.00	0.00	Node: 50
N03 (10in)	...	320.0	200.00	4000.00	Node: 70
Chimney Nozzle	...	220.0	200.00	4000.00	Node: 70
M1 (24in)	950.000	90.0	150.00	0.00	Node: 20
M2 (24in)	3050.000	0.0	150.00	0.00	Node: 30

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 20 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Minimum Design Metal Temperature Results Summary :

Description	Notes	Curve	Basic MDMT °C	Reduced MDMT °C	UG-20 (f) MDMT °C	Thickness ratio	Gov Thk mm.	E*	PWHT reqd
	[11]	A	-8	-104	-29	0.215	10.000	1.00	Yes
	[11]	A	4	-14		0.677	15.000	1.00	Yes
	[10]	B	-29	-104	-29	0.339	10.000	1.00	Yes
	[7]	B	-23	-104	-29	0.266	12.000	1.00	Yes
	[8]	B	-29	-104	-29	0.338	10.000	1.00	Yes
	[8]	B	-29	-104	-29	0.338	10.000	1.00	Yes
	[8]	B	-29	-104	-29	0.338	10.000	1.00	Yes
	[8]	B	-29	-104	-29	0.338	10.000	1.00	Yes
N08 (1in)	[1]	A	-8	-104	-29	0.231	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
N02 (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
N12 (1in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
M1 (24in)	[1]	B	-8	-104	-29	0.129	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
N07C (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
N07B (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K9B (3in)	[1]	B	-8	-104	-29	0.039	6.668	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K9A (3in)	[1]	B	-8	-104	-29	0.039	6.668	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K10A (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K10B (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K11A (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K11B (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K7A (3in)	[1]	B	-8	-104	-29	0.039	6.668	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K7B (3in)	[1]	B	-8	-104	-29	0.039	6.668	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
N05 (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-29	-104					
K2B (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
K2A (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
K3A (3in)	[1]	B	-8	-104	-29	0.039	6.668	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
K3B (3in)	[1]	B	-8	-104	-29	0.039	6.668	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
N11 (1in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 21 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

M2 (24in)	[1]	B	-29	-104		0.129	10.000	1.00	Yes
Nozzle Flg	[5]	B	-18	-104					
K8 (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
N04 (6in)	[1]	B	-29	-104		0.041	9.601	1.00	Yes
Nozzle Flg	[5]	B	-18	-104					
K1B (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
N07A (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
N09A (1.5in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
N09B (1.5in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
K4A (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
K6 (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
K1 (2in)	[1]	A	-8	-104	-29	0.257	10.000	1.00	Yes
Nozzle Flg	[5]	A	-18	-104					
N01 (10in)	[1]	B	-29	-104		0.090	8.112	1.00	Yes
Nozzle Flg	[5]	B	-18	-104					
N03 (10in)	[1]	A	-20	-104	-29	0.043	13.202	1.00	Yes
Nozzle Flg	[5]	B	-18	-104					
Chimney Nozzle	[1]	A	-20	-104	-29	0.043	13.202	1.00	Yes
Nozzle Flg	[5]	B	-18	-104					
Bolting	[21]		-48						

Warmest MDMT: 4 -14

Required Minimum Design Metal Temperature 5.0 °C
Warmest Computed Minimum Design Metal Temperature -14.0 °C

Notes:

- [!] - This was an impact tested material.
- [1] - Governing Nozzle Weld.
- [4] - ANSI Flange MDMT Calcs; Thickness ratio per UCS-66(b)(1)(-c).
- [5] - ANSI Flange MDMT Calcs; Thickness ratio per UCS-66(b)(1)(-b).
- [6] - MDMT Calculations at the Shell/Head Joint.
- [7] - MDMT Calculations for the Straight Flange.
- [8] - Cylinder/Cone/Flange Junction MDMT.
- [9] - Calculations in the Spherical Portion of the Head.
- [10] - Calculations in the Knuckle Portion of the Head.
- [11] - Calculated (Body Flange) Flange MDMT.
- [12] - Calculated Flat Head MDMT per UCS-66.3
- [13] - Tubesheet MDMT, shell side, if applicable
- [14] - Tubesheet MDMT, tube side, if applicable
- [15] - Nozzle Material
- [16] - Shell or Head Material
- [17] - Impact Testing required
- [18] - Impact Testing not required, see UCS-66(b)(3)
- [20] - Cylinder/Cone Junction MDMT based on Longitudinal Stress considerations
- [21] - Bolting Material

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 22 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

UG-84(b)(2) was not considered.

UCS-66(g) was not considered.

UCS-66(i) was not considered.

Notes:

Impact test temps were not entered in and not considered in the analysis.

UCS-66(i) applies to impact tested materials not by specification and

UCS-66(g) applies to materials impact tested per UG-84.1 General Note (c).

The Basic MDMT includes the (30F) PWHT credit if applicable.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد 08_0010-CO-GCS-HD-BK)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 23 از 411
	پروژه BK	بسته کاری GCS	صادر کننده MF	تسهیلات 120	رشته ME	نوع مدرک CN	سویال 0009	نسخه V00	

Class From To : Basic Element Checks.

Class From To: Check of Additional Element Data

There were no geometry errors or warnings.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 24 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

PV Elite Vessel Analysis Program: Input Data

Design Internal Pressure (for Hydrotest)	4.1	bars
Design Internal Temperature	234.0	°C
Type of Hydrotest	UG-99 (b) Note [36]	
Hydrotest Position	Horizontal	
Projection of Nozzle from Vessel Top	0	mm.
Projection of Nozzle from Vessel Bottom	0	mm.
Minimum Design Metal Temperature	5.0	°C
Type of Construction	Welded	
Special Service	Lethal	
Degree of Radiography	RT-1	
Use Higher Longitudinal Stresses (Flag)	Y	
Select t for Internal Pressure (Flag)	N	
Select t for External Pressure (Flag)	N	
Select t for Axial Stress (Flag)	N	
Select Location for Stiff. Rings (Flag)	N	
Consider Vortex Shedding	Y	
Perform a Corroded Hydrotest	Y	
Load Case 1	NP+EW+WI+FW+BW	
Load Case 2	NP+EW+EE+FS+BS	
Load Case 3	NP+OW+WI+FW+BW	
Load Case 4	NP+OW+EQ+FS+BS	
Load Case 5	NP+HW+HI	
Load Case 6	NP+HW+HE	
Load Case 7	IP+OW+WI+FW+BW	
Load Case 8	IP+OW+EQ+FS+BS	
Load Case 9	EP+OW+WI+FW+BW	
Load Case 10	EP+OW+EQ+FS+BS	
Load Case 11	HP+HW+HI	
Load Case 12	HP+HW+HE	
Load Case 13	IP+WE+EW	
Load Case 14	IP+WF+CW	
Load Case 15	IP+VO+OW	
Load Case 16	IP+VE+EW	
Load Case 17	NP+VO+OW	
Load Case 18	FS+BS+IP+OW	
Load Case 19	FS+BS+EP+OW	
Wind Design Code	ASCE-7 2010	
Wind Load Reduction Scale Factor	0.600	
Basic Wind Speed	[V]	120 Km/hr
Surface Roughness Category	C: Open Terrain	
Importance Factor	1.0	
Type of Surface	Moderately Smooth	
Base Elevation	100 mm.	
Percent Wind for Hydrotest	33.0	
Using User defined Wind Press. Vs Elev.	N	
Height of Hill or Escarpment	H or Hh	0 mm.
Distance Upwind of Crest	Lh	0 mm.
Distance from Crest to the Vessel	x	0 mm.
Type of Terrain (Hill, Escarpment)	Flat	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 25 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Damping Factor (Beta) for Wind (Ope) 0.0100
Damping Factor (Beta) for Wind (Empty) 0.0000
Damping Factor (Beta) for Wind (Filled) 0.0000

Seismic Design Code ASCE 7-2010
Seismic Load Reduction Scale Factor 0.700
Importance Factor 1.250
Table Value Fa 1.111
Table Value Fv 1.575
Short Period Acceleration value Ss 1.377
Long Period Acceleration Value Sl 0.367
Moment Reduction Factor Tau 1.000
Force Modification Factor R 3.000
Site Class C
Component Elevation Ratio z/h 1.000
Amplification Factor Ap 1.000
Force Factor 0.000
Consider Vertical Acceleration No
Minimum Acceleration Multiplier 0.000
User Value of Sds (used if > 0) 1.020
User Value of Sd1 (used if > 0) 0.385

Design Pressure + Static Head Y
Consider MAP New and Cold in Noz. Design N
Consider External Loads for Nozzle Des. Y
Use ASME VIII-1 Appendix 1-9 N

Material Database Year Current w/Addenda or Code Year

Configuration Directives:

Do not use Nozzle MDMT Interpretation VIII-1 01-37 No
Use Table G instead of exact equation for "A" Yes
Shell Head Joints are Tapered Yes
Compute "K" in corroded condition Yes
Use Code Case 2286 No
Use the MAWP to compute the MDMT Yes
For thickness ratios <= 0.35, MDMT will be -155F (-104C) Yes
For PWHT & P1 Materials the MDMT can be < -55F (-48C) No

Using Metric Material Databases, ASME II D No
Calculate B31.3 type stress for Nozzles with Loads Yes
Reduce the MDMT due to lower membrane stress Yes
Consider Longitudinal Stress in MDMT calcs. (Div. 1) Yes

Complete Listing of Vessel Elements and Details:

Element From Node 10
Element To Node 20
Element Type Elliptical
Description
Distance "FROM" to "TO" 50 mm.
Inside Diameter 1200 mm.
Element Thickness 10 mm.
Internal Corrosion Allowance 3 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 26 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nominal Thickness	12	mm.
External Corrosion Allowance	0	mm.
Design Internal Pressure	4.1	bars
Design Temperature Internal Pressure	234	°C
Design External Pressure	1.034	bars
Design Temperature External Pressure	100	°C
Effective Diameter Multiplier	1.2	
Material Name	SA-516 70	
Allowable Stress, Ambient	137.9	N./mm ²
Allowable Stress, Operating	137.9	N./mm ²
Allowable Stress, Hydrotest	235.81	N./mm ²
Material Density	7750.4	kg/m ³
P Number Thickness	31.75	mm.
Yield Stress, Operating	218.59	N./mm ²
UCS-66 Chart Curve Designation	B	
External Pressure Chart Name	CS-2	
UNS Number	K02700	
Product Form	Plate	
Efficiency, Longitudinal Seam	1.0	
Efficiency, Circumferential Seam	1.0	
Elliptical Head Factor	2.0	
Weld is pre-Heated	No	
Element From Node	10	
Detail Type	Platform	
Detail ID	PLAT:[1 OF 1]	
Dist. from "FROM" Node / Offset dist	0	mm.
Platform Start Angle (degrees)	0.0	
Platform End Angle (degrees)	0.0	
Platform Wind Area	31680	cm ²
Platform Weight	19.243	kN
Platform Railing Weight	0	kN/mm.
Platform Grating Weight	0.025	Kgs/cm ²
Platform Width	1200	mm.
Platform Height	1100	mm.
Platform Clearance or End Offset	150	mm.
Platform Force Coefficient	1.2	
Ladder Layout Angle	0.0	
Ladder Start Elevation	0	mm.
Ladder End Elevation	2000	mm.
Unit Weight of Ladder	0.00035	kN/mm.
Platform Length (top head platform)	6300	mm.
Element From Node	10	
Detail Type	Liquid	
Detail ID	Liquid: 10	
Dist. from "FROM" Node / Offset dist	0	mm.
Height/Length of Liquid	550	mm.
Liquid Density	1019.5	kg/m ³
Element From Node	10	
Detail Type	Insulation	
Detail ID	Ins: 20	
Dist. from "FROM" Node / Offset dist	-300	mm.
Height/Length of Insulation	350	mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 27 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Thickness of Insulation 90 mm.
Density 125 kg/m³

Element From Node 10
Detail Type Nozzle
Detail ID N08 (1in)
Dist. from "FROM" Node / Offset dist 400 mm.
Nozzle Diameter 2 in.
Nozzle Schedule None
Nozzle Class 150
Layout Angle 270.0
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.07081 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-105

Element From Node 20
Element To Node 30
Element Type Cylinder
Description
Distance "FROM" to "TO" 1500 mm.
Inside Diameter 1200 mm.
Element Thickness 10 mm.
Internal Corrosion Allowance 3 mm.
Nominal Thickness 0 mm.
External Corrosion Allowance 0 mm.
Design Internal Pressure 4.1 bars
Design Temperature Internal Pressure 234 °C
Design External Pressure 1.034 bars
Design Temperature External Pressure 100 °C
Effective Diameter Multiplier 1.2
Material Name SA-516 70
Efficiency, Longitudinal Seam 1.0
Efficiency, Circumferential Seam 1.0
Weld is pre-Heated No

Element From Node 20
Detail Type Saddle
Detail ID Lft Sdl
Dist. from "FROM" Node / Offset dist 850 mm.
Width of Saddle 150 mm.
Height of Saddle at Bottom 1200 mm.
Saddle Contact Angle 120.0
Height of Composite Ring Stiffener 0 mm.
Width of Wear Plate 260 mm.
Thickness of Wear Plate 10 mm.
Contact Angle, Wear Plate (degrees) 145.0
Friction coefficient 0.30000001
Moment Factor 3.0
Dimension E at base (optional) 0 mm.
Circumferential Eff. over Saddle 1.0
Circumferential Eff. at Midspan 1.0
Tangent to Tangent dist. (optional) 0 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 28 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Element From Node 20
Detail Type Insulation
Detail ID Ins: 20
Dist. from "FROM" Node / Offset dist 0 mm.
Height/Length of Insulation 1500 mm.
Thickness of Insulation 90 mm.
Density 125 kg/m³

Element From Node 20
Detail Type Nozzle
Detail ID N02 (2in)
Dist. from "FROM" Node / Offset dist 150 mm.
Nozzle Diameter 2 in.
Nozzle Schedule None
Nozzle Class 150
Layout Angle 270.0
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.07081 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-105

Element From Node 20
Detail Type Nozzle
Detail ID N12 (1in)
Dist. from "FROM" Node / Offset dist 200 mm.
Nozzle Diameter 1 in.
Nozzle Schedule None
Nozzle Class 150
Layout Angle 90.0
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.032 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-105

Element From Node 20
Detail Type Nozzle
Detail ID M1 (24in)
Dist. from "FROM" Node / Offset dist 900 mm.
Nozzle Diameter 24 in.
Nozzle Schedule STD
Nozzle Class 150
Layout Angle 90.0
Blind Flange (Y/N) Y
Weight of Nozzle (Used if > 0) 3.5021 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-516 70

Element From Node 20
Detail Type Nozzle
Detail ID N07C (2in)
Dist. from "FROM" Node / Offset dist 400 mm.
Nozzle Diameter 2 in.
Nozzle Schedule None
Nozzle Class 150

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 29 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Layout Angle	270.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.07081	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-105	
Element From Node	20	
Detail Type	Nozzle	
Detail ID	N07B (2in)	
Dist. from "FROM" Node / Offset dist	1100	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	150	
Layout Angle	270.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.07081	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-105	
Element From Node	20	
Detail Type	Nozzle	
Detail ID	K9B (3in)	
Dist. from "FROM" Node / Offset dist	150	mm.
Nozzle Diameter	3	in.
Nozzle Schedule	80	
Nozzle Class	300	
Layout Angle	-55.051998	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.1413	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-106 B	
Element From Node	20	
Detail Type	Nozzle	
Detail ID	K9A (3in)	
Dist. from "FROM" Node / Offset dist	150	mm.
Nozzle Diameter	3	in.
Nozzle Schedule	80	
Nozzle Class	300	
Layout Angle	55.051998	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.1413	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-106 B	
Element From Node	20	
Detail Type	Nozzle	
Detail ID	K10A (2in)	
Dist. from "FROM" Node / Offset dist	400	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	300	
Layout Angle	-21.341999	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.08459	kN

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 30 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-105
Element From Node	20
Detail Type	Nozzle
Detail ID	K10B (2in)
Dist. from "FROM" Node / Offset dist	400 mm.
Nozzle Diameter	2 in.
Nozzle Schedule	None
Nozzle Class	300
Layout Angle	-51.591999
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.1247 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-105
Element From Node	20
Detail Type	Nozzle
Detail ID	K11A (2in)
Dist. from "FROM" Node / Offset dist	550 mm.
Nozzle Diameter	2 in.
Nozzle Schedule	None
Nozzle Class	300
Layout Angle	21.341999
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.08459 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-105
Element From Node	20
Detail Type	Nozzle
Detail ID	K11B (2in)
Dist. from "FROM" Node / Offset dist	550 mm.
Nozzle Diameter	2 in.
Nozzle Schedule	None
Nozzle Class	300
Layout Angle	51.591999
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.1247 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-105
Element From Node	20
Detail Type	Nozzle
Detail ID	K7A (3in)
Dist. from "FROM" Node / Offset dist	1200 mm.
Nozzle Diameter	3 in.
Nozzle Schedule	80
Nozzle Class	300
Layout Angle	4.7016501
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.1285 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-106 B

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 31 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Element From Node 20
Detail Type Nozzle
Detail ID K7B (3in)
Dist. from "FROM" Node / Offset dist 1200 mm.
Nozzle Diameter 3 in.
Nozzle Schedule 80
Nozzle Class 300
Layout Angle -35.013599
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.1349 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-106 B

Element From Node 20
Detail Type Nozzle
Detail ID N05 (2in)
Dist. from "FROM" Node / Offset dist 1365 mm.
Nozzle Diameter 2 in.
Nozzle Schedule None
Nozzle Class 150
Layout Angle 270.0
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.07081 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-105

Element From Node 20
Detail Type Weight
Detail ID WEIR 1
Dist. from "FROM" Node / Offset dist 700 mm.
Miscellaneous Weight 0.9806 kN
Offset from Element Centerline 0 mm.

Element From Node 20
Detail Type Weight
Detail ID GAS SPARGER
Dist. from "FROM" Node / Offset dist 1325 mm.
Miscellaneous Weight 0.4903 kN
Offset from Element Centerline 400 mm.

Element From Node 30
Element To Node 40
Element Type Cylinder
Description
Distance "FROM" to "TO" 2000 mm.
Inside Diameter 1200 mm.
Element Thickness 10 mm.
Internal Corrosion Allowance 3 mm.
Nominal Thickness 0 mm.
External Corrosion Allowance 0 mm.
Design Internal Pressure 4.1 bars
Design Temperature Internal Pressure 234 °C
Design External Pressure 1.034 bars

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 32 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Design Temperature	External Pressure	100 °C
Effective Diameter	Multiplier	1.2
Material Name		SA-516 70
Efficiency, Longitudinal Seam		1.0
Efficiency, Circumferential Seam		1.0
Weld is pre-Heated		No
Element From Node		30
Detail Type		Insulation
Detail ID		Ins: 30
Dist. from "FROM" Node / Offset dist		0 mm.
Height/Length of Insulation		2000 mm.
Thickness of Insulation		90 mm.
Density		125 kg/m³
Element From Node		30
Detail Type		Nozzle
Detail ID		K2B (2in)
Dist. from "FROM" Node / Offset dist		650 mm.
Nozzle Diameter		2 in.
Nozzle Schedule		None
Nozzle Class		300
Layout Angle		-21.9484
Blind Flange (Y/N)		N
Weight of Nozzle (Used if > 0)		0.08459 kN
Grade of Attached Flange		GR 1.1
Nozzle Matl		SA-105
Element From Node		30
Detail Type		Nozzle
Detail ID		K2A (2in)
Dist. from "FROM" Node / Offset dist		650 mm.
Nozzle Diameter		2 in.
Nozzle Schedule		None
Nozzle Class		300
Layout Angle		2.6308999
Blind Flange (Y/N)		N
Weight of Nozzle (Used if > 0)		0.08459 kN
Grade of Attached Flange		GR 1.1
Nozzle Matl		SA-105
Element From Node		30
Detail Type		Nozzle
Detail ID		K3A (3in)
Dist. from "FROM" Node / Offset dist		900 mm.
Nozzle Diameter		3 in.
Nozzle Schedule		80
Nozzle Class		300
Layout Angle		40.975601
Blind Flange (Y/N)		N
Weight of Nozzle (Used if > 0)		0.1349 kN
Grade of Attached Flange		GR 1.1
Nozzle Matl		SA-106 B
Element From Node		30

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 33 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Detail Type	Nozzle
Detail ID	K3B (3in)
Dist. from "FROM" Node / Offset dist	900 mm.
Nozzle Diameter	3 in.
Nozzle Schedule	80
Nozzle Class	300
Layout Angle	-19.1395
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.1285 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-106 B

Element From Node	30
Detail Type	Nozzle
Detail ID	N11 (1in)
Dist. from "FROM" Node / Offset dist	200 mm.
Nozzle Diameter	1 in.
Nozzle Schedule	None
Nozzle Class	150
Layout Angle	90.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.032 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-105

Element From Node	30
Detail Type	Nozzle
Detail ID	M2 (24in)
Dist. from "FROM" Node / Offset dist	1500 mm.
Nozzle Diameter	24 in.
Nozzle Schedule	STD
Nozzle Class	150
Layout Angle	0.0
Blind Flange (Y/N)	Y
Weight of Nozzle (Used if > 0)	3.5021 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-516 70

Element From Node	30
Detail Type	Nozzle
Detail ID	K8 (2in)
Dist. from "FROM" Node / Offset dist	197.4 mm.
Nozzle Diameter	2 in.
Nozzle Schedule	None
Nozzle Class	300
Layout Angle	0.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.09794 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-105

Element From Node	30
Detail Type	Weight
Detail ID	WEIR 2
Dist. from "FROM" Node / Offset dist	450 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 34 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Miscellaneous Weight 0.9806 kN
Offset from Element Centerline 0 mm.

Element From Node 30
Detail Type Weight
Detail ID SMOKE BOX
Dist. from "FROM" Node / Offset dist 1000 mm.
Miscellaneous Weight 1.9612 kN
Offset from Element Centerline 200 mm.

Element From Node 40
Element To Node 50
Element Type Cylinder
Description
Distance "FROM" to "TO" 2000 mm.
Inside Diameter 1200 mm.
Element Thickness 10 mm.
Internal Corrosion Allowance 3 mm.
Nominal Thickness 0 mm.
External Corrosion Allowance 0 mm.
Design Internal Pressure 4.1 bars
Design Temperature Internal Pressure 234 °C
Design External Pressure 1.034 bars
Design Temperature External Pressure 100 °C
Effective Diameter Multiplier 1.2
Material Name SA-516 70
Efficiency, Longitudinal Seam 1.0
Efficiency, Circumferential Seam 1.0
Weld is pre-Heated No

Element From Node 40
Detail Type Insulation
Detail ID Ins: 40
Dist. from "FROM" Node / Offset dist 0 mm.
Height/Length of Insulation 2000 mm.
Thickness of Insulation 90 mm.
Density 125 kg/m³

Element From Node 40
Detail Type Ring
Detail ID Ring R1 Fr40
Dist. from "FROM" Node / Offset dist 50 mm.
Inside Diameter of Ring 1200 mm.
Thickness of Ring 15 mm.
Outside Diameter of Ring 1400 mm.
Material Name SA-516 70
Height of Section Ring 0 mm.
Using Custom Stiffener Section No

Element From Node 40
Detail Type Nozzle
Detail ID N04 (6in)
Dist. from "FROM" Node / Offset dist 1000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 35 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Diameter 6 in.
Nozzle Schedule 80
Nozzle Class 150
Layout Angle 90.0
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.2147 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-106 B

Element From Node 40
Detail Type Nozzle
Detail ID K1B (2in)
Dist. from "FROM" Node / Offset dist 1850 mm.
Nozzle Diameter 2 in.
Nozzle Schedule None
Nozzle Class 300
Layout Angle 90.0
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.08459 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-105

Element From Node 40
Detail Type Nozzle
Detail ID N07A (2in)
Dist. from "FROM" Node / Offset dist 1000 mm.
Nozzle Diameter 2 in.
Nozzle Schedule None
Nozzle Class 150
Layout Angle 270.0
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.07081 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-105

Element From Node 40
Detail Type Nozzle
Detail ID N09A (1.5in)
Dist. from "FROM" Node / Offset dist 200 mm.
Nozzle Diameter 1.5 in.
Nozzle Schedule None
Nozzle Class 150
Layout Angle 289.13901
Blind Flange (Y/N) N
Weight of Nozzle (Used if > 0) 0.05009 kN
Grade of Attached Flange GR 1.1
Nozzle Matl SA-105

Element From Node 40
Detail Type Nozzle
Detail ID N09B (1.5in)
Dist. from "FROM" Node / Offset dist 200 mm.
Nozzle Diameter 1.5 in.
Nozzle Schedule None
Nozzle Class 150

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 36 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Layout Angle	250.86099	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.05009	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-105	
Element From Node	40	
Detail Type	Nozzle	
Detail ID	K4A (2in)	
Dist. from "FROM" Node / Offset dist	1100	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	300	
Layout Angle	40.975601	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.09794	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-105	
Element From Node	40	
Detail Type	Nozzle	
Detail ID	K6 (2in)	
Dist. from "FROM" Node / Offset dist	1450	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	300	
Layout Angle	90.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.08459	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-105	
Element From Node	40	
Detail Type	Nozzle	
Detail ID	K1 (2in)	
Dist. from "FROM" Node / Offset dist	1650	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	None	
Nozzle Class	300	
Layout Angle	40.975601	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.09794	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-105	
Element From Node	40	
Detail Type	Weight	
Detail ID	SPARGER 2	
Dist. from "FROM" Node / Offset dist	1000	mm.
Miscellaneous Weight	0.9806	kN
Offset from Element Centerline	400	mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 37 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Element To Node	60
Element Type	Cylinder
Description	
Distance "FROM" to "TO"	700 mm.
Inside Diameter	1200 mm.
Element Thickness	10 mm.
Internal Corrosion Allowance	3 mm.
Nominal Thickness	0 mm.
External Corrosion Allowance	0 mm.
Design Internal Pressure	4.1 bars
Design Temperature Internal Pressure	234 °C
Design External Pressure	1.034 bars
Design Temperature External Pressure	100 °C
Effective Diameter Multiplier	1.2
Material Name	SA-516 70
Efficiency, Longitudinal Seam	1.0
Efficiency, Circumferential Seam	1.0
Weld is pre-Heated	No

Element From Node	50
Detail Type	Saddle
Detail ID	New Sdl
Dist. from "FROM" Node / Offset dist	303.33 mm.
Width of Saddle	150 mm.
Height of Saddle at Bottom	1200 mm.
Saddle Contact Angle	120.0
Height of Composite Ring Stiffener	0 mm.
Width of Wear Plate	260 mm.
Thickness of Wear Plate	10 mm.
Contact Angle, Wear Plate (degrees)	145.0
Friction coefficient	0.0
Moment Factor	3.0
Dimension E at base (optional)	0 mm.
Circumferential Eff. over Saddle	1.0
Circumferential Eff. at Midspan	1.0
Tangent to Tangent dist. (optional)	0 mm.

Element From Node	50
Detail Type	Insulation
Detail ID	Ins: 50
Dist. from "FROM" Node / Offset dist	0 mm.
Height/Length of Insulation	700 mm.
Thickness of Insulation	90 mm.
Density	125 kg/m³

Element From Node	50
Detail Type	Nozzle
Detail ID	N01 (10in)
Dist. from "FROM" Node / Offset dist	350 mm.
Nozzle Diameter	10 in.
Nozzle Schedule	40
Nozzle Class	150
Layout Angle	90.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.5796 kN

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 38 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Grade of Attached Flange GR 1.1
Nozzle Matl SA-106 B

Element From Node 50
Detail Type Weight
Detail ID E-100 & C-200
Dist. from "FROM" Node / Offset dist 350 mm.
Miscellaneous Weight 9.806 kN
Offset from Element Centerline 600 mm.

Element From Node 60
Element To Node 70
Element Type Flange
Description
Distance "FROM" to "TO" 160 mm.
Flange Inside Diameter 1200 mm.
Element Thickness 130 mm.
Internal Corrosion Allowance 3 mm.
Nominal Thickness 0 mm.
External Corrosion Allowance 0 mm.
Design Internal Pressure 4.1 bars
Design Temperature Internal Pressure 234 °C
Design External Pressure 1.034 bars
Design Temperature External Pressure 100 °C
Effective Diameter Multiplier 1.2
Material Name SA-105
Allowable Stress, Ambient 137.9 N./mm²
Allowable Stress, Operating 136.4 N./mm²
Allowable Stress, Hydrotest 223.4 N./mm²
Material Density 7750.4 kg/m³
P Number Thickness 30.988 mm.
Yield Stress, Operating 206.9 N./mm²
UCS-66 Chart Curve Designation A
External Pressure Chart Name CS-2
UNS Number K03504
Product Form Forgings
Perform Flange Stress Calculation (Y/N) Y
Weight of Standard Flange 0 kN
Class of Standard Flange
Grade of Standard Flange
Weld is pre-Heated No

Element From Node 60
Detail Type Insulation
Detail ID Ins: 60
Dist. from "FROM" Node / Offset dist 0 mm.
Height/Length of Insulation 188.98 mm.
Thickness of Insulation 90 mm.
Density 125 kg/m³

Element From Node 70

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 39 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Element To Node	80
Element Type	Flange
Description	
Distance "FROM" to "TO"	60 mm.
Flange Outside Diameter	1420 mm.
Element Thickness	60 mm.
Internal Corrosion Allowance	3 mm.
Nominal Thickness	0 mm.
External Corrosion Allowance	0 mm.
Design Internal Pressure	4.1 bars
Design Temperature Internal Pressure	234 °C
Design External Pressure	1.034 bars
Design Temperature External Pressure	100 °C
Effective Diameter Multiplier	1.2
Material Name	SA-105
Perform Flange Stress Calculation (Y/N)	Y
Weight of Standard Flange	0 kN
Class of Standard Flange	
Grade of Standard Flange	
Weld is pre-Heated	No
Element From Node	70
Detail Type	Insulation
Detail ID	Ins: 70
Dist. from "FROM" Node / Offset dist	0 mm.
Height/Length of Insulation	106.43 mm.
Thickness of Insulation	90 mm.
Density	125 kg/m³
Element From Node	70
Detail Type	Nozzle
Detail ID	N03 (10in)
Dist. from "FROM" Node / Offset dist	320 mm.
Nozzle Diameter	10 in.
Nozzle Schedule	80
Nozzle Class	150
Layout Angle	320.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	3.7756 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-106 B
Element From Node	70
Detail Type	Nozzle
Detail ID	Chimney Nozzle
Dist. from "FROM" Node / Offset dist	320 mm.
Nozzle Diameter	10 in.
Nozzle Schedule	80
Nozzle Class	150
Layout Angle	220.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	3.7756 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-106 B

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد 08_0010-CO-GCS-HD-BK)								
شماره پیمان: 053-073-9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 40 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Element From Node	70
Detail Type	Weight
Detail ID	CHIMNEY
Dist. from "FROM" Node / Offset dist	106 mm.
Miscellaneous Weight	7.8448 kN
Offset from Element Centerline	320 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 41 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

XY Coordinate Calculations:

From	To	X (Horiz.) mm.	Y (Vert.) mm.	DX (Horiz.) mm.	DY (Vert.) mm.
10	20	50	...	50	...
20	30	1550	...	1500	...
30	40	3550	...	2000	...
40	50	5550	...	2000	...
50	60	6250	...	700	...
60	70	6410	...	160	...
70	80	6479.52	...	60	...

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 42 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Flange Input Data Values

Description: FLANGE :

Item: Node 60 to 70

Description of Flange Geometry (Type)		Integral Weld Neck	
Design Pressure	P	4.10	bars
Design Temperature		234	°C
Internal Corrosion Allowance	ci	3.0000	mm.
External Corrosion Allowance	ce	0.0000	mm.
Use Corrosion Allowance in Thickness Calcs.		Yes	
Flange Inside Diameter	B	1200.000	mm.
Flange Outside Diameter	A	1420.000	mm.
Flange Thickness	t	130.0000	mm.
Thickness of Hub at Small End	go	10.0000	mm.
Thickness of Hub at Large End	gl	15.0000	mm.
Length of Hub	h	30.0000	mm.
Flange Material		SA-105	
Flange Material UNS number		K03504	
Flange Allowable Stress At Temperature	Sfo	136.40	N./mm ²
Flange Allowable Stress At Ambient	Sfa	137.90	N./mm ²
Bolt Material		SA-193 B7	
Bolt Allowable Stress At Temperature	Sb	172.38	N./mm ²
Bolt Allowable Stress At Ambient	Sa	172.38	N./mm ²
Diameter of Bolt Circle	C	1335.000	mm.
Nominal Bolt Diameter	a	38.1000	mm.
Type of Threads	TEMA Thread Series		
Number of Bolts		44	
Flange Face Outside Diameter	Fod	1270.000	mm.
Flange Face Inside Diameter	Fid	1200.000	mm.
Flange Facing Sketch		1, Code Sketch 1a	
Gasket Outside Diameter	Go	1265.000	mm.
Gasket Inside Diameter	Gi	1220.000	mm.
Gasket Factor	m	3.0000	
Gasket Design Seating Stress	y	68.95	N./mm ²
Column for Gasket Seating		2, Code Column II	
Gasket Thickness	tg	3.1750	mm.



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 43 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

ASME Code, Section VIII Division 1, 2019

Hub Small End Required Thickness due to Internal Pressure:

$$\begin{aligned}
 &= (P \cdot (D/2 + C_a)) / (S \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot (1200.0/2 + 3.0)) / (136.4 \cdot 1.0 - 0.6 \cdot 4.1) + C_a \\
 &= 4.8159 \text{ mm.}
 \end{aligned}$$

Hub Small End Hub MAWP:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (136.4 \cdot 1.0 \cdot 7.0) / (603.0 + 0.6 \cdot 7.0) \\
 &= 15.724 \text{ bars}
 \end{aligned}$$

Corroded Flange Thickness, $t_c = T - c_i$	127.000	mm.
Corroded Flange ID, $B_{cor} = B + 2 \cdot F_{cor}$	1206.000	mm.
Corroded Large Hub, $g1_{cor} = g1 - c_i$	12.000	mm.
Corroded Small Hub, $g0_{cor} = g0 - c_i$	7.000	mm.
Code R Dimension, $R = ((C - B_{cor})/2) - g1_{cor}$	52.500	mm.
Gasket Contact Width, $N = (G_o - G_i) / 2$	22.500	mm.
Basic Gasket Width, $b_o = N / 2$	11.250	mm.
Effective Gasket Width, $b = C_b \cdot \sqrt{b_o}$	8.452	mm.
Gasket Reaction Diameter, $G = G_o - 2 \cdot b$	1248.096	mm.

Basic Flange and Bolt Loads:

Hydrostatic End Load due to Pressure [H]:

$$\begin{aligned}
 &= 0.785 \cdot G^2 \cdot P_{eq} \\
 &= 0.785 \cdot 1248.0959^2 \cdot 4.1 \\
 &= 501.600 \text{ kN}
 \end{aligned}$$

Contact Load on Gasket Surfaces [Hp]:

$$\begin{aligned}
 &= 2 \cdot b \cdot P_i \cdot G \cdot m \cdot P \\
 &= 2 \cdot 8.4521 \cdot 3.1416 \cdot 1248.0959 \cdot 3.0 \cdot 4.1 \\
 &= 81.524 \text{ kN}
 \end{aligned}$$

Hydrostatic End Load at Flange ID [Hd]:

$$\begin{aligned}
 &= P_i \cdot B_{cor}^2 \cdot P / 4 \\
 &= 3.1416 \cdot 1206.0^2 \cdot 4.1 / 4 \\
 &= 468.335 \text{ kN}
 \end{aligned}$$

Pressure Force on Flange Face [Ht]:

$$\begin{aligned}
 &= H - H_d \\
 &= 502 - 468 \\
 &= 33.265 \text{ kN}
 \end{aligned}$$

Operating Bolt Load [Wm1]:

$$\begin{aligned}
 &= \max(H + H_p + H'p, 0) \\
 &= \max(502 + 82 + 0, 0) \\
 &= 583.124 \text{ kN}
 \end{aligned}$$

Gasket Seating Bolt Load [Wm2]:

$$\begin{aligned}
 &= y \cdot b \cdot P_i \cdot G + y_{Part} \cdot b_{Part} \cdot l_p \\
 &= 68.95 \cdot 8.4521 \cdot 3.1416 \cdot 1248.096 + 0.0 \cdot 0.0 \cdot 0.0 \\
 &= 2284.852 \text{ kN}
 \end{aligned}$$

Required Bolt Area [Am]:

$$\begin{aligned}
 &= \text{Maximum of } Wm1/S_b, Wm2/S_a \\
 &= \text{Maximum of } 583/172, 2285/172 \\
 &= 132.563 \text{ cm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 44 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

ASME Maximum Circumferential Spacing between Bolts per App. 2 eq. (3) [Bsmax]:

$$\begin{aligned}
 &= 2a + 6t / (m + 0.5) \\
 &= 2 * 38.1 + 6 * 127.0 / (3.0 + 0.5) \\
 &= 293.914 \text{ mm.}
 \end{aligned}$$

Actual Circumferential Bolt Spacing [Bs]:

$$\begin{aligned}
 &= C * \sin(\pi / n) \\
 &= 1335.0 * \sin(3.142/44) \\
 &= 95.238 \text{ mm.}
 \end{aligned}$$

ASME Moment Multiplier for Bolt Spacing per App. 2 eq. (7) [Bsc]:

$$\begin{aligned}
 &= \max(\sqrt{Bs / (2a + t)}, 1) \\
 &= \max(\sqrt{95.238 / (2 * 38.1 + 127.0)}, 1) \\
 &= 1.0000
 \end{aligned}$$

Bolting Information for TEMA Imperial Thread Series (Non Mandatory):

	Minimum	Actual	Maximum
Bolt Area, cm ²	132.563	398.838	
Radial Distance between Hub and Bolts:	50.800	52.500	
Radial Distance between Bolts and Edge:	38.100	42.500	
Circ. Spacing between the Bolts:	82.550	95.238	293.914

Min. Gasket Contact Width (Brownell Young) [Not an ASME Calc] [Nmin]:

$$\begin{aligned}
 &= Ab * Sa / (y * \pi * (Go + Gi)) \\
 &= 398.838 * 172.38 / (68.95 * 3.14 * (1265.0 + 1220.0)) \\
 &= 12.772 \text{ mm.}
 \end{aligned}$$

Note: Recommended Min. Width for Sheet and Composite Gaskets per table 2-4 :

$$= 32.000 \text{ mm. [Note: Exceeds actual gasket width, 22.500]}$$

Flange Design Bolt Load, Gasket Seating [W]:

$$\begin{aligned}
 &= Sa * (Am + Ab) / 2 \\
 &= 172.38 * (132.5625 + 398.8379) / 2 \\
 &= 4579.62 \text{ kN}
 \end{aligned}$$

Gasket Load for the Operating Condition [HG]:

$$\begin{aligned}
 &= Wm1 - H \\
 &= 583 - 502 \\
 &= 81.52 \text{ kN}
 \end{aligned}$$

Moment Arm Calculations:

Distance to Gasket Load Reaction [hg]:

$$\begin{aligned}
 &= (C - G) / 2 \\
 &= (1335.0 - 1248.0959) / 2 \\
 &= 43.4520 \text{ mm.}
 \end{aligned}$$

Distance to Face Pressure Reaction [ht]:

$$\begin{aligned}
 &= (R + g1 + hg) / 2 \\
 &= (52.5 + 12.0 + 43.452) / 2 \\
 &= 53.9760 \text{ mm.}
 \end{aligned}$$

Distance to End Pressure Reaction [hd]:

$$= R + (g1 / 2)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 45 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= 52.5 + (12.0/2.0)$$

$$= 58.5000 \text{ mm.}$$

Summary of Moments for Internal Pressure: (N-m)

Loading	Force	Distance	Bolt Corr	Moment
End Pressure, Md	468.	58.5000	1.0000	27409.
Face Pressure, Mt	33.	53.9760	1.0000	1796.
Gasket Load, Mg	82.	43.4520	1.0000	3544.
Gasket Seating, Matm	4580.	43.4520	1.0000	199074.
Total Moment for Operation, Mop				32749. N-m
Total Moment for Gasket seating, Matm				199074. N-m

$$\text{Effective Hub Length, } h_0 = \sqrt{B_{cor} * g_{oCor}} = 91.880 \text{ mm.}$$

$$\text{Hub Ratio, } h/h_0 = H_L / H_0 = 0.327$$

$$\text{Thickness Ratio, } g_1/g_0 = (g_{1Cor}/g_{oCor}) = 1.714$$

Flange Factors for Integral Flange:

Factor F	0.869
Factor V	0.323
Factor f	1.417
Factors from Figure 2-7.1	K = 1.177
T = 1.848	U = 13.152
Y = 11.968	Z = 6.176
d = 0.18312E+06 mm. ³	e = 0.0095 mm. ⁻¹
Stress Factors	ALPHA = 2.201
BETA = 2.601	GAMMA = 1.191
DELTA = 11.186	Lamda = 12.377

Longitudinal Hub Stress, Operating [SHo]:

$$= (f * Mop / B_{cor}) / (L * g_1^2)$$

$$= (1.4167 * 32749 / 1206.0) / (12.377 * 12.0^2)$$

$$= 21.58 \text{ N./mm}^2$$

Longitudinal Hub Stress, Seating [SHa]:

$$= (f * Matm / B_{cor}) / (L * g_1^2)$$

$$= (1.4167 * 199074 / 1206.0) / (12.377 * 12.0^2)$$

$$= 131.17 \text{ N./mm}^2$$

Radial Flange Stress, Operating [SRo]:

$$= (Beta * Mop / B_{cor}) / (L * t^2)$$

$$= (2.6013 * 32749 / 1206.0) / (12.377 * 127.0^2)$$

$$= 0.35 \text{ N./mm}^2$$

Radial Flange Stress, Seating [SRa]:

$$= (Beta * Matm / B_{cor}) / (L * t^2)$$

$$= (2.6013 * 199074 / 1206.0) / (12.377 * 127.0^2)$$

$$= 2.15 \text{ N./mm}^2$$

Tangential Flange Stress, Operating [STo]:

$$= (Y * Mo / (t^2 * B_{cor})) - Z * S_{Ro}$$

$$= (11.9679 * 32749 / (127.0^2 * 1206.0)) - 6.1763 * 0.4$$

$$= 17.96 \text{ N./mm}^2$$

Tangential Flange Stress, Seating [STa]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 46 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

$$= (y * Matm / (t^2 * Bcor)) - Z * SRa$$

$$= (11.9679 * 199074 / (127.0^2 * 1206.0)) - 6.1763 * 2$$

$$= 109.16 \text{ N./mm}^2$$

Average Flange Stress, Operating [SAo]:

$$= (SHo + \max(SRO, STO)) / 2$$

$$= (22 + \max(0.4, 18)) / 2$$

$$= 19.77 \text{ N./mm}^2$$

Average Flange Stress, Seating [SAa]:

$$= (SHA + \max(SRA, STA)) / 2$$

$$= (131 + \max(2, 109)) / 2$$

$$= 120.17 \text{ N./mm}^2$$

Bolt Stress, Operating [BSO]:

$$= Wm1 / Ab$$

$$= 583 / 398.8379$$

$$= 14.62 \text{ N./mm}^2$$

Bolt Stress, Seating [BSa]:

$$= (Wm2 / Ab)$$

$$= (2285 / 398.8379)$$

$$= 57.29 \text{ N./mm}^2$$

Flange Stress Analysis Results: N./mm²

	Actual	Operating Allowed	Gasket Seating Actual	Gasket Seating Allowed
Longitudinal Hub	21.58	204.60	131.17	206.85
Radial Flange	0.35	136.40	2.15	137.90
Tangential Flange	17.96	136.40	109.16	137.90
Maximum Average	19.77	136.40	120.17	137.90
Bolting	14.62	172.38	57.29	172.38

Minimum Required Flange Thickness [Rigidity] 129.565 mm.

Estimated M.A.W.P. (Operating) 24 bars

Estimated Finished Weight of Flange at given Thk. 467.2 kg.

Estimated Unfinished Weight of Forging at given Thk 561.4 kg.

Flange Rigidity Based on Required Thickness [ASME]:

Flange Rigidity Index, Seating (rotation check) per APP. 2 [Js]:

$$= 52.14 * Ma / Bsc * Cnv_fac * V / (Lambda * Eamb * go^2 * ho * Ki)$$

$$= 52.14 * 199074.5 / 1.0 * 999.68 * 0.323 / (12.254 * 202713 * 7.0^2 * 91.88 * 0.3)$$

$$= 1.000 \quad (\text{should be } \leq 1)$$

Flange Rigidity Index Operating (rotation check) per APP. 2 [J]:

$$= 52.14 * Mo / Bsc * Cnv_fac * V / (Lambda * Eop * goc^2 * ho * Ki)$$

$$= 52.14 * 32748.8 / 1.0 * 999.68 * 0.323 / (12.254 * 190171 * 7.0^2 * 91.88 * 0.3)$$

$$= 0.175 \quad (\text{should be } \leq 1)$$

Flange Rigidity Based on Given Thickness [ASME]:

Flange Rigidity Index, Seating (rotation check) per APP. 2 [Js]:

$$= 52.14 * Ma / Bsc * Cnv_fac * V / (Lambda * Eamb * go^2 * ho * Ki)$$

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 47 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

$$= 52.14 \times 199074.5 / 1.0 \times 999.68 \times 0.323 / (12.377 \times 202713 \times 7.0^2 \times 91.88 \times 0.3)$$

$$= 0.990 \quad (\text{should be } \leq 1)$$

Flange Rigidity Index Operating (rotation check) per APP. 2 [J]:

$$= 52.14 \times Mo / Bsc \times Cnv_fac \times V / (\text{Lambda} \times Eop \times goc^2 \times ho \times Ki)$$

$$= 52.14 \times 32748.8 / 1.0 \times 999.68 \times 0.323 / (12.377 \times 190171 \times 7.0^2 \times 91.88 \times 0.3)$$

$$= 0.174 \quad (\text{should be } \leq 1)$$

Minimum Design Metal Temperature Results:

Thickness Ratio = 0.215, Temperature Reduction per Fig. UCS 66.1 = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20 (f)	-29 °C

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 48 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Flange Input Data Values

Description: FLANGE :

Item: Node 70 to 80

Description of Flange Geometry (Type)		Blind	
Design Pressure	P	4.10	bars
Design Temperature		234	°C
Internal Corrosion Allowance	ci	3.0000	mm.
External Corrosion Allowance	ce	0.0000	mm.
Use Corrosion Allowance in Thickness Calcs.		Yes	
Flange Outside Diameter	A	1420.000	mm.
Flange Thickness	t	60.0000	mm.
Flange Material		SA-105	
Flange Material UNS number		K03504	
Flange Allowable Stress At Temperature	Sfo	136.40	N./mm ²
Flange Allowable Stress At Ambient	Sfa	137.90	N./mm ²
Bolt Material		SA-193 B7	
Bolt Allowable Stress At Temperature	Sb	172.38	N./mm ²
Bolt Allowable Stress At Ambient	Sa	172.38	N./mm ²
Diameter of the Load Reaction, Long Span	D	0.000	mm.
Diameter of the Load Reaction, Short Span	d	0.000	mm.
Perimeter along the Center of the Bolts	L	4194.026	mm.
Diameter of Bolt Circle	C	1335.000	mm.
Nominal Bolt Diameter	a	38.1000	mm.
Type of Threads	TEMA Thread Series		
Number of Bolts		44	
Flange Face Outside Diameter	Fod	1270.000	mm.
Flange Face Inside Diameter	Fid	1200.000	mm.
Flange Facing Sketch	1, Code Sketch 1a		
Gasket Outside Diameter	Go	1265.000	mm.
Gasket Inside Diameter	Gi	1220.000	mm.
Gasket Factor	m	3.0000	
Gasket Design Seating Stress	y	68.95	N./mm ²
Column for Gasket Seating	2, Code Column II		
Gasket Thickness	tg	3.1750	mm.



 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 49 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

ASME Code, Section VIII Division 1, 2019

Gasket Contact Width,	$N = (G_o - G_i) / 2$	22.500	mm.
Basic Gasket Width,	$b_o = N / 2$	11.250	mm.
Effective Gasket Width,	$b = C_b \sqrt{b_o}$	8.452	mm.
Gasket Reaction Diameter,	$G = G_o - 2 * b$	1248.096	mm.

Basic Flange and Bolt Loads:

Hydrostatic End Load due to Pressure [H]:

$$\begin{aligned}
 &= 0.785 * G^2 * P_{eq} \\
 &= 0.785 * 1248.0959^2 * 4.1 \\
 &= 501.600 \text{ kN}
 \end{aligned}$$

Contact Load on Gasket Surfaces [Hp]:

$$\begin{aligned}
 &= 2 * b * \pi * G * m * P \\
 &= 2 * 8.4521 * 3.1416 * 1248.0959 * 3.0 * 4.1 \\
 &= 81.524 \text{ kN}
 \end{aligned}$$

Operating Bolt Load [Wm1]:

$$\begin{aligned}
 &= \max(H + H_p + H'p, 0) \\
 &= \max(502 + 82 + 0, 0) \\
 &= 583.124 \text{ kN}
 \end{aligned}$$

Gasket Seating Bolt Load [Wm2]:

$$\begin{aligned}
 &= y * b * \pi * G + y_{Part} * b_{Part} * l_p \\
 &= 68.95 * 8.4521 * 3.141 * 1248.096 + 0.0 * 0.0 * 0.0 \\
 &= 2284.852 \text{ kN}
 \end{aligned}$$

Required Bolt Area [Am]:

$$\begin{aligned}
 &= \text{Maximum of } Wm1/S_b, Wm2/S_a \\
 &= \text{Maximum of } 583/172, 2285/172 \\
 &= 132.563 \text{ cm}^2
 \end{aligned}$$

ASME Maximum Circumferential Spacing between Bolts per App. 2 eq. (3) [Bsmax]:

$$\begin{aligned}
 &= 2a + 6t / (m + 0.5) \\
 &= 2 * 38.1 + 6 * 57.0 / (3.0 + 0.5) \\
 &= 173.914 \text{ mm.}
 \end{aligned}$$

Actual Circumferential Bolt Spacing [Bs]:

$$\begin{aligned}
 &= C * \sin(\pi / n) \\
 &= 1335.0 * \sin(3.142/44) \\
 &= 95.238 \text{ mm.}
 \end{aligned}$$

ASME Moment Multiplier for Bolt Spacing per App. 2 eq. (7) [Bsc]:

$$\begin{aligned}
 &= \max(\sqrt{Bs / (2a + t)}, 1) \\
 &= \max(\sqrt{95.238 / (2 * 38.1 + 57.0)}, 1) \\
 &= 1.0000
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 50 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Bolting Information for TEMA Imperial Thread Series (Non Mandatory):

	Minimum	Actual	Maximum
Bolt Area, cm ²	132.563	398.838	
Radial Distance between Bolts and Edge:	38.100	42.500	
Circ. Spacing between the Bolts:	82.550	95.238	173.914

Min. Gasket Contact Width (Brownell Young) [Not an ASME Calc] [Nmin]:

$$\begin{aligned}
 &= A_b * S_a / (y * \pi * (G_o + G_i)) \\
 &= 398.838 * 172.38 / (68.95 * 3.14 * (1265.0 + 1220.0)) \\
 &= 12.772 \text{ mm.}
 \end{aligned}$$

Flange Design Bolt Load, Gasket Seating [W]:

$$\begin{aligned}
 &= S_a * (A_m + A_b) / 2 \\
 &= 172.38 * (132.5625 + 398.8379) / 2 \\
 &= 4579.62 \text{ kN}
 \end{aligned}$$

Gasket Load for the Operating Condition [HG]:

$$\begin{aligned}
 &= W_{m1} \\
 &= 583.12 \text{ kN}
 \end{aligned}$$

Moment Arm Calculations:

Distance to Gasket Load Reaction [hg]:

$$\begin{aligned}
 &= (C - G) / 2 \\
 &= (1335.0 - 1248.0959) / 2 \\
 &= 43.4520 \text{ mm.}
 \end{aligned}$$

Tangential Flange Stress, Flat Head (UG-34), Operating [STo]:

$$\begin{aligned}
 &= 1.9 * W_{m1} * h_G * B_{sc} / (t^2 * G) + C * Z * P_{eq} * G^2 / t^2 \\
 &= 1.9 * 583 * 43.452 * 1.0 / (57.0^2 * 1248.0959) + \\
 &\quad 0.3 * 1.0 * 4.1 * 1248.0959^2 / 57.0^2 \\
 &= 70.85 \text{ N./mm}^2
 \end{aligned}$$

Tangential Flange Stress, Flat Head (UG-34), Seating [STa]:

$$\begin{aligned}
 &= 1.9 * W * h_G * B_{sc} / (t^2 * G) \\
 &= 1.9 * 4580 * 43.452 * 1.0 / (57.0^2 * 1248.0959) \\
 &= 93.25 \text{ N./mm}^2
 \end{aligned}$$

Bolt Stress, Operating [BSo]:

$$\begin{aligned}
 &= W_{m1} / A_b \\
 &= 583 / 398.8379 \\
 &= 14.62 \text{ N./mm}^2
 \end{aligned}$$

Bolt Stress, Seating [BSa]:

$$\begin{aligned}
 &= (W_{m2} / A_b) \\
 &= (2285 / 398.8379) \\
 &= 57.29 \text{ N./mm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 51 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Flange Stress Analysis Results: N./mm²

	Actual	Operating Allowed	Gasket Seating Actual Allowed
Tangential Flange	70.85	136.40	93.25 137.90
Bolting	14.62	172.38	57.29 172.38
Reqd. Blind Flange Thickness at Center	49.872 mm.		
Reqd. Blind Flange Thickness at Gasket	49.872 mm.		
Estimated M.A.W.P. (Operating)	8 bars		
Estimated Finished Weight of Flange at given Thk.	736.5 kg.		
Estimated Unfinished Weight of Forging at given Thk	736.5 kg.		

Minimum Design Metal Temperature Results:

Thickness Ratio = 0.677, Temperature Reduction per Fig. UCS 66.1 = 18 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	4 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-14 °C

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 52 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Element Thickness, Pressure, Diameter and Allowable Stress :

From	To	Int. Press + Liq. Hd bars	Nominal Thickness mm.	Total Corr Allowance mm.	Element Diameter mm.	Allowable Stress (SE) N./mm ²
10	20	4.1553	12	3	1200	137.9
20	30	4.1	...	3	1200	137.9
30	40	4.1	...	3	1200	137.9
40	50	4.1	...	3	1200	137.9
50	60	4.1	...	3	1200	137.9
60	70	4.1	...	3	1200	136.4
70	80	4.1	...	3	1420	136.4

Element Required Thickness and MAWP :

From	To	Design Pressure bars	M.A.W.P. Corroded bars	M.A.P. New & Cold bars	Minimum Thickness mm.	Required Thickness mm.
10	20	4.1	16.0394	22.9438	10	4.80568
20	30	4.1	15.8966	22.7545	10	4.79613
30	40	4.1	15.8966	22.7545	10	4.79613
40	50	4.1	15.8966	22.7545	10	4.79613
50	60	4.1	15.8966	22.7545	10	4.79613
60	70	4.1	15.7237	27.3405	130	129.565
70	80	4.1	7.89294	8.84163	60	49.8715
Minimum			8	9		

MAWP: 5 bars, limited by: Nozzle Reinforcement.

Elements Suitable for Design Internal Pressure.

Internal Pressure Calculation Results:

ASME Code, Section VIII Division 1, 2019

Elliptical Head From 10 To 20 SA-516 70 , UCS-66 Crv. B at 234 °C

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned}
 &= (P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P) \text{ Appendix 1-4 (c)} \\
 &= (4.155 \cdot 1206.0 \cdot 0.993) / (2 \cdot 137.9 \cdot 1.0 - 0.2 \cdot 4.155) \\
 &= 1.8057 + 3.0000 = 4.8057 \text{ mm.}
 \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 0.055 bars

$$\begin{aligned}
 &= (2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t) \text{ per Appendix 1-4 (c)} \\
 &= (2 \cdot 137.9 \cdot 1.0 \cdot 7.0) / (0.993 \cdot 1206.0 + 0.2 \cdot 7.0) \\
 &= 16 - 0.1 = 16 \text{ bars}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 53 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (2 * S * E * t) / (K * D + 0.2 * t) \text{ per Appendix 1-4 (c)}$$

$$= (2 * 137.9 * 1.0 * 10.0) / (1.0 * 1200.0 + 0.2 * 10.0)$$

$$= 23 \text{ bars}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P * (K_{cor} * D + 0.2 * t)) / (2 * E * t)$$

$$= (4.155 * (0.993 * 1206.0 + 0.2 * 7.0)) / (2 * 1.0 * 7.0)$$

$$= 35.603 \text{ N./mm}^2$$

Straight Flange Required Thickness:

$$= (P * R) / (S * E - 0.6 * P) + c \text{ per UG-27 (c) (1)}$$

$$= (4.155 * 603.0) / (137.9 * 1.0 - 0.6 * 4.155) + 3.0$$

$$= 4.820 \text{ mm.}$$

Straight Flange Maximum Allowable Working Pressure:

Less Operating Hydrostatic Head Pressure of 0.055 bars

$$= (S * E * t) / (R + 0.6 * t) \text{ per UG-27 (c) (1)}$$

$$= (137.9 * 1.0 * 9.0) / (603.0 + 0.6 * 9.0)$$

$$= 20 - 0.1 = 20 \text{ bars}$$

Factor K, corroded condition [Kcor]:

$$= (2 + (\text{Inside Diameter} / (2 * \text{Inside Head Depth}))^2) / 6$$

$$= (2 + (1206.0 / (2 * 303.0))^2) / 6$$

$$= 0.993416$$

Percent Elong. per UCS-79, VIII-1-01-57 $(75 * t_{nom} / R_f) * (1 - R_f / R_o)$ 4.286 %

MDMT Calculations in the Knuckle Portion:

Govrn. thk, tg = 10.0, tr = 2.373, c = 3.0 mm., E* = 1.0

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.339$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C

Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

MDMT Calculations in the Head Straight Flange:

Govrn. thk, tg = 12.0, tr = 2.394, c = 3.0 mm., E* = 1.0

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.266$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -23 °C

Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Min Metal Temp. w/o impact per UG-20 (f) -29 °C

Note:

Post Weld Heat Treatment is required for this Element/Joint and it was specified as being heat treated.

Cylindrical Shell From 20 To 30 SA-516 70 , UCS-66 Crv. B at 234 °C

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$= (P * R) / (S * E - 0.6 * P) \text{ per UG-27 (c) (1)}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 54 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= (4.1 \times 603.0) / (137.9 \times 1.0 - 0.6 \times 4.1)$$

$$= 1.7961 + 3.0000 = 4.7961 \text{ mm.}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$= (S \times E \times t) / (R + 0.6 \times t) \text{ per UG-27 (c) (1)}$$

$$= (137.9 \times 1.0 \times 7.0) / (603.0 + 0.6 \times 7.0)$$

$$= 16 \text{ bars}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (S \times E \times t) / (R + 0.6 \times t) \text{ per UG-27 (c) (1)}$$

$$= (137.9 \times 1.0 \times 10.0) / (600.0 + 0.6 \times 10.0)$$

$$= 23 \text{ bars}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P \times (R + 0.6 \times t)) / (E \times t)$$

$$= (4.1 \times (603.0 + 0.6 \times 7.0)) / (1.0 \times 7.0)$$

$$= 35.567 \text{ N./mm}^2$$

% Elongation per Table UG-79-1 (50*tnom/Rf*(1-Rf/Ro)) 0.826 %

Minimum Design Metal Temperature Results:

Govrn. thk, tg = 10.0, tr = 2.369, c = 3.0 mm., E* = 1.0

Thickness Ratio = tr * (E*) / (tg - c) = 0.338, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Note:

Post Weld Heat Treatment is required for this Element/Joint and it was specified as being heat treated.

Cylindrical Shell From 30 To 40 SA-516 70 , UCS-66 Crv. B at 234 °C

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$= (P \times R) / (S \times E - 0.6 \times P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \times 603.0) / (137.9 \times 1.0 - 0.6 \times 4.1)$$

$$= 1.7961 + 3.0000 = 4.7961 \text{ mm.}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$= (S \times E \times t) / (R + 0.6 \times t) \text{ per UG-27 (c) (1)}$$

$$= (137.9 \times 1.0 \times 7.0) / (603.0 + 0.6 \times 7.0)$$

$$= 16 \text{ bars}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (S \times E \times t) / (R + 0.6 \times t) \text{ per UG-27 (c) (1)}$$

$$= (137.9 \times 1.0 \times 10.0) / (600.0 + 0.6 \times 10.0)$$

$$= 23 \text{ bars}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P \times (R + 0.6 \times t)) / (E \times t)$$

$$= (4.1 \times (603.0 + 0.6 \times 7.0)) / (1.0 \times 7.0)$$

$$= 35.567 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 55 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

% Elongation per Table UG-79-1 ($50 \cdot t_{nom} / R_f \cdot (1 - R_f / R_o)$) 0.826 %

Minimum Design Metal Temperature Results:

Govrn. thk, $t_g = 10.0$, $t_r = 2.369$, $c = 3.0$ mm., $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.338$, Temp. Reduction = 78°C

Min Metal Temp. w/o impact per UCS-66, Curve B -29°C
 Min Metal Temp. at Required thickness (UCS 66.1) -104°C

Note:

Post Weld Heat Treatment is required for this Element/Joint and it was specified as being heat treated.

Cylindrical Shell From 40 To 50 SA-516 70 , UCS-66 Crv. B at 234°C

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned}
 &= (P \cdot R) / (S \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (137.9 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 + 3.0000 = 4.7961 \text{ mm.}
 \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (137.9 \cdot 1.0 \cdot 7.0) / (603.0 + 0.6 \cdot 7.0) \\
 &= 16 \text{ bars}
 \end{aligned}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (137.9 \cdot 1.0 \cdot 10.0) / (600.0 + 0.6 \cdot 10.0) \\
 &= 23 \text{ bars}
 \end{aligned}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$\begin{aligned}
 &= (P \cdot (R + 0.6 \cdot t)) / (E \cdot t) \\
 &= (4.1 \cdot (603.0 + 0.6 \cdot 7.0)) / (1.0 \cdot 7.0) \\
 &= 35.567 \text{ N./mm}^2
 \end{aligned}$$

% Elongation per Table UG-79-1 ($50 \cdot t_{nom} / R_f \cdot (1 - R_f / R_o)$) 0.826 %

Minimum Design Metal Temperature Results:

Govrn. thk, $t_g = 10.0$, $t_r = 2.369$, $c = 3.0$ mm., $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.338$, Temp. Reduction = 78°C

Min Metal Temp. w/o impact per UCS-66, Curve B -29°C
 Min Metal Temp. at Required thickness (UCS 66.1) -104°C

Note:

Post Weld Heat Treatment is required for this Element/Joint and it was specified as being heat treated.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 56 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Cylindrical Shell From 50 To 60 SA-516 70 , UCS-66 Crv. B at 234 °C

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned}
 &= (P \cdot R) / (S \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (137.9 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 + 3.0000 = 4.7961 \text{ mm.}
 \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (137.9 \cdot 1.0 \cdot 7.0) / (603.0 + 0.6 \cdot 7.0) \\
 &= 16 \text{ bars}
 \end{aligned}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$\begin{aligned}
 &= (S \cdot E \cdot t) / (R + 0.6 \cdot t) \text{ per UG-27 (c) (1)} \\
 &= (137.9 \cdot 1.0 \cdot 10.0) / (600.0 + 0.6 \cdot 10.0) \\
 &= 23 \text{ bars}
 \end{aligned}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$\begin{aligned}
 &= (P \cdot (R + 0.6 \cdot t)) / (E \cdot t) \\
 &= (4.1 \cdot (603.0 + 0.6 \cdot 7.0)) / (1.0 \cdot 7.0) \\
 &= 35.567 \text{ N./mm}^2
 \end{aligned}$$

% Elongation per Table UG-79-1 (50*tnom/Rf*(1-Rf/Ro)) 0.826 %

Minimum Design Metal Temperature Results:

Govrn. thk, tg = 10.0, tr = 2.369, c = 3.0 mm., E* = 1.0

Thickness Ratio = tr * (E*) / (tg - c) = 0.338, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Note:

Post Weld Heat Treatment is required for this Element/Joint and it was specified as being heat treated.

Note: Heads and Shells Exempted to -20F (-29C) by paragraph UG-20F

Hydrostatic Test Pressure Results:

Pressure per UG99b	= 1.30 * M.A.W.P. * Sa/S	7.027 bars
Pressure per UG99b[36]	= 1.30 * Design Pres * Sa/S	5.330 bars
Pressure per UG99c	= 1.30 * M.A.P. - Head(Hyd)	11.355 bars
Pressure per UG100	= 1.10 * M.A.W.P. * Sa/S	5.946 bars
Pressure per PED	= max(1.43*DP, 1.25*DP*ratio)	5.863 bars
Pressure per App 27-4	= M.A.W.P.	5.406 bars

UG-99(b) Note 36, Test Pressure Calculation:

$$\begin{aligned}
 &= \text{Test Factor} * \text{Design Pressure} * \text{Stress Ratio} \\
 &= 1.3 * 4.1 * 1.0 \\
 &= 5.330 \text{ bars}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 57 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Horizontal Test performed per: UG-99b (Note 36)

Please note that Nozzle, Shell, Head, Flange, etc MAWPs are all considered when determining the hydrotest pressure for those test types that are based on the MAWP of the vessel.

Stresses on Elements due to Test Pressure (N./mm² & bars):

From	To	Stress	Allowable	Ratio	Pressure
10	20	46.7	235.8	0.198	5.45
20	30	47.3	235.8	0.200	5.45
30	40	47.3	235.8	0.200	5.45
40	50	47.3	235.8	0.200	5.45
50	60	47.3	235.8	0.200	5.45

Stress ratios for Nozzle and Pad Materials (N./mm²):

Description	Pad/Nozzle	Ambient	Operating	Ratio
N08 (1in)	Nozzle	137.90	136.43	1.011
N02 (2in)	Nozzle	137.90	136.43	1.011
N12 (1in)	Nozzle	137.90	136.43	1.011
M1 (24in)	Nozzle	137.90	137.90	1.000
M1 (24in)	Pad	137.90	137.90	1.000
N07C (2in)	Nozzle	137.90	136.43	1.011
N07B (2in)	Nozzle	137.90	136.43	1.011
K9B (3in)	Nozzle	117.90	117.90	1.000
K9B (3in)	Pad	137.90	137.90	1.000
K9A (3in)	Nozzle	117.90	117.90	1.000
K9A (3in)	Pad	137.90	137.90	1.000
K10A (2in)	Nozzle	137.90	136.43	1.011
K10B (2in)	Nozzle	137.90	136.43	1.011
K11A (2in)	Nozzle	137.90	136.43	1.011
K11B (2in)	Nozzle	137.90	136.43	1.011
K7A (3in)	Nozzle	117.90	117.90	1.000
K7A (3in)	Pad	137.90	137.90	1.000
K7B (3in)	Nozzle	117.90	117.90	1.000
K7B (3in)	Pad	137.90	137.90	1.000
N05 (2in)	Nozzle	137.90	136.43	1.011
K2B (2in)	Nozzle	137.90	136.43	1.011
K2A (2in)	Nozzle	137.90	136.43	1.011
K3A (3in)	Nozzle	117.90	117.90	1.000
K3A (3in)	Pad	137.90	137.90	1.000
K3B (3in)	Nozzle	117.90	117.90	1.000
K3B (3in)	Pad	137.90	137.90	1.000
N11 (1in)	Nozzle	137.90	136.43	1.011
M2 (24in)	Nozzle	137.90	137.90	1.000
M2 (24in)	Pad	137.90	137.90	1.000
K8 (2in)	Nozzle	137.90	136.43	1.011
N04 (6in)	Nozzle	117.90	117.90	1.000
N04 (6in)	Pad	137.90	137.90	1.000
K1B (2in)	Nozzle	137.90	136.43	1.011

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 58 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

N07A (2in)	Nozzle	137.90	136.43	1.011
N09A (1.5in)	Nozzle	137.90	136.43	1.011
N09B (1.5in)	Nozzle	137.90	136.43	1.011
K4A (2in)	Nozzle	137.90	136.43	1.011
K6 (2in)	Nozzle	137.90	136.43	1.011
K1 (2in)	Nozzle	137.90	136.43	1.011
N01 (10in)	Nozzle	117.90	117.90	1.000
N01 (10in)	Pad	137.90	137.90	1.000
N03 (10in)	Nozzle	117.90	117.90	1.000
N03 (10in)	Pad	137.90	137.90	1.000
Chimney Nozzle	Nozzle	117.90	117.90	1.000
Chimney Nozzle	Pad	137.90	137.90	1.000

Minimum				1.000

Stress ratios for Stiffening Ring Materials (N./mm²):

Description	Ambient	Operating	Ratio

Ring R1 Fr40	137.90	137.90	1.000

Minimum			1.000

Stress ratios for Pressurized Vessel Elements (N./mm²):

Description	Ambient	Operating	Ratio

	137.90	137.90	1.000
	137.90	137.90	1.000
	137.90	137.90	1.000
	137.90	137.90	1.000
	137.90	137.90	1.000
	137.90	136.40	1.011
	137.90	136.40	1.011

Minimum			1.000

Hoop Stress in Nozzle Wall during Pressure Test (N./mm²):

Description	Ambient	Operating	Ratio

N08 (1in)	1.53	223.40	0.007
N02 (2in)	1.53	223.40	0.007
N12 (1in)	1.20	223.40	0.005
M1 (24in)	23.50	235.81	0.100
N07C (2in)	1.53	223.40	0.007
N07B (2in)	1.53	223.40	0.007
K9B (3in)	6.38	217.19	0.029
K9A (3in)	6.38	217.19	0.029
K10A (2in)	1.46	223.40	0.007
K10B (2in)	1.46	223.40	0.007
K11A (2in)	1.46	223.40	0.007
K11B (2in)	1.46	223.40	0.007
K7A (3in)	6.38	217.19	0.029

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 59 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

K7B (3in)	6.38	217.19	0.029
N05 (2in)	1.53	223.40	0.007
K2B (2in)	1.46	223.40	0.007
K2A (2in)	1.46	223.40	0.007
K3A (3in)	6.38	217.19	0.029
K3B (3in)	6.38	217.19	0.029
N11 (1in)	1.20	223.40	0.005
M2 (24in)	23.50	235.81	0.100
K8 (2in)	1.46	223.40	0.007
N04 (6in)	6.73	217.19	0.031
K1B (2in)	1.46	223.40	0.007
N07A (2in)	1.53	223.40	0.007
N09A (1.5in)	1.38	223.40	0.006
N09B (1.5in)	1.38	223.40	0.006
K4A (2in)	1.46	223.40	0.007
K6 (2in)	1.94	223.40	0.009
K1 (2in)	1.46	223.40	0.007
N01 (10in)	14.33	217.19	0.066
N03 (10in)	7.10	217.19	0.033
Chimney Nozzle	7.10	217.19	0.033

Elements Suitable for Test Pressure.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 60 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

External Pressure Calculation Results :

External Pressure Calculations:

From	To	Section Length mm.	Outside Diameter mm.	Corroded Thickness mm.	Factor A	Factor B N./mm ²
10	20	No Calc	1220	7	0.0007969	78.0139
20	30	3700	1220	7	0.00018359	18.3547
30	40	3700	1220	7	0.00018359	18.3547
40	Ring	3700	1220	7	0.00018359	18.3547
Ring	50	2650	1220	7	0.00026068	26.0625
50	60	2650	1220	7	0.00026068	26.0625
60	70	No Calc	...	127	No Calc	No Calc
70	80	No Calc	...	57	No Calc	No Calc

External Pressure Calculations:

From	To	External Actual T. mm.	External Required T. mm.	External Design Pressure bars	External M.A.W.P. bars
10	20	10	6.15855	1.034	4.97328
20	30	10	9.22129	1.034	1.4041
30	40	10	9.22129	1.034	1.4041
40	Ring	10	9.22129	1.034	1.4041
Ring	50	10	8.39371	1.034	1.99374
50	60	10	8.39371	1.034	1.99374
60	70	130	129.565	1.034	No Calc
70	80	60	49.8856	1.034	No Calc

Minimum

1

External Pressure Calculations:

From	To	Actual Length Bet. Stiffeners mm.	Allowable Length Bet. Stiffeners mm.	Ring Inertia Required cm**4	Ring Inertia Available cm**4
10	20	No Calc	No Calc	No Calc	No Calc
20	30	3700	4945.73	No Calc	No Calc
30	40	3700	4945.73	No Calc	No Calc
40	Ring	3700	4945.73	No Calc	No Calc
Ring	50	2650	4945.66	41.1436	263.43
50	60	2650	4945.66	No Calc	No Calc
60	70	No Calc	No Calc	No Calc	No Calc
70	80	No Calc	No Calc	No Calc	No Calc

Elements Suitable for External Pressure.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 61 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

ASME Code, Section VIII Division 1, 2019

Elliptical Head From 10 to 20 Ext. Chart: CS-2 at 100 °C

Elastic Modulus from Chart: CS-2 at 100 °C: 199943392.000 KPa.

Results for Maximum Allowable Ext. Pressure						MAEP
Tca	Outer Dia	Do/t	Factor A	Factor B		
7.000	1220.00	174.29	0.0007969	78.01		

$$MAEP = B / (K0 * Do / t) = 78.0139 / (0.9 * 174.2857) = 4.9733 \text{ bars}$$

Results for Required Thickness						Tca
Tca	Outer Dia	Do/t	Factor A	Factor B		
3.159	1220.00	386.25	0.0003596	35.95		

$$MAEP = B / (K0 * Do / t) = 35.9499 / (0.9 * 386.2534) = 1.0341 \text{ bars}$$

*Check the requirements of UG-33(a)(1) using $P = 1.67 * \text{External Design pressure for this head.}$*

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned}
 &= (P * D * K_{cor}) / (2 * S * E - 0.2 * P) \text{ Appendix 1-4 (c)} \\
 &= (1.727 * 1206.0 * 0.993) / (2 * 137.9 * 1.0 - 0.2 * 1.727) \\
 &= 0.7502 + 3.0000 = 3.7502 \text{ mm.}
 \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned}
 &= ((2 * S * E * t) / (K_{cor} * D + 0.2 * t)) / 1.67 \text{ per Appendix 1-4 (c)} \\
 &= ((2 * 137.9 * 1.0 * 7.0) / (0.993 * 1206.0 + 0.2 * 7.0)) / 1.67 \\
 &= 10 \text{ bars}
 \end{aligned}$$

Maximum Allowable External Pressure [MAEP]:

$$\begin{aligned}
 &= \min(MAEP, MAWP) \\
 &= \min(4.97, 9.6375) \\
 &= 4.973 \text{ bars}
 \end{aligned}$$

Thickness requirements per UG-33(a)(1) do not govern the required thickness of this head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 62 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Cylindrical Shell From 20 to 30 Ext. Chart: CS-2 at 100 °C

Elastic Modulus from Chart: CS-2 at 100 °C: 199943392.000 KPa.

Results for Maximum Allowable Ext. Pressure							MAEP
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
7.000	1220.00	3700.00	174.29	3.0328	0.0001836	18.35	

$$MAEP = (4*B) / (3*(Do/t)) = (4*18.3547) / (3*174.2857) = 1.4041 \text{ bars}$$

Results for Required Thickness							Tca
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
6.221	1220.00	3700.00	196.10	3.0328	0.0001521	15.21	

$$MAEP = (4*B) / (3*(Do/t)) = (4*15.209) / (3*196.1009) = 1.034 \text{ bars}$$

Results for Maximum Stiffened Length							Slen
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
7.000	1220.00	4945.73	174.29	4.0539	0.0001353	13.53	

$$MAEP = (4*B) / (3*(Do/t)) = (4*13.5259) / (3*174.2857) = 1.0347 \text{ bars}$$

Cylindrical Shell From 30 to 40 Ext. Chart: CS-2 at 100 °C

Elastic Modulus from Chart: CS-2 at 100 °C: 199943392.000 KPa.

Results for Maximum Allowable Ext. Pressure							MAEP
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
7.000	1220.00	3700.00	174.29	3.0328	0.0001836	18.35	

$$MAEP = (4*B) / (3*(Do/t)) = (4*18.3547) / (3*174.2857) = 1.4041 \text{ bars}$$

Results for Required Thickness							Tca
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
6.221	1220.00	3700.00	196.10	3.0328	0.0001521	15.21	

$$MAEP = (4*B) / (3*(Do/t)) = (4*15.209) / (3*196.1009) = 1.034 \text{ bars}$$

Results for Maximum Stiffened Length							Slen
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 63 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

7.000 | 1220.00 | 4945.73 | 174.29 | 4.0539 | 0.0001353 | 13.53 |

$$MAEP = (4*B) / (3*(Do/t)) = (4*13.5259) / (3*174.2857) = 1.0347 \text{ bars}$$

Cylindrical Shell From 40 to Ring R1 Fr40 Ext. Chart: CS-2 at 100 °C

Elastic Modulus from Chart: CS-2 at 100 °C: 199943392.000 KPa.

Results for Maximum Allowable Ext. Pressure	MAEP
---	------

Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B
7.000	1220.00	3700.00	174.29	3.0328	0.0001836	18.35

$$MAEP = (4*B) / (3*(Do/t)) = (4*18.3547) / (3*174.2857) = 1.4041 \text{ bars}$$

Results for Required Thickness	Tca
--------------------------------	-----

Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B
6.221	1220.00	3700.00	196.10	3.0328	0.0001521	15.21

$$MAEP = (4*B) / (3*(Do/t)) = (4*15.209) / (3*196.1009) = 1.034 \text{ bars}$$

Results for Maximum Stiffened Length	Slen
--------------------------------------	------

Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B
7.000	1220.00	4945.73	174.29	4.0539	0.0001353	13.53

$$MAEP = (4*B) / (3*(Do/t)) = (4*13.5259) / (3*174.2857) = 1.0347 \text{ bars}$$

Cylindrical Shell From Ring R1 Fr40 to 50 Ext. Chart: CS-2 at 100 °C

Elastic Modulus from Chart: CS-2 at 100 °C: 199943392.000 KPa.

Results for Maximum Allowable Ext. Pressure	MAEP
---	------

Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B
7.000	1220.00	2650.00	174.29	2.1721	0.0002607	26.06

$$MAEP = (4*B) / (3*(Do/t)) = (4*26.0625) / (3*174.2857) = 1.9937 \text{ bars}$$

Results for Required Thickness	Tca
--------------------------------	-----

Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B
5.394	1220.00	2650.00	226.19	2.1721	0.0001755	17.54

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 64 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$MAEP = (4*B) / (3*(Do/t)) = (4*17.5426) / (3*226.1893) = 1.034 \text{ bars}$$

Results for Maximum Stiffened Length							Slen
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
7.000	1220.00	4945.66	174.29	4.0538	0.0001353	13.53	

$$MAEP = (4*B) / (3*(Do/t)) = (4*13.5261) / (3*174.2857) = 1.0347 \text{ bars}$$

Cylindrical Shell From 50 to 60 Ext. Chart: CS-2 at 100 °C

Elastic Modulus from Chart: CS-2 at 100 °C: 199943392.000 KPa.

Results for Maximum Allowable Ext. Pressure							MAEP
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
7.000	1220.00	2650.00	174.29	2.1721	0.0002607	26.06	

$$MAEP = (4*B) / (3*(Do/t)) = (4*26.0625) / (3*174.2857) = 1.9937 \text{ bars}$$

Results for Required Thickness							Tca
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
5.394	1220.00	2650.00	226.19	2.1721	0.0001755	17.54	

$$MAEP = (4*B) / (3*(Do/t)) = (4*17.5426) / (3*226.1893) = 1.034 \text{ bars}$$

Results for Maximum Stiffened Length							Slen
Tca	Outer Dia	Slen	Do/t	L/D	Factor A	Factor B	
7.000	1220.00	4945.66	174.29	4.0538	0.0001353	13.53	

$$MAEP = (4*B) / (3*(Do/t)) = (4*13.5261) / (3*174.2857) = 1.0347 \text{ bars}$$

Stiffening Ring Calcs for : Ring R1 Fr40 , SA-516 70 , Bar Ring: 100 x 15 mm.

Effective Length of Shell: 102 mm.

	Area (cm ²)	Distance (mm.)	Area*Dist
Shell:	7.116	3.5000	24.905
Ring :	15.000	57.0000	855.000
Total:	22.116		879.905

Centroid of Ring plus Shell: 40 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 65 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

	Inertia	Distance	A*Dist ²
Shell:	0.291	36.2864	9369.297
Ring :	125.000	-17.2136	4444.628
Total:	125.290		13813.925

Available Moment of Inertia, Ring plus Shell:			263 cm**4
Required Stress in Ring plus Shell	Breq	12.66	N./mm ²
Required Strain in Ring plus Shell	Areq	0.0001270	

Required Moment of Inertia, Ring plus Shell:

$$= (OD^2 * Slen(Tca + Aring/Slen)Areq) / 10.9$$

$$= (1220.0^2 * 3175.0 (7.0 + 15.0 / 3175.0) 0.000127) / 10.9$$

$$= 41 \text{ cm}^4$$

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 66 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Element and Detail Weights:

From	To	Element Metal Wgt. kg.	Element ID Volume Cm.	Corroded Metal Wgt. kg.	Corroded ID Volume Cm.	Extra due Misc %
10	20	181.221	282794	135.916	286772	9.06107
20	30	441.935	1696763	310.121	1713774	22.0968
30	40	589.248	2262351	413.494	2285032	29.4624
40	50	589.248	2262351	413.494	2285032	29.4624
50	60	206.237	791823	144.723	799761	10.3118
60	70	467.2	182462	453.14	182803	23.36
70	80	736.458	...	736.458	...	36.8229
Total		3211	7478547.00	2607	7553174.50	160

Weight of Details:

From	Type	Weight of Detail kg.	X Offset, Dtl. Cent. mm.	Y Offset, Dtl. Cent. mm.	Description
10	Plat	2060.48	3150	686.2	PLAT:[1 OF 1]
10	Liqd	126.161	-100	325	Liquid: 10
10	Insl	28.4793	-125	...	Ins: 20
10	Nozl	7.58193	-223.607	...	N08 (1in)
20	Sadl	218.003	850	890	Lft Sdl
20	Insl	69.4507	750	...	Ins: 20
20	Nozl	7.58193	150	625.4	N02 (2in)
20	Nozl	3.4263	200	612.7	N12 (1in)
20	Nozl	374.995	900	904.8	M1 (24in)
20	Nozl	7.58193	400	625.4	N07C (2in)
20	Nozl	7.58193	1100	625.4	N07B (2in)
20	Nozl	15.1297	150	637.782	K9B (3in)
20	Nozl	15.1297	150	637.782	K9A (3in)
20	Nozl	9.05726	400	625.4	K10A (2in)
20	Nozl	13.3479	400	625.4	K10B (2in)
20	Nozl	9.05726	550	625.4	K11A (2in)
20	Nozl	13.3479	550	625.4	K11B (2in)
20	Nozl	13.7604	1200	637.782	K7A (3in)
20	Nozl	14.445	1200	637.782	K7B (3in)
20	Nozl	7.58193	1365	625.4	N05 (2in)
20	Wght	100	700	...	WEIR 1
20	Wght	50	1325	400	GAS SPARGER
30	Insl	92.601	1000	...	Ins: 30
30	Nozl	9.05726	650	625.4	K2B (2in)
30	Nozl	9.05726	650	625.4	K2A (2in)
30	Nozl	14.445	900	637.782	K3A (3in)
30	Nozl	13.7604	900	637.782	K3B (3in)
30	Nozl	3.4263	200	612.7	N11 (1in)
30	Nozl	374.995	1500	904.8	M2 (24in)
30	Nozl	10.4875	197.4	625.4	K8 (2in)
30	Wght	100	450	...	WEIR 2
30	Wght	200	1000	200	SMOKE BOX

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 67 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

40 Insl	92.601	1000	...	Ins: 40
40 Ring	49.8544	50	...	Ring R1 Fr40
40 Nozl	22.992	1000	674.536	N04 (6in)
40 Nozl	9.05726	1850	625.4	K1B (2in)
40 Nozl	7.58193	1000	625.4	N07A (2in)
40 Nozl	5.36388	200	619.05	N09A (1.5in)
40 Nozl	5.36388	200	619.05	N09B (1.5in)
40 Nozl	10.4875	1100	625.4	K4A (2in)
40 Nozl	9.05726	1450	625.4	K6 (2in)
40 Nozl	10.4875	1650	625.4	K1 (2in)
40 Wght	100	1000	400	SPARGER 2
50 Sadl	218.003	303.333	890	New Sdl
50 Insl	32.4103	350	...	Ins: 50
50 Nozl	62.0567	350	728.413	N01 (10in)
50 Wght	1000	350	600	E-100 & C-200
60 Insl	6.38356	94.488	...	Ins: 60
70 Insl	20.6037	53.213	...	Ins: 70
70 Nozl	404.278	...	833.323	N03 (10in)
70 Nozl	404.278	...	833.323	Chimney Nozzle
70 Wght	800	106	320	CHIMNEY

Total Weight of Each Detail Type:

Saddles	436.0
Platforms	2060.5
Liquid	126.2
Insulation	342.5
Stiffeners	49.9
Nozzles	1905.8
Weights	2350.0

Sum of the Detail Weights 7270.9 kg.

Weight Summation Results: (kg.)

	Fabricated	Shop Test	Shipping	Erected	Empty	Operating
Main Elements	3372.1	3372.1	3372.1	3372.1	3372.1	3372.1
Saddles	436.0	436.0	436.0	436.0	436.0	436.0
Stif. Rings	49.9	49.9	49.9	49.9	49.9	49.9
Nozzles	1905.8	1905.8	1905.8	1905.8	1905.8	1905.8
Wld Weights	1350.0	1350.0	1350.0	1350.0	1350.0	1350.0
Platforms	...	...	2060.5	2060.5	2060.5	2060.5
Insulation	...	...	342.5	342.5	342.5	342.5
Empty Weights	...	...	...	1000.0	1000.0	...
Ope Weights	...	...	...	...	...	1000.0
Ope. Liquid	...	...	...	...	...	126.2
Test Liquid	...	7474.0	...	...	...	...
Totals	7113.8	14587.8	9516.8	10516.8	10516.8	10643.0

 NISOC	تگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 68 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Field Installation Options:

Miscellaneous Weight Percent: 5.0 %

Note that the above value for the miscellaneous weight percent has been applied to the shells/heads/flange/tubesheets/tubes etc. in the weight calculations for metallic components.

Weight Summary:

Fabricated Wt.	- Bare Weight without Removable Internals	7113.8 kg.
Shop Test Wt.	- Fabricated Weight + Water (Full)	14587.8 kg.
Shipping Wt.	- Fab. Weight + removable Intls.+ Shipping App.	9516.8 kg.
Erected Wt.	- Fab. Wt + or - loose items (trays,platforms etc.)	10516.8 kg.
Ope. Wt. no Liq	- Fab. Weight + Internals. + Details + Weights	10516.8 kg.
Operating Wt.	- Empty Weight + Operating Liq. Uncorroded	10643.0 kg.
Oper. Wt. + CA	- Corr Wt. + Operating Liquid	10008.6 kg.
Field Test Wt.	- Empty Weight + Water (Full)	16431.0 kg.

Note:

The Corroded Weight and thickness are used in the Horizontal Vessel Analysis (Ope Case) and Earthquake Load Calculations.

Note: The Field Test weight as computed in the corroded condition.

Outside Surface Areas of Elements:

From	To	Surface Area cm ²
10	20	18162.7
20	30	57491.1
30	40	76654.9
40	50	76654.9
50	60	26829.2
60	70	11485.7
70	80	18513.4
Total		285791.812 cm ²

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 69 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Nozzle Flange MAWP Results: (bars & °C)

Nozzle Description	Flange Rating Ope.	Flange Rating Ambient	Design Temp	Class	Grade/Group	Equiv. Press	UG-44 (b)	Max Pressure 50%	DNV
N08 (1in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
N02 (2in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
N12 (1in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
M1 (24in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
N07C (2in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
N07B (2in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
K9B (3in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K9A (3in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K10A (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K10B (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K11A (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K11B (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K7A (3in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K7B (3in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
N05 (2in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
K2B (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K2A (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K3A (3in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K3B (3in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
N11 (1in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
M2 (24in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
K8 (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
N04 (6in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
K1B (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
N07A (2in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
N09A (1.5in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
N09B (1.5in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
K4A (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K6 (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
K1 (2in)	42.51	51.10	234	300	GR 1.1	...	...	...	...
N01 (10in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
N03 (10in)	12.64	19.60	234	150	GR 1.1	...	...	...	...
Chimney Nozzle	12.64	19.60	234	150	GR 1.1	...	...	...	...
Min Rating	12.644	19.600 bars [for Core Elements]					0.000	0.000	0.000

ANSI Ratings are per ANSI/ASME B16.5 2013 Metric Edition

Warning:

There are nozzles in this model, but no flange MAWPs were de-rated. Be sure this is what you intended. There is a check box in the nozzle dialog that instructs PV Elite to perform the de-rating for each nozzle flange. See ASME VIII-1, UG-44(b) for more information.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 70 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Input Values:

Wind Design Code	ASCE-7 2010
Wind Load Reduction Scale Factor	0.600
Basic Wind Speed	120 Km/hr
Surface Roughness Category	C: Open Terrain
Importance Factor	1.0
Type of Surface	Moderately Smooth
Base Elevation	100 mm.
Percent Wind for Hydrotest	33.0
Using User defined Wind Press. Vs Elev.	N
Height of Hill or Escarpment H or Hh	0 mm.
Distance Upwind of Crest Lh	0 mm.
Distance from Crest to the Vessel x	0 mm.
Type of Terrain (Hill, Escarpment)	Flat
Damping Factor (Beta) for Wind (Ope)	0.0100
Damping Factor (Beta) for Wind (Empty)	0.0000
Damping Factor (Beta) for Wind (Filled)	0.0000

Wind Analysis Results

Static Gust-Effect Factor, Operating Case [G]:

$$\begin{aligned}
 &= \min(0.85, 0.925((1 + 1.7 * gQ * Izbar * Q) / (1 + 1.7 * gV * Izbar))) \\
 &= \min(0.85, 0.925((1 + 1.7 * 3.4 * 0.228 * 0.982) / (1 + 1.7 * 3.4 * 0.228))) \\
 &= \min(0.85, 0.915) \\
 &= 0.850
 \end{aligned}$$

Natural Frequency of Vessel (Operating)	33.000 Hz
Natural Frequency of Vessel (Empty)	33.000 Hz
Natural Frequency of Vessel (Test)	33.000 Hz

Force Coefficient	[Cf] 0.561
Structure Height to Diameter ratio	4.631

This is classified as a rigid structure. Static analysis performed.

Sample Calculation for the First Element

The ASCE code performs all calculations in Imperial Units only. The wind pressure is therefore computed in these units.

Value of [Alpha] and [Zg]:

Exposure Category: C from Table 26.9.1
Alpha = 9.5: Zg = 274320. mm.

Effective Height [z]:

$$\begin{aligned}
 &= \text{Centroid Height} + \text{Vessel Base Elevation} \\
 &= 1200.0 + 100.0 = 1300.0 \text{ mm.} \\
 &= 4.265 \text{ ft. Imperial Units}
 \end{aligned}$$

Velocity Pressure coefficient evaluated at height z [Kz]:

$$\begin{aligned}
 &\text{Because } z (4.265 \text{ ft.}) < 15 \text{ ft.} \\
 &= 2.01 * (15 / Zg)^{2 / \text{Alpha}}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 71 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= 2.01 * (15/900.0)^{2/9.5}$$

$$= 0.849$$

Type of Hill: No Hill

Wind Directionality Factor [Kd]:
= 0.95, per Table 26.6-1

As there is No Hill Present: [Kzt]:
K1 = 0, K2 = 0, K3 = 0

Topographical Factor [Kzt]:
= (1 + K1 * K2 * K3)²
= (1 + 0.0* 0.0* 0.0)²
= 1.0

Velocity Pressure evaluated at height z, Imperial Units [qz]:
= max(16, 0.00256 * Kz * Kzt * Kd * V(mph)²)
= max(16, 0.00256 * 0.849 * 1.0 * 0.95 * 74.567²)
= 16.0 psf [78.12] Kgs/m²

Force on the first element [F]:
= qz * G * Cf * WindArea
= 16.0 * 0.85 * 0.561 * 5.638
= 43.0 lbs. [0.2] kN

Element	Hgt (z) mm.	K1	K2	K3	Kz	Kzt	qz Kgs/m ²
Node 10 to 20	1300.0	0.000	0.000	0.000	0.849	1.000	78.120
Node 20 to 30	1300.0	0.000	0.000	0.000	0.849	1.000	78.120
Node 30 to 40	1300.0	0.000	0.000	0.000	0.849	1.000	78.120
Node 40 to 50	1300.0	0.000	0.000	0.000	0.849	1.000	78.120
Node 50 to 60	1300.0	0.000	0.000	0.000	0.849	1.000	78.120
Node 60 to 70	1300.0	0.000	0.000	0.000	0.849	1.000	78.120
Node 70 to 80	1300.0	0.000	0.000	0.000	0.849	1.000	78.120

Platform Load Calculations

ID	Wind Area cm ²	Elevation mm.	Pressure Kgs/m ²	Force kN	Cf

PLAT:[1 OF 1]	31680.00	1300.00	78.12	2.43	1.20

Wind Loads on Masses/Equipment/Piping

ID	Wind Area cm ²	Elevation mm.	Pressure Kgs/m ²	Force kN

WEIR 1	0.00	1300.00	78.12	0.00
GAS SPARGER	0.00	100.00	78.12	0.00
WEIR 2	0.00	1300.00	78.12	0.00

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 72 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

SMOKE BOX	0.00	100.00	78.12	0.00
SPARGER 2	0.00	100.00	78.12	0.00
E-100 & C-200	0.00	1900.00	78.12	0.00
CHIMNEY	0.00	100.00	78.12	0.00

Wind Load Calculation:

From	To	Wind Height mm.	Wind Diameter mm.	Wind Area cm ²	Wind Pressure Kgs/m ²	Element Wind Load kN
10	20	1300	1680	5238.23	78.12	1.57081
20	30	1300	1680	25200	78.12	0.55183
30	40	1300	1680	33600	78.12	0.73578
40	50	1300	1680	33600	78.12	0.73578
50	60	1300	1680	11760	78.12	0.25752
60	70	1300	1656	2649.6	78.12	0.058021
70	80	1300	1920	1152	78.12	0.025227

Note:

The Wind Loads calculated and printed in the Wind Load calculation report have been factored by the input scalar/load reduction factor of: 0.600.

Be sure the wind speed is in accordance with the specified wind design code.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 73 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Earthquake Load Calculation:

Input Values:

Seismic Design Code		ASCE 7-2010
Seismic Load Reduction Scale Factor		0.700
Importance Factor		1.250
Table Value Fa		1.111
Table Value Fv		1.575
Short Period Acceleration value Ss		1.377
Long Period Acceleration Value Sl		0.367
Moment Reduction Factor Tau		1.000
Force Modification Factor R		3.000
Site Class		C
Component Elevation Ratio	z/h	1.000
Amplification Factor	Ap	1.000
Force Factor		0.000
Consider Vertical Acceleration		No
Minimum Acceleration Multiplier		0.000
User Value of Sds (used if > 0)		1.020
User Value of Sd1 (used if > 0)		0.385

Seismic Analysis Results:

$$Sms = Fa * Ss = 1.111 * 1.377 = 1.53$$

$$Sm1 = Fv * S1 = 1.575 * 0.367 = 0.578$$

$$Sds = 2/3 * Sms = 2/3 * 1.53 = 1.02$$

$$Sds = \text{Max}(0.8 * Sds, SdsUser)$$

$$= \text{Max}(0.816, 1.02)$$

$$= 1.020$$

$$Sd1 = 2/3 * Sm1 = 2/3 * 0.578 = 0.385$$

$$Sd1 = \text{Max}(0.8 * Sd1, Sd1User)$$

$$= \text{Max}(0.308, 0.385)$$

$$= 0.385$$

Check Approximate Fundamental Period from 12.8-7 [Ta]:

$$= Ct * hn^x \text{ where } Ct = 0.020, x = 0.75 \text{ and } hn = \text{Structural Height (ft.)}$$

$$= 0.020 * (6.2664^{0.75})$$

$$= 0.079 \text{ seconds}$$

The Coefficient Cu from Table 12.8-1 is : 1.400

Fundamental Period (1/Frequency) [T]:

$$= (1/\text{Natural Frequency}) = (1/33.0)$$

$$= 0.030$$

Check the Value of T which is the smaller of Cu*Ta and T:

$$= \text{Minimum Value of } (1.4 * 0.079, 0.03) \text{ per 12.8.2}$$

$$= 0.030$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 74 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Compute the Seismic Force per equation 13.3-1, [Fp]:

$$\begin{aligned}
 &= 0.4 * A_p * S_{ds} * W * (1 + 2*(z/h)) / (R / I_e) \\
 &= 0.4 * 1.0 * 1.02 * 98 * (1 + 2*1.0) / (3.0/1.25) \\
 &= 50.053 \text{ kN}
 \end{aligned}$$

Check the Maximum value of Fp per equation 13.3-2:

$$\begin{aligned}
 &= 1.6 * S_{ds} * I * W \\
 &= 1.6 * 1.02 * 1.25 * 98 = 200.21 \text{ kN}
 \end{aligned}$$

Check the Minimum value of Fp per equation 13.3-3:

$$\begin{aligned}
 &= 0.3 * 1.02 * 1.25 * 98 \\
 &= 37.540 \text{ kN}
 \end{aligned}$$

Compute the Total Base Shear V = Fp, [V]:

$$= 50.053 \text{ kN}$$

Final Base Shear, $V = 35.04 \text{ kN}$

Earthquake Load Calculation:

From	To	Earthquake Height mm.	Earthquake Weight kN	Element Ope Load kN
10	20	600	10.9049	3.81533
20	30	600	10.9049	3.81533
20	30	600	10.9049	3.81533
30	40	600	10.9049	3.81533
40	50	600	10.9049	3.81533
50	0	600	10.9049	3.81533
50	60	600	10.9049	3.81533
60	70	600	10.9049	3.81533
70	80	710	10.9049	4.51481

Note:

The Earthquake Loads calculated and printed in the Earthquake Load calculation report have been factored by the input scalar/load reduction factor of: 0.700.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 75 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Shop/Field Installation Options :

Platform(s) installed in the Shop.
Insulation is installed in the Shop.

Note : The CG is computed from the first Element From Node

Center of Gravity of the Saddles	3376.667 mm.
Center of Gravity of the Platforms	3150.000 mm.
Center of Gravity of the Liquid	-100.000 mm.
Center of Gravity of the Insulation	3137.105 mm.
Center of Gravity of the Stiffening Rings	3600.000 mm.
Center of Gravity of the Nozzles	4016.682 mm.
Center of Gravity of the Added Weights (Operating)	5289.008 mm.
Center of Gravity of the Added Weights (Empty)	5289.008 mm.
Center of Gravity of Bare Shell New and Cold	4184.072 mm.
Center of Gravity of Bare Shell Corroded	4463.569 mm.
Vessel CG in the Operating Condition	4147.287 mm.
Vessel CG in the Fabricated (Shop/Empty) Condition	4127.698 mm.
Vessel CG in the Test Condition	3702.211 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 76 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

ASME Horizontal Vessel Analysis: Stresses for the Left Saddle

(per ASME Sec. VIII Div. 2 based on the Zick method.)

Horizontal Vessel Stress Calculations : Operating Case

Input and Calculated Values:

Vessel Mean Radius	Rm	606.50	mm.
Stiffened Vessel Length per 4.15.6	L	6250.00	mm.
Distance from Saddle to Vessel tangent	a	850.00	mm.
Saddle Width	b	150.00	mm.
Saddle Bearing Angle	theta	120.00	degrees
Wear Plate Width	b1	260.00	mm.
Wear Plate Bearing Angle	theta1	145.00	degrees
Wear Plate Thickness	tr	10.0	mm.
Wear Plate Allowable Stress	Sr	137.90	N./mm ²
Inside Depth of Head	h2	303.00	mm.
Shell Allowable Stress used in Calculation		137.90	N./mm ²
Head Allowable Stress used in Calculation		137.90	N./mm ²
Circumferential Efficiency in Plane of Saddle		1.00	
Circumferential Efficiency at Mid-Span		1.00	
Distance from Saddle Base to Centerline	B	1200.00	mm.
Coefficient of Friction	mu	0.30	
Saddle Force Q, Operating Case		90.47	kN

Horizontal Vessel Analysis Results:	Actual	Allowable
	N./mm ²	N./mm ²
Long. Stress at Top of Midspan	10.62	137.90
Long. Stress at Bottom of Midspan	24.90	137.90
Long. Stress at Top of Saddles	32.39	137.90
Long. Stress at Bottom of Saddles	9.65	137.90
Tangential Shear in Shell	17.06	110.32
Circ. Stress at Horn of Saddle	30.11	172.38
Circ. Compressive Stress in Shell	3.90	137.90

Intermediate Results: Saddle Reaction Q due to Wind or Seismic:

Saddle Reaction Force due to Wind Ft [Fwt]:

$$= F_{tr} (F_t / \text{Num of Saddles} + Z \text{ Force Load}) * B / E$$

$$= 3.0 (3.9/2 + 0) * 1200.0/1073.8717$$

$$= 6.6 \text{ kN}$$

Saddle Reaction Force due to Wind Fl or Friction [Fwl]:

$$= \max(F_l, \text{Friction Load, Sum of X Forces}) * B / L_s$$

$$= \max(1.58, 10.16, 0) * 1200.0/4953.3335$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 77 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= 2.5 \text{ kN}$$

Saddle Reaction Force due to Earthquake Fl or Friction [Fsl]:

$$= \max(\text{Fl, Friction Force, Sum of X Forces}) * B / Ls$$

$$= \max(35.04, 10.16, 0) * 1200.0/4953.3335$$

$$= 8.5 \text{ kN}$$

Saddle Reaction Force due to Earthquake Ft [Fst]:

$$= Ftr(\text{Ft/Num of Saddles} + \text{Z Force Load}) * B / E$$

$$= 3.0(35/2 + 0) * 1200.0/1073.8717$$

$$= 58.7 \text{ kN}$$

Load Combination Results for Q + Wind or Seismic [Q]:

$$= \text{Saddle Load} + \max(\text{Fwl, Fwt, Fsl, Fst})$$

$$= 32 + \max(2, 7, 8, 59)$$

$$= 90.5 \text{ kN}$$

Longitudinal Wind Force [Fl]:

$$= \text{WindScalar} * \text{WindPress}(\text{Platform Area} + (\text{End Area} * \text{WindDiaMult}))$$

$$= 0.6 * 766.08(1.584 + (1.539 * 1.2))$$

$$= 1577.182 \text{ N}$$

Summary of Loads at the base of this Saddle:

Vertical Load (including saddle weight)	92.60	kN
Transverse Shear Load Saddle	17.52	kN
Longitudinal Shear Load Saddle	35.04	kN

Formulas and Substitutions for Horizontal Vessel Analysis:

Note: Wear Plate is Welded to the Shell, $k = 0.1$

Saddle Dimension [E]:

$$= \min(2(\text{ShellID}/2 + t + \text{WearPadThickness})\sin(\text{theta}/2), 2*Rm)$$

$$= \min(2(1200.0/2 + 10.0 + 10.0)\sin(60.0/2), 2*606.5)$$

$$= 1073.872 \text{ mm.}$$

The Computed K values from Table 4.15.1:

K1 = 0.1066	K2 = 1.1707	K3 = 0.8799	K4 = 0.4011
K5 = 0.7603	K6 = 0.0529	K7 = 0.0529	K8 = 0.3405
K9 = 0.2711	K10 = 0.0581	K1* = 0.1923	K6p = 0.0347
K7p = 0.0347			

The suffix 'p' denotes the values for a wear plate if it exists.

Note: Dimension a is greater than or equal to $Rm / 2$.

Moment per Equation 4.15.3 [M1]:

$$= -Q*a[1 - (1 - a/L + (Rm^2 - h^2)/(2a*L))/(1 + (4h^2)/3L)]$$

$$= -90*850.0[1 - (1 - 850.0/6250.0 + (606.5^2 - 303.0^2)/(2*850.0*6250.0))/(1 + (4*303.0)/(3*6250.0))]$$

$$= -12620.4 \text{ N-m}$$

Moment per Equation 4.15.4 [M2]:

$$= Q*L/4(1 + 2(Rm^2 - h^2)/(L^2))/(1 + (4h^2)/(3L)) - 4a/L$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 78 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

$$= 90 * 6250 / 4 (1 + 2 (607^2 - 303^2) / (6250^2)) / (1 + (4 * 303) / (3 * 6250)) - 4 * 850 / 6250$$

$$= 57774.6 \text{ N-m}$$

Longitudinal Stress at Top of Shell (4.15.6) [Sigma1]:

$$= P * R_m / (2t) - M2 / (\pi * R_m^2 * t)$$

$$= 4.1 * 606.5 / (2 * 7.0) - 57774.6 / (\pi * 606.5^2 * 7.0)$$

$$= 10.62 \text{ N./mm}^2$$

Longitudinal Stress at Bottom of Shell (4.15.7) [Sigma2]:

$$= P * R_m / (2t) + M2 / (\pi * R_m^2 * t)$$

$$= 4.1 * 606.5 / (2 * 7.0) + 57774.6 / (\pi * 606.5^2 * 7.0)$$

$$= 24.90 \text{ N./mm}^2$$

Longitudinal Stress at Top of Shell at Support (4.15.10) [Sigma*3]:

$$= P * R_m / (2t) - M1 / (K1 * \pi * R_m^2 * t)$$

$$= 4.1 * 606.5 / (2 * 7.0) - 12620.4 / (0.1066 * \pi * 606.5^2 * 7.0)$$

$$= 32.39 \text{ N./mm}^2$$

Longitudinal Stress at Bottom of Shell at Support (4.15.11) [Sigma*4]:

$$= P * R_m / (2t) + M1 / (K1 * \pi * R_m^2 * t)$$

$$= 4.1 * 606.5 / (2 * 7.0) + 12620.4 / (0.1923 * \pi * 606.5^2 * 7.0)$$

$$= 9.65 \text{ N./mm}^2$$

Maximum Shear Force in the Saddle (4.15.5) [T]:

$$= Q (L - 2a) / (L + (4 * h^2 / 3))$$

$$= 90 (6250.0 - 2 * 850.0) / (6250.0 + (4 * 303.0 / 3))$$

$$= 61.9 \text{ kN}$$

Shear Stress in the shell no rings, not stiffened (4.15.14) [tau2]:

$$= K2 * T / (R_m * t)$$

$$= 1.1707 * 61.86 / (606.5 * 7.0)$$

$$= 17.06 \text{ N./mm}^2$$

Decay Length (4.15.22) [x1,x2]:

$$= 0.78 * \sqrt{R_m * t}$$

$$= 0.78 * \sqrt{606.5 * 7.0}$$

$$= 50.823 \text{ mm.}$$

Circumferential Stress in shell, no rings (4.15.23) [sigma6]:

$$= -K5 * Q * k / (t * (b + X1 + X2))$$

$$= -0.7603 * 90 * 0.1 / (7.0 * (150.0 + 50.82 + 50.82))$$

$$= -3.90 \text{ N./mm}^2$$

Effective reinforcing plate width (4.15.1) [B1]:

$$= \min(b + 1.56 * \sqrt{R_m * t}, 2a)$$

$$= \min(150.0 + 1.56 * \sqrt{606.5 * 7.0}, 2 * 850.0)$$

$$= 251.65 \text{ mm.}$$

Wear Plate/Shell Stress ratio (4.15.29) [eta]:

$$= \min(S_r / S, 1)$$

$$= \min(137.9 / 137.9, 1)$$

$$= 1.0000$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 - 073 - 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 79 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Circumferential Stress at Saddle Base with Wear Plate (4.15.26) [σ_6, r]:

$$= -K5 * Q * k / (B1(t + \eta * t_r))$$

$$= - 0.7603 * 90 * 0.1 / (251.646(7.0 + 1.0 * 10.0))$$

$$= -1.61 \text{ N./mm}^2$$

Circ. Comp. Stress at Horn of Saddle, $L \geq 8R_m$ (4.15.27) [σ_7, r]:

$$= -Q / (4(t + \eta * t_r) b1) - 3 * K7 * Q / (2(t + \eta * t_r)^2)$$

$$= -90 / (4(7.0 + 1.0 * 10.0) 251.646) -$$

$$3 * 0.053 * 90 / (2(7.0 + 1.0 * 10.0)^2)$$

$$= -30.11 \text{ N./mm}^2$$

Distance between Saddle Supports [L_s]:

$$= 4953.3 \text{ mm.}$$

Free Un-Restrained Thermal Expansion between the Saddles [Exp]:

$$= \alpha * L_s (\text{Design Temperature} - \text{Ambient Temperature})$$

$$= 0.000013 * 4953.333 (234.0 - 21.1)$$

$$= 13.677 \text{ mm.}$$

Results for Vessel Ribs, Web and Base:

Baseplate Length	Bplen	1200.0000	mm.
Baseplate Thickness	Bpthk	15.0000	mm.
Baseplate Width	Bpwid	170.0000	mm.
Number of Ribs (inc. outside ribs)	Nribs	4	
Rib Thickness	Ribtk	15.0000	mm.
Web Thickness	Webtk	15.0000	mm.
Web Location	Webloc	Center	
Saddle Yield Stress	Sy	239.9	N./
Height of Web at Center	Hw, c	585.0	mm.
Friction Coefficient	mu	0.300	

Note: In the tables below I_o is I for the rectangle + Area * Centroid Distance²

Moment of Inertia of Saddle - Transverse Direction (90 degrees to long axis)

	B	D	Y	A	AY	I_o
Shell	361.4	7.0	3.5	25.3	8853.1	0.157E+05
Wearplate	260.0	10.0	12.0	26.0	31200.0	0.151E+05
Web	15.0	565.0	299.5	84.8	2538262.8	0.244E+05
BasePlate	170.0	15.0	589.5	25.5	1503225.0	0.289E+05
Totals	...	...	...	161.5	4081541.2	0.841E+05

Distance to Centroid [C1]:

$$= AY / A$$

$$= 1606.906 / 161.545$$

$$= 252.657 \text{ mm.}$$

Angle [beta]:

$$= 180 - \text{Saddle Angle} / 2$$

$$= 180 - 120.0 / 2$$

$$= 120.0$$

Saddle Splitting Coefficient [K1]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 80 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= (1 + \cos(\beta) - 0.5 \sin(\beta)^2) / (\pi - \beta + \sin(\beta) \cos(\beta))$$

$$= (1 + \cos(120.0) - 0.5 \sin(120.0)^2) / (\pi - 2.094 + \sin(120.0) \cos(120.0))$$

$$= 0.2035$$

Saddle Splitting Force [Fh]:

$$= K1 * Q$$

$$= 0.204 * 90.466$$

$$= 18.4118 \text{ kN}$$

$$\text{Tension Stress, } St = (Fh / As) = 1.3514 \text{ N./mm}^2$$

$$\text{Allowed Stress, } Sa = 0.6 * \text{Yield Str} = 143.9676 \text{ N./mm}^2$$

Saddle Splitting Dimension [d]:

$$= B - R * \sin(\theta/2) / (\theta/2 \text{ in radians})$$

$$= 1200.0 - 603.0 * \sin(120.0/2) / 1.0472$$

$$= 701.323 \text{ mm.}$$

$$\text{Bending Moment, } M = Fh * d = 12917.8691 \text{ N-m}$$

$$\text{Bending Stress, } Sb = (M * C1 / I) = 3.8793 \text{ N./mm}^2$$

$$\text{Allowed Stress, } Sa = 2/3 * \text{Yield Str} = 159.9640 \text{ N./mm}^2$$

Minimum Thickness of Baseplate per Moss:

$$= (3 (Q + \text{Saddle_Wt}) \text{BasePlateWidth} / (4 * \text{BasePlateLength} * \text{AllStress}))^{1/2}$$

$$= (3 (90 + 2) 170.0 / (4 * 1200.0 * 159.964))^{1/2}$$

$$= 7.843 \text{ mm.}$$

Calculation of Axial Load, Intermediate Values and Compressive Stress:

Web Length Dimension [Web Length]:

$$= 2 * \cos(90 - \text{Saddle Angle}/2) (\text{Inside Radius} + \text{Shell Thk} + \text{Wear Plate Thk})$$

$$= 2 * \cos(90 - 120.0/2) (600.0 + 10.0 + 10.0)$$

$$= 1073.872 \text{ mm.}$$

Distance between Ribs [e]:

$$= \text{Web Length} / (\text{Nr ribs} - 1)$$

$$= 1073.8716 / (4 - 1)$$

$$= 357.957 \text{ mm.}$$

Baseplate Pressure Area [Ap]:

$$= e * \text{Bpwid} / 2$$

$$= 357.9572 * 170.0/2$$

$$= 304.264 \text{ cm}^2$$

Bearing Pressure [Bp]:

$$= Q / (\text{BasePlateLength} * \text{BasePlateWidth})$$

$$= 90.466 / (1200.0 * 170.0)$$

$$= 0.044 \text{ kN/cm}^2$$

Axial Load [P]:

$$= Ap * Bp$$

$$= 304.3 * 0.04$$

$$= 13.493 \text{ kN}$$

Area of the Rib and Web [Ar]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 81 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$\begin{aligned}
 &= \text{Rib Area} + \text{Web Area} \\
 &= 20.25 + 26.847 \\
 &= 47.097 \text{ cm}^2
 \end{aligned}$$

Compressive Stress [Sc]:

$$\begin{aligned}
 &= P/Ar \\
 &= 13.5/47.0968 \\
 &= 2.865 \text{ N./mm}^2
 \end{aligned}$$

Check of Outside Ribs:

Inertia of Saddle, Outer Ribs - Longitudinal Direction

	B	D	Y	A	AY	Io
Rib+Web	15.0	150.0	...	22.5	...	422.

Rib dimension [D]:

$$\begin{aligned}
 &= \text{Saddle Width} - \text{Web Thickness} \\
 &= 150.0 - 15.0 \\
 &= 135.000 \text{ mm.}
 \end{aligned}$$

Distance to Centroid from Datum [ytot]:

$$\begin{aligned}
 &= AY / A \\
 &= 0.0/47.097 \\
 &= 0.000 \text{ mm.}
 \end{aligned}$$

Distance to Centroid [C1]:

$$\begin{aligned}
 &= \text{Saddle Width} / 2 \\
 &= 150.0/2 \\
 &= 75.000 \text{ mm.}
 \end{aligned}$$

Radius of Gyration [r]:

$$\begin{aligned}
 &= \sqrt{\text{Total Inertia} / \text{Total Area}} \\
 &= \sqrt{421.9/47.097} \\
 &= 29.929 \text{ mm.}
 \end{aligned}$$

Length of Outer Rib [L]:

$$\begin{aligned}
 &= \text{Saddle Height} - \cos(\theta/2) (\text{radius} + \text{shlthk} + \text{wpdthk}) - \text{bpthk} \\
 &= 1200.0 - \cos(120.0/2) (600.0 + 10.0 + 10.0) - 15.0 \\
 &= 875.000 \text{ mm.}
 \end{aligned}$$

Intermediate Term [Cc]:

$$\begin{aligned}
 &= \sqrt{2 * \pi^2 * \text{Elastic Modulus} / \text{Yield Stress}} \\
 &= \sqrt{2 * \pi^2 * 0.19994\text{E}+09/239.9} \\
 &= 128.255
 \end{aligned}$$

Slenderness ratio [KL/r]:

$$\begin{aligned}
 &= KL/r \\
 &= 1 * 875.0/29.929 \\
 &= 29.236
 \end{aligned}$$

Bending Moment [Rm]:

$$= Fl / (2 * B_{plen}) * e * L / 2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 82 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= 35.0 / (2 * 1200.0) * 357.957 * 875.0 / 2$$

$$= 2287.212 \text{ N-m}$$

Compressive Allowable, $KL/r < Cc$ (29.2356 < 128.2549) per AISC E2-1 [Sca]:

$$= (1 - (Klr)^2 / (2 * Cc^2)) Fy / (5/3 + 3 * (Klr) / (8 * Cc) - (Klr^3) / (8 * Cc^3))$$

$$= (1 - (29.24)^2 / (2 * 128.25^2)) 240 / (5/3 + 3 * (29.24) / (8 * 128.25) - (29.24^3) / (8 * 128.25^3))$$

$$= 133.5 \text{ N./mm}^2$$

AISC Unity Check of Outside Ribs (must be <= 1)

$$= Sc/Sca + (Rm * C1 / I) / Sba$$

$$= 2.87 / 133.5 + (2287.21 * 75.0 / 4218750) / 159.96$$

$$= 0.276$$

Check of Inside Ribs:

Inertia of Saddle, Inner Ribs - Axial Direction

	B	D	Y	A	AY	Io
Rib	15.0	135.0	0.0	20.2	0.0	421.
Web	358.0	15.0	0.0	53.7	0.0	10.1
Totals	...	...	...	73.9	...	432.

Distance to Centroid from Datum [ytot]:

$$= AY / A$$

$$= 0.0 / 73.944$$

$$= 0.000 \text{ mm.}$$

Distance to Centroid [C1]:

$$= \text{Saddle Width} / 2$$

$$= 150.0 / 2$$

$$= 75.000 \text{ mm.}$$

Length of Inner Rib [L]:

$$= \text{Saddle Height} - \sqrt{ (Ro + Wpdthk)^2 - (Pitch/2)^2 } - Bpthk$$

$$= 1200.0 - \sqrt{ (620.0 + 10.0)^2 - (357.957/2)^2 } - 15.0$$

$$= 591.395 \text{ mm.}$$

Radius of Gyration [r]:

$$= \sqrt{ \text{Total Inertia} / \text{Total Area} }$$

$$= \sqrt{ 431.5 / 73.944 }$$

$$= 24.157 \text{ mm.}$$

Slenderness ratio [KL/r]:

$$= KL/r$$

$$= 1 * 591.395 / 24.157$$

$$= 24.481$$

Unit Force [Force,u]:

$$= F1 / (2 * \text{Baseplate Length})$$

$$= 35.037 / (2 * 1200.0)$$

$$= 0.015 \text{ kN/mm.}$$

Moment at base of inner Rib [Mbase,c]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 83 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$\begin{aligned}
 &= \text{Unit Force} * e * L \\
 &= 0.015 * 357.957 * 591.395 \\
 &= 3091.762 \text{ N-m}
 \end{aligned}$$

Bending Stress due to Transverse Force and Weight Load [SigmaB,base,c]:

$$\begin{aligned}
 &= \text{Bending Moment} / \text{Section Modulus} \\
 &= 3091.762 / 57536.086 \\
 &= 53.719 \text{ N./mm}^2
 \end{aligned}$$

Compressive Allowable, $KL/r < Cc$ ($24.4809 < 128.2549$) per AISC E2-1 [Sca]:

$$\begin{aligned}
 &= (1 - (KL/r)^2 / (2 * Cc^2)) Fy / (5/3 + 3 * (KL/r) / (8 * Cc) - (KL/r)^3 / (8 * Cc^3)) \\
 &= (1 - (24.48)^2 / (2 * 128.25^2)) 240 / \\
 &\quad (5/3 + 3 * (24.48) / (8 * 128.25) - (24.48^3) / (8 * 128.25^3)) \\
 &= 135.6 \text{ N./mm}^2
 \end{aligned}$$

AISC Unity Check of Inside Ribs (must be ≤ 1)

$$\begin{aligned}
 &= Sc/Sca + (Mbase,c * Cl/I) / Sba \\
 &= 3.69 / 135.59 + (3091.76 * 75.0 / 431.52) / 159.96 \\
 &= 0.363
 \end{aligned}$$

Input Data for Base Plate Bolting Calculations:

Total Number of Bolts per BasePlate	Nbolts	4
Total Number of Bolts in Tension/Baseplate	Nbt	2
Bolt Material Specification	SA-193 B7	
Bolt Allowable Stress	Stba	300.00 N./mm ²
Bolt Corrosion Allowance	Bca	0.0 mm.
Distance from Bolts to Edge	Edgedis	150.0 mm.
Nominal Bolt Diameter	Bnd	20.0000 mm.
Thread Series	Series	TEMA Metric
BasePlate Allowable Stress	S	95.15 N./mm ²
Area Available in a Single Bolt	BlArea	2.1705 cm ²
Saddle Load QO (Weight)	QO	33.9 kN
Saddle Load QL (Wind/Seismic contribution)	QL	8.5 kN
Maximum Transverse Force	Ft	17.5 kN
Maximum Longitudinal Force	F1	35.0 kN
Saddle Bolted to Steel Foundation		Yes

Shear Stress in a Single Bolt, Longitudinal Direction [taub,l]:

$$\begin{aligned}
 &= F1 / (\text{Bolt Area} * \text{Number of Bolts}) \\
 &= 35 / (2.17 * 4) \\
 &= 40.4 \text{ N./mm}^2. \text{ Must be less than } 180.0 \text{ N./mm}^2.
 \end{aligned}$$

Shear Stress in a Single Bolt, Transverse Direction [taub,t]:

$$\begin{aligned}
 &= Ft / (\text{Bolt Area} * \text{Number of Bolts}) \\
 &= 18 / (2.17 * 4) \\
 &= 20.2 \text{ N./mm}^2. \text{ Must be less than } 180.0 \text{ N./mm}^2.
 \end{aligned}$$

Bolt Area Calculation per Dennis R. Moss

Bolt Area Requirement Due to Longitudinal Load [Bltarearl]:

$$= 0.0 \text{ (} QO > QL \text{ --> No Uplift in Longitudinal direction)}$$

Bolt Area due to Shear Load [Bltarears]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 84 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

$$\begin{aligned}
 &= F1 / (BoltShearAllowable * Nbolts) \\
 &= 35.04 / (180.0 * 4.0) \\
 &= 0.4867 \text{ cm}^2
 \end{aligned}$$

Bolt Area due to Transverse Load:

Moment on Baseplate Due to Transverse Load [Rmom]:

$$\begin{aligned}
 &= B * Ft + \text{Sum of X Moments} \\
 &= 1200.0 * 17.52 + 0.0 \\
 &= 21030.99 \text{ N-m}
 \end{aligned}$$

Eccentricity (e):

$$\begin{aligned}
 &= Rmom / QO \\
 &= 21030.99 / 33.87 \\
 &= 620.59 \text{ mm.} > Bplen / 6 \rightarrow \text{Uplift in Transverse direction}
 \end{aligned}$$

$$\begin{aligned}
 f &= Bplen / 2 - Edgedis \\
 &= 1200.0 / 2 - 150.0 \\
 &= 450.00 \text{ mm.}
 \end{aligned}$$

$$\begin{aligned}
 K1 &= 3 (e - 0.5 * Bplen) \\
 &= 3 (620.59 - 0.5 * 1200.0) \\
 &= 61.77 \text{ mm.}
 \end{aligned}$$

$$\begin{aligned}
 K2 &= 6 * n1 * At / Bpwid * (f + e) \\
 &= 6 * 1.0 * 4.34 / 170.0 * (450.0 + 620.59) \\
 &= 16402.80 \text{ mm.}^2
 \end{aligned}$$

$$\begin{aligned}
 K3 &= -K2 * (0.5 * Bplen + f) \\
 &= -16402.79 * (0.5 * 1200.0 + 450.0) \\
 &= -17222935.44 \text{ mm.}^3
 \end{aligned}$$

Iteratively Solving for the Effective Bearing Length:

$$\begin{aligned}
 Y^3 + K1 * Y^2 + K2 * Y + K3 &= 0 \\
 Y^3 + 61.77 * Y^2 + 16402.79 * Y - 0.2E+08 &= 0 \\
 Y &= 219.88 \text{ mm.}
 \end{aligned}$$

$$\begin{aligned}
 Num &= (Bplen / 2 - Y / 3 - e) \\
 &= (1200.0 / 2 - 219.88 / 3 - 620.59) \\
 &= -93.88
 \end{aligned}$$

$$\begin{aligned}
 Denom &= (Bplen / 2 - Y / 3 + f) \\
 &= (1200.0 / 2 - 219.88 / 3 + 450.0) \\
 &= 976.71
 \end{aligned}$$

Total Bolt Tension Force [Tforce]:

$$\begin{aligned}
 &= - QO * Num / Denom \\
 &= - 33.87 * -93.88 / 976.71 \\
 &= 3.26 \text{ kN}
 \end{aligned}$$

Bolt Area Required due to Transverse Load [Bltareart]:

$$\begin{aligned}
 &= Tforce / (Stba * Nbt) \\
 &= 3.26 / (300.0 * 2.0) \\
 &= 0.0543 \text{ cm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 85 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Required Area of a Single Bolt [Bltarear]:

$$= \max[\text{Bltarearl}, \text{Bltarears}, \text{Bltareart}]$$

$$= \max[0.0, 0.4867, 0.0543]$$

$$= 0.4867 \text{ cm}^2$$

Baseplate Thickness Calculation per D. Moss:

Bearing Pressure (fc)

$$= 2(QO + Tforce) / (Y * Bpwid)$$

$$= 2(33.87 + 3.26) / (219.88 * 170.0)$$

$$= 19.87 \text{ bars}$$

Distance from Baseplate Edge to the Web [ADIST]:

$$= (Bplen - Weblength) / 2$$

$$= (1200.0 - 1149.2) / 2$$

$$= 25.4000 \text{ mm.}$$

Overturning Moment due To Bolt Tension [Mt]:

$$= Tforce * Adist$$

$$= 3.26 * 25.4$$

$$= 82.74 \text{ N-m}$$

Equivalent Bearing Pressure (f1):

$$= fc * (Y - Adist) / Y$$

$$= 19.87 * (219.88 - 25.4) / 219.88$$

$$= 17.57 \text{ bars}$$

Overturning Moment due to Bearing Pressure [Mc]:

$$= (Adist^2 * Bpwid / 6) * (f1 + 2 * fc)$$

$$= (25.4^2 * 170.0 / 6) * (17.57 + 2 * 19.87)$$

$$= 104.80 \text{ N-m}$$

Baseplate Required Thickness [Treq]:

$$= (6 * \max(Mt, Mc) / (Bpwid * Sba))^{1/2}$$

$$= (6 * \max(82.74, 104.8) / (170.0 * 142.73))^{1/2}$$

$$= 5.0898 \text{ mm.}$$

ASME Horizontal Vessel Analysis: Stresses for the Right Saddle

(per ASME Sec. VIII Div. 2 based on the Zick method.)

Input and Calculated Values:

Vessel Mean Radius	Rm	606.50	mm.
Stiffened Vessel Length per 4.15.6	L	6250.00	mm.
Distance from Saddle to Vessel tangent	a	850.00	mm.
Saddle Width	b	150.00	mm.
Saddle Bearing Angle	theta	120.00	degrees
Wear Plate Width	b1	260.00	mm.
Wear Plate Bearing Angle	theta1	145.00	degrees

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 86 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Wear Plate Thickness	tr	10.0	mm.
Wear Plate Allowable Stress	Sr	137.90	N./mm ²
Shell Allowable Stress used in Calculation		137.90	N./mm ²
Head Allowable Stress used in Calculation		136.40	N./mm ²
Circumferential Efficiency in Plane of Saddle		1.00	
Circumferential Efficiency at Mid-Span		1.00	
Distance from Saddle Base to Centerline	B	1200.00	mm.
Coefficient of Friction	mu	0.00	
Saddle Force Q, Operating Case		120.86	kN
Horizontal Vessel Analysis Results:	Actual Allowable	N./mm ² N./mm ²	

Long. Stress at Top of Midspan	6.68	137.90	
Long. Stress at Bottom of Midspan	28.85	137.90	
Long. Stress at Top of Saddles	29.84	137.90	
Long. Stress at Bottom of Saddles	11.07	137.90	

Tangential Shear in Shell	24.26	110.32	
Circ. Stress at Horn of Saddle	40.22	172.38	
Circ. Compressive Stress in Shell	5.22	137.90	

Intermediate Results: Saddle Reaction Q due to Wind or Seismic:

Saddle Reaction Force due to Wind Ft [Fwt]:

$$= F_{tr} (F_t / \text{Num of Saddles} + Z \text{ Force Load}) * B / E$$

$$= 3.0 (3.9/2 + 0) * 1200.0/1073.8717$$

$$= 6.6 \text{ kN}$$

Saddle Reaction Force due to Wind Fl or Friction [Fwl]:

$$= \max (F_l, \text{Friction Load, Sum of X Forces}) * B / L_s$$

$$= \max (1.58, 0.0, 0) * 1200.0/4953.3335$$

$$= 0.4 \text{ kN}$$

Saddle Reaction Force due to Earthquake Fl or Friction [Fsl]:

$$= \max (F_l, \text{Friction Force, Sum of X Forces}) * B / L_s$$

$$= \max (35.04, 0.0, 0) * 1200.0/4953.3335$$

$$= 8.5 \text{ kN}$$

Saddle Reaction Force due to Earthquake Ft [Fst]:

$$= F_{tr} (F_t / \text{Num of Saddles} + Z \text{ Force Load}) * B / E$$

$$= 3.0 (35/2 + 0) * 1200.0/1073.8717$$

$$= 58.7 \text{ kN}$$

Load Combination Results for Q + Wind or Seismic [Q]:

$$= \text{Saddle Load} + \max (F_{wl}, F_{wt}, F_{sl}, F_{st})$$

$$= 62 + \max (0.4, 7, 8, 59)$$

$$= 120.9 \text{ kN}$$

Longitudinal Wind Force [Fl]:

$$= \text{WindScalar} * \text{WindPress} (\text{Platform Area} + (\text{End Area} * \text{WindDiaMult}))$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 87 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= 0.6 * 766.08 (1.584 + (1.539 * 1.2))$$

$$= 1577.182 \text{ N}$$

Summary of Loads at the base of this Saddle:

Vertical Load (including saddle weight)	123.00	kN
Transverse Shear Load Saddle	17.52	kN
Longitudinal Shear Load Saddle	35.04	kN

Formulas and Substitutions for Horizontal Vessel Analysis:

Note: Wear Plate is Welded to the Shell, $k = 0.1$

Saddle Dimension [E]:

$$= \min(2(\text{ShellID}/2 + t + \text{WearPadThickness}) \sin(\text{theta}/2), 2 * R_m)$$

$$= \min(2(1200.0/2 + 10.0 + 10.0) \sin(60.0/2), 2 * 606.5)$$

$$= 1073.872 \text{ mm.}$$

The Computed K values from Table 4.15.1:

K1 = 0.1066	K2 = 1.1707	K3 = 0.8799	K4 = 0.4011
K5 = 0.7603	K6 = 0.0529	K7 = 0.0529	K8 = 0.3405
K9 = 0.2711	K10 = 0.0581	K1* = 0.1923	K6p = 0.0347
K7p = 0.0347			

The suffix 'p' denotes the values for a wear plate if it exists.

Note: Dimension a is greater than or equal to $R_m / 2$.

Moment per Equation 4.15.3 [M1]:

$$= -Q * a [1 - (1 - a/L + (R_m^2 - h^2) / (2a * L)) / (1 + (4h^2) / (3L))]$$

$$= -121 * 850.0 [1 - (1 - 850.0/6250.0 + (606.5^2 - 0.0^2) / (2 * 850.0 * 6250.0)) / (1 + (4 * 0.0) / (3 * 6250.0))]$$

$$= -10419.1 \text{ N-m}$$

Moment per Equation 4.15.4 [M2]:

$$= Q * L / 4 (1 + 2 (R_m^2 - h^2) / (L^2)) / (1 + (4h^2) / (3L)) - 4a/L$$

$$= 121 * 6250 / 4 (1 + 2 (607^2 - 0^2) / (6250^2)) / (1 + (4 * 0) / (3 * 6250)) - 4 * 850 / 6250$$

$$= 89706.1 \text{ N-m}$$

Longitudinal Stress at Top of Shell (4.15.6) [Sigma1]:

$$= P * R_m / (2t) - M2 / (\pi * R_m^2 * t)$$

$$= 4.1 * 606.5 / (2 * 7.0) - 89706.1 / (\pi * 606.5^2 * 7.0)$$

$$= 6.68 \text{ N./mm}^2$$

Longitudinal Stress at Bottom of Shell (4.15.7) [Sigma2]:

$$= P * R_m / (2t) + M2 / (\pi * R_m^2 * t)$$

$$= 4.1 * 606.5 / (2 * 7.0) + 89706.1 / (\pi * 606.5^2 * 7.0)$$

$$= 28.85 \text{ N./mm}^2$$

Longitudinal Stress at Top of Shell at Support (4.15.10) [Sigma*3]:

$$= P * R_m / (2t) - M1 / (K1 * \pi * R_m^2 * t)$$

$$= 4.1 * 606.5 / (2 * 7.0) - 10419.1 / (0.1066 * \pi * 606.5^2 * 7.0)$$

$$= 29.84 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>پروژه</th><th>بسته کاری</th><th>صادر کننده</th><th>تسهیلات</th><th>رشته</th><th>نوع مدرک</th><th>سریال</th><th>نسخه</th></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 88 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه																			
BK	GCS	MF	120	ME	CN	0009	V00																			

Longitudinal Stress at Bottom of Shell at Support (4.15.11) [σ^4]:

$$= P * R_m / (2t) + M1 / (K1 * \pi * R_m^2 * t)$$

$$= 4.1 * 606.5 / (2 * 7.0) + 10419.1 / (0.1923 * \pi * 606.5^2 * 7.0)$$

$$= 11.07 \text{ N./mm}^2$$

Maximum Shear Force in the Saddle (4.15.5) [T]:

$$= Q(L-2a) / (L + (4 * h^2 / 3))$$

$$= 121(6250.0 - 2 * 850.0) / (6250.0 + (4 * 0.0 / 3))$$

$$= 88.0 \text{ kN}$$

Shear Stress in the shell no rings, not stiffened (4.15.14) [τ_2]:

$$= K2 * T / (R_m * t)$$

$$= 1.1707 * 87.99 / (606.5 * 7.0)$$

$$= 24.26 \text{ N./mm}^2$$

Decay Length (4.15.22) [x_1, x_2]:

$$= 0.78 * \sqrt{R_m * t}$$

$$= 0.78 * \sqrt{606.5 * 7.0}$$

$$= 50.823 \text{ mm.}$$

Circumferential Stress in shell, no rings (4.15.23) [σ_6]:

$$= -K5 * Q * k / (t * (b + X1 + X2))$$

$$= -0.7603 * 121 * 0.1 / (7.0 * (150.0 + 50.82 + 50.82))$$

$$= -5.22 \text{ N./mm}^2$$

Effective reinforcing plate width (4.15.1) [B1]:

$$= \min(b + 1.56 * \sqrt{R_m * t}, 2a)$$

$$= \min(150.0 + 1.56 * \sqrt{606.5 * 7.0}, 2 * 850.0)$$

$$= 251.65 \text{ mm.}$$

Wear Plate/Shell Stress ratio (4.15.29) [η]:

$$= \min(S_r / S, 1)$$

$$= \min(137.9 / 137.9, 1)$$

$$= 1.0000$$

Circumferential Stress at Saddle Base with Wear Plate (4.15.26) [σ_6, r]:

$$= -K5 * Q * k / (B1(t + \eta * t_r))$$

$$= -0.7603 * 121 * 0.1 / (251.646(7.0 + 1.0 * 10.0))$$

$$= -2.15 \text{ N./mm}^2$$

Circ. Comp. Stress at Horn of Saddle, $L \geq 8R_m$ (4.15.27) [σ_7, r]:

$$= -Q / (4(t + \eta * t_r) b1) - 3 * K7 * Q / (2(t + \eta * t_r)^2)$$

$$= -121 / (4(7.0 + 1.0 * 10.0) 251.646) -$$

$$3 * 0.053 * 121 / (2(7.0 + 1.0 * 10.0)^2)$$

$$= -40.22 \text{ N./mm}^2$$

Results for Vessel Ribs, Web and Base:

Baseplate Length	Bplen	1200.0000	mm.
Baseplate Thickness	Bpthk	15.0000	mm.
Baseplate Width	Bpwid	170.0000	mm.
Number of Ribs (inc. outside ribs)	Nribs	4	
Rib Thickness	Ribtk	15.0000	mm.
Web Thickness	Webtk	15.0000	mm.
Web Location	Webloc	Center	



خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)

شماره پیمان:

053-073-9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 89 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

Saddle Yield Stress	Sy	239.9	N./
Height of Web at Center	Hw, c	585.0	mm.
Friction Coefficient	mu	0.000	

Note: In the tables below I_o is I for the rectangle + Area * Centroid Distance²

Moment of Inertia of Saddle - Transverse Direction (90 degrees to long axis)

	B	D	Y	A	AY	Io
Shell	361.4	7.0	3.5	25.3	8853.1	0.157E+05
Wearplate	260.0	10.0	12.0	26.0	31200.0	0.151E+05
Web	15.0	565.0	299.5	84.8	2538262.8	0.244E+05
BasePlate	170.0	15.0	589.5	25.5	1503225.0	0.289E+05
Totals	...	...	...	161.5	4081541.2	0.841E+05

Distance to Centroid [C1]:

$$= 252.657 \text{ mm.}$$

Angle [beta]:

```
= 180 - Saddle Angle/2
= 180 - 120.0/2
= 120.0
```

Saddle Splitting Coefficient [K1]:

```
= ( 1 + cos(beta) - 0.5*sin(beta)^2 )/(pi - beta + sin(beta)cos(beta) )
= ( 1 + cos(120.0) - 0.5*sin(120.0)^2 )/(pi - 2.094 + sin(120.0)cos(120.0) )
= 0.2035
```

Saddle Splitting Force [Fh]:

$$= 0.204 \cdot 120.86 = 24.5977 \text{ kN}$$

Tension Stress, St = (Fh/As)	=	1.8055	N./mm ²
Allowed Stress, Sa = 0.6 * Yield Str	=	143.9676	N./mm ²

Saddle Splitting Dimension [d]:

```
= B - R * sin(theta/2)/(theta/2 in radians)
= 1200.0 - 603.0 * sin(120.0/2)/1.0472
= 701.323 mm.
```

$$\text{Bending Moment, } M = Fh * d = 17257.9473 \text{ N-m}$$

Bending Stress, $S_b = (M * C1 / I) = 5.1826 \text{ N./mm}^2$
 Allowed Stress, $S_a = 2/3 * \text{Yield Str} = 159.9640 \text{ N./mm}^2$

Minimum Thickness of Baseplate per Moss:

$$= (3(Q + \text{Saddle_Wt}) \text{BasePlateWidth} / (4 * \text{BasePlateLength} * \text{AllStress}))^{1/2}$$

$$= (3(121 + 2)170.0 / (4 * 1200.0 * 159.964))^{1/2}$$

$$= 9.039 \text{ mm.}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 90 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Calculation of Axial Load, Intermediate Values and Compressive Stress:

Web Length Dimension [Web Length]:

$$\begin{aligned}
 &= 2 * \cos(90 - \text{Saddle Angle}/2) (\text{Inside Radius} + \text{Shell Thk} + \text{Wear Plate Thk}) \\
 &= 2 * \cos(90 - 120.0/2) (600.0 + 10.0 + 10.0) \\
 &= 1073.872 \text{ mm.}
 \end{aligned}$$

Distance between Ribs [e]:

$$\begin{aligned}
 &= \text{Web Length} / (\text{Nr ribs} - 1) \\
 &= 1073.8716 / (4 - 1) \\
 &= 357.957 \text{ mm.}
 \end{aligned}$$

Baseplate Pressure Area [Ap]:

$$\begin{aligned}
 &= e * \text{Bpwid} / 2 \\
 &= 357.9572 * 170.0/2 \\
 &= 304.264 \text{ cm}^2
 \end{aligned}$$

Bearing Pressure [Bp]:

$$\begin{aligned}
 &= Q / (\text{BasePlateLength} * \text{BasePlateWidth}) \\
 &= 120.86 / (1200.0 * 170.0) \\
 &= 0.059 \text{ kN/cm}^2
 \end{aligned}$$

Axial Load [P]:

$$\begin{aligned}
 &= \text{Ap} * \text{Bp} \\
 &= 304.3 * 0.06 \\
 &= 18.026 \text{ kN}
 \end{aligned}$$

Area of the Rib and Web [Ar]:

$$\begin{aligned}
 &= \text{Rib Area} + \text{Web Area} \\
 &= 20.25 + 26.847 \\
 &= 47.097 \text{ cm}^2
 \end{aligned}$$

Compressive Stress [Sc]:

$$\begin{aligned}
 &= P/\text{Ar} \\
 &= 18.0/47.0968 \\
 &= 3.828 \text{ N./mm}^2
 \end{aligned}$$

Check of Outside Ribs:

Inertia of Saddle, Outer Ribs - Longitudinal Direction

	B	D	Y	A	AY	I _o
-----	-----	-----	-----	-----	-----	-----
Rib+Web	15.0	150.0	...	22.5	...	422.

Rib dimension [D]:

$$\begin{aligned}
 &= \text{Saddle Width} - \text{Web Thickness} \\
 &= 150.0 - 15.0 \\
 &= 135.000 \text{ mm.}
 \end{aligned}$$

Distance to Centroid from Datum [ytot]:

$$\begin{aligned}
 &= \text{AY} / \text{A} \\
 &= 0.0/47.097 \\
 &= 0.000 \text{ mm.}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 91 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Distance to Centroid [C1]:

$$= \text{Saddle Width} / 2$$

$$= 150.0/2$$

$$= 75.000 \text{ mm.}$$

Radius of Gyration [r]:

$$= \sqrt{\text{Total Inertia} / \text{Total Area}}$$

$$= \sqrt{421.9/47.097}$$

$$= 29.929 \text{ mm.}$$

Length of Outer Rib [L]:

$$= \text{Saddle Height} - \cos(\theta/2) (\text{radius} + \text{shlthk} + \text{wpdthk}) - \text{bpthk}$$

$$= 1200.0 - \cos(120.0/2) (600.0 + 10.0 + 10.0) - 15.0$$

$$= 875.000 \text{ mm.}$$

Intermediate Term [Cc]:

$$= \sqrt{2 * \pi^2 * \text{Elastic Modulus} / \text{Yield Stress}}$$

$$= \sqrt{2 * \pi^2 * 0.19994\text{E}+09/239.9}$$

$$= 128.255$$

Slenderness ratio [KL/r]:

$$= KL/r$$

$$= 1 * 875.0/29.929$$

$$= 29.236$$

Bending Moment [Rm]:

$$= F1 / (2 * B_{plen}) * e * L / 2$$

$$= 35.0 / (2 * 1200.0) * 357.957 * 875.0/2$$

$$= 2287.212 \text{ N-m}$$

Compressive Allowable, $KL/r < Cc$ ($29.2356 < 128.2549$) per AISC E2-1 [Sca]:

$$= (1 - (KL/r)^2 / (2 * Cc^2)) F_y / (5/3 + 3 * (KL/r) / (8 * Cc)) - (KL/r^3) / (8 * Cc^3)$$

$$= (1 - (29.24)^2 / (2 * 128.25^2)) 240 /$$

$$(5/3 + 3 * (29.24) / (8 * 128.25)) - (29.24^3) / (8 * 128.25^3)$$

$$= 133.5 \text{ N./mm}^2$$

AISC Unity Check of Outside Ribs (must be ≤ 1)

$$= S_c/S_{ca} + (R_m * C1 / I) / S_{ba}$$

$$= 3.83/133.5 + (2287.21 * 75.0/4218750) / 159.96$$

$$= 0.283$$

Check of Inside Ribs:

Inertia of Saddle, Inner Ribs - Axial Direction

	B	D	Y	A	AY	Io
Rib	15.0	135.0	0.0	20.2	0.0	421.
Web	358.0	15.0	0.0	53.7	0.0	10.1
Totals	...	...	...	73.9	...	432.

Distance to Centroid from Datum [ytot]:

$$= AY / A$$

$$= 0.0/73.944$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 92 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

= 0.000 mm.

Distance to Centroid [C1]:

= Saddle Width / 2
= 150.0/2
= 75.000 mm.

Length of Inner Rib [L]:

= Saddle Height - sqrt((Ro + Wpdthk)^2 - (Pitch/2)^2) - Bpthk
= 1200.0 - sqrt((620.0 + 10.0)^2 - (357.957/2)^2) - 15.0
= 591.395 mm.

Radius of Gyration [r]:

= sqrt(Total Inertia / Total Area)
= sqrt(431.5/73.944)
= 24.157 mm.

Slenderness ratio [KL/r]:

= KL/r
= 1 * 591.395/24.157
= 24.481

Unit Force [Force,u]:

= F1 / (2 * Baseplate Length)
= 35.037/(2 * 1200.0)
= 0.015 kN/mm.

Moment at base of inner Rib [Mbase,c]:

= Unit Force * e * L
= 0.015 * 357.957 * 591.395
= 3091.762 N-m

Bending Stress due to Transverse Force and Weight Load [SigmaB,base,c]:

= Bending Moment / Section Modulus
= 3091.762/57536.086
= 53.719 N./mm²

Compressive Allowable, KL/r < Cc (24.4809 < 128.2549) per AISC E2-1 [Sca]:

= (1 - (KL/r)² / (2*Cc²)) Fy / (5/3 + 3*(KL/r) / (8*Cc) - (KL/r)³ / (8*Cc³))
= (1 - (24.48)² / (2 * 128.25²)) 240 /
(5/3 + 3*(24.48) / (8* 128.25) - (24.48³) / (8*128.25³))
= 135.6 N./mm²

AISC Unity Check of Inside Ribs (must be <= 1)

= Sc/Sca + (Mbase,c * C1/I)/Sba
= 4.93/135.59 + (3091.76 * 75.0/431.52)/159.96
= 0.372

Input Data for Base Plate Bolting Calculations:

Total Number of Bolts per BasePlate	Nbolts	4
Total Number of Bolts in Tension/Baseplate	Nbt	2
Bolt Material Specification	SA-193 B7	
Bolt Allowable Stress	Stba	300.00 N./mm ²
Bolt Corrosion Allowance	Bca	0.0 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 93 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Distance from Bolts to Edge	Edgedis	150.0	mm.
Nominal Bolt Diameter	Bnd	20.0000	mm.
Thread Series	Series	TEMA	Metric
BasePlate Allowable Stress	S	95.15	N./mm ²
Area Available in a Single Bolt	BltArea	2.1705	cm ²
Saddle Load QO (Weight)	QO	64.3	kN
Saddle Load QL (Wind/Seismic contribution)	QL	8.5	kN
Maximum Transverse Force	Ft	17.5	kN
Maximum Longitudinal Force	F1	35.0	kN
Saddle Bolted to Steel Foundation		Yes	

Shear Stress in a Single Bolt, Transverse Direction [taub,t]:

$$= F_t / (\text{Bolt Area} * \text{Number of Bolts})$$

$$= 18 / (2.17 * 4)$$

$$= 20.2 \text{ N./mm}^2. \text{ Must be less than } 180.0 \text{ N./mm}^2.$$

Bolt Area Calculation per Dennis R. Moss

Bolt Area Requirement Due to Longitudinal Load [Bltarearl]:

$$= 0.0 \text{ (} Q_O > Q_L \text{ --> No Uplift in Longitudinal direction)}$$

Bolt Area due to Shear Load [Bltarears]:

$$= F_1 / (\text{BoltShearAllowable} * \text{Nbolts})$$

$$= 35.04 / (180.0 * 4.0)$$

$$= 0.4867 \text{ cm}^2$$

Bolt Area due to Transverse Load:

Moment on Baseplate Due to Transverse Load [Rmom]:

$$= B * F_t + \text{Sum of X Moments}$$

$$= 1200.0 * 17.52 + 0.0$$

$$= 21030.99 \text{ N-m}$$

Eccentricity (e):

$$= R_{mom} / Q_O$$

$$= 21030.99 / 64.27$$

$$= 327.10 \text{ mm.} > B_{plen} / 6 \text{ --> Uplift in Transverse direction}$$

$$f = B_{plen} / 2 - \text{Edgedis}$$

$$= 1200.0 / 2 - 150.0$$

$$= 450.00 \text{ mm.}$$

$$K_1 = 3 (e - 0.5 * B_{plen})$$

$$= 3 (327.1 - 0.5 * 1200.0)$$

$$= -818.70 \text{ mm.}$$

$$K_2 = 6 * n_1 * A_t / B_{pwid} * (f + e)$$

$$= 6 * 1.0 * 4.34 / 170.0 * (450.0 + 327.1)$$

$$= 11906.14 \text{ mm.}^2$$

$$K_3 = -K_2 * (0.5 * B_{plen} + f)$$

$$= -11906.14 * (0.5 * 1200.0 + 450.0)$$

$$= -12501447.61 \text{ mm.}^3$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 94 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Iteratively Solving for the Effective Bearing Length:

$$Y^3 + K1 * Y^2 + K2 * Y + K3 = 0$$

$$Y^3 + -818.7 * Y^2 + 11906.14 * Y + -0.1E+08 = 0$$

$$Y = 822.70 \text{ mm.}$$

$$\text{Num} = (\text{Bplen} / 2 - Y / 3 - e)$$

$$= (1200.0/2 - 822.7/3 - 327.1)$$

$$= -1.33$$

$$\text{Denom} = (\text{Bplen} / 2 - Y / 3 + f)$$

$$= (1200.0/2 - 822.7/3 + 450.0)$$

$$= 775.77$$

Total Bolt Tension Force [Tforce]:

$$= - QO * \text{Num} / \text{Denom}$$

$$= - 64.27 * -1.33/775.77$$

$$= 0.11 \text{ kN}$$

Bolt Area Required due to Transverse Load [Bltareart]:

$$= \text{Tforce} / (\text{Stba} * \text{Nbt})$$

$$= 0.11 / (300.0 * 2.0)$$

$$= 0.0018 \text{ cm}^2$$

Required Area of a Single Bolt [Bltarearl]:

$$= \max[\text{Bltarearl}, \text{Bltarears}, \text{Bltareart}]$$

$$= \max[0.0, 0.4867, 0.0018]$$

$$= 0.4867 \text{ cm}^2$$

Baseplate Thickness Calculation per D. Moss:

Bearing Pressure (fc)

$$= 2(QO + \text{Tforce}) / (Y * \text{Bpwid})$$

$$= 2(64.27 + 0.11) / (822.7 * 170.0)$$

$$= 9.21 \text{ bars}$$

Distance from Baseplate Edge to the Web [ADIST]:

$$= (\text{Bplen} - \text{Weblngth}) / 2$$

$$= (1200.0 - 1149.2) / 2$$

$$= 25.4000 \text{ mm.}$$

Overturning Moment due To Bolt Tension [Mt]:

$$= \text{Tforce} * \text{Adist}$$

$$= 0.11 * 25.4$$

$$= 2.81 \text{ N-m}$$

Equivalent Bearing Pressure (f1):

$$= f_c * (Y - \text{Adist}) / Y$$

$$= 9.21 * (822.7 - 25.4) / 822.7$$

$$= 8.92 \text{ bars}$$

Overturning Moment due to Bearing Pressure [Mc]:

$$= (\text{Adist}^2 * \text{Bpwid} / 6) * (f1 + 2 * f_c)$$

$$= (25.4^2 * 170.0/6) * (8.92 + 2 * 9.21)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 95 از 411
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	
	V00	0009	CN	ME	120	MF	GCS	
BK	GCS	MF	120	ME	CN	0009	V00	

$$= 49.99 \text{ N-m}$$

Baseplate Required Thickness [Treq]:

$$= (6 * \max(Mt, Mc) / (Bpwid * Sba))^{1/2}$$

$$= (6 * \max(2.81, 49.99 / (170.0 * 142.73))^{1/2}$$

$$= 3.5153 \text{ mm.}$$

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 96 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

ASME Horizontal Vessel Analysis: Stresses for the Left Saddle

(per ASME Sec. VIII Div. 2 based on the Zick method.)

Horizontal Vessel Stress Calculations : Test Case

Input and Calculated Values:

Vessel Mean Radius	Rm	606.50	mm.
Stiffened Vessel Length per 4.15.6	L	6250.00	mm.
Distance from Saddle to Vessel tangent	a	850.00	mm.
Saddle Width	b	150.00	mm.
Saddle Bearing Angle	theta	120.00	degrees
Wear Plate Width	b1	260.00	mm.
Wear Plate Bearing Angle	theta1	145.00	degrees
Wear Plate Thickness	tr	10.0	mm.
Wear Plate Allowable Stress	Sr	137.90	N./mm ²
Inside Depth of Head	h2	303.00	mm.
Shell Allowable Stress used in Calculation		196.73	N./mm ²
Head Allowable Stress used in Calculation		196.73	N./mm ²
Circumferential Efficiency in Plane of Saddle		1.00	
Circumferential Efficiency at Mid-Span		1.00	
Distance from Saddle Base to Centerline	B	1200.00	mm.
Coefficient of Friction	mu	0.30	
Saddle Force Q, Test Case, no Ext. Forces		76.88	kN

Horizontal Vessel Analysis Results:	Actual	Allowable
	N./mm ²	N./mm ²
-----	-----	-----
Long. Stress at Top of Midspan	17.28	196.73
Long. Stress at Bottom of Midspan	29.42	196.73
Long. Stress at Top of Saddles	35.78	196.73
Long. Stress at Bottom of Saddles	16.46	196.73
-----	-----	-----
Tangential Shear in Shell	14.50	139.65
Circ. Stress at Horn of Saddle	25.58	295.10
Circ. Compressive Stress in Shell	3.32	196.73
-----	-----	-----

Intermediate Results: Saddle Reaction Q due to Wind or Seismic:

Saddle Reaction Force due to Wind Ft [Fwt]:

$$\begin{aligned}
 &= F_{tr} (F_t / \text{Num of Saddles} + Z \text{ Force Load}) * B / E \\
 &= 3.0 (1.3/2 + 0) * 1200.0/1073.8717 \\
 &= 2.2 \text{ kN}
 \end{aligned}$$

Saddle Reaction Force due to Wind Fl or Friction [Fwl]:

$$\begin{aligned}
 &= \max (F_l, \text{Friction Load, Sum of X Forces}) * B / L_s \\
 &= \max (0.52, 0.0, 0) * 1200.0/4953.3335
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 97 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= 0.1 \text{ kN}$$

Load Combination Results for Q + Wind or Seismic [Q]:

$$= \text{Saddle Load} + \max(F_{w1}, F_{w2}, F_{s1}, F_{s2})$$

$$= 75 + \max(0.1, 2, 0, 0)$$

$$= 76.9 \text{ kN}$$

Longitudinal Wind Force [F]:

$$= \text{WindScalar} * \text{WindPress}(\text{Platform Area} + (\text{End Area} * \text{WindDiaMult}))$$

$$= 0.6 * 766.08(1.584 + (1.539 * 1.2))$$

$$= 1577.182 \text{ N}$$

Summary of Loads at the base of this Saddle:

Vertical Load (including saddle weight)	79.02	kN
Transverse Shear Load Saddle	0.65	kN
Longitudinal Shear Load Saddle	0.52	kN

Hydrostatic Test Pressure at center of Vessel 5.389 bars

Formulas and Substitutions for Horizontal Vessel Analysis:

Note: Wear Plate is Welded to the Shell, $k = 0.1$

Saddle Dimension [E]:

$$= \min(2(\text{ShellID}/2 + t + \text{WearPadThickness})\sin(\theta/2), 2R_m)$$

$$= \min(2(1200.0/2 + 10.0 + 10.0)\sin(60.0/2), 2*606.5)$$

$$= 1073.872 \text{ mm.}$$

The Computed K values from Table 4.15.1:

K1 = 0.1066	K2 = 1.1707	K3 = 0.8799	K4 = 0.4011
K5 = 0.7603	K6 = 0.0529	K7 = 0.0529	K8 = 0.3405
K9 = 0.2711	K10 = 0.0581	K1* = 0.1923	K6p = 0.0347
K7p = 0.0347			

The suffix 'p' denotes the values for a wear plate if it exists.

Note: Dimension a is greater than or equal to $R_m / 2$.

Moment per Equation 4.15.3 [M1]:

$$= -Q*a[1 - (1 - a/L + (R_m^2 - h^2)/(2a*L))/(1 + (4h^2)/(3L))]$$

$$= -77*850.0[1 - (1 - 850.0/6250.0 + (606.5^2 - 303.0^2)/(2*850.0*6250.0))/(1 + (4*303.0)/(3*6250.0))]$$

$$= -10724.8 \text{ N-m}$$

Moment per Equation 4.15.4 [M2]:

$$= Q*L/4(1 + 2(R_m^2 - h^2)/(L^2))/(1 + (4h^2)/(3L)) - 4a/L$$

$$= 77*6250/4(1 + 2(607^2 - 303^2)/(6250^2))/(1 + (4*303)/(3*6250)) - 4*850/6250$$

$$= 49097.0 \text{ N-m}$$

Longitudinal Stress at Top of Shell (4.15.6) [Sigma1]:

$$= P * R_m/(2t) - M2/(pi*R_m^2*t)$$

$$= 5.389 * 606.5/(2*7.0) - 49097.0/(pi*606.5^2*7.0)$$

$$= 17.28 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 98 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Longitudinal Stress at Bottom of Shell (4.15.7) [Sigma2]:

$$= P * R_m / (2t) + M_2 / (\pi * R_m^2 * t)$$

$$= 5.389 * 606.5 / (2 * 7.0) + 49097.0 / (\pi * 606.5^2 * 7.0)$$

$$= 29.42 \text{ N./mm}^2$$

Longitudinal Stress at Top of Shell at Support (4.15.10) [Sigma*3]:

$$= P * R_m / (2t) - M_1 / (K_1 * \pi * R_m^2 * t)$$

$$= 5.389 * 606.5 / (2 * 7.0) - 10724.8 / (0.1066 * \pi * 606.5^2 * 7.0)$$

$$= 35.78 \text{ N./mm}^2$$

Longitudinal Stress at Bottom of Shell at Support (4.15.11) [Sigma*4]:

$$= P * R_m / (2t) + M_1 / (K_1 * \pi * R_m^2 * t)$$

$$= 5.389 * 606.5 / (2 * 7.0) + 10724.8 / (0.1923 * \pi * 606.5^2 * 7.0)$$

$$= 16.46 \text{ N./mm}^2$$

Maximum Shear Force in the Saddle (4.15.5) [T]:

$$= Q(L-2a) / (L + (4 * h^2 / 3))$$

$$= 77(6250.0 - 2 * 850.0) / (6250.0 + (4 * 303.0 / 3))$$

$$= 52.6 \text{ kN}$$

Shear Stress in the shell no rings, not stiffened (4.15.14) [tau2]:

$$= K_2 * T / (\pi * R_m * t)$$

$$= 1.1707 * 52.57 / (\pi * 606.5 * 7.0)$$

$$= 14.50 \text{ N./mm}^2$$

Decay Length (4.15.22) [x1,x2]:

$$= 0.78 * \sqrt{R_m * t}$$

$$= 0.78 * \sqrt{606.5 * 7.0}$$

$$= 50.823 \text{ mm.}$$

Circumferential Stress in shell, no rings (4.15.23) [sigma6]:

$$= -K_5 * Q * k / (t * (b + x_1 + x_2))$$

$$= -0.7603 * 77 * 0.1 / (7.0 * (150.0 + 50.82 + 50.82))$$

$$= -3.32 \text{ N./mm}^2$$

Effective reinforcing plate width (4.15.1) [B1]:

$$= \min(b + 1.56 * \sqrt{R_m * t}, 2a)$$

$$= \min(150.0 + 1.56 * \sqrt{606.5 * 7.0}, 2 * 850.0)$$

$$= 251.65 \text{ mm.}$$

Wear Plate/Shell Stress ratio (4.15.29) [eta]:

$$= 1.0000 \text{ Materials are the same, test case}$$

Circumferential Stress at Saddle Base with Wear Plate (4.15.26) [sigma6,r]:

$$= -K_5 * Q * k / (B_1(t + \eta * t_r))$$

$$= -0.7603 * 77 * 0.1 / (251.646(7.0 + 1.0 * 10.0))$$

$$= -1.37 \text{ N./mm}^2$$

Circ. Comp. Stress at Horn of Saddle, L>=8Rm (4.15.27) [sigma7,r]:

$$= -Q / (4(t + \eta * t_r) b_1) - 3 * K_7 * Q / (2(t + \eta * t_r)^2)$$

$$= -77 / (4(7.0 + 1.0 * 10.0) 251.646) - 3 * 0.053 * 77 / (2(7.0 + 1.0 * 10.0)^2)$$

$$= -25.58 \text{ N./mm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 99 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Results for Vessel Ribs, Web and Base:

Baseplate Length	Bplen	1200.0000	mm.
Baseplate Thickness	Bpthk	15.0000	mm.
Baseplate Width	Bpwid	170.0000	mm.
Number of Ribs (inc. outside ribs)	Nribs	4	
Rib Thickness	Ribtk	15.0000	mm.
Web Thickness	Webtk	15.0000	mm.
Web Location	Webloc	Center	
Saddle Yield Stress	Sy	239.9	N./
Height of Web at Center	Hw,c	585.0	mm.
Friction Coefficient	mu	0.300	

Note: In the tables below I_o is I for the rectangle + Area * Centroid Distance²

Moment of Inertia of Saddle - Transverse Direction (90 degrees to long axis)

	B	D	Y	A	AY	I _o
Shell	361.4	7.0	3.5	25.3	8853.1	0.157E+05
Wearplate	260.0	10.0	12.0	26.0	31200.0	0.151E+05
Web	15.0	565.0	299.5	84.8	2538262.8	0.244E+05
BasePlate	170.0	15.0	589.5	25.5	1503225.0	0.289E+05
Totals	...	...	...	161.5	4081541.2	0.841E+05

Distance to Centroid [C1]:

$$\begin{aligned}
 &= AY / A \\
 &= 1606.906 / 161.545 \\
 &= 252.657 \text{ mm.}
 \end{aligned}$$

Angle [beta]:

$$\begin{aligned}
 &= 180 - \text{Saddle Angle} / 2 \\
 &= 180 - 120.0 / 2 \\
 &= 120.0
 \end{aligned}$$

Saddle Splitting Coefficient [K1]:

$$\begin{aligned}
 &= (1 + \cos(\beta) - 0.5 \sin^2(\beta)) / (\pi - \beta + \sin(\beta) \cos(\beta)) \\
 &= (1 + \cos(120.0) - 0.5 \sin^2(120.0)) / (\pi - 2.094 + \sin(120.0) \cos(120.0)) \\
 &= 0.2035
 \end{aligned}$$

Saddle Splitting Force [Fh]:

$$\begin{aligned}
 &= K1 * Q \\
 &= 0.204 * 76.878 \\
 &= 15.6464 \text{ kN}
 \end{aligned}$$

$$\begin{aligned}
 \text{Tension Stress, } St &= (Fh / A_s) = 1.1485 \text{ N./mm}^2 \\
 \text{Allowed Stress, } Sa &= 0.6 * \text{Yield Str} = 143.9676 \text{ N./mm}^2
 \end{aligned}$$

Saddle Splitting Dimension [d]:

$$\begin{aligned}
 &= B - R * \sin(\theta/2) / (\theta/2 \text{ in radians}) \\
 &= 1200.0 - 603.0 * \sin(120.0/2) / 1.0472 \\
 &= 701.323 \text{ mm.}
 \end{aligned}$$

$$\text{Bending Moment, } M = Fh * d = 10977.6348 \text{ N-m}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 100 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$\begin{aligned} \text{Bending Stress, } S_b &= (M * C_1 / I) = 3.2966 \text{ N./mm}^2 \\ \text{Allowed Stress, } S_a &= 2/3 * \text{Yield Str} = 159.9640 \text{ N./mm}^2 \end{aligned}$$

Minimum Thickness of Baseplate per Moss:

$$\begin{aligned} &= (3(Q + \text{Saddle_Wt}) \text{BasePlateWidth} / (4 * \text{BasePlateLength} * \text{AllStress}))^{1/2} \\ &= (3(77 + 2)170.0 / (4 * 1200.0 * 159.964))^{1/2} \\ &= 7.245 \text{ mm.} \end{aligned}$$

Calculation of Axial Load, Intermediate Values and Compressive Stress:

Web Length Dimension [Web Length]:

$$\begin{aligned} &= 2 * \cos(90 - \text{Saddle Angle}/2) (\text{Inside Radius} + \text{Shell Thk} + \text{Wear Plate Thk}) \\ &= 2 * \cos(90 - 120.0/2) (600.0 + 10.0 + 10.0) \\ &= 1073.872 \text{ mm.} \end{aligned}$$

Distance between Ribs [e]:

$$\begin{aligned} &= \text{Web Length} / (\text{Nr ribs} - 1) \\ &= 1073.8716 / (4 - 1) \\ &= 357.957 \text{ mm.} \end{aligned}$$

Baseplate Pressure Area [Ap]:

$$\begin{aligned} &= e * \text{Bpwid} / 2 \\ &= 357.9572 * 170.0/2 \\ &= 304.264 \text{ cm}^2 \end{aligned}$$

Bearing Pressure [Bp]:

$$\begin{aligned} &= Q / (\text{BasePlateLength} * \text{BasePlateWidth}) \\ &= 76.878 / (1200.0 * 170.0) \\ &= 0.038 \text{ kN/cm}^2 \end{aligned}$$

Axial Load [P]:

$$\begin{aligned} &= A_p * B_p \\ &= 304.3 * 0.04 \\ &= 11.466 \text{ kN} \end{aligned}$$

Area of the Rib and Web [Ar]:

$$\begin{aligned} &= \text{Rib Area} + \text{Web Area} \\ &= 20.25 + 26.847 \\ &= 47.097 \text{ cm}^2 \end{aligned}$$

Compressive Stress [Sc]:

$$\begin{aligned} &= P / A_r \\ &= 11.5 / 47.0968 \\ &= 2.435 \text{ N./mm}^2 \end{aligned}$$

Check of Outside Ribs:

Inertia of Saddle, Outer Ribs - Longitudinal Direction

	B	D	Y	A	AY	Io
-----	-----	-----	-----	-----	-----	-----
Rib+Web	15.0	150.0	...	22.5	...	422.

Rib dimension [D]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 101 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

= Saddle Width - Web Thickness
= 150.0 - 15.0
= 135.000 mm.

Distance to Centroid from Datum [ytot]:
= AY / A
= 0.0/47.097
= 0.000 mm.

Distance to Centroid [C1]:
= Saddle Width / 2
= 150.0/2
= 75.000 mm.

Radius of Gyration [r]:
= sqrt(Total Inertia / Total Area)
= sqrt(421.9/47.097)
= 29.929 mm.

Length of Outer Rib [L]:
= Saddle Height - cos(theta/2) (radius + shlthk + wpdthk) - bpthk
= 1200.0 - cos(120.0/2) (600.0 + 10.0 + 10.0) - 15.0
= 875.000 mm.

Intermediate Term [Cc]:
= sqrt(2 * pi² * Elastic Modulus / Yield Stress)
= sqrt(2 * pi² * 0.19994E+09/239.9)
= 128.255

Slenderness ratio [KL/r]:
= KL/r
= 1 * 875.0/29.929
= 29.236

Bending Moment [Rm]:
= Fl / (2 * Bplen) * e * L / 2
= 0.5 / (2 * 1200.0) * 357.957 * 875.0/2
= 33.974 N-m

Compressive Allowable, KL/r < Cc (29.2356 < 128.2549) per AISC E2-1 [Sca]:
= (1 - (KLr)² / (2 * Cc²)) Fy / (5/3 + 3 * (KLr) / (8 * Cc) - (KLr)³ / (8 * Cc³))
= (1 - (29.24)² / (2 * 128.25²)) 240 /
(5/3 + 3 * (29.24) / (8 * 128.25) - (29.24³) / (8 * 128.25³))
= 133.5 N./mm²

AISC Unity Check of Outside Ribs (must be <= 1)
= Sc/Sca + (Rm * C1 / I) / Sba
= 2.43/133.5 + (33.97 * 75.0/4218750) / 159.96
= 0.022

Check of Inside Ribs:

Inertia of Saddle, Inner Ribs - Axial Direction

B | D | Y | A | AY | Io |

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 102 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Rib	15.0		135.0		0.0		20.2		0.0		421.	
Web	358.0		15.0		0.0		53.7		0.0		10.1	
Totals	...		...		...		73.9		...		432.	

Distance to Centroid from Datum [ytot]:

$$= AY / A$$

$$= 0.0/73.944$$

$$= 0.000 \text{ mm.}$$

Distance to Centroid [C1]:

$$= \text{Saddle Width} / 2$$

$$= 150.0/2$$

$$= 75.000 \text{ mm.}$$

Length of Inner Rib [L]:

$$= \text{Saddle Height} - \sqrt{(\text{Ro} + \text{Wpdthk})^2 - (\text{Pitch}/2)^2} - \text{Bpthk}$$

$$= 1200.0 - \sqrt{(620.0 + 10.0)^2 - (357.957/2)^2} - 15.0$$

$$= 591.395 \text{ mm.}$$

Radius of Gyration [r]:

$$= \sqrt{\text{Total Inertia} / \text{Total Area}}$$

$$= \sqrt{431.5/73.944}$$

$$= 24.157 \text{ mm.}$$

Slenderness ratio [KL/r]:

$$= KL/r$$

$$= 1 * 591.395/24.157$$

$$= 24.481$$

Unit Force [Force,u]:

$$= F1 / (2 * \text{Baseplate Length})$$

$$= 0.52/(2 * 1200.0)$$

$$= 0.000 \text{ kN/mm.}$$

Moment at base of inner Rib [Mbase,c]:

$$= \text{Unit Force} * e * L$$

$$= 0. * 357.957 * 591.395$$

$$= 45.925 \text{ N-m}$$

Bending Stress due to Transverse Force and Weight Load [SigmaB,base,c]:

$$= \text{Bending Moment} / \text{Section Modulus}$$

$$= 45.925/57536.086$$

$$= 0.798 \text{ N./mm}^2$$

Compressive Allowable, $KL/r < Cc$ ($24.4809 < 128.2549$) per AISC E2-1 [Sca]:

$$= (1 - (KL/r)^2 / (2 * Cc^2)) Fy / (5/3 + 3 * (KL/r) / (8 * Cc) - (KL/r^3) / (8 * Cc^3))$$

$$= (1 - (24.48)^2 / (2 * 128.25^2)) 240 / (5/3 + 3 * (24.48) / (8 * 128.25) - (24.48^3) / (8 * 128.25^3))$$

$$= 135.6 \text{ N./mm}^2$$

AISC Unity Check of Inside Ribs (must be ≤ 1)

$$= Sc/Sca + (Mbase,c * C1/I) / Sba$$

$$= 3.14/135.59 + (45.92 * 75.0/431.52) / 159.96$$

$$= 0.028$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 103 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input Data for Base Plate Bolting Calculations:

Total Number of Bolts per BasePlate	Nbolts	4
Total Number of Bolts in Tension/Baseplate	Nbt	2
Bolt Material Specification		SA-193 B7
Bolt Allowable Stress	Stba	300.00 N./mm ²
Bolt Corrosion Allowance	Bca	0.0 mm.
Distance from Bolts to Edge	Edgedis	150.0 mm.
Nominal Bolt Diameter	Bnd	20.0000 mm.
Thread Series	Series	TEMA Metric
BasePlate Allowable Stress	S	95.15 N./mm ²
Area Available in a Single Bolt	BlArea	2.1705 cm ²
Saddle Load QO (Weight)	QO	76.8 kN
Saddle Load QL (Wind/Seismic contribution)	QL	0.1 kN
Maximum Transverse Force	Ft	0.6 kN
Maximum Longitudinal Force	Fl	0.5 kN
Saddle Bolted to Steel Foundation		Yes

Shear Stress in a Single Bolt, Longitudinal Direction [taub,l]:

$$= Fl / (Bolt Area * Number of Bolts)$$

$$= 0.5 / (2.17 * 4)$$

$$= 0.6 \text{ N./mm}^2. \text{ Must be less than } 180.0 \text{ N./mm}^2.$$

Shear Stress in a Single Bolt, Transverse Direction [taub,t]:

$$= Ft / (Bolt Area * Number of Bolts)$$

$$= 0.6 / (2.17 * 4)$$

$$= 0.7 \text{ N./mm}^2. \text{ Must be less than } 180.0 \text{ N./mm}^2.$$

Bolt Area Calculation per Dennis R. Moss

Bolt Area Requirement Due to Longitudinal Load [Bltarearl]:

$$= 0.0 \text{ (} QO > QL \text{ --> No Uplift in Longitudinal direction)}$$

Bolt Area due to Shear Load [Bltarears]:

$$= Fl / (BoltShearAllowable * Nbolts)$$

$$= 0.52 / (180.0 * 4.0)$$

$$= 0.0072 \text{ cm}^2$$

Bolt Area due to Transverse Load:

Moment on Baseplate Due to Transverse Load [Rmom]:

$$= B * Ft + \text{Sum of X Moments}$$

$$= 1200.0 * 0.65 + 0.0$$

$$= 779.44 \text{ N-m}$$

Eccentricity (e):

$$= Rmom / QO$$

$$= 779.44 / 76.84$$

$$= 10.14 \text{ mm.} < Bplen/6 \text{ --> No Uplift in Transverse direction}$$

Bolt Area due to Transverse Load [Bltareart]:

$$= 0 \text{ (No Uplift)}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 104 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Required Area of a Single Bolt [Bltarear]:

$= \max[\text{Bltarearl}, \text{Bltarears}, \text{Bltareart}]$
 $= \max[0.0, 0.0072, 0.0]$
 $= 0.0072 \text{ cm}^2$

ASME Horizontal Vessel Analysis: Stresses for the Right Saddle

(per ASME Sec. VIII Div. 2 based on the Zick method.)

Input and Calculated Values:

Vessel Mean Radius	Rm	606.50	mm.
Stiffened Vessel Length per 4.15.6	L	6250.00	mm.
Distance from Saddle to Vessel tangent	a	850.00	mm.
Saddle Width	b	150.00	mm.
Saddle Bearing Angle	theta	120.00	degrees
Wear Plate Width	b1	260.00	mm.
Wear Plate Bearing Angle	theta1	145.00	degrees
Wear Plate Thickness	tr	10.0	mm.
Wear Plate Allowable Stress	Sr	137.90	N./mm ²
Shell Allowable Stress used in Calculation		196.73	N./mm ²
Head Allowable Stress used in Calculation		196.73	N./mm ²
Circumferential Efficiency in Plane of Saddle		1.00	
Circumferential Efficiency at Mid-Span		1.00	
Distance from Saddle Base to Centerline	B	1200.00	mm.
Coefficient of Friction	mu	0.00	
Saddle Force Q, Test Case, no Ext. Forces		89.81	kN
Horizontal Vessel Analysis Results:	Actual Allowable		
	N./mm ² N./mm ²		
Long. Stress at Top of Midspan	15.11	196.73	
Long. Stress at Bottom of Midspan	31.59	196.73	
Long. Stress at Top of Saddles	32.32	196.73	
Long. Stress at Bottom of Saddles	18.37	196.73	
Tangential Shear in Shell	18.03	139.65	
Circ. Stress at Horn of Saddle	29.89	295.10	
Circ. Compressive Stress in Shell	3.88	196.73	

Intermediate Results: Saddle Reaction Q due to Wind or Seismic:

Saddle Reaction Force due to Wind Ft [Fwt]:

$= \text{Ftr} (\text{Ft/Num of Saddles} + \text{Z Force Load}) * B / E$
 $= 3.0 (1.3/2 + 0) * 1200.0/1073.8717$
 $= 2.2 \text{ kN}$

Saddle Reaction Force due to Wind FI or Friction [Fwl]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 105 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادرکننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

$= \max(F_l, \text{Friction Load, Sum of X Forces}) * B / L_s$
 $= \max(0.52, 0.0, 0) * 1200.0/4953.3335$
 $= 0.1 \text{ kN}$

Load Combination Results for Q + Wind or Seismic [Q]:

$= \text{Saddle Load} + \max(F_{wl}, F_{wt}, F_{sl}, F_{st})$
 $= 88 + \max(0.1, 2, 0, 0)$
 $= 89.8 \text{ kN}$

Longitudinal Wind Force [F_l]:

$= \text{WindScalar} * \text{WindPress}(\text{Platform Area} + (\text{End Area} * \text{WindDiaMult}))$
 $= 0.6 * 766.08(1.584 + (1.539 * 1.2))$
 $= 1577.182 \text{ N}$

Summary of Loads at the base of this Saddle:

Vertical Load (including saddle weight)	91.95	kN
Transverse Shear Load Saddle	0.65	kN
Longitudinal Shear Load Saddle	0.52	kN

Hydrostatic Test Pressure at center of Vessel 5.389 bars

Formulas and Substitutions for Horizontal Vessel Analysis:

Note: Wear Plate is Welded to the Shell, $k = 0.1$

Saddle Dimension [E]:

$= \min(2(\text{ShellID}/2 + t + \text{WearPadThickness}) \sin(\text{theta}/2), 2 * R_m)$
 $= \min(2(1200.0/2 + 10.0 + 10.0) \sin(60.0/2), 2 * 606.5)$
 $= 1073.872 \text{ mm.}$

The Computed K values from Table 4.15.1:

K1 = 0.1066	K2 = 1.1707	K3 = 0.8799	K4 = 0.4011
K5 = 0.7603	K6 = 0.0529	K7 = 0.0529	K8 = 0.3405
K9 = 0.2711	K10 = 0.0581	K1* = 0.1923	K6p = 0.0347
K7p = 0.0347			

The suffix 'p' denotes the values for a wear plate if it exists.

Note: Dimension a is greater than or equal to $R_m / 2$.

Moment per Equation 4.15.3 [M1]:

$= -Q * a [1 - (1 - a/L + (R_m^2 - h^2) / (2a * L)) / (1 + (4h^2) / (3L))]$
 $= -90 * 850.0 [1 - (1 - 850.0/6250.0 + (606.5^2 - 0.0^2) / (2 * 850.0 * 6250.0)) / (1 + (4 * 0.0) / (3 * 6250.0))]$
 $= -7742.4 \text{ N-m}$

Moment per Equation 4.15.4 [M2]:

$= Q * L / 4 (1 + 2 (R_m^2 - h^2) / (L^2)) / (1 + (4h^2) / (3L)) - 4a/L$
 $= 90 * 6250 / 4 (1 + 2 (607^2 - 0^2) / (6250^2)) / (1 + (4 * 0) / (3 * 6250)) - 4 * 850 / 6250$
 $= 66660.4 \text{ N-m}$

Longitudinal Stress at Top of Shell (4.15.6) [Sigma₁]:

$= P * R_m / (2t) - M_2 / (\pi * R_m^2 t)$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 106 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= 5.389 * 606.5 / (2 * 7.0) - 66660.4 / (\pi * 606.5^2 * 7.0)$$

$$= 15.11 \text{ N./mm}^2$$

Longitudinal Stress at Bottom of Shell (4.15.7) [Sigma2]:

$$= P * R_m / (2t) + M_2 / (\pi * R_m^2 * t)$$

$$= 5.389 * 606.5 / (2 * 7.0) + 66660.4 / (\pi * 606.5^2 * 7.0)$$

$$= 31.59 \text{ N./mm}^2$$

Longitudinal Stress at Top of Shell at Support (4.15.10) [Sigma*3]:

$$= P * R_m / (2t) - M_1 / (K_1 * \pi * R_m^2 * t)$$

$$= 5.389 * 606.5 / (2 * 7.0) - 7742.4 / (0.1066 * \pi * 606.5^2 * 7.0)$$

$$= 32.32 \text{ N./mm}^2$$

Longitudinal Stress at Bottom of Shell at Support (4.15.11) [Sigma*4]:

$$= P * R_m / (2t) + M_1 / (K_1 * \pi * R_m^2 * t)$$

$$= 5.389 * 606.5 / (2 * 7.0) + 7742.4 / (0.1923 * \pi * 606.5^2 * 7.0)$$

$$= 18.37 \text{ N./mm}^2$$

Maximum Shear Force in the Saddle (4.15.5) [T]:

$$= Q(L - 2a) / (L + (4 * h^2 / 3))$$

$$= 90(6250.0 - 2 * 850.0) / (6250.0 + (4 * 0.0 / 3))$$

$$= 65.4 \text{ kN}$$

Shear Stress in the shell no rings, not stiffened (4.15.14) [tau2]:

$$= K_2 * T / (\pi * R_m * t)$$

$$= 1.1707 * 65.38 / (\pi * 606.5 * 7.0)$$

$$= 18.03 \text{ N./mm}^2$$

Decay Length (4.15.22) [x1,x2]:

$$= 0.78 * \sqrt{R_m * t}$$

$$= 0.78 * \sqrt{606.5 * 7.0}$$

$$= 50.823 \text{ mm.}$$

Circumferential Stress in shell, no rings (4.15.23) [sigma6]:

$$= -K_5 * Q * k / (t * (b + X_1 + X_2))$$

$$= -0.7603 * 90 * 0.1 / (7.0 * (150.0 + 50.82 + 50.82))$$

$$= -3.88 \text{ N./mm}^2$$

Effective reinforcing plate width (4.15.1) [B1]:

$$= \min(b + 1.56 * \sqrt{R_m * t}, 2a)$$

$$= \min(150.0 + 1.56 * \sqrt{606.5 * 7.0}, 2 * 850.0)$$

$$= 251.65 \text{ mm.}$$

Wear Plate/Shell Stress ratio (4.15.29) [eta]:

$$= 1.0000 \text{ Materials are the same, test case}$$

Circumferential Stress at Saddle Base with Wear Plate (4.15.26) [sigma6,r]:

$$= -K_5 * Q * k / (B_1(t + \eta * t_r))$$

$$= -0.7603 * 90 * 0.1 / (251.646(7.0 + 1.0 * 10.0))$$

$$= -1.60 \text{ N./mm}^2$$

Circ. Comp. Stress at Horn of Saddle, L>=8Rm (4.15.27) [sigma7,r]:

$$= -Q / (4(t + \eta * t_r) b_1) - 3 * K_7 * Q / (2(t + \eta * t_r)^2)$$

$$= -90 / (4(7.0 + 1.0 * 10.0) 251.646) -$$

$$3 * 0.053 * 90 / (2(7.0 + 1.0 * 10.0)^2)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 107 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= -29.89 \text{ N./mm}^2$$

Results for Vessel Ribs, Web and Base:

Baseplate Length	Bplen	1200.0000	mm.
Baseplate Thickness	Bpthk	15.0000	mm.
Baseplate Width	Bpwid	170.0000	mm.
Number of Ribs (inc. outside ribs)	Nribs	4	
Rib Thickness	Ribtk	15.0000	mm.
Web Thickness	Webtk	15.0000	mm.
Web Location	Webloc	Center	
Saddle Yield Stress	Sy	239.9	N./
Height of Web at Center	Hw,c	585.0	mm.
Friction Coefficient	mu	0.000	

Note: In the tables below Io is I for the rectangle + Area * Centroid Distance^2

Moment of Inertia of Saddle - Transverse Direction (90 degrees to long axis)

	B	D	Y	A	AY	Io
Shell	361.4	7.0	3.5	25.3	8853.1	0.157E+05
Wearplate	260.0	10.0	12.0	26.0	31200.0	0.151E+05
Web	15.0	565.0	299.5	84.8	2538262.8	0.244E+05
BasePlate	170.0	15.0	589.5	25.5	1503225.0	0.289E+05
Totals	...	...	...	161.5	4081541.2	0.841E+05

Distance to Centroid [C1]:

$$= AY / A$$

$$= 1606.906/161.545$$

$$= 252.657 \text{ mm.}$$

Angle [beta]:

$$= 180 - \text{Saddle Angle}/2$$

$$= 180 - 120.0/2$$

$$= 120.0$$

Saddle Splitting Coefficient [K1]:

$$= (1 + \cos(\text{beta}) - 0.5 \cdot \sin(\text{beta})^2) / (\pi - \text{beta} + \sin(\text{beta}) \cos(\text{beta}))$$

$$= (1 + \cos(120.0) - 0.5 \cdot \sin(120.0)^2) / (\pi - 2.094 + \sin(120.0) \cos(120.0))$$

$$= 0.2035$$

Saddle Splitting Force [Fh]:

$$= K1 * Q$$

$$= 0.204 * 89.811$$

$$= 18.2785 \text{ kN}$$

$$\text{Tension Stress, St} = (Fh/As) = 1.3417 \text{ N./mm}^2$$

$$\text{Allowed Stress, Sa} = 0.6 * \text{Yield Str} = 143.9676 \text{ N./mm}^2$$

Saddle Splitting Dimension [d]:

$$= B - R * \sin(\text{theta}/2) / (\text{theta}/2 \text{ in radians})$$

$$= 1200.0 - 603.0 * \sin(120.0/2) / 1.0472$$

$$= 701.323 \text{ mm.}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 108 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$\text{Bending Moment, } M = F_h * d = 12824.3477 \text{ N-m}$$

$$\text{Bending Stress, } S_b = (M * C_1 / I) = 3.8512 \text{ N./mm}^2$$

$$\text{Allowed Stress, } S_a = 2/3 * \text{Yield Str} = 159.9640 \text{ N./mm}^2$$

Minimum Thickness of Baseplate per Moss:

$$= (3 (Q + \text{Saddle_Wt}) \text{BasePlateWidth} / (4 * \text{BasePlateLength} * \text{AllStress}))^{1/2}$$

$$= (3 (90 + 2) 170.0 / (4 * 1200.0 * 159.964))^{1/2}$$

$$= 7.815 \text{ mm.}$$

Calculation of Axial Load, Intermediate Values and Compressive Stress:

Web Length Dimension [Web Length]:

$$= 2 * \cos(90 - \text{Saddle Angle}/2) (\text{Inside Radius} + \text{Shell Thk} + \text{Wear Plate Thk})$$

$$= 2 * \cos(90 - 120.0/2) (600.0 + 10.0 + 10.0)$$

$$= 1073.872 \text{ mm.}$$

Distance between Ribs [e]:

$$= \text{Web Length} / (\text{Nr ribs} - 1)$$

$$= 1073.8716 / (4 - 1)$$

$$= 357.957 \text{ mm.}$$

Baseplate Pressure Area [Ap]:

$$= e * \text{Bpwid} / 2$$

$$= 357.9572 * 170.0/2$$

$$= 304.264 \text{ cm}^2$$

Bearing Pressure [Bp]:

$$= Q / (\text{BasePlateLength} * \text{BasePlateWidth})$$

$$= 89.811 / (1200.0 * 170.0)$$

$$= 0.044 \text{ kN/cm}^2$$

Axial Load [P]:

$$= A_p * B_p$$

$$= 304.3 * 0.04$$

$$= 13.395 \text{ kN}$$

Area of the Rib and Web [Ar]:

$$= \text{Rib Area} + \text{Web Area}$$

$$= 20.25 + 26.847$$

$$= 47.097 \text{ cm}^2$$

Compressive Stress [Sc]:

$$= P / A_r$$

$$= 13.4 / 47.0968$$

$$= 2.844 \text{ N./mm}^2$$

Check of Outside Ribs:

Inertia of Saddle, Outer Ribs - Longitudinal Direction

B | D | Y | A | AY | Io |

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 109 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Rib+Web 15.0 | 150.0 | ... | 22.5 | ... | 422. |

Rib dimension [D]:

$$\begin{aligned}
 &= \text{Saddle Width} - \text{Web Thickness} \\
 &= 150.0 - 15.0 \\
 &= 135.000 \text{ mm.}
 \end{aligned}$$

Distance to Centroid from Datum [ytot]:

$$\begin{aligned}
 &= AY / A \\
 &= 0.0/47.097 \\
 &= 0.000 \text{ mm.}
 \end{aligned}$$

Distance to Centroid [C1]:

$$\begin{aligned}
 &= \text{Saddle Width} / 2 \\
 &= 150.0/2 \\
 &= 75.000 \text{ mm.}
 \end{aligned}$$

Radius of Gyration [r]:

$$\begin{aligned}
 &= \sqrt{\text{Total Inertia} / \text{Total Area}} \\
 &= \sqrt{421.9/47.097} \\
 &= 29.929 \text{ mm.}
 \end{aligned}$$

Length of Outer Rib [L]:

$$\begin{aligned}
 &= \text{Saddle Height} - \cos(\theta/2) (\text{radius} + \text{shlthk} + \text{wpdthk}) - \text{bpthk} \\
 &= 1200.0 - \cos(120.0/2) (600.0 + 10.0 + 10.0) - 15.0 \\
 &= 875.000 \text{ mm.}
 \end{aligned}$$

Intermediate Term [Cc]:

$$\begin{aligned}
 &= \sqrt{2 * \pi^2 * \text{Elastic Modulus} / \text{Yield Stress}} \\
 &= \sqrt{2 * \pi^2 * 0.19994\text{E}+09/239.9} \\
 &= 128.255
 \end{aligned}$$

Slenderness ratio [KL/r]:

$$\begin{aligned}
 &= KL/r \\
 &= 1 * 875.0/29.929 \\
 &= 29.236
 \end{aligned}$$

Bending Moment [Rm]:

$$\begin{aligned}
 &= Fl / (2 * B_{pln}) * e * L / 2 \\
 &= 0.5 / (2 * 1200.0) * 357.957 * 875.0/2 \\
 &= 33.974 \text{ N-m}
 \end{aligned}$$

Compressive Allowable, $KL/r < C_c$ ($29.2356 < 128.2549$) per AISC E2-1 [Sca]:

$$\begin{aligned}
 &= (1 - (KL/r)^2 / (2 * C_c^2)) F_y / (5/3 + 3 * (KL/r) / (8 * C_c) - (KL/r)^3 / (8 * C_c^3)) \\
 &= (1 - (29.24)^2 / (2 * 128.25^2)) 240 / \\
 &\quad (5/3 + 3 * (29.24) / (8 * 128.25) - (29.24^3) / (8 * 128.25^3)) \\
 &= 133.5 \text{ N./mm}^2
 \end{aligned}$$

AISC Unity Check of Outside Ribs (must be <= 1)

$$\begin{aligned}
 &= Sc/Sca + (Rm * C1 / I) / Sba \\
 &= 2.84/133.5 + (33.97 * 75.0/4218750) / 159.96 \\
 &= 0.025
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 110 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Check of Inside Ribs:

Inertia of Saddle, Inner Ribs - Axial Direction

	B	D	Y	A	AY	I _o
Rib	15.0	135.0	0.0	20.2	0.0	421.
Web	358.0	15.0	0.0	53.7	0.0	10.1
Totals	...	...	...	73.9	...	432.

Distance to Centroid from Datum [ytot]:

$$\begin{aligned}
 &= AY / A \\
 &= 0.0/73.944 \\
 &= 0.000 \text{ mm.}
 \end{aligned}$$

Distance to Centroid [C1]:

$$\begin{aligned}
 &= \text{Saddle Width} / 2 \\
 &= 150.0/2 \\
 &= 75.000 \text{ mm.}
 \end{aligned}$$

Length of Inner Rib [L]:

$$\begin{aligned}
 &= \text{Saddle Height} - \sqrt{(\text{Ro} + \text{Wpdthk})^2 - (\text{Pitch}/2)^2} - \text{Bpthk} \\
 &= 1200.0 - \sqrt{(620.0 + 10.0)^2 - (357.957/2)^2} - 15.0 \\
 &= 591.395 \text{ mm.}
 \end{aligned}$$

Radius of Gyration [r]:

$$\begin{aligned}
 &= \sqrt{\text{Total Inertia} / \text{Total Area}} \\
 &= \sqrt{431.5/73.944} \\
 &= 24.157 \text{ mm.}
 \end{aligned}$$

Slenderness ratio [KL/r]:

$$\begin{aligned}
 &= KL/r \\
 &= 1 * 591.395/24.157 \\
 &= 24.481
 \end{aligned}$$

Unit Force [Force,u]:

$$\begin{aligned}
 &= F_l / (2 * \text{Baseplate Length}) \\
 &= 0.52 / (2 * 1200.0) \\
 &= 0.000 \text{ kN/mm.}
 \end{aligned}$$

Moment at base of inner Rib [Mbase,c]:

$$\begin{aligned}
 &= \text{Unit Force} * e * L \\
 &= 0. * 357.957 * 591.395 \\
 &= 45.925 \text{ N-m}
 \end{aligned}$$

Bending Stress due to Transverse Force and Weight Load [SigmaB,base,c]:

$$\begin{aligned}
 &= \text{Bending Moment} / \text{Section Modulus} \\
 &= 45.925/57536.086 \\
 &= 0.798 \text{ N./mm}^2
 \end{aligned}$$

Compressive Allowable, KL/r < Cc (24.4809 < 128.2549) per AISC E2-1 [Sca]:

$$\begin{aligned}
 &= (1 - (KL/r)^2 / (2 * Cc^2)) F_y / (5/3 + 3 * (KL/r) / (8 * Cc) - (KL/r^3) / (8 * Cc^3)) \\
 &= (1 - (24.48)^2 / (2 * 128.25^2)) 240 / \\
 &\quad (5/3 + 3 * (24.48) / (8 * 128.25) - (24.48^3) / (8 * 128.25^3)) \\
 &= 135.6 \text{ N./mm}^2
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 111 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

AISC Unity Check of Inside Ribs (must be <= 1)

$$= Sc/Sca + (Mbase,c * C1/I)/Sba$$

$$= 3.66/135.59 + (45.92 * 75.0/431.52)/159.96$$

$$= 0.032$$

Input Data for Base Plate Bolting Calculations:

Total Number of Bolts per BasePlate	Nbolts	4
Total Number of Bolts in Tension/Baseplate	Nbt	2
Bolt Material Specification	SA-193 B7	
Bolt Allowable Stress	Stba	300.00 N./mm ²
Bolt Corrosion Allowance	Bca	0.0 mm.
Distance from Bolts to Edge	Edgedis	150.0 mm.
Nominal Bolt Diameter	Bnd	20.0000 mm.
Thread Series	Series	TEMA Metric
BasePlate Allowable Stress	S	95.15 N./mm ²
Area Available in a Single Bolt	BlArea	2.1705 cm ²
Saddle Load QO (Weight)	QO	89.8 kN
Saddle Load QL (Wind/Seismic contribution)	QL	0.1 kN
Maximum Transverse Force	Ft	0.6 kN
Maximum Longitudinal Force	Fl	0.5 kN
Saddle Bolted to Steel Foundation		Yes

Shear Stress in a Single Bolt, Transverse Direction [taub,t]:

$$= Ft / (Bolt Area * Number of Bolts)$$

$$= 0.6 / (2.17 * 4)$$

$$= 0.7 \text{ N./mm}^2. \text{ Must be less than } 180.0 \text{ N./mm}^2.$$

Bolt Area Calculation per Dennis R. Moss

Bolt Area Requirement Due to Longitudinal Load [Bltarearl]:

$$= 0.0 \text{ (} QO > QL \text{ --> No Uplift in Longitudinal direction)}$$

Bolt Area due to Shear Load [Bltarears]:

$$= Fl / (BoltShearAllowable * Nbolts)$$

$$= 0.52 / (180.0 * 4.0)$$

$$= 0.0072 \text{ cm}^2$$

Bolt Area due to Transverse Load:

Moment on Baseplate Due to Transverse Load [Rmom]:

$$= B * Ft + \text{Sum of X Moments}$$

$$= 1200.0 * 0.65 + 0.0$$

$$= 779.44 \text{ N-m}$$

Eccentricity (e):

$$= Rmom / QO$$

$$= 779.44/89.77$$

$$= 8.68 \text{ mm.} < Bplen/6 \text{ --> No Uplift in Transverse direction}$$

Bolt Area due to Transverse Load [Bltareart]:

$$= 0 \text{ (No Uplift)}$$

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 112 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Required Area of a Single Bolt [Bltarear]:

= max[Bltarearl, Bltarears, Bltareart]
= max[0.0, 0.0072, 0.0]
= 0.0072 cm²

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 113 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Input, Nozzle Desc: N08 (1in)

From: 10

Pressure for Reinforcement Calculations	P	4.135	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Elliptical Head	D	1200.00	mm.
Aspect Ratio of Elliptical Head	Ar	2.00	
Head Finished (Minimum) Thickness	t	10.0000	mm.
Head Internal Corrosion Allowance	c	3.0000	mm.
Head External Corrosion Allowance	co	0.0000	mm.
Distance from Head Centerline	L1	400.0000	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		270.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	15.8500	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	
Flange Series	Series	=	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 114 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle in the Meridional direction.

Reinforcement CALCULATION, Description: N08 (1in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.624 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Elliptical Head, Tr [Int. Press]

$$= (P \cdot K_1 \cdot D) / (2 \cdot S_v \cdot E - 0.2 \cdot P) \text{ per UG-37 (a) (3)}$$

$$= (4.13 \cdot 0.896 \cdot 1206.0) / (2 \cdot 137.9 \cdot 1.0 - 0.2 \cdot 4.13)$$

$$= 1.6202 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.13 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.13)$$

$$= 0.0862 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3393 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	124.3751 mm.
Parallel to Vessel Wall, opening length	d	62.1876 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 136.4 / 137.9)$$

$$= 0.989$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 115 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 136.4/137.9)$$

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.012	0.986	NA
Area in Shell	A1	3.331	2.378	NA
Area in Nozzle Wall	A2	4.735	4.641	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	9.055	8.009	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 65.97 Degr.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(62.1876 \cdot 3.1585 \cdot 1 + 2 \cdot 12.85 \cdot 3.1585 \cdot 1(1 - 0.99))$$

$$= 0.986 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 \cdot t - F \cdot tr) - 2 \cdot t_n(E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 62.188(1.0 \cdot 7.0 - 1.0 \cdot 3.159) - 2 \cdot 12.85$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 3.1585) \cdot (1 - 0.989)$$

$$= 2.378 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp})(t_n - t_{rn})fr2/\sin(\alpha3)$$

$$= (2 \cdot 17.5)(12.85 - 0.34)0.9894/\sin(69.0)$$

$$= 4.641 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr2 + (W_i - can/0.707)^2 \cdot fr2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 116 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.62, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.231$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A -8 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
Min Metal Temp. w/o impact per UG-20(f) -29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.13 / 19.60 = 0.211$

Weld Size Calculations, Description: N08 (1in)

Intermediate Calc. for nozzle/shell Welds Tmin 9.0000 mm.

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld 6.0000 = Min per Code 7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * tn * fr1 * (E1 * t - tr)) * Sv)$$

$$= \max(0, (0.9864 - 2.3784 + 2 * 12.85 * 0.9894 * (1.0 * 7.0 - 3.1585)) * 138)$$

$$= \max(0, -5.73) \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (Wi - Can / .707)^2 * fr2) * Sv$$

$$= (4.6407 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 77.63 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.6407 + 0.0 + 0.9894 + (1.7799)) * 138$$

$$= 102.17 \text{ kN}$$

Weld Load [W3]:

$$= (A2 + A3 + A4 + A5 + (2 * tn * t * fr1)) * S$$

$$= (4.6407 + 0.0 + 0.9894 + 0.0 + (1.7799)) * 138$$

$$= 102.17 \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 117 از 411	
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری		پروژه
	V00	0009	CN	ME	120	MF	GCS		BK

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 90.3253 * 10.0 * 0.49 * 136$$

$$= 95. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 38.1282) * (15.85 - 3.0) * 0.7 * 136$$

$$= 147. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi} - Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 90.3253 * (10.0 - 3.0) * 0.74 * 138$$

$$= 101. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (95 + 147) = 242 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (95 + 0 + 101 + 0) = 196 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (95 + 101 + 0) = 196 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 241 kN , must exceed W = 0 kN or W1 = 77 kN
 Path 2-2 = 196 kN , must exceed W = 0 kN or W2 = 102 kN
 Path 3-3 = 196 kN , must exceed W = 0 kN or W3 = 102 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in the Latitudinal direction.

Reinforcement CALCULATION, Description: N08 (1in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.624 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Elliptical Head, Tr [Int. Press]

$$= (P * K1 * D) / (2 * S_v * E - 0.2 * P) \text{ per UG-37 (a) (3)}$$

$$= (4.13 * 0.896 * 1206.0) / (2 * 137.9 * 1.0 - 0.2 * 4.13)$$

$$= 1.6202 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 118 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.13 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.13)$$

$$= 0.0862 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3393 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000	mm.
Parallel to Vessel Wall, opening length	d	56.8000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	0.925	0.901	NA
Area in Shell	A1	3.041	2.171	NA
Area in Nozzle Wall	A2	4.420	4.332	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.450	7.493	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F (1 - fr1)) \text{ per UG-37 (d)}$$

$$= 0.5 (56.8 \cdot 3.1585 \cdot 1 + 2 \cdot 12.85 \cdot 3.1585 \cdot 1 (1 - 0.99))$$

$$= 0.901 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 \cdot t - F \cdot tr) - 2 \cdot tn (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 56.8 (1.0 \cdot 7.0 - 1.0 \cdot 3.159) - 2 \cdot 12.85$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 3.1585) \cdot (1 - 0.989)$$

$$= 2.171 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot tlnp) (tn - trn) fr2$$

$$= (2 \cdot 17.5) (12.85 - 0.34) 0.9894$$

$$= 4.332 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 \cdot fr2 + (Wi - can / 0.707)^2 \cdot fr2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures $t_a = 3.3393 \text{ mm.}$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 119 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Wall Thickness per UG16(b), $tr16b = 4.5000 \text{ mm.}$
 Wall Thickness, shell/head, internal pressure $trb1 = 4.7969 \text{ mm.}$
 Wall Thickness $tb1 = \max(trb1, tr16b) = 4.7969 \text{ mm.}$
 Wall Thickness, shell/head, external pressure $trb2 = 3.4492 \text{ mm.}$
 Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
 Wall Thickness per table UG-45 $tb3 = 7.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:

$= \min[tb3, \max(tb1, tb2)]$
 $= \min[7.8, \max(4.7969, 4.5)]$
 $= 4.7969 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$= \max(ta, tb)$
 $= \max(3.3393, 4.7969)$
 $= 4.7969 \text{ mm.}$

Available Nozzle Neck Thickness = 15.8500 mm. --> OK

Weld Size Calculations, Description: N08 (1in)

Intermediate Calc. for nozzle/shell Welds $Tmin = 9.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
 Nozzle Weld $6.0000 = \text{Min per Code } 7.0700 = 0.7 * Wo \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (0.9013 - 2.1714 + 2 * 12.85 * 0.9894 * (1.0 * 7.0 - 3.1585))138)$
 $= \max(0, -4.04) \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$
 $= (4.3322 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$
 $= 73.38 \text{ kN}$

Weld Load [W2]:

$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$
 $= (4.3322 + 0.0 + 0.9894 + (1.7799)) * 138$
 $= 97.92 \text{ kN}$

Weld Load [W3]:

$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$
 $= (4.3322 + 0.0 + 0.9894 + 0.0 + (1.7799)) * 138$
 $= 97.92 \text{ kN}$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 120 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 82.5 * 10.0 * 0.49 * 136$$

$$= 87. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (T_{hk} - C_{an}) * 0.7 * S_n$$

$$= (3.1416 * 34.825) * (15.85 - 3.0) * 0.7 * 136$$

$$= 134. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 82.5 * (10.0 - 3.0) * 0.74 * 136$$

$$= 93. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (87 + 134) = 221 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (87 + 0 + 93 + 0) = 179 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (87 + 93 + 0) = 179 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 220 kN , must exceed W = 0 kN or W1 = 73 kN
 Path 2-2 = 179 kN , must exceed W = 0 kN or W2 = 97 kN
 Path 3-3 = 179 kN , must exceed W = 0 kN or W3 = 97 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 17.2963 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 178.0417 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 121 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Input, Nozzle Desc: N02 (2in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		200.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		270.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	15.8500	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 122 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: N02 (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.624 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3393 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000 mm.
Parallel to Vessel Wall, opening length	d	56.8000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 123 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.775	NA
Area in Shell	A1	2.942	0.440	NA
Area in Nozzle Wall	A2	4.420	4.332	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.351	5.762	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(56.8 * 6.2213 * 1 + 2 * 12.85 * 6.2213 * 1(1-0.99))$$

$$= 1.775 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 56.8(1.0 * 7.0 - 1.0 * 6.221) - 2 * 12.85$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 17.5) (12.85 - 0.34) 0.9894$$

$$= 4.332 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3393 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 124 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 7.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:

$= \min[tb3, \max(tb1, tb2)]$
 $= \min[7.8, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$= \max(ta, tb)$
 $= \max(3.3393, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 15.8500 mm. --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained	: 12.0,	Allowable	: 136.4 N./mm ²	Passed
Expansion	: 0.0,	Allowable	: 330.9 N./mm ²	Passed
Occasional	: 0.4,	Allowable	: 181.5 N./mm ²	Passed
Shear	: 3.1,	Allowable	: 95.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c)	-29 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b)	-104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 19.60 = 0.209$

Weld Size Calculations, Description: N02 (2in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.9000 = 0.7 * t_{min.}$	$7.0700 = 0.7 * W_o \text{ mm.}$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 125 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (1.7753 - 0.4402 + 2 * 12.85 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 6.2213))138) \\
 &= 21.14 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (4.3322 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 73.38 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (4.3322 + 0.0 + 0.9894 + (1.7799)) * 138 \\
 &= 97.92 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (4.3322 + 0.0 + 0.9894 + 0.0 + (1.7799)) * 138 \\
 &= 97.92 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 82.5 * 10.0 * 0.49 * 136 \\
 &= 87. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 34.825) * (15.85 - 3.0) * 0.7 * 136 \\
 &= 134. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 82.5 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 93. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (87 + 134) = 221 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (87 + 0 + 93 + 0) = 179 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (87 + 93 + 0) = 179 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 220 \text{ kN}, \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W1 = 73 \text{ kN} \\
 \text{Path 2-2} &= 179 \text{ kN}, \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W2 = 97 \text{ kN} \\
 \text{Path 3-3} &= 179 \text{ kN}, \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W3 = 97 \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 126 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادر کننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 1.4197 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 161.4197 mm.

Input Echo, WRC107/537 Item 1, Description: N02 (2in) :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	1200.000	mm.
Vessel Thickness	Tv	10.000	mm.
Design Temperature	T1	234.0	°C
Vessel Material		SA-516 70	
Vessel UNS Number		K02700	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²

Note:

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-516 70

Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	ID	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	50.800	mm.
Nozzle Thickness	Tn	15.850	mm.
Nozzle Material		SA-105	
Nozzle UNS Number		K03504	
Nozzle Cold S.I. Allowable	SNmc	137.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	136.43	N./mm ²
Design Internal Pressure	Dp	4.100	bars
Include Pressure Thrust	No		

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.8	kN
Longitudinal Shear (SUS)	Vl	2.8	kN
Circumferential Shear (SUS)	Vc	-2.1	kN
Circumferential Moment (SUS)	Mc	-280.0	N-m
Longitudinal Moment (SUS)	Ml	-360.0	N-m
Torsional Moment (SUS)	Mt	-420.0	N-m

Use Interactive Control

No

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 127 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

WRC107 Version

Version March 1979

Include Pressure Stress Indices per Div. 2

No

Compute Pressure Stress per WRC-368


No

Local Loads applied at end of Nozzle/Attachment

No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".



Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$\begin{aligned}
 &= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(t - ca)) \\
 &= 82.5 + 2 * 1.65 * \text{sqrt}(606.5 (10.0 - 3.0)) \\
 &= 297.520 \text{ mm.}
 \end{aligned}$$

WRC 107 Stress Calculation for SUSTAINED loads:

Radial Load	P	2.8	kN
Circumferential Shear	VC	-2.1	kN
Longitudinal Shear	VL	2.8	kN
Circumferential Moment	MC	-280.0	N-m
Longitudinal Moment	ML	-360.0	N-m
Torsional Moment	MT	-420.0	N-m

Dimensionless Parameters used : Gamma = 86.64

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.060	4C	15.037	(A,B)
N(PHI) / (P/Rm)	0.060	3C	14.463	(C,D)
M(PHI) / (P)	0.060	2C1	0.100	(A,B)
M(PHI) / (P)	0.060	1C	0.139	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.060	3A	2.228	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.060	1A	0.096	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.060	3B	7.820	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.060	1B	0.049	(A,B,C,D)
N(x) / (P/Rm)	0.060	3C	14.463	(A,B)
N(x) / (P/Rm)	0.060	4C	15.037	(C,D)
M(x) / (P)	0.060	1C1	0.143	(A,B)
M(x) / (P)	0.060	2C	0.101	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.060	4A	3.056	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.060	2A	0.057	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.060	4B	2.219	(A,B,C,D)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 128 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

M(x) / (ML/(Rm * Beta)) 0.060 2B 0.080 (A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Type of Stress Load		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-9.9	-9.9	-9.9	-9.9	-9.5	-9.5	-9.5	-9.5
Circ. Bend. P		-34.4	34.4	-34.4	34.4	-47.7	47.7	-47.7	47.7
Circ. Memb. MC		0.0	0.0	0.0	0.0	4.1	4.1	-4.1	-4.1
Circ. Memb. MC		0.0	0.0	0.0	0.0	91.5	-91.5	-91.5	91.5
Circ. Memb. ML		18.4	18.4	-18.4	-18.4	0.0	0.0	0.0	0.0
Circ. Bend. ML		60.3	-60.3	-60.3	60.3	0.0	0.0	0.0	0.0
Tot. Circ. Str.		34.3	-17.4	-123.1	66.5	38.3	-49.2	-152.8	125.6
Long. Memb. P		-9.5	-9.5	-9.5	-9.5	-9.9	-9.9	-9.9	-9.9
Long. Bend. P		-49.2	49.2	-49.2	49.2	-34.6	34.6	-34.6	34.6
Long. Memb. MC		0.0	0.0	0.0	0.0	5.6	5.6	-5.6	-5.6
Long. Bend. MC		0.0	0.0	0.0	0.0	53.8	-53.8	-53.8	53.8
Long. Memb. ML		5.2	5.2	-5.2	-5.2	0.0	0.0	0.0	0.0
Long. Bend. ML		97.2	-97.2	-97.2	97.2	0.0	0.0	0.0	0.0
Tot. Long. Str.		43.7	-52.3	-161.1	131.6	14.8	-23.5	-103.8	72.8
Shear VC		-2.3	-2.3	2.3	2.3	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-3.1	-3.1	3.1	3.1
Shear MT		-5.6	-5.6	-5.6	-5.6	-5.6	-5.6	-5.6	-5.6
Tot. Shear		-7.9	-7.9	-3.3	-3.3	-8.7	-8.7	-2.5	-2.5
Str. Int.		48.2	54.0	161.4	131.8	41.1	51.9	152.9	125.7

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress Load		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		35.1	35.5	35.1	35.5	35.1	35.5	35.1	35.5
Circ. Pl (SUS)		8.4	8.4	-28.3	-28.3	-5.5	-5.5	-13.6	-13.6
Circ. Q (SUS)		25.9	-25.9	-94.8	94.8	43.7	-43.7	-139.2	139.2
Long. Pm (SUS)		17.6	17.6	17.6	17.6	17.6	17.6	17.6	17.6
Long. Pl (SUS)		-4.3	-4.3	-14.8	-14.8	-4.3	-4.3	-15.5	-15.5
Long. Q (SUS)		48.0	-48.0	-146.3	146.3	19.2	-19.2	-88.3	88.3

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 129 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Shear Pm (SUS)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)	-2.3	-2.3	2.3	2.3	-3.1	-3.1	3.1	3.1
Shear Q (SUS)	-5.6	-5.6	-5.6	-5.6	-5.6	-5.6	-5.6	-5.6
Pm (SUS)	35.1	35.5	35.1	35.5	35.1	35.5	35.1	35.5
Pm+Pl (SUS)	43.7	44.1	7.9	8.2	30.2	30.6	22.0	22.4
Pm+Pl+Q (Total)	74.3	55.2	143.7	149.4	75.1	19.3	117.9	161.2

Vessel Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	35.53	137.90	Passed
Pm+Pl (SUS)	44.15	206.85	Passed
Pm+Pl+Q (TOTAL)	161.21	413.70	Passed

Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 130 از 411
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه											
V00	0009	CN	ME	120	MF	GCS	BK											

Input, Nozzle Desc: N12 (1in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		250.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		90.00	deg
Diameter		1.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	12.8000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 131 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: N12 (1in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	1.000 in.
Actual Thickness Used in Calculation	0.504 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per App. 1 of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)} \\
 &= 15.7 \left(\exp \left(\frac{4.1}{136.43 \cdot 1.0} \right) - 1 \right) \\
 &= 0.0473 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2571 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	65.0000 mm.
Parallel to Vessel Wall	Rn+tn+t	32.5000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 132 از 411
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	0.568	0.983	NA
Area in Shell	A1	1.738	0.260	NA
Area in Nozzle Wall	A2	3.377	3.305	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.900	0.900	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	6.015	4.465	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(31.4 \cdot 6.2213 \cdot 1 + 2 \cdot 9.8 \cdot 6.2213 \cdot 1(1 - 0.99))$$

$$= 0.983 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 \cdot t - F \cdot tr) - 2 \cdot tn(E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 33.6(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 9.8$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989)$$

$$= 0.260 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot tlnp)(tn - trn)fr2$$

$$= (2 \cdot 17.5)(9.8 - 0.26) \cdot 0.9894$$

$$= 3.305 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= (Wo^2 - \text{Area Lost}) \cdot fr2 + ((Wi - can/0.707)^2 - \text{Area Lost}) \cdot fr2$$

$$= (10.0^2 - 0.09) \cdot 0.9894 + (0.0^2 - 0.0) \cdot 0.9894$$

$$= 0.900 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.2571 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 133 از 411	
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری		پروژه
	V00	0009	CN	ME	120	MF	GCS		BK

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 6.4200 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:
 $= \min[tb3, \max(tb1, tb2)]$
 $= \min[6.42, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 $= \max(ta, tb)$
 $= \max(3.2571, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 12.8000 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = $78 \text{ }^\circ\text{C}$

Min Metal Temp. w/o impact per UCS-66, Curve A $-8 \text{ }^\circ\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^\circ\text{C}$
Min Metal Temp. w/o impact per UG-20(f) $-29 \text{ }^\circ\text{C}$

Gov. MDMT of the nozzle to shell joint welded assembly : $-104 \text{ }^\circ\text{C}$

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) $-29 \text{ }^\circ\text{C}$
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) $-104 \text{ }^\circ\text{C}$

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
Design Pressure/Ambient Rating = $4.10/19.60 = 0.209$

Weld Size Calculations, Description: N12 (1in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld $4.9000 = 0.7 * t_{min}$ $7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:
 $= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (0.9832 - 0.26 + 2 * 9.8 * 0.9894 * (1.0 * 7.0 - 6.2213))138)$
 $= 12.05 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 134 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (3.3045 + 0.0 + 0.9003 - 0.0 * 0.99) * 138$$

$$= 57.98 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (3.3045 + 0.0 + 0.9003 + (1.3574)) * 138$$

$$= 76.70 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (3.3045 + 0.0 + 0.9003 + 0.0 + (1.3574)) * 138$$

$$= 76.70 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 51.0 * 10.0 * 0.49 * 136$$

$$= 54. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 20.6) * (12.8 - 3.0) * 0.7 * 136$$

$$= 61. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 51.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 57. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (54 + 61) = 114 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (54 + 0 + 57 + 0) = 111 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (54 + 57 + 0) = 111 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 114 kN , must exceed W = 12 kN or W1 = 57 kN

Path 2-2 = 110 kN , must exceed W = 12 kN or W2 = 76 kN

Path 3-3 = 110 kN , must exceed W = 12 kN or W3 = 76 kN

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 135 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 0.5421 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 160.5421 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 136 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input, Nozzle Desc: M1 (24in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.

Note : User defined Limit(s) of Reinforcement specified below:

Physical Maximum for Diameter Limit	Dmax	920.0001	mm.
Distance from Bottom/Left Tangent		950.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-516	70
Material UNS Number		K02700	
Material Specification/Type		Plate	
Allowable Stress at Temperature	Sn	137.90	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		90.00	deg
Diameter		24.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	10.0000	mm.
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 137 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	800.0000	mm.
Thickness of Pad	te	10.0000	mm.
Weld leg size between Pad and Shell	Wp	8.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	10.0000	mm.
Reinforcing Pad Width		95.2000	mm.
This is a Manway or Access Opening.			

Flange Class	150
Flange Grade	GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: M1 (24in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	24.000	in.
Actual Thickness Used in Calculation	0.394	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)} \\
 &= (4.1 \cdot 304.8) / (138 \cdot 1.0 + 0.4 \cdot 4.1) \\
 &= 0.9052 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 1.0868 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 138 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 920.0001 mm.
 Parallel to Vessel Wall, opening length d 460.0000 mm.
 Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Weld Strength Reduction Factor [fr1]:

= min(1, Sn/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr2]:

= min(1, Sn/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr4]:

= min(1, Sp/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr3]:

= min(fr2, fr4)
 = min(1.0, 1.0)
 = 1.000

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	10.698	18.527	NA
Area in Shell	A1	16.881	2.526	NA
Area in Nozzle Wall	A2	2.133	2.070	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		1.577	1.577	NA
Area in Element	A5	19.040	19.040	NA
TOTAL AREA AVAILABLE	Atot	39.632	25.213	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
 Based on given Pad Thickness: 733.1372 10.0000 mm.
 Based on given Pad Diameter: 800.0001 6.4883 mm.
 Based on Shell or Nozzle Thickness: 733.1372 10.0000 mm.

Area Required [A]:

= 0.5(d * tr*F + 2 * tn * tr*F(1-fr1)) per UG-37(d)
 = 0.5(595.6*6.2213*1+2*7.0*6.2213*1(1-1.0))
 = 18.527 cm²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 139 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot t_r) - 2 \cdot t_n(E1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\
 &= 324.4(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 7.0 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 1.0) \\
 &= 2.526 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot T_{lwp}) \cdot (t_n - t_{rn}) \cdot f_{r2} \\
 &= (2 \cdot 17.5) \cdot (7.0 - 1.09) \cdot 1.0 \\
 &= 2.070 \text{ cm}^2
 \end{aligned}$$

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (W_o^2 - A_r \text{ Lost}) \cdot F_{r3} + ((W_i - c_n / 0.707)^2 - A_r \text{ Lost}) \cdot f_{r2} + W_p^2 \cdot f_{r4} \\
 &= (0.9375) \cdot 1.0 + (0.0) \cdot 1.0 + 203.2^2 \cdot 1.0 \\
 &= 1.577 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(D_p, D_L) - (\text{Nozzle OD})) \cdot (\min(t_p, T_{lwp}, t_e)) \cdot f_{r4} \\
 &= (800.0 - 609.6) \cdot 10.0 \cdot 1.0 \\
 &= 19.040 \text{ cm}^2
 \end{aligned}$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, min(Curve:B, Curve:A)

Govrn. thk, $t_g = 10.0$, $t_r = 0.905$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.129$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, $t_g = 10.0$, $t_r = 0.905$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.129$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, $t_g = 10.0$, $t_r = 0.905$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.129$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, $t_g = 10.0$, $t_r = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 140 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)(1)(b)), Curve: B

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0$ mm., $E^* = 1.0$
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
Flange MDMT with Temp reduction per UCS-66(b)(1)(-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
Design Pressure/Ambient Rating = $4.10 / 19.60 = 0.209$

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	893.4000	mm.
Parallel to Vessel Wall, opening length	d	446.7000	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		17.5000	mm.

Reinforcement Areas for Large Nozzle (Per App 1-7(a)): (cm²)

AREA AVAILABLE, A1 to A6		No Pad	With Pad
Area Required [External Pressure]	AR	12.352	12.352
Area Available in Shell	A1	2.319	2.319
Area Available in Nozzle Wall	A2	2.070	2.070
Area Available in Inward Nozzle	A3	0.000	0.000
Area Available in Welds	A4	1.000	1.577
Area Available in Pad	A5	0.000	19.040
Area Available in Hub	A6	0.000	0.000
TOTAL AREA AVAILABLE	Atot	5.389	25.006

The area available without a pad is Insufficient.
The area available with the given pad is Sufficient.

Note: The Nozzle does not fall within the scope of the diameter requirements of App. 1-7(b). Therefore, the Membrane and Bending stress checks are not required.

Weld Size Calculations, Description: M1 (24in)

Intermediate Calc. for nozzle/shell Welds	Tmin	7.0000	mm.
Intermediate Calc. for pad/shell Welds	TminPad	7.0000	mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 141 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.9000 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o \text{ mm.}$
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) * S_v) \\
 &= \max(0, (18.527 - 2.5261 + 2 * 7.0 * 1.0 * (1.0 * 7.0 - 6.2213)) * 138) \\
 &= 222.14 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (2.0696 + 19.04 + 1.5775 - 0.0 * 1.0) * 138 \\
 &= 312.83 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (2.0696 + 0.0 + 1. + (0.98)) * 138 \\
 &= 55.84 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S \\
 &= (2.0696 + 0.0 + 1.5775 + 19.04 + (0.98)) * 138 \\
 &= 326.34 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 609.6 * 10.0 * 0.49 * 138 \\
 &= 647. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi / 2) * D_P * W_P * 0.49 * S_{EW} \\
 &= (3.1416 / 2.0) * 800.0 * 8.0 * 0.49 * 138 \\
 &= 679. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 301.3) * (10.0 - 3.0) * 0.7 * 138 \\
 &= 640. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_{gpn} * 0.74 * S_{eg} \\
 &= (3.1416 / 2) * 609.6 * 10.0 * 0.74 * 138 \\
 &= 977. \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 142 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 609.6 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 684. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (679 + 640) = 1319 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (647 + 977 + 684 + 0) = 2308 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (679 + 684 + 0) = 1363 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 1318 kN , must exceed W = 222 kN or W1 = 312 kN
 Path 2-2 = 2307 kN , must exceed W = 222 kN or W2 = 55 kN
 Path 3-3 = 1363 kN , must exceed W = 222 kN or W3 = 326 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 11 bars

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 83.1858 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 243.1858 mm.

Percent Elongation Calculations:

% Elongation per Table UG-79-1 (50*tnom/Rf*(1-Rf/Ro)) 1.668 %

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 143 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input, Nozzle Desc: N07C (2in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		450.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		270.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	15.8500	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 144 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: N07C (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.624 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3393 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000 mm.
Parallel to Vessel Wall, opening length	d	56.8000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 145 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.775	NA
Area in Shell	A1	2.942	0.440	NA
Area in Nozzle Wall	A2	4.420	4.332	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.351	5.762	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(56.8 * 6.2213 * 1 + 2 * 12.85 * 6.2213 * 1(1-0.99))$$

$$= 1.775 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 56.8(1.0 * 7.0 - 1.0 * 6.221) - 2 * 12.85$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 17.5) (12.85 - 0.34) 0.9894$$

$$= 4.332 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3393 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 146 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 7.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:

$= \min[tb3, \max(tb1, tb2)]$
 $= \min[7.8, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$= \max(ta, tb)$
 $= \max(3.3393, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 15.8500 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio $= tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A $-8 \text{ }^{\circ}\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^{\circ}\text{C}$
Min Metal Temp. w/o impact per UG-20(f) $-29 \text{ }^{\circ}\text{C}$

Gov. MDMT of the nozzle to shell joint welded assembly : $-104 \text{ }^{\circ}\text{C}$

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) $-29 \text{ }^{\circ}\text{C}$
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) $-104 \text{ }^{\circ}\text{C}$

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating $= 4.10/19.60 = 0.209$

Weld Size Calculations, Description: N07C (2in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld $4.9000 = 0.7 * t_{min}$ $7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (1.7753 - 0.4402 + 2 * 12.85 * 0.9894 * (1.0 * 7.0 - 6.2213))138)$
 $= 21.14 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 147 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (4.3322 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 73.38 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.3322 + 0.0 + 0.9894 + (1.7799)) * 138$$

$$= 97.92 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.3322 + 0.0 + 0.9894 + 0.0 + (1.7799)) * 138$$

$$= 97.92 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.1416/2.0) * 82.5 * 10.0 * 0.49 * 136$$

$$= 87. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (pi * (Dlr + Dlo) /4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.1416 * 34.825) * (15.85 - 3.0) * 0.7 * 136$$

$$= 134. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.1416/2.0) * 82.5 * (10.0 - 3.0) * 0.74 * 138$$

$$= 93. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (87 + 134) = 221 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (87 + 0 + 93 + 0) = 179 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (87 + 93 + 0) = 179 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 220 kN , must exceed W = 21 kN or W1 = 73 kN

Path 2-2 = 179 kN , must exceed W = 21 kN or W2 = 97 kN

Path 3-3 = 179 kN , must exceed W = 21 kN or W3 = 97 kN

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 148 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 1.4197 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 161.4197 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 149 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: N07B (2in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		1150.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		270.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	15.8500	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 150 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: N07B (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.624 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3393 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000 mm.
Parallel to Vessel Wall, opening length	d	56.8000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 151 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.775	NA
Area in Shell	A1	2.942	0.440	NA
Area in Nozzle Wall	A2	4.420	4.332	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.351	5.762	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(56.8 * 6.2213 * 1 + 2 * 12.85 * 6.2213 * 1(1-0.99))$$

$$= 1.775 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 56.8(1.0 * 7.0 - 1.0 * 6.221) - 2 * 12.85$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 17.5) (12.85 - 0.34) 0.9894$$

$$= 4.332 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3393 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 152 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 7.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:

$= \min[tb3, \max(tb1, tb2)]$
 $= \min[7.8, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$= \max(ta, tb)$
 $= \max(3.3393, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 15.8500 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio $= tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A $-8 \text{ }^{\circ}\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^{\circ}\text{C}$
Min Metal Temp. w/o impact per UG-20(f) $-29 \text{ }^{\circ}\text{C}$

Gov. MDMT of the nozzle to shell joint welded assembly : $-104 \text{ }^{\circ}\text{C}$

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) $-29 \text{ }^{\circ}\text{C}$
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) $-104 \text{ }^{\circ}\text{C}$

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10/19.60 = 0.209$

Weld Size Calculations, Description: N07B (2in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld $4.9000 = 0.7 * t_{min}$ $7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (1.7753 - 0.4402 + 2 * 12.85 * 0.9894 * (1.0 * 7.0 - 6.2213))138)$
 $= 21.14 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 153 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (4.3322 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 73.38 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.3322 + 0.0 + 0.9894 + (1.7799)) * 138$$

$$= 97.92 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.3322 + 0.0 + 0.9894 + 0.0 + (1.7799)) * 138$$

$$= 97.92 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 82.5 * 10.0 * 0.49 * 136$$

$$= 87. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 34.825) * (15.85 - 3.0) * 0.7 * 136$$

$$= 134. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 82.5 * (10.0 - 3.0) * 0.74 * 138$$

$$= 93. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (87 + 134) = 221 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (87 + 0 + 93 + 0) = 179 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (87 + 93 + 0) = 179 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 220 kN , must exceed W = 21 kN or W1 = 73 kN

Path 2-2 = 179 kN , must exceed W = 21 kN or W2 = 97 kN

Path 3-3 = 179 kN , must exceed W = 21 kN or W3 = 97 kN

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 154 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 1.4197 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 161.4197 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 155 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K9B (3in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	500.0000	mm.
Distance from Bottom/Left Tangent		200.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-106	B
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		-55.05	deg
Diameter		3.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	300.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²


	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 156 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Diameter of Pad along vessel surface	Dp	200.0000	mm.
Thickness of Pad	te	10.0000	mm.
Weld leg size between Pad and Shell	Wp	8.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	10.0000	mm.
Reinforcing Pad Width		55.5500	mm.

Flange Class	300
Flange Grade	GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K9B (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.975	in.
Actual Thickness Used in Calculation	0.263	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4726 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 157 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 294.0029 mm.
Parallel to Vessel Wall, opening length d 147.0015 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Weld Strength Reduction Factor [fr1]:

= min(1, Sn/Sv)
= min(1, 117.9/137.9)
= 0.855

Weld Strength Reduction Factor [fr2]:

= min(1, Sn/Sv)
= min(1, 117.9/137.9)
= 0.855

Weld Strength Reduction Factor [fr4]:

= min(1, Sp/Sv)
= min(1, 137.9/137.9)
= 1.000

Weld Strength Reduction Factor [fr3]:

= min(fr2, fr4)
= min(0.855, 1.0)
= 0.855

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	2.659	4.606	NA
Area in Shell	A1	7.594	1.136	NA
Area in Nozzle Wall	A2	1.631	1.478	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		1.442	1.442	NA
Area in Element	A5	11.110	11.110	NA
TOTAL AREA AVAILABLE	Atot	21.777	15.166	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 33.70 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
Based on given Pad Thickness: 94.3965 10.0000 mm.
Based on given Pad Diameter: 200.0000 0.4947 mm.
Based on Shell or Nozzle Thickness: 168.4648 6.6675 mm.

Area Required [A]:

= 0.5(d * tr*F + 2 * tn * tr*F(1-fr1)) per UG-37(d)
= 0.5(147.0015*6.2213*1+2*3.6675*6.2213*1(1-0.86))
= 4.606 cm²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 158 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot t_r) - 2 \cdot t_n(E1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\
 &= 147.001(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 3.668 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.855) \\
 &= 1.136 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot T_{lwp}) \cdot (t_n - t_{rn}) \cdot fr2 / \sin(\alpha3) \\
 &= (2 \cdot 17.5) \cdot (3.67 - 0.47) \cdot 0.855 / \sin(40.3) \\
 &= 1.478 \text{ cm}^2
 \end{aligned}$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (W_o^2 - A_r \text{ Lost}) \cdot Fr3 + ((W_i - c_{an} / 0.707)^2 - A_r \text{ Lost}) \cdot fr2 + W_p^2 \cdot fr4 \\
 &= (0.9375) \cdot 0.86 + (0.0) \cdot 0.86 + 203.2^2 \cdot 1.0 \\
 &= 1.442 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(D_p, D_L) - (\text{Nozzle OD})) \cdot (\min(t_p, T_{lwp}, t_e)) \cdot fr4 \\
 &= (271.321 - 160.2211) \cdot 10.0 \cdot 1.0 \\
 &= 11.110 \text{ cm}^2
 \end{aligned}$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, min(Curve:B, Curve:A)

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 159 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 51.10 = 0.080$

Weld Size Calculations, Description: K9B (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.
Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) S_v)$$

$$= \max(0, (4.6058 - 1.1364 + 2 * 3.6675 * 0.855 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 48.51 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v$$

$$= (1.4781 + 11.11 + 1.4416 - 0.0 * 0.86) * 138$$

$$= 193.45 \text{ kN}$$

Weld Load [W2]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 160 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (1.4781 + 0.0 + 0.8491 + (0.439)) * 138$$

$$= 38.14 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*t_n*t*f_{r1}))*S$$

$$= (1.4781 + 0.0 + 1.4416 + 11.11 + (0.439)) * 138$$

$$= 199.51 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 160.2211 * 10.0 * 0.49 * 118$$

$$= 145. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416/2.0) * 200.0 * 8.0 * 0.49 * 138$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 76.8056) * (6.6675 - 3.0) * 0.7 * 118$$

$$= 73. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416/2) * 160.2211 * 10.0 * 0.74 * 138$$

$$= 257. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 160.2211 * (10.0 - 3.0) * 0.74 * 138$$

$$= 180. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (170 + 73) = 243 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (145 + 257 + 180 + 0) = 582 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (170 + 180 + 0) = 350 \text{ kN}$$

Summary of Failure Path Calculations:

$$\text{Path 1-1} = 242 \text{ kN} , \text{ must exceed } W = 48 \text{ kN} \text{ or } W1 = 193 \text{ kN}$$

$$\text{Path 2-2} = 581 \text{ kN} , \text{ must exceed } W = 48 \text{ kN} \text{ or } W2 = 38 \text{ kN}$$

$$\text{Path 3-3} = 349 \text{ kN} , \text{ must exceed } W = 48 \text{ kN} \text{ or } W3 = 199 \text{ kN}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 161 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K9B (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.975 in.
Actual Thickness Used in Calculation 0.263 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4726 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 163.1300 mm.
Parallel to Vessel Wall, opening length d 81.5650 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.484	2.570	NA
Area in Shell	A1	4.189	0.627	NA
Area in Nozzle Wall	A2	1.055	0.956	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	7.423	7.423	NA
TOTAL AREA AVAILABLE	Atot	13.469	9.807	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 90.7578 10.0000 mm.

Based on given Pad Diameter: 200.0000 0.2503 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 162 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Based on Shell or Nozzle Thickness: 91.6863 6.6675 mm.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(81.565 * 6.2213 * 1 + 2 * 3.6675 * 6.2213 * 1(1 - 0.86))$$

$$= 2.570 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 81.565(1.0 * 7.0 - 1.0 * 6.221) - 2 * 3.668$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.855)$$

$$= 0.627 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 17.5) * (3.67 - 0.47) * 0.855$$

$$= 0.956 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= (Wo^2 - Ar \text{ Lost}) * Fr3 + ((Wi - can / 0.707)^2 - Ar \text{ Lost}) * fr2 + Wp^2 * fr4$$

$$= (0.9375) * 0.86 + (0.0) * 0.86 + 0.0^2 * 1.0$$

$$= 0.802 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (Nozzle \text{ OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (163.13 - 88.9) * 10.0 * 1.0$$

$$= 7.423 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.4726 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.4726, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 6.6675 mm. --> OK

Weld Size Calculations, Description: K9B (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 163 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v)$$

$$= \max(0, (2.5703 - 0.6269 + 2 * 3.6675 * 0.855 * (1.0 * 7.0 - 6.2213)) * 138)$$

$$= 27.47 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v$$

$$= (0.9561 + 7.423 + 0.8016 - 0.0 * 0.86) * 138$$

$$= 126.59 \text{ kN}$$

Weld Load [W2]:

$$= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (0.9561 + 0.0 + 0.8491 + (0.439)) * 138$$

$$= 30.94 \text{ kN}$$

Weld Load [W3]:

$$= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S$$

$$= (0.9561 + 0.0 + 0.8016 + 7.423 + (0.439)) * 138$$

$$= 132.64 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416 / 2.0) * 88.9 * 10.0 * 0.49 * 118$$

$$= 81. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi / 2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416 / 2.0) * 200.0 * 8.0 * 0.49 * 138$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n$$

$$= (3.1416 * 42.6162) * (6.6675 - 3.0) * 0.7 * 118$$

$$= 41. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi / 2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416 / 2) * 88.9 * 10.0 * 0.74 * 138$$

$$= 142. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 164 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 88.9 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 100. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170 + 41) = 210 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (81 + 142 + 100 + 0) = 323 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (170 + 100 + 0) = 270 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 210 kN , must exceed W = 27 kN or W1 = 126 kN
 Path 2-2 = 322 kN , must exceed W = 27 kN or W2 = 30 kN
 Path 3-3 = 269 kN , must exceed W = 27 kN or W3 = 132 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 79.5232 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 397.2889 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 165 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K9A (3in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	500.0000	mm.
Distance from Bottom/Left Tangent		200.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-106	B
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		55.05	deg
Diameter		3.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	300.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 166 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Diameter of Pad along vessel surface	Dp	200.0000	mm.
Thickness of Pad	te	10.0000	mm.
Weld leg size between Pad and Shell	Wp	8.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	10.0000	mm.
Reinforcing Pad Width		55.5500	mm.

Flange Class	300
Flange Grade	GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K9A (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.975	in.
Actual Thickness Used in Calculation	0.263	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4726 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 167 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 294.0029 mm.
 Parallel to Vessel Wall, opening length d 147.0015 mm.
 Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Weld Strength Reduction Factor [fr1]:

= min(1, Sn/Sv)
 = min(1, 117.9/137.9)
 = 0.855

Weld Strength Reduction Factor [fr2]:

= min(1, Sn/Sv)
 = min(1, 117.9/137.9)
 = 0.855

Weld Strength Reduction Factor [fr4]:

= min(1, Sp/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr3]:

= min(fr2, fr4)
 = min(0.855, 1.0)
 = 0.855

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	2.659	4.606	NA
Area in Shell	A1	7.594	1.136	NA
Area in Nozzle Wall	A2	1.631	1.478	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		1.442	1.442	NA
Area in Element	A5	11.110	11.110	NA
TOTAL AREA AVAILABLE	Atot	21.777	15.166	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 33.70 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
 Based on given Pad Thickness: 94.3965 10.0000 mm.
 Based on given Pad Diameter: 200.0000 0.4947 mm.
 Based on Shell or Nozzle Thickness: 168.4648 6.6675 mm.

Area Required [A]:

= 0.5(d * tr*F + 2 * tn * tr*F(1-fr1)) per UG-37(d)
 = 0.5(147.0015*6.2213*1+2*3.6675*6.2213*1(1-0.86))
 = 4.606 cm²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 168 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot t_r) - 2 \cdot t_n(E1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\
 &= 147.001(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 3.668 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.855) \\
 &= 1.136 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot T_{lwp}) \cdot (t_n - t_{rn}) \cdot fr2 / \sin(\alpha3) \\
 &= (2 \cdot 17.5) \cdot (3.67 - 0.47) \cdot 0.855 / \sin(40.3) \\
 &= 1.478 \text{ cm}^2
 \end{aligned}$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (W_o^2 - A_r \text{ Lost}) \cdot Fr3 + ((W_i - c_{an} / 0.707)^2 - A_r \text{ Lost}) \cdot fr2 + W_p^2 \cdot fr4 \\
 &= (0.9375) \cdot 0.86 + (0.0) \cdot 0.86 + 203.2^2 \cdot 1.0 \\
 &= 1.442 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(D_p, D_L) - (\text{Nozzle OD})) \cdot (\min(t_p, T_{lwp}, t_e)) \cdot fr4 \\
 &= (271.321 - 160.2211) \cdot 10.0 \cdot 1.0 \\
 &= 11.110 \text{ cm}^2
 \end{aligned}$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, min(Curve:B, Curve:A)

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 169 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 51.10 = 0.080$

Weld Size Calculations, Description: K9A (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.
Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) S_v)$$

$$= \max(0, (4.6058 - 1.1364 + 2 * 3.6675 * 0.855 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 48.51 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v$$

$$= (1.4781 + 11.11 + 1.4416 - 0.0 * 0.86) * 138$$

$$= 193.45 \text{ kN}$$

Weld Load [W2]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 170 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (1.4781 + 0.0 + 0.8491 + (0.439)) * 138$$

$$= 38.14 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*t_n*t*f_{r1}))*S$$

$$= (1.4781 + 0.0 + 1.4416 + 11.11 + (0.439)) * 138$$

$$= 199.51 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 160.2211 * 10.0 * 0.49 * 118$$

$$= 145. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416/2.0) * 200.0 * 8.0 * 0.49 * 138$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 76.8056) * (6.6675 - 3.0) * 0.7 * 118$$

$$= 73. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416/2) * 160.2211 * 10.0 * 0.74 * 138$$

$$= 257. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 160.2211 * (10.0 - 3.0) * 0.74 * 138$$

$$= 180. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (170 + 73) = 243 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (145 + 257 + 180 + 0) = 582 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (170 + 180 + 0) = 350 \text{ kN}$$

Summary of Failure Path Calculations:

$$\text{Path 1-1} = 242 \text{ kN} , \text{ must exceed } W = 48 \text{ kN} \text{ or } W1 = 193 \text{ kN}$$

$$\text{Path 2-2} = 581 \text{ kN} , \text{ must exceed } W = 48 \text{ kN} \text{ or } W2 = 38 \text{ kN}$$

$$\text{Path 3-3} = 349 \text{ kN} , \text{ must exceed } W = 48 \text{ kN} \text{ or } W3 = 199 \text{ kN}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 171 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادر کننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K9A (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.975 in.
Actual Thickness Used in Calculation 0.263 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4726 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 163.1300 mm.
Parallel to Vessel Wall, opening length d 81.5650 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.484	2.570	NA
Area in Shell	A1	4.189	0.627	NA
Area in Nozzle Wall	A2	1.055	0.956	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	7.423	7.423	NA
TOTAL AREA AVAILABLE	Atot	13.469	9.807	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 90.7578 10.0000 mm.

Based on given Pad Diameter: 200.0000 0.2503 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 172 از 411
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											

Based on Shell or Nozzle Thickness: 91.6863 6.6675 mm.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(81.565 * 6.2213 * 1 + 2 * 3.6675 * 6.2213 * 1(1 - 0.86))$$

$$= 2.570 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 81.565(1.0 * 7.0 - 1.0 * 6.221) - 2 * 3.668$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.855)$$

$$= 0.627 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 17.5) * (3.67 - 0.47) * 0.855$$

$$= 0.956 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= (Wo^2 - Ar \text{ Lost}) * Fr3 + ((Wi - can / 0.707)^2 - Ar \text{ Lost}) * fr2 + Wp^2 * fr4$$

$$= (0.9375) * 0.86 + (0.0) * 0.86 + 0.0^2 * 1.0$$

$$= 0.802 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (163.13 - 88.9) * 10.0 * 1.0$$

$$= 7.423 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.4726 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.4726, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 6.6675 mm. --> OK

Weld Size Calculations, Description: K9A (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 173 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o \text{ mm.}$
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v) \\
 &= \max(0, (2.5703 - 0.6269 + 2 * 3.6675 * 0.855 * \\
 &\quad (1.0 * 7.0 - 6.2213)) * 138) \\
 &= 27.47 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (0.9561 + 7.423 + 0.8016 - 0.0 * 0.86) * 138 \\
 &= 126.59 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.9561 + 0.0 + 0.8491 + (0.439)) * 138 \\
 &= 30.94 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.9561 + 0.0 + 0.8016 + 7.423 + (0.439)) * 138 \\
 &= 132.64 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 88.9 * 10.0 * 0.49 * 118 \\
 &= 81. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi / 2) * D_P * W_P * 0.49 * S_{EW} \\
 &= (3.1416 / 2.0) * 200.0 * 8.0 * 0.49 * 138 \\
 &= 170. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 42.6162) * (6.6675 - 3.0) * 0.7 * 118 \\
 &= 41. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_{gpn} * 0.74 * S_{eg} \\
 &= (3.1416 / 2) * 88.9 * 10.0 * 0.74 * 138 \\
 &= 142. \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 174 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 88.9 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 100. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170 + 41) = 210 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (81 + 142 + 100 + 0) = 323 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (170 + 100 + 0) = 270 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 210 \text{ kN}, \text{ must exceed } W = 27 \text{ kN} \text{ or } W1 = 126 \text{ kN} \\
 \text{Path 2-2} &= 322 \text{ kN}, \text{ must exceed } W = 27 \text{ kN} \text{ or } W2 = 30 \text{ kN} \\
 \text{Path 3-3} &= 269 \text{ kN}, \text{ must exceed } W = 27 \text{ kN} \text{ or } W3 = 132 \text{ kN}
 \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 79.5232 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 397.2889 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 175 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K10A (2in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	222.0000	mm.
Distance from Bottom/Left Tangent		450.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		-21.34	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 176 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K10A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	122.1596 mm.
Parallel to Vessel Wall, opening length	d	61.0798 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 177 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar		0.551		1.909		NA
Area in Shell	A1		3.709		0.473		NA
Area in Nozzle Wall	A2		4.952		4.858		NA
Area in Inward Nozzle	A3		0.000		0.000		NA
Area in Welds A41+A42+A43			0.989		0.989		NA
Area in Element	A5		0.000		0.000		NA
TOTAL AREA AVAILABLE	Atot		9.651		6.321		NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 68.42 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(61.0798 * 6.2213 * 1 + 2 * 13.6 * 6.2213 * 1(1 - 0.99))$$

$$= 1.909 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 61.08(1.0 * 7.0 - 1.0 * 6.221) - 2 * 13.6$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.473 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 * 17.5) (13.6 - 0.34) 0.9894 / \sin(70.9)$$

$$= 4.858 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 178 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/51.10 = 0.080

Weld Size Calculations, Description: K10A (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (1.909 - 0.4734 + 2 * 13.6 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 6.2213))138) \\
 &= 22.68 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (4.858 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 80.63 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (4.858 + 0.0 + 0.9894 + (1.8838)) * 138 \\
 &= 106.60 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (4.858 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138 \\
 &= 106.60 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 90.3293 * 10.0 * 0.49 * 136 \\
 &= 95. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo)/4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 37.8523) * (16.6 - 3.0) * 0.7 * 136 \\
 &= 154. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 179 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 90.3293 * (10.0 - 3.0) * 0.74 * 138$$

$$= 101. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (95 + 154) = 249 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (95 + 0 + 101 + 0) = 196 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (95 + 101 + 0) = 196 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 249 kN , must exceed W = 22 kN or W1 = 80 kN
 Path 2-2 = 196 kN , must exceed W = 22 kN or W2 = 106 kN
 Path 3-3 = 196 kN , must exceed W = 22 kN or W3 = 106 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K10A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.0855 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 113.6000 mm.
 Parallel to Vessel Wall, opening length d 56.8000 mm.
 Normal to Vessel Wall (Thickness Limit), no pad Tlnp 17.5000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 180 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.776	NA
Area in Shell	A1	2.941	0.440	NA
Area in Nozzle Wall	A2	4.680	4.591	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.610	6.020	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degr.

The area available without a pad is Sufficient.

Area Required [A]:

$$\begin{aligned}
 &= 0.5(d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F(1-fr1)) \text{ per UG-37(d)} \\
 &= 0.5(56.8 \cdot 6.2213 \cdot 1 + 2 \cdot 13.6 \cdot 6.2213 \cdot 1(1-0.99)) \\
 &= 1.776 \text{ cm}^2
 \end{aligned}$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot tr) - 2 \cdot tn(E1 \cdot t - F \cdot tr) \cdot (1 - fr1) \\
 &= 56.8(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 13.6 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989) \\
 &= 0.440 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot tlnp) (tn - trn) fr2 \\
 &= (2 \cdot 17.5) (13.6 - 0.34) 0.9894 \\
 &= 4.591 \text{ cm}^2
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^2 \cdot fr2 + (Wi - can / 0.707)^2 \cdot fr2 \\
 &= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894 \\
 &= 0.989 \text{ cm}^2
 \end{aligned}$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3430 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$\begin{aligned}
 &= \min[tb3, \max(tb1, tb2)] \\
 &= \min[7.8, \max(4.7961, 4.5)] \\
 &= 4.7961 \text{ mm.}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 181 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(t_a, t_b)$$

$$= \max(3.343, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Weld Size Calculations, Description: K10A (2in)

Intermediate Calc. for nozzle/shell Welds t_{min} 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.9000 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v)$$

$$= \max(0, (1.7758 - 0.4401 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 21.31 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v$$

$$= (4.5906 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.94 \text{ kN}$$

Weld Load [W2]:

$$= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (4.5906 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Weld Load [W3]:

$$= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S$$

$$= (4.5906 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416 / 2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 182 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (88 + 144) = 232 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (88 + 0 + 94 + 0) = 182 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (88 + 94 + 0) = 182 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 231 kN , must exceed W = 21 kN or W1 = 76 kN
 Path 2-2 = 182 kN , must exceed W = 21 kN or W2 = 102 kN
 Path 3-3 = 182 kN , must exceed W = 21 kN or W3 = 102 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 18.6204 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 179.3703 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 183 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K10B (2in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	478.0000	mm.
Distance from Bottom/Left Tangent		450.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		-51.59	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	300.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 184 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K10B (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4569 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	185.8421 mm.
Parallel to Vessel Wall, opening length	d	92.9211 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 185 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar		0.837		2.899		NA
Area in Shell	A1		5.652		0.721		NA
Area in Nozzle Wall	A2		7.038		6.844		NA
Area in Inward Nozzle	A3		0.000		0.000		NA
Area in Welds A41+A42+A43			0.989		0.989		NA
Area in Element	A5		0.000		0.000		NA
TOTAL AREA AVAILABLE	Atot		13.679		8.555		NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 37.68 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(92.9211 * 6.2213 * 1 + 2 * 13.6 * 6.2213 * 1(1 - 0.99))$$

$$= 2.899 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 92.921(1.0 * 7.0 - 1.0 * 6.221) - 2 * 13.6$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.721 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 * 17.5) (13.6 - 0.46) 0.9894 / \sin(41.7)$$

$$= 6.844 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 186 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/51.10 = 0.080

Weld Size Calculations, Description: K10B (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (2.8994 - 0.7213 + 2 * 13.6 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 6.2213)) 138) \\
 &= 32.92 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (6.8443 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 108.02 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (6.8443 + 0.0 + 0.9894 + (1.8838)) * 138 \\
 &= 133.99 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (6.8443 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138 \\
 &= 133.99 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 137.4185 * 10.0 * 0.49 * 136 \\
 &= 144. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 57.5849) * (16.6 - 3.0) * 0.7 * 136 \\
 &= 235. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 187 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 137.4185 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 154. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (144 + 235) = 379 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (144 + 0 + 154 + 0) = 298 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (144 + 154 + 0) = 298 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 379 \text{ kN}, \text{ must exceed } W = 32 \text{ kN} \text{ or } W1 = 108 \text{ kN} \\
 \text{Path 2-2} &= 298 \text{ kN}, \text{ must exceed } W = 32 \text{ kN} \text{ or } W2 = 133 \text{ kN} \\
 \text{Path 3-3} &= 298 \text{ kN}, \text{ must exceed } W = 32 \text{ kN} \text{ or } W3 = 133 \text{ kN}
 \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K10B (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4569 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000	mm.
Parallel to Vessel Wall, opening length	d	56.8000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 188 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.776	NA
Area in Shell	A1	2.941	0.440	NA
Area in Nozzle Wall	A2	4.680	4.551	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.610	5.981	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F (1 - fr_1)) \text{ per UG-37(d)}$$

$$= 0.5 (56.8 \cdot 6.2213 \cdot 1 + 2 \cdot 13.6 \cdot 6.2213 \cdot 1 (1 - 0.99))$$

$$= 1.776 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 56.8 (1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 13.6 (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp}) (t_n - tr_n) fr_2$$

$$= (2 \cdot 17.5) (13.6 - 0.46) \cdot 0.9894$$

$$= 4.551 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr_2 + (W_i - can / 0.707)^2 \cdot fr_2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.4569 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb_3, \max(tb_1, tb_2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 189 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

$$= \max(3.4569, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Weld Size Calculations, Description: K10B (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (1.7758 - 0.4401 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 21.31 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (4.5512 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.40 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.5512 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.37 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.5512 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.37 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 190 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SONW} + \text{SNW}) = (88 + 144) = 232 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 0 + 94 + 0) = 182 \text{ kN} \\ \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 94 + 0) = 182 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned} \text{Path 1-1} &= 231 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W1 = 76 \text{ kN} \\ \text{Path 2-2} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W2 = 102 \text{ kN} \\ \text{Path 3-3} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W3 = 102 \text{ kN} \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 63.3188 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 379.6345 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 191 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K11A (2in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	222.0000	mm.
Distance from Bottom/Left Tangent		600.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		21.34	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 192 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K11A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	122.1596 mm.
Parallel to Vessel Wall, opening length	d	61.0798 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 193 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar		0.551		1.909		NA
Area in Shell	A1		3.709		0.473		NA
Area in Nozzle Wall	A2		4.952		4.858		NA
Area in Inward Nozzle	A3		0.000		0.000		NA
Area in Welds A41+A42+A43			0.989		0.989		NA
Area in Element	A5		0.000		0.000		NA
TOTAL AREA AVAILABLE	Atot		9.651		6.321		NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 68.42 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(61.0798 * 6.2213 * 1 + 2 * 13.6 * 6.2213 * 1(1-0.99))$$

$$= 1.909 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 61.08(1.0 * 7.0 - 1.0 * 6.221) - 2 * 13.6$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.473 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 * 17.5) (13.6 - 0.34) 0.9894 / \sin(70.9)$$

$$= 4.858 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi-can/0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 194 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/51.10 = 0.080

Weld Size Calculations, Description: K11A (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

Required Thickness Actual Thickness
 Nozzle Weld 4.9000 = 0.7 * tmin. 7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (1.909 - 0.4734 + 2 * 13.6 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 6.2213)) 138) \\
 &= 22.68 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (4.858 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 80.63 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (4.858 + 0.0 + 0.9894 + (1.8838)) * 138 \\
 &= 106.60 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (4.858 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138 \\
 &= 106.60 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 90.3293 * 10.0 * 0.49 * 136 \\
 &= 95. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 37.8523) * (16.6 - 3.0) * 0.7 * 136 \\
 &= 154. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 195 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 90.3293 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 101. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (95 + 154) = 249 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (95 + 0 + 101 + 0) = 196 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (95 + 101 + 0) = 196 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 249 kN , must exceed W = 22 kN or W1 = 80 kN
 Path 2-2 = 196 kN , must exceed W = 22 kN or W2 = 106 kN
 Path 3-3 = 196 kN , must exceed W = 22 kN or W3 = 106 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K11A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000	mm.
Parallel to Vessel Wall, opening length	d	56.8000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 196 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.776	NA
Area in Shell	A1	2.941	0.440	NA
Area in Nozzle Wall	A2	4.680	4.591	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.610	6.020	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F (1 - fr_1)) \text{ per UG-37(d)}$$

$$= 0.5 (56.8 \cdot 6.2213 \cdot 1 + 2 \cdot 13.6 \cdot 6.2213 \cdot 1 (1 - 0.99))$$

$$= 1.776 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 56.8 (1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 13.6$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp}) (t_n - t_{rn}) fr_2$$

$$= (2 \cdot 17.5) (13.6 - 0.34) 0.9894$$

$$= 4.591 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr_2 + (W_i - can / 0.707)^2 \cdot fr_2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3430 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb_3, \max(tb_1, tb_2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 197 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= \max(3.343, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Weld Size Calculations, Description: K11A (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (1.7758 - 0.4401 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 21.31 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (4.5906 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.94 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.5906 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.5906 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 198 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SONW} + \text{SNW}) = (88 + 144) = 232 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 0 + 94 + 0) = 182 \text{ kN} \\ \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 94 + 0) = 182 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned} \text{Path 1-1} &= 231 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \text{ or } W1 = 76 \text{ kN} \\ \text{Path 2-2} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \text{ or } W2 = 102 \text{ kN} \\ \text{Path 3-3} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \text{ or } W3 = 102 \text{ kN} \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 18.6204 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 179.3703 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 199 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input, Nozzle Desc: K11B (2in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.

Note : User defined Limit(s) of Reinforcement specified below:

Physical Maximum for Diameter Limit	Dmax	90.0000	mm.
Distance from Cylinder/Cone Centerline	L1	478.0000	mm.
Distance from Bottom/Left Tangent		600.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		51.59	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	300.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 200 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Flange Class
Flange Grade

300
GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K11B (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4569 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	147.2341 mm.
Parallel to Vessel Wall, opening length	d	73.6170 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 201 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	0.837	2.899	NA
Area in Shell	A1	3.296	0.421	NA
Area in Nozzle Wall	A2	7.038	6.844	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	11.324	8.254	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 37.68 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5 (92.9211 \cdot 6.2213 \cdot 1 + 2 \cdot 13.6 \cdot 6.2213 \cdot 1 (1 - 0.99))$$

$$= 2.899 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 \cdot t - F \cdot tr) - 2 \cdot tn (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 54.313 (1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 13.6$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989)$$

$$= 0.421 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 \cdot 17.5) (13.6 - 0.46) 0.9894 / \sin(41.7)$$

$$= 6.844 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 \cdot fr2 + (Wi - can / 0.707)^2 \cdot fr2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 202 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = 4.10/51.10 = 0.080

Weld Size Calculations, Description: K11B (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (2.8994 - 0.4207 + 2 * 13.6 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 6.2213)) 138) \\
 &= 37.07 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (6.8443 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 108.02 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (6.8443 + 0.0 + 0.9894 + (1.8838)) * 138 \\
 &= 133.99 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (6.8443 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138 \\
 &= 133.99 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 137.4185 * 10.0 * 0.49 * 136 \\
 &= 144. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 57.5849) * (16.6 - 3.0) * 0.7 * 136 \\
 &= 235. \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 203 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 137.4185 * (10.0 - 3.0) * 0.74 * 138$$

$$= 154. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (144 + 235) = 379 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (144 + 0 + 154 + 0) = 298 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (144 + 154 + 0) = 298 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 379 kN , must exceed W = 37 kN or W1 = 108 kN
 Path 2-2 = 298 kN , must exceed W = 37 kN or W2 = 133 kN
 Path 3-3 = 298 kN , must exceed W = 37 kN or W3 = 133 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K11B (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.0855 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4569 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 90.0000 mm.
 Parallel to Vessel Wall, opening length d 45.0000 mm.
 Normal to Vessel Wall (Thickness Limit), no pad Tlnp 17.5000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 204 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.776	NA
Area in Shell	A1	1.713	0.256	NA
Area in Nozzle Wall	A2	4.680	4.551	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.505	0.505	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	6.897	5.312	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degr.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F (1 - fr1)) \text{ per UG-37 (d)}$$

$$= 0.5 (56.8 \cdot 6.2213 \cdot 1 + 2 \cdot 13.6 \cdot 6.2213 \cdot 1 (1 - 0.99))$$

$$= 1.776 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 \cdot t - F \cdot tr) - 2 \cdot tn (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 33.2 (1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 13.6$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989)$$

$$= 0.256 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot tlnp) (tn - trn) fr2$$

$$= (2 \cdot 17.5) (13.6 - 0.46) 0.9894$$

$$= 4.551 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= (Wo^2 - \text{Area Lost}) \cdot fr2 + ((Wi - can / 0.707)^2 - \text{Area Lost}) \cdot fr2$$

$$= (10.0^2 - 0.49) \cdot 0.9894 + (0.0^2 - 0.0) \cdot 0.9894$$

$$= 0.505 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.4569 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min [tb3, \max (tb1, tb2)]$$

$$= \min [7.8, \max (4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 205 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(t_a, t_b)$$

$$= \max(3.4569, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Weld Size Calculations, Description: K11B (2in)

Intermediate Calc. for nozzle/shell Welds $t_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.9000 = 0.7 * t_{min}.$	$7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) S_v)$$

$$= \max(0, (1.7758 - 0.2563 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 23.84 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v$$

$$= (4.5512 + 0.0 + 0.5046 - 0.0 * 0.99) * 138$$

$$= 69.71 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (4.5512 + 0.0 + 0.5046 + (1.8838)) * 138$$

$$= 95.69 \text{ kN}$$

Weld Load [W3]:

$$= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S$$

$$= (4.5512 + 0.0 + 0.5046 + 0.0 + (1.8838)) * 138$$

$$= 95.69 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416 / 2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 206 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SONW} + \text{SNW}) = (88 + 144) = 232 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (88 + 0 + 94 + 0) = 182 \text{ kN}$$

$$\text{PATH33} = (\text{Sonw} + \text{Tngw} + \text{Sinw})$$

$$= (88 + 94 + 0) = 182 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 231 kN , must exceed W = 23 kN or W1 = 69 kN
 Path 2-2 = 182 kN , must exceed W = 23 kN or W2 = 95 kN
 Path 3-3 = 182 kN , must exceed W = 23 kN or W3 = 95 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 63.3188 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 379.6345 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 207 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K7A (3in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	50.0000	mm.
Distance from Bottom/Left Tangent		1250.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-106	B
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		4.70	deg
Diameter		3.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²


	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 208 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Diameter of Pad along vessel surface	Dp	200.0000	mm.
Thickness of Pad	te	10.0000	mm.
Weld leg size between Pad and Shell	Wp	8.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	10.0000	mm.
Reinforcing Pad Width		55.5500	mm.

Flange Class	300
Flange Grade	GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K7A (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.975	in.
Actual Thickness Used in Calculation	0.263	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3989 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 209 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 163.8150 mm.
 Parallel to Vessel Wall, opening length d 81.9075 mm.
 Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

= min(1, Sn/Sv)
 = min(1, 117.9/137.9)
 = 0.855

Weld Strength Reduction Factor [fr2]:

= min(1, Sn/Sv)
 = min(1, 117.9/137.9)
 = 0.855

Weld Strength Reduction Factor [fr4]:

= min(1, Sp/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr3]:

= min(fr2, fr4)
 = min(0.855, 1.0)
 = 0.855

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.490	2.581	NA
Area in Shell	A1	4.207	0.630	NA
Area in Nozzle Wall	A2	1.055	0.978	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	7.454	7.454	NA
TOTAL AREA AVAILABLE	Atot	13.518	9.864	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 84.76 Degr.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
 Based on given Pad Thickness: 90.6140 10.0000 mm.
 Based on given Pad Diameter: 200.0000 0.2299 mm.
 Based on Shell or Nozzle Thickness: 91.8440 6.6675 mm.

Area Required [A]:

= 0.5(d * tr*F + 2 * tn * tr*F(1-fr1)) per UG-37(d)
 = 0.5(81.9075*6.2213*1+2*3.6675*6.2213*1(1-0.86))

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 210 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= 2.581 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot t_r) - 2 \cdot t_n(E1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\
 &= 81.908(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 3.668 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.855) \\
 &= 0.630 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot T_{lwp}) \cdot (t_n - t_{rn}) \cdot f_{r2} / \sin(\alpha_3) \\
 &= (2 \cdot 17.5) \cdot (3.67 - 0.4) \cdot 0.855 / \sin(88.6) \\
 &= 0.978 \text{ cm}^2
 \end{aligned}$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (W_o^2 - A_r \text{ Lost}) \cdot F_{r3} + ((W_i - c_{an} / 0.707)^2 - A_r \text{ Lost}) \cdot f_{r2} + W_p^2 \cdot f_{r4} \\
 &= (0.9375) \cdot 0.86 + (0.0) \cdot 0.86 + 0.0^2 \cdot 1.0 \\
 &= 0.802 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(D_p, D_L) - (\text{Nozzle OD})) \cdot (\min(t_p, T_{lwp}, t_e)) \cdot f_{r4} \\
 &= (163.815 - 89.2733) \cdot 10.0 \cdot 1.0 \\
 &= 7.454 \text{ cm}^2
 \end{aligned}$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, min(Curve:B, Curve:A)

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 211 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 51.10 = 0.080$

Weld Size Calculations, Description: K7A (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.
Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) S_v)$$

$$= \max(0, (2.5809 - 0.6295 + 2 * 3.6675 * 0.855 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 27.58 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v$$

$$= (0.9784 + 7.4542 + 0.8016 - 0.0 * 0.86) * 138$$

$$= 127.33 \text{ kN}$$

Weld Load [W2]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 212 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (0.9784 + 0.0 + 0.8491 + (0.439)) * 138$$

$$= 31.25 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*t_n*t*f_{r1}))*S$$

$$= (0.9784 + 0.0 + 0.8016 + 7.4542 + (0.439)) * 138$$

$$= 133.38 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 89.2733 * 10.0 * 0.49 * 118$$

$$= 81. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416/2.0) * 200.0 * 8.0 * 0.49 * 138$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 42.7952) * (6.6675 - 3.0) * 0.7 * 118$$

$$= 41. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416/2) * 89.2733 * 10.0 * 0.74 * 138$$

$$= 143. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 89.2733 * (10.0 - 3.0) * 0.74 * 138$$

$$= 100. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (170 + 41) = 211 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (81 + 143 + 100 + 0) = 324 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (170 + 100 + 0) = 270 \text{ kN}$$

Summary of Failure Path Calculations:

$$\text{Path 1-1} = 210 \text{ kN , must exceed } W = 27 \text{ kN or } W1 = 127 \text{ kN}$$

$$\text{Path 2-2} = 324 \text{ kN , must exceed } W = 27 \text{ kN or } W2 = 31 \text{ kN}$$

$$\text{Path 3-3} = 269 \text{ kN , must exceed } W = 27 \text{ kN or } W3 = 133 \text{ kN}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 213 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K7A (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.975 in.
Actual Thickness Used in Calculation 0.263 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3989 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 163.1300 mm.
Parallel to Vessel Wall, opening length d 81.5650 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.484	2.570	NA
Area in Shell	A1	4.189	0.627	NA
Area in Nozzle Wall	A2	1.055	0.978	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	7.423	7.423	NA
TOTAL AREA AVAILABLE	Atot	13.469	9.830	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 90.5371 10.0000 mm.

Based on given Pad Diameter: 200.0000 0.2206 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 214 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Based on Shell or Nozzle Thickness: 91.3554 6.6675 mm.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(81.565 * 6.2213 * 1 + 2 * 3.6675 * 6.2213 * 1(1 - 0.86))$$

$$= 2.570 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 81.565(1.0 * 7.0 - 1.0 * 6.221) - 2 * 3.668$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.855)$$

$$= 0.627 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 17.5) * (3.67 - 0.4) * 0.855$$

$$= 0.978 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= (Wo^2 - Ar \text{ Lost}) * Fr3 + ((Wi - can / 0.707)^2 - Ar \text{ Lost}) * fr2 + Wp^2 * fr4$$

$$= (0.9375) * 0.86 + (0.0) * 0.86 + 0.0^2 * 1.0$$

$$= 0.802 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (min(Dp, DL) - (Nozzle OD)) * (min(tp, Tlwp, te)) * fr4$$

$$= (163.13 - 88.9) * 10.0 * 1.0$$

$$= 7.423 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3989 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.3989, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 6.6675 mm. --> OK

Weld Size Calculations, Description: K7A (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 215 از 411	
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری		پروژه
	V00	0009	CN	ME	120	MF	GCS		BK

Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v) \\
 &= \max(0, (2.5703 - 0.6269 + 2 * 3.6675 * 0.855 * (1.0 * 7.0 - 6.2213)) * 138) \\
 &= 27.47 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (0.9781 + 7.423 + 0.8016 - 0.0 * 0.86) * 138 \\
 &= 126.89 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.9781 + 0.0 + 0.8491 + (0.439)) * 138 \\
 &= 31.25 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.9781 + 0.0 + 0.8016 + 7.423 + (0.439)) * 138 \\
 &= 132.95 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 88.9 * 10.0 * 0.49 * 118 \\
 &= 81. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi / 2) * D_P * W_P * 0.49 * S_{EW} \\
 &= (3.1416 / 2.0) * 200.0 * 8.0 * 0.49 * 138 \\
 &= 170. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 42.6162) * (6.6675 - 3.0) * 0.7 * 118 \\
 &= 41. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_{gpn} * 0.74 * S_{eg} \\
 &= (3.1416 / 2) * 88.9 * 10.0 * 0.74 * 138 \\
 &= 142. \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 216 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 88.9 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 100. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170 + 41) = 210 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (81 + 142 + 100 + 0) = 323 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (170 + 100 + 0) = 270 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 210 kN , must exceed W = 27 kN or W1 = 126 kN
 Path 2-2 = 322 kN , must exceed W = 27 kN or W2 = 31 kN
 Path 3-3 = 269 kN , must exceed W = 27 kN or W3 = 132 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 5.3937 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 215.4280 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 217 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Input, Nozzle Desc: K7B (3in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	350.0000	mm.
Distance from Bottom/Left Tangent		1250.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle


Material		SA-106	B
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		-35.01	deg
Diameter		3.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	250.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 218 از 411	
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری		پروژه
	V00	0009	CN	ME	120	MF	GCS		BK

Diameter of Pad along vessel surface	Dp	200.0000	mm.
Thickness of Pad	te	10.0000	mm.
Weld leg size between Pad and Shell	Wp	8.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	10.0000	mm.
Reinforcing Pad Width		55.5500	mm.
Flange Class		300	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K7B (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.975	in.
Actual Thickness Used in Calculation	0.263	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.1421 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4399 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 219 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 200.3822 mm.
Parallel to Vessel Wall, opening length d 100.1911 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Weld Strength Reduction Factor [fr1]:

= min(1, Sn/Sv)
= min(1, 117.9/137.9)
= 0.855

Weld Strength Reduction Factor [fr2]:

= min(1, Sn/Sv)
= min(1, 117.9/137.9)
= 0.855

Weld Strength Reduction Factor [fr4]:

= min(1, Sp/Sv)
= min(1, 137.9/137.9)
= 1.000

Weld Strength Reduction Factor [fr3]:

= min(fr2, fr4)
= min(0.855, 1.0)
= 0.855

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.819	3.150	NA
Area in Shell	A1	5.158	0.772	NA
Area in Nozzle Wall	A2	1.232	1.128	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	9.118	9.118	NA
TOTAL AREA AVAILABLE	Atot	16.310	11.820	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 54.50 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
Based on given Pad Thickness: 93.3801 10.0000 mm.
Based on given Pad Diameter: 200.0000 0.4913 mm.
Based on Shell or Nozzle Thickness: 115.9204 6.6675 mm.

Area Required [A]:

= 0.5(d * tr*F + 2 * tn * tr*F(1-fr1)) per UG-37(d)
= 0.5(100.1911*6.2213*1+2*3.6675*6.2213*1(1-0.86))
= 3.150 cm²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 220 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot t_r) - 2 \cdot t_n(E1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\
 &= 100.191(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 3.668 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.855) \\
 &= 0.772 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot T_{lwp}) \cdot (t_n - t_{rn}) \cdot fr2 / \sin(\alpha_3) \\
 &= (2 \cdot 17.5) \cdot (3.67 - 0.44) \cdot 0.855 / \sin(58.9) \\
 &= 1.128 \text{ cm}^2
 \end{aligned}$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (W_o^2 - A_r \text{ Lost}) \cdot Fr3 + ((W_i - c_{an} / 0.707)^2 - A_r \text{ Lost}) \cdot fr2 + W_p^2 \cdot fr4 \\
 &= (0.9375) \cdot 0.86 + (0.0) \cdot 0.86 + 0.0^2 \cdot 1.0 \\
 &= 0.802 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(D_p, D_L) - (\text{Nozzle OD})) \cdot (\min(t_p, T_{lwp}, t_e)) \cdot fr4 \\
 &= (200.3822 - 109.2011) \cdot 10.0 \cdot 1.0 \\
 &= 9.118 \text{ cm}^2
 \end{aligned}$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, min(Curve:B, Curve:A)

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.039, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.039, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.039, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 221 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -29 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 51.10 = 0.080$

Weld Size Calculations, Description: K7B (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.
Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) S_v)$$

$$= \max(0, (3.1497 - 0.7719 + 2 * 3.6675 * 0.855 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 33.46 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v$$

$$= (1.1282 + 9.1181 + 0.8016 - 0.0 * 0.86) * 138$$

$$= 152.34 \text{ kN}$$

Weld Load [W2]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 222 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (1.1282 + 0.0 + 0.8491 + (0.439)) * 138$$

$$= 33.32 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*t_n*t*f_{r1}))*S$$

$$= (1.1282 + 0.0 + 0.8016 + 9.1181 + (0.439)) * 138$$

$$= 158.39 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 109.2011 * 10.0 * 0.49 * 118$$

$$= 99. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416/2.0) * 200.0 * 8.0 * 0.49 * 138$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 52.3481) * (6.6675 - 3.0) * 0.7 * 118$$

$$= 50. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416/2) * 109.2011 * 10.0 * 0.74 * 138$$

$$= 175. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 109.2011 * (10.0 - 3.0) * 0.74 * 138$$

$$= 123. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (170 + 50) = 220 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (99 + 175 + 123 + 0) = 397 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (170 + 123 + 0) = 292 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 219 kN , must exceed W = 33 kN or W1 = 152 kN
 Path 2-2 = 396 kN , must exceed W = 33 kN or W2 = 33 kN
 Path 3-3 = 292 kN , must exceed W = 33 kN or W3 = 158 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 223 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K7B (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.975 in.
Actual Thickness Used in Calculation 0.263 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4399 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 163.1300 mm.
Parallel to Vessel Wall, opening length d 81.5650 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.484	2.570	NA
Area in Shell	A1	4.189	0.627	NA
Area in Nozzle Wall	A2	1.055	0.966	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	7.423	7.423	NA
TOTAL AREA AVAILABLE	Atot	13.469	9.817	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
Based on given Pad Thickness: 90.6597 10.0000 mm.
Based on given Pad Diameter: 200.0000 0.2371 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 224 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Based on Shell or Nozzle Thickness: 91.5392 6.6675 mm.

Area Required [A]:

$$\begin{aligned}
 &= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)} \\
 &= 0.5(81.565 * 6.2213 * 1 + 2 * 3.6675 * 6.2213 * 1(1 - 0.86)) \\
 &= 2.570 \text{ cm}^2
 \end{aligned}$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1) \\
 &= 81.565(1.0 * 7.0 - 1.0 * 6.221) - 2 * 3.668 \\
 &\quad (1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.855) \\
 &= 0.627 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 * Tlwp) * (tn - trn) * fr2 \\
 &= (2 * 17.5) * (3.67 - 0.44) * 0.855 \\
 &= 0.966 \text{ cm}^2
 \end{aligned}$$

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (Wo^2 - Ar \text{ Lost}) * Fr3 + ((Wi - can / 0.707)^2 - Ar \text{ Lost}) * fr2 + Wp^2 * fr4 \\
 &= (0.9375) * 0.86 + (0.0) * 0.86 + 0.0^2 * 1.0 \\
 &= 0.802 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(Dp, DL) - (Nozzle \text{ OD})) * (\min(tp, Tlwp, te)) * fr4 \\
 &= (163.13 - 88.9) * 10.0 * 1.0 \\
 &= 7.423 \text{ cm}^2
 \end{aligned}$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.4399 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$\begin{aligned}
 &= \min[tb3, \max(tb1, tb2)] \\
 &= \min[7.8, \max(4.7961, 4.5)] \\
 &= 4.7961 \text{ mm.}
 \end{aligned}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$\begin{aligned}
 &= \max(ta, tb) \\
 &= \max(3.4399, 4.7961) \\
 &= 4.7961 \text{ mm.}
 \end{aligned}$$

Available Nozzle Neck Thickness = 6.6675 mm. --> OK

Weld Size Calculations, Description: K7B (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 225 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o \text{ mm.}$
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v) \\
 &= \max(0, (2.5703 - 0.6269 + 2 * 3.6675 * 0.855 * \\
 &\quad (1.0 * 7.0 - 6.2213)) * 138) \\
 &= 27.47 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (0.9659 + 7.423 + 0.8016 - 0.0 * 0.86) * 138 \\
 &= 126.73 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.9659 + 0.0 + 0.8491 + (0.439)) * 138 \\
 &= 31.08 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.9659 + 0.0 + 0.8016 + 7.423 + (0.439)) * 138 \\
 &= 132.78 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 88.9 * 10.0 * 0.49 * 118 \\
 &= 81. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi / 2) * D_P * W_P * 0.49 * S_{EW} \\
 &= (3.1416 / 2.0) * 200.0 * 8.0 * 0.49 * 138 \\
 &= 170. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 42.6162) * (6.6675 - 3.0) * 0.7 * 118 \\
 &= 41. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_{gpn} * 0.74 * S_{eg} \\
 &= (3.1416 / 2) * 88.9 * 10.0 * 0.74 * 138 \\
 &= 142. \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 226 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 88.9 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 100. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170 + 41) = 210 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (81 + 142 + 100 + 0) = 323 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (170 + 100 + 0) = 270 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 210 kN , must exceed W = 27 kN or W1 = 126 kN
 Path 2-2 = 322 kN , must exceed W = 27 kN or W2 = 31 kN
 Path 3-3 = 269 kN , must exceed W = 27 kN or W3 = 132 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 35.2234 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 297.4835 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 227 از 411
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											

Input, Nozzle Desc: N05 (2in)

From: 20

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		1415.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		270.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	15.8500	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 228 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: N05 (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.624 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3393 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000 mm.
Parallel to Vessel Wall, opening length	d	56.8000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 229 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.775	NA
Area in Shell	A1	2.942	0.440	NA
Area in Nozzle Wall	A2	4.420	4.332	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.351	5.762	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(56.8 * 6.2213 * 1 + 2 * 12.85 * 6.2213 * 1(1-0.99))$$

$$= 1.775 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 56.8(1.0 * 7.0 - 1.0 * 6.221) - 2 * 12.85$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 17.5) (12.85 - 0.34) 0.9894$$

$$= 4.332 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3393 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 - 073 - 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 230 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 7.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:

$= \min[tb3, \max(tb1, tb2)]$
 $= \min[7.8, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$= \max(ta, tb)$
 $= \max(3.3393, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 15.8500 mm. --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained	: 12.0,	Allowable	: 136.4 N./mm ²	Passed
Expansion	: 0.0,	Allowable	: 330.9 N./mm ²	Passed
Occasional	: 0.4,	Allowable	: 181.5 N./mm ²	Passed
Shear	: 3.1,	Allowable	: 95.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c)	-29 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b)	-104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 19.60 = 0.209$

Weld Size Calculations, Description: N05 (2in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.9000 = 0.7 * t_{min.}$	$7.0700 = 0.7 * W_o \text{ mm.}$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 231 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (1.7753 - 0.4402 + 2 * 12.85 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 6.2213)) 138) \\
 &= 21.14 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (4.3322 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 73.38 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (4.3322 + 0.0 + 0.9894 + (1.7799)) * 138 \\
 &= 97.92 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (4.3322 + 0.0 + 0.9894 + 0.0 + (1.7799)) * 138 \\
 &= 97.92 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 82.5 * 10.0 * 0.49 * 136 \\
 &= 87. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 34.825) * (15.85 - 3.0) * 0.7 * 136 \\
 &= 134. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng \\
 &= (3.1416/2.0) * 82.5 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 93. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (87 + 134) = 221 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (87 + 0 + 93 + 0) = 179 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (87 + 93 + 0) = 179 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 220 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W1 = 73 \text{ kN} \\
 \text{Path 2-2} &= 179 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W2 = 97 \text{ kN} \\
 \text{Path 3-3} &= 179 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W3 = 97 \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 232 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادر کننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 1.4197 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 161.4197 mm.

Input Echo, WRC107/537 Item 1, Description: N05 (2in) :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	1200.000	mm.
Vessel Thickness	Tv	10.000	mm.
Design Temperature	T1	234.0	°C
Vessel Material		SA-516 70	
Vessel UNS Number		K02700	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²

Note:

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-516 70

Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	ID	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	50.800	mm.
Nozzle Thickness	Tn	15.850	mm.
Nozzle Material		SA-105	
Nozzle UNS Number		K03504	
Nozzle Cold S.I. Allowable	SNmc	137.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	136.43	N./mm ²
Design Internal Pressure	Dp	4.100	bars
Include Pressure Thrust	No		

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.8	kN
Longitudinal Shear (SUS)	Vl	2.8	kN
Circumferential Shear (SUS)	Vc	-2.1	kN
Circumferential Moment (SUS)	Mc	-280.0	N-m
Longitudinal Moment (SUS)	Ml	-360.0	N-m
Torsional Moment (SUS)	Mt	-420.0	N-m

Use Interactive Control

No

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 233 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

WRC107 Version

Version March 1979

Include Pressure Stress Indices per Div. 2

No

Compute Pressure Stress per WRC-368


No

Local Loads applied at end of Nozzle/Attachment

No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".



Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$\begin{aligned}
 &= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(\text{t} - \text{ca})) \\
 &= 82.5 + 2 * 1.65 * \text{sqrt}(606.5 (10.0 - 3.0)) \\
 &= 297.520 \text{ mm.}
 \end{aligned}$$

WRC 107 Stress Calculation for SUSTAINED loads:

Radial Load	P	2.8	kN
Circumferential Shear	VC	-2.1	kN
Longitudinal Shear	VL	2.8	kN
Circumferential Moment	MC	-280.0	N-m
Longitudinal Moment	ML	-360.0	N-m
Torsional Moment	MT	-420.0	N-m

Dimensionless Parameters used : Gamma = 86.64

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.060	4C	15.037	(A,B)
N(PHI) / (P/Rm)	0.060	3C	14.463	(C,D)
M(PHI) / (P)	0.060	2C1	0.100	(A,B)
M(PHI) / (P)	0.060	1C	0.139	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.060	3A	2.228	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.060	1A	0.096	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.060	3B	7.820	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.060	1B	0.049	(A,B,C,D)
N(x) / (P/Rm)	0.060	3C	14.463	(A,B)
N(x) / (P/Rm)	0.060	4C	15.037	(C,D)
M(x) / (P)	0.060	1C1	0.143	(A,B)
M(x) / (P)	0.060	2C	0.101	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.060	4A	3.056	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.060	2A	0.057	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.060	4B	2.219	(A,B,C,D)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 234 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

M(x) / (ML/(Rm * Beta)) 0.060 2B 0.080 (A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Type of Stress Load		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-9.9	-9.9	-9.9	-9.9	-9.5	-9.5	-9.5	-9.5
Circ. Bend. P		-34.4	34.4	-34.4	34.4	-47.7	47.7	-47.7	47.7
Circ. Memb. MC		0.0	0.0	0.0	0.0	4.1	4.1	-4.1	-4.1
Circ. Memb. MC		0.0	0.0	0.0	0.0	91.5	-91.5	-91.5	91.5
Circ. Memb. ML		18.4	18.4	-18.4	-18.4	0.0	0.0	0.0	0.0
Circ. Bend. ML		60.3	-60.3	-60.3	60.3	0.0	0.0	0.0	0.0
Tot. Circ. Str.		34.3	-17.4	-123.1	66.5	38.3	-49.2	-152.8	125.6
Long. Memb. P		-9.5	-9.5	-9.5	-9.5	-9.9	-9.9	-9.9	-9.9
Long. Bend. P		-49.2	49.2	-49.2	49.2	-34.6	34.6	-34.6	34.6
Long. Memb. MC		0.0	0.0	0.0	0.0	5.6	5.6	-5.6	-5.6
Long. Bend. MC		0.0	0.0	0.0	0.0	53.8	-53.8	-53.8	53.8
Long. Memb. ML		5.2	5.2	-5.2	-5.2	0.0	0.0	0.0	0.0
Long. Bend. ML		97.2	-97.2	-97.2	97.2	0.0	0.0	0.0	0.0
Tot. Long. Str.		43.7	-52.3	-161.1	131.6	14.8	-23.5	-103.8	72.8
Shear VC		-2.3	-2.3	2.3	2.3	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-3.1	-3.1	3.1	3.1
Shear MT		-5.6	-5.6	-5.6	-5.6	-5.6	-5.6	-5.6	-5.6
Tot. Shear		-7.9	-7.9	-3.3	-3.3	-8.7	-8.7	-2.5	-2.5
Str. Int.		48.2	54.0	161.4	131.8	41.1	51.9	152.9	125.7

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress Load		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		35.1	35.5	35.1	35.5	35.1	35.5	35.1	35.5
Circ. Pl (SUS)		8.4	8.4	-28.3	-28.3	-5.5	-5.5	-13.6	-13.6
Circ. Q (SUS)		25.9	-25.9	-94.8	94.8	43.7	-43.7	-139.2	139.2
Long. Pm (SUS)		17.6	17.6	17.6	17.6	17.6	17.6	17.6	17.6
Long. Pl (SUS)		-4.3	-4.3	-14.8	-14.8	-4.3	-4.3	-15.5	-15.5
Long. Q (SUS)		48.0	-48.0	-146.3	146.3	19.2	-19.2	-88.3	88.3

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 - 073 - 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 235 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Shear Pm (SUS)		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0		0.0
Shear Pl (SUS)		-2.3		-2.3		2.3		2.3		-3.1		-3.1		3.1		3.1		3.1
Shear Q (SUS)		-5.6		-5.6		-5.6		-5.6		-5.6		-5.6		-5.6		-5.6		-5.6
Pm (SUS)		35.1		35.5		35.1		35.5		35.1		35.5		35.1		35.5		35.5
Pm+Pl (SUS)		43.7		44.1		7.9		8.2		30.2		30.6		22.0		22.4		22.4
Pm+Pl+Q (Total)		74.3		55.2		143.7		149.4		75.1		19.3		117.9		161.2		161.2

Vessel Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	35.53	137.90	Passed
Pm+Pl (SUS)	44.15	206.85	Passed
Pm+Pl+Q (TOTAL)	161.21	413.70	Passed

Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 236 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K2B (2in)

From: 30

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	228.0000	mm.
Distance from Bottom/Left Tangent		2200.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		-21.95	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 237 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K2B (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	122.6836 mm.
Parallel to Vessel Wall, opening length	d	61.3418 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 238 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar		0.553		1.917		NA
Area in Shell	A1		3.725		0.475		NA
Area in Nozzle Wall	A2		4.971		4.876		NA
Area in Inward Nozzle	A3		0.000		0.000		NA
Area in Welds A41+A42+A43			0.989		0.989		NA
Area in Element	A5		0.000		0.000		NA
TOTAL AREA AVAILABLE	Atot		9.685		6.341		NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 67.81 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(61.3418 * 6.2213 * 1 + 2 * 13.6 * 6.2213 * 1(1 - 0.99))$$

$$= 1.917 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 61.342(1.0 * 7.0 - 1.0 * 6.221) - 2 * 13.6$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.475 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 * 17.5) (13.6 - 0.34) 0.9894 / \sin(70.3)$$

$$= 4.876 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 239 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/51.10 = 0.080

Weld Size Calculations, Description: K2B (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

 Required Thickness Actual Thickness
 Nozzle Weld 4.9000 = 0.7 * tmin. 7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (1.9171 - 0.4754 + 2 * 13.6 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 6.2213))138) \\
 &= 22.77 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (4.8759 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 80.88 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (4.8759 + 0.0 + 0.9894 + (1.8838)) * 138 \\
 &= 106.85 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (4.8759 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138 \\
 &= 106.85 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 90.7167 * 10.0 * 0.49 * 136 \\
 &= 95. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo)/4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 38.0146) * (16.6 - 3.0) * 0.7 * 136 \\
 &= 155. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 240 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 90.7167 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 102. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (95 + 155) = 250 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (95 + 0 + 102 + 0) = 197 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (95 + 102 + 0) = 197 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 250 kN , must exceed W = 22 kN or W1 = 80 kN
 Path 2-2 = 197 kN , must exceed W = 22 kN or W2 = 106 kN
 Path 3-3 = 197 kN , must exceed W = 22 kN or W3 = 106 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K2B (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000	mm.
Parallel to Vessel Wall, opening length	d	56.8000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 241 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.776	NA
Area in Shell	A1	2.941	0.440	NA
Area in Nozzle Wall	A2	4.680	4.591	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.610	6.020	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F (1 - fr_1)) \text{ per UG-37(d)}$$

$$= 0.5 (56.8 \cdot 6.2213 \cdot 1 + 2 \cdot 13.6 \cdot 6.2213 \cdot 1 (1 - 0.99))$$

$$= 1.776 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 56.8 (1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 13.6$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp}) (t_n - t_{rn}) fr_2$$

$$= (2 \cdot 17.5) (13.6 - 0.34) 0.9894$$

$$= 4.591 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr_2 + (W_i - can / 0.707)^2 \cdot fr_2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3430 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 242 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= \max(3.343, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Weld Size Calculations, Description: K2B (2in)

Intermediate Calc. for nozzle/shell Welds T_{min} 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * t _{min} .	7.0700 = 0.7 * W _o mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (1.7758 - 0.4401 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 21.31 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (4.5906 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.94 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.5906 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.5906 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 243 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SONW} + \text{SNW}) = (88 + 144) = 232 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 0 + 94 + 0) = 182 \text{ kN} \\ \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 94 + 0) = 182 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned} \text{Path 1-1} &= 231 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W1 = 76 \text{ kN} \\ \text{Path 2-2} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W2 = 102 \text{ kN} \\ \text{Path 3-3} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W3 = 102 \text{ kN} \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 19.1747 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 179.9709 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 244 از 411
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											

Input, Nozzle Desc: K2A (2in)

From: 30

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	28.0000	mm.
Distance from Bottom/Left Tangent		2200.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		2.63	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 245 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K2A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.7635	mm.
Parallel to Vessel Wall, opening length	d	56.8818	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 246 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar		0.513		1.778		NA
Area in Shell	A1		3.453		0.441		NA
Area in Nozzle Wall	A2		4.680		4.591		NA
Area in Inward Nozzle	A3		0.000		0.000		NA
Area in Welds A41+A42+A43			0.989		0.989		NA
Area in Element	A5		0.000		0.000		NA
TOTAL AREA AVAILABLE	Atot		9.123		6.021		NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 86.93 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(56.8818 * 6.2213 * 1 + 2 * 13.6 * 6.2213 * 1(1 - 0.99))$$

$$= 1.778 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 56.882(1.0 * 7.0 - 1.0 * 6.221) - 2 * 13.6$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.441 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 * 17.5) (13.6 - 0.34) 0.9894 / \sin(89.5)$$

$$= 4.591 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 247 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/51.10 = 0.080

Weld Size Calculations, Description: K2A (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

 Required Thickness Actual Thickness
 Nozzle Weld 4.9000 = 0.7 * tmin. 7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (1.7784 - 0.4407 + 2 * 13.6 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 6.2213))138) \\
 &= 21.33 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (4.5908 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 76.94 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (4.5908 + 0.0 + 0.9894 + (1.8838)) * 138 \\
 &= 102.92 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (4.5908 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138 \\
 &= 102.92 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 84.1209 * 10.0 * 0.49 * 136 \\
 &= 88. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo)/4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 35.2507) * (16.6 - 3.0) * 0.7 * 136 \\
 &= 144. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 248 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 84.1209 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 94. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (88 + 144) = 232 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (88 + 0 + 94 + 0) = 183 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (88 + 94 + 0) = 183 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 232 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \text{ or } W1 = 76 \text{ kN} \\
 \text{Path 2-2} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \text{ or } W2 = 102 \text{ kN} \\
 \text{Path 3-3} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \text{ or } W3 = 102 \text{ kN}
 \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

$$\text{Converged Max. Allow. Pressure in Operating case} = 16 \text{ bars}$$

Note: The MAWP of this junction was limited by the parent Shell/Head.

$$\text{Nozzle is O.K. for the External Pressure} = 1 \text{ bars}$$

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K2A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

$$\begin{aligned}
 \text{Actual Inside Diameter Used in Calculation} &= 2.000 \text{ in.} \\
 \text{Actual Thickness Used in Calculation} &= 0.654 \text{ in.}
 \end{aligned}$$

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

$$\begin{aligned}
 \text{Parallel to Vessel Wall (Diameter Limit)} &D1 = 113.6000 \text{ mm.} \\
 \text{Parallel to Vessel Wall, opening length} &d = 56.8000 \text{ mm.} \\
 \text{Normal to Vessel Wall (Thickness Limit), no pad} &T_{lnp} = 17.5000 \text{ mm.}
 \end{aligned}$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 249 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.776	NA
Area in Shell	A1	2.941	0.440	NA
Area in Nozzle Wall	A2	4.680	4.591	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.610	6.020	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F (1 - fr_1)) \text{ per UG-37(d)}$$

$$= 0.5 (56.8 \cdot 6.2213 \cdot 1 + 2 \cdot 13.6 \cdot 6.2213 \cdot 1 (1 - 0.99))$$

$$= 1.776 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 56.8 (1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 13.6 (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp}) (t_n - tr_n) fr_2$$

$$= (2 \cdot 17.5) (13.6 - 0.34) 0.9894$$

$$= 4.591 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr_2 + (W_i - can / 0.707)^2 \cdot fr_2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3430 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb_3, \max(tb_1, tb_2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 250 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= \max(3.343, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Weld Size Calculations, Description: K2A (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (1.7758 - 0.4401 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 21.31 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (4.5906 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.94 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.5906 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.5906 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 251 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SONW} + \text{SNW}) = (88 + 144) = 232 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 0 + 94 + 0) = 182 \text{ kN} \\ \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 94 + 0) = 182 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned} \text{Path 1-1} &= 231 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W1 = 76 \text{ kN} \\ \text{Path 2-2} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W2 = 102 \text{ kN} \\ \text{Path 3-3} &= 182 \text{ kN} , \text{ must exceed } W = 21 \text{ kN} \quad \text{or } W3 = 102 \text{ kN} \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 3.4436 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 163.4544 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 252 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K3A (3in)

From: 30

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	400.0000	mm.
Distance from Bottom/Left Tangent		2450.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-106	B
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		40.98	deg
Diameter		3.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	250.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 253 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Diameter of Pad along vessel surface	Dp	200.0000	mm.
Thickness of Pad	te	10.0000	mm.
Weld leg size between Pad and Shell	Wp	8.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	10.0000	mm.
Reinforcing Pad Width		55.5500	mm.

Flange Class	300
Flange Grade	GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K3A (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.975	in.
Actual Thickness Used in Calculation	0.263	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4399 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 254 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	218.1052	mm.
Parallel to Vessel Wall, opening length	d	109.0526	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		17.5000	mm.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p/S_v)$$

$$= \min(1, 137.9/137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.855, 1.0)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.978	3.425	NA
Area in Shell	A1	5.620	0.841	NA
Area in Nozzle Wall	A2	1.317	1.206	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	9.925	9.925	NA
TOTAL AREA AVAILABLE	Atot	17.663	12.773	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 48.41 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	94.6694	10.0000 mm.
Based on given Pad Diameter:	200.0000	0.5813 mm.
Based on Shell or Nozzle Thickness:	127.5125	6.6675 mm.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * t_n * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(109.0526 * 6.2213 * 1 + 2 * 3.6675 * 6.2213 * 1(1 - 0.86))$$

$$= 3.425 \text{ cm}^2$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 255 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot t_r) - 2 \cdot t_n(E1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\
 &= 109.053(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 3.668 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.855) \\
 &= 0.841 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot T_{lwp}) \cdot (t_n - t_{rn}) \cdot fr2 / \sin(\alpha3) \\
 &= (2 \cdot 17.5) \cdot (3.67 - 0.44) \cdot 0.855 / \sin(53.2) \\
 &= 1.206 \text{ cm}^2
 \end{aligned}$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (W_o^2 - A_r \text{ Lost}) \cdot Fr3 + ((W_i - c_{an} / 0.707)^2 - A_r \text{ Lost}) \cdot fr2 + W_p^2 \cdot fr4 \\
 &= (0.9375) \cdot 0.86 + (0.0) \cdot 0.86 + 0.0^2 \cdot 1.0 \\
 &= 0.802 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(D_p, D_L) - (\text{Nozzle OD})) \cdot (\min(t_p, T_{lwp}, t_e)) \cdot fr4 \\
 &= (218.1052 - 118.8595) \cdot 10.0 \cdot 1.0 \\
 &= 9.925 \text{ cm}^2
 \end{aligned}$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, min(Curve:B, Curve:A)

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.039, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.039, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.039, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 256 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 51.10 = 0.080$

Weld Size Calculations, Description: K3A (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.
Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v)$$

$$= \max(0, (3.4253 - 0.8409 + 2 * 3.6675 * 0.855 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 36.31 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A_2 + A_5 + A_4 - (W_i - Can / .707)^2 * f_{r2}) * S_v$$

$$= (1.2059 + 9.9246 + 0.8016 - 0.0 * 0.86) * 138$$

$$= 164.53 \text{ kN}$$

Weld Load [W2]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 257 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (1.2059 + 0.0 + 0.8491 + (0.439)) * 138$$

$$= 34.39 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*t_n*t*f_{r1}))*S$$

$$= (1.2059 + 0.0 + 0.8016 + 9.9246 + (0.439)) * 138$$

$$= 170.58 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 118.8595 * 10.0 * 0.49 * 118$$

$$= 108. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416/2.0) * 200.0 * 8.0 * 0.49 * 138$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 56.978) * (6.6675 - 3.0) * 0.7 * 118$$

$$= 54. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416/2) * 118.8595 * 10.0 * 0.74 * 138$$

$$= 191. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 118.8595 * (10.0 - 3.0) * 0.74 * 138$$

$$= 133. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (170 + 54) = 224 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (108 + 191 + 133 + 0) = 432 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (170 + 133 + 0) = 303 \text{ kN}$$

Summary of Failure Path Calculations:

$$\text{Path 1-1} = 223 \text{ kN} , \text{ must exceed } W = 36 \text{ kN} \text{ or } W1 = 164 \text{ kN}$$

$$\text{Path 2-2} = 431 \text{ kN} , \text{ must exceed } W = 36 \text{ kN} \text{ or } W2 = 34 \text{ kN}$$

$$\text{Path 3-3} = 303 \text{ kN} , \text{ must exceed } W = 36 \text{ kN} \text{ or } W3 = 170 \text{ kN}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 258 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K3A (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.975 in.
Actual Thickness Used in Calculation 0.263 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.4399 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 163.1300 mm.
Parallel to Vessel Wall, opening length d 81.5650 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.484	2.570	NA
Area in Shell	A1	4.189	0.627	NA
Area in Nozzle Wall	A2	1.055	0.966	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	7.423	7.423	NA
TOTAL AREA AVAILABLE	Atot	13.469	9.817	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 90.6597 10.0000 mm.

Based on given Pad Diameter: 200.0000 0.2371 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 259 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Based on Shell or Nozzle Thickness: 91.5392 6.6675 mm.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(81.565 * 6.2213 * 1 + 2 * 3.6675 * 6.2213 * 1(1 - 0.86))$$

$$= 2.570 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 81.565(1.0 * 7.0 - 1.0 * 6.221) - 2 * 3.668$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.855)$$

$$= 0.627 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 17.5) * (3.67 - 0.44) * 0.855$$

$$= 0.966 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= (Wo^2 - Ar \text{ Lost}) * Fr3 + ((Wi - can / 0.707)^2 - Ar \text{ Lost}) * fr2 + Wp^2 * fr4$$

$$= (0.9375) * 0.86 + (0.0) * 0.86 + 0.0^2 * 1.0$$

$$= 0.802 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (163.13 - 88.9) * 10.0 * 1.0$$

$$= 7.423 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.4399 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.4399, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 6.6675 mm. --> OK

Weld Size Calculations, Description: K3A (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 260 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o \text{ mm.}$
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v) \\
 &= \max(0, (2.5703 - 0.6269 + 2 * 3.6675 * 0.855 * \\
 &\quad (1.0 * 7.0 - 6.2213)) * 138) \\
 &= 27.47 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (0.9659 + 7.423 + 0.8016 - 0.0 * 0.86) * 138 \\
 &= 126.73 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.9659 + 0.0 + 0.8491 + (0.439)) * 138 \\
 &= 31.08 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.9659 + 0.0 + 0.8016 + 7.423 + (0.439)) * 138 \\
 &= 132.78 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 88.9 * 10.0 * 0.49 * 118 \\
 &= 81. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi / 2) * D_P * W_P * 0.49 * S_{EW} \\
 &= (3.1416 / 2.0) * 200.0 * 8.0 * 0.49 * 138 \\
 &= 170. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 42.6162) * (6.6675 - 3.0) * 0.7 * 118 \\
 &= 41. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_{gpn} * 0.74 * S_{eg} \\
 &= (3.1416 / 2) * 88.9 * 10.0 * 0.74 * 138 \\
 &= 142. \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 261 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 88.9 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 100. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170 + 41) = 210 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (81 + 142 + 100 + 0) = 323 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (170 + 100 + 0) = 270 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 210 kN , must exceed W = 27 kN or W1 = 126 kN
 Path 2-2 = 322 kN , must exceed W = 27 kN or W2 = 31 kN
 Path 3-3 = 269 kN , must exceed W = 27 kN or W3 = 132 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 44.1451 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 307.4748 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 262 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K3B (3in)

From: 30

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	200.0000	mm.
Distance from Bottom/Left Tangent		2450.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-106	B
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		-19.14	deg
Diameter		3.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 263 از 411	
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری		پروژه
	V00	0009	CN	ME	120	MF	GCS		BK

Diameter of Pad along vessel surface	Dp	200.0000	mm.
Thickness of Pad	te	10.0000	mm.
Weld leg size between Pad and Shell	Wp	8.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	10.0000	mm.
Reinforcing Pad Width		55.5500	mm.

Flange Class	300
Flange Grade	GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K3B (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.975	in.
Actual Thickness Used in Calculation	0.263	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3989 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 264 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 173.0097 mm.
 Parallel to Vessel Wall, opening length d 86.5048 mm.
 Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

= min(1, Sn/Sv)
 = min(1, 117.9/137.9)
 = 0.855

Weld Strength Reduction Factor [fr2]:

= min(1, Sn/Sv)
 = min(1, 117.9/137.9)
 = 0.855

Weld Strength Reduction Factor [fr4]:

= min(1, Sp/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr3]:

= min(fr2, fr4)
 = min(0.855, 1.0)
 = 0.855

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.573	2.724	NA
Area in Shell	A1	4.446	0.665	NA
Area in Nozzle Wall	A2	1.096	1.016	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	7.873	7.873	NA
TOTAL AREA AVAILABLE	Atot	14.216	10.356	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 70.54 Degr.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
 Based on given Pad Thickness: 91.3093 10.0000 mm.
 Based on given Pad Diameter: 200.0000 0.3060 mm.
 Based on Shell or Nozzle Thickness: 97.8975 6.6675 mm.

Area Required [A]:

= 0.5(d * tr*F + 2 * tn * tr*F(1-fr1)) per UG-37(d)
 = 0.5(86.5048*6.2213*1+2*3.6675*6.2213*1(1-0.86))

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 265 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= 2.724 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot t_r) - 2 \cdot t_n(E1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\
 &= 86.505(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 3.668 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.855) \\
 &= 0.665 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot T_{lwp}) \cdot (t_n - t_{rn}) \cdot f_{r2} / \sin(\alpha_3) \\
 &= (2 \cdot 17.5) \cdot (3.67 - 0.4) \cdot 0.855 / \sin(74.3) \\
 &= 1.016 \text{ cm}^2
 \end{aligned}$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (W_o^2 - A_r \text{ Lost}) \cdot F_{r3} + ((W_i - c_{an} / 0.707)^2 - A_r \text{ Lost}) \cdot f_{r2} + W_p^2 \cdot f_{r4} \\
 &= (0.9375) \cdot 0.86 + (0.0) \cdot 0.86 + 0.0^2 \cdot 1.0 \\
 &= 0.802 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(D_p, D_L) - (\text{Nozzle OD})) \cdot (\min(t_p, T_{lwp}, t_e)) \cdot f_{r4} \\
 &= (173.0097 - 94.2841) \cdot 10.0 \cdot 1.0 \\
 &= 7.873 \text{ cm}^2
 \end{aligned}$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, min(Curve:B, Curve:A)

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, $t_g = 6.668$, $t_r = 0.142$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 266 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 6.668, tr = 0.142, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.039$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 51.10 = 0.080$

Weld Size Calculations, Description: K3B (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.
Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) S_v)$$

$$= \max(0, (2.7239 - 0.6653 + 2 * 3.6675 * 0.855 * (1.0 * 7.0 - 6.2213)) 138)$$

$$= 29.06 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v$$

$$= (1.0161 + 7.8726 + 0.8016 - 0.0 * 0.86) * 138$$

$$= 133.62 \text{ kN}$$

Weld Load [W2]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 267 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (1.0161 + 0.0 + 0.8491 + (0.439)) * 138$$

$$= 31.77 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*t_n*t*f_{r1}))*S$$

$$= (1.0161 + 0.0 + 0.8016 + 7.8726 + (0.439)) * 138$$

$$= 139.67 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 94.2841 * 10.0 * 0.49 * 118$$

$$= 86. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416/2.0) * 200.0 * 8.0 * 0.49 * 138$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 45.1972) * (6.6675 - 3.0) * 0.7 * 118$$

$$= 43. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416/2) * 94.2841 * 10.0 * 0.74 * 138$$

$$= 151. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 94.2841 * (10.0 - 3.0) * 0.74 * 138$$

$$= 106. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (170 + 43) = 213 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (86 + 151 + 106 + 0) = 342 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (170 + 106 + 0) = 276 \text{ kN}$$

Summary of Failure Path Calculations:

$$\text{Path 1-1} = 212 \text{ kN} , \text{ must exceed } W = 29 \text{ kN} \text{ or } W1 = 133 \text{ kN}$$

$$\text{Path 2-2} = 342 \text{ kN} , \text{ must exceed } W = 29 \text{ kN} \text{ or } W2 = 31 \text{ kN}$$

$$\text{Path 3-3} = 275 \text{ kN} , \text{ must exceed } W = 29 \text{ kN} \text{ or } W3 = 139 \text{ kN}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 268 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K3B (3in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.975 in.
Actual Thickness Used in Calculation 0.263 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 40.78) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.1421 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3989 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 163.1300 mm.
Parallel to Vessel Wall, opening length d 81.5650 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.484	2.570	NA
Area in Shell	A1	4.189	0.627	NA
Area in Nozzle Wall	A2	1.055	0.978	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.802	0.802	NA
Area in Element	A5	7.423	7.423	NA
TOTAL AREA AVAILABLE	Atot	13.469	9.830	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 90.5371 10.0000 mm.

Based on given Pad Diameter: 200.0000 0.2206 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 269 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Based on Shell or Nozzle Thickness: 91.3554 6.6675 mm.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(81.565 * 6.2213 * 1 + 2 * 3.6675 * 6.2213 * 1(1 - 0.86))$$

$$= 2.570 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 81.565(1.0 * 7.0 - 1.0 * 6.221) - 2 * 3.668$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.855)$$

$$= 0.627 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 17.5) * (3.67 - 0.4) * 0.855$$

$$= 0.978 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= (Wo^2 - Ar \text{ Lost}) * Fr3 + ((Wi - can / 0.707)^2 - Ar \text{ Lost}) * fr2 + Wp^2 * fr4$$

$$= (0.9375) * 0.86 + (0.0) * 0.86 + 0.0^2 * 1.0$$

$$= 0.802 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (163.13 - 88.9) * 10.0 * 1.0$$

$$= 7.423 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3989 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.3989, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 6.6675 mm. --> OK

Weld Size Calculations, Description: K3B (3in)

Intermediate Calc. for nozzle/shell Welds Tmin 3.6675 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 270 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$2.5673 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o \text{ mm.}$
Pad Weld	$3.5000 = 0.5 * t_{minPad}$	$5.6560 = 0.7 * W_p \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v) \\
 &= \max(0, (2.5703 - 0.6269 + 2 * 3.6675 * 0.855 * \\
 &\quad (1.0 * 7.0 - 6.2213)) * 138) \\
 &= 27.47 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (0.9781 + 7.423 + 0.8016 - 0.0 * 0.86) * 138 \\
 &= 126.89 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (0.9781 + 0.0 + 0.8491 + (0.439)) * 138 \\
 &= 31.25 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S \\
 &= (0.9781 + 0.0 + 0.8016 + 7.423 + (0.439)) * 138 \\
 &= 132.95 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 88.9 * 10.0 * 0.49 * 118 \\
 &= 81. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi / 2) * D_P * W_P * 0.49 * S_{EW} \\
 &= (3.1416 / 2.0) * 200.0 * 8.0 * 0.49 * 138 \\
 &= 170. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 42.6162) * (6.6675 - 3.0) * 0.7 * 118 \\
 &= 41. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_{gpn} * 0.74 * S_{eg} \\
 &= (3.1416 / 2) * 88.9 * 10.0 * 0.74 * 138 \\
 &= 142. \text{ kN}
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 271 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 88.9 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 100. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170 + 41) = 210 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (81 + 142 + 100 + 0) = 323 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (170 + 100 + 0) = 270 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 210 kN , must exceed W = 27 kN or W1 = 126 kN
 Path 2-2 = 322 kN , must exceed W = 27 kN or W2 = 31 kN
 Path 3-3 = 269 kN , must exceed W = 27 kN or W3 = 132 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 8 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 17.7400 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 228.3358 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 272 از 411
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											

Input, Nozzle Desc: N11 (1in)

From: 30

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		1750.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		90.00	deg
Diameter		1.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	12.8000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	8.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 273 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: N11 (1in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	1.000 in.
Actual Thickness Used in Calculation	0.504 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per App. 1 of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)} \\
 &= 15.7 \left(\exp \left(\frac{4.1}{136.43 \cdot 1.0} \right) - 1 \right) \\
 &= 0.0473 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2571 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	65.0000 mm.
Parallel to Vessel Wall	Rn+tn+t	32.5000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 274 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	0.568	0.983	NA
Area in Shell	A1	1.738	0.260	NA
Area in Nozzle Wall	A2	3.377	3.305	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.623	0.623	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	5.738	4.188	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(31.4 \cdot 6.2213 \cdot 1 + 2 \cdot 9.8 \cdot 6.2213 \cdot 1(1 - 0.99))$$

$$= 0.983 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 \cdot t - F \cdot tr) - 2 \cdot tn(E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 33.6(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 9.8(1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 0.989)$$

$$= 0.260 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot tlnp)(tn - trn)fr2$$

$$= (2 \cdot 17.5)(9.8 - 0.26) \cdot 0.9894$$

$$= 3.305 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= (Wo^2 - \text{Area Lost}) \cdot fr2 + ((Wi - can/0.707)^2 - \text{Area Lost}) \cdot fr2$$

$$= (8.0^2 - 0.01) \cdot 0.9894 + (0.0^2 - 0.0) \cdot 0.9894$$

$$= 0.623 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.2571 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 275 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 6.4200 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:
 $= \min[tb3, \max(tb1, tb2)]$
 $= \min[6.42, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 $= \max(ta, tb)$
 $= \max(3.2571, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 12.8000 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = $78 \text{ }^\circ\text{C}$

Min Metal Temp. w/o impact per UCS-66, Curve A $-8 \text{ }^\circ\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^\circ\text{C}$
Min Metal Temp. w/o impact per UG-20(f) $-29 \text{ }^\circ\text{C}$

Gov. MDMT of the nozzle to shell joint welded assembly : $-104 \text{ }^\circ\text{C}$

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) $-18 \text{ }^\circ\text{C}$
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) $-104 \text{ }^\circ\text{C}$

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
Design Pressure/Ambient Rating = $4.10/19.60 = 0.209$

Weld Size Calculations, Description: N11 (1in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld $4.9000 = 0.7 * t_{min}$ $5.6560 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:
 $= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (0.9832 - 0.26 + 2 * 9.8 * 0.9894 * (1.0 * 7.0 - 6.2213))138)$
 $= 12.05 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 276 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (3.3045 + 0.0 + 0.6233 - 0.0 * 0.99) * 138$$

$$= 54.16 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (3.3045 + 0.0 + 0.6233 + (1.3574)) * 138$$

$$= 72.88 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (3.3045 + 0.0 + 0.6233 + 0.0 + (1.3574)) * 138$$

$$= 72.88 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 51.0 * 8.0 * 0.49 * 136$$

$$= 43. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 20.6) * (12.8 - 3.0) * 0.7 * 136$$

$$= 61. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 51.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 57. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (43 + 61) = 103 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (43 + 0 + 57 + 0) = 100 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (43 + 57 + 0) = 100 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 103 kN , must exceed W = 12 kN or W1 = 54 kN

Path 2-2 = 100 kN , must exceed W = 12 kN or W2 = 72 kN

Path 3-3 = 100 kN , must exceed W = 12 kN or W3 = 72 kN

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 277 از 411
	پروژه BK	بسته کاری GCS	صادر کننده MF	تسهیلات 120	رشته ME	نوع مدرک CN	سریال 0009	نسخه V00	

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 0.5421 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 160.5421 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 278 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: M2 (24in)

From: 30

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.

Note : User defined Limit(s) of Reinforcement specified below:

Physical Maximum for Diameter Limit	Dmax	1000.0000	mm.
Distance from Bottom/Left Tangent		3050.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-516	70
Material UNS Number		K02700	
Material Specification/Type		Plate	
Allowable Stress at Temperature	Sn	137.90	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		24.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	10.0000	mm.
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 279 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00


Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	800.0000	mm.
Thickness of Pad	te	10.0000	mm.
Weld leg size between Pad and Shell	Wp	8.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	10.0000	mm.
Reinforcing Pad Width		95.2000	mm.

This is a Manway or Access Opening.

Flange Class	150
Flange Grade	GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: M2 (24in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	24.000	in.
Actual Thickness Used in Calculation	0.394	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (4.1 \cdot 304.8) / (138 \cdot 1.0 + 0.4 \cdot 4.1)$$

$$= 0.9052 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 1.0868 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 280 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 1000.0000 mm.
 Parallel to Vessel Wall, opening length d 500.0000 mm.
 Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

Weld Strength Reduction Factor [fr1]:

= min(1, Sn/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr2]:

= min(1, Sn/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr4]:

= min(1, Sp/Sv)
 = min(1, 137.9/137.9)
 = 1.000

Weld Strength Reduction Factor [fr3]:

= min(fr2, fr4)
 = min(1.0, 1.0)
 = 1.000

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	10.698	18.527	NA
Area in Shell	A1	21.044	3.149	NA
Area in Nozzle Wall	A2	2.133	2.070	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		1.577	1.577	NA
Area in Element	A5	19.040	19.040	NA
TOTAL AREA AVAILABLE	Atot	43.795	25.836	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
 Based on given Pad Thickness: 726.9075 10.0000 mm.
 Based on given Pad Diameter: 800.0001 6.1611 mm.
 Based on Shell or Nozzle Thickness: 726.9075 10.0000 mm.

Area Required [A]:

= 0.5(d * tr*F + 2 * tn * tr*F(1-fr1)) per UG-37(d)
 = 0.5(595.6*6.2213*1+2*7.0*6.2213*1(1-1.0))
 = 18.527 cm²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 281 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادرکننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d(E1 \cdot t - F \cdot t_r) - 2 \cdot t_n(E1 \cdot t - F \cdot t_r) \cdot (1 - f_{r1}) \\
 &= 404.4(1.0 \cdot 7.0 - 1.0 \cdot 6.221) - 2 \cdot 7.0 \\
 &\quad (1.0 \cdot 7.0 - 1.0 \cdot 6.2213) \cdot (1 - 1.0) \\
 &= 3.149 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 \cdot T_{lwp}) \cdot (t_n - t_{rn}) \cdot f_{r2} \\
 &= (2 \cdot 17.5) \cdot (7.0 - 1.09) \cdot 1.0 \\
 &= 2.070 \text{ cm}^2
 \end{aligned}$$

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned}
 &= (W_o^2 - A_r \text{ Lost}) \cdot F_{r3} + ((W_i - c_{an}/0.707)^2 - A_r \text{ Lost}) \cdot f_{r2} + W_p^2 \cdot f_{r4} \\
 &= (0.9375) \cdot 1.0 + (0.0) \cdot 1.0 + 203.2^2 \cdot 1.0 \\
 &= 1.577 \text{ cm}^2
 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned}
 &= (\min(D_p, D_L) - (\text{Nozzle OD})) \cdot (\min(t_p, T_{lwp}, t_e)) \cdot f_{r4} \\
 &= (800.0 - 609.6) \cdot 10.0 \cdot 1.0 \\
 &= 19.040 \text{ cm}^2
 \end{aligned}$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, Curve: B

Govrn. thk, $t_g = 10.0$, $t_r = 0.905$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.129$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, $t_g = 10.0$, $t_r = 0.905$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.129$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, $t_g = 10.0$, $t_r = 0.905$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.129$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-29 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, $t_g = 10.0$, $t_r = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
 Thickness Ratio = $t_r \cdot (E^*) / (t_g - c) = 0.257$, Temp. Reduction = 78 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 282 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = 4.10/19.60 = 0.209

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	893.4000	mm.
Parallel to Vessel Wall, opening length	d	446.7000	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		17.5000	mm.

Reinforcement Areas for Large Nozzle (Per App 1-7(a)): (cm²)

AREA AVAILABLE, A1 to A6		No Pad	With Pad
Area Required [External Pressure]	AR	12.352	12.352
Area Available in Shell	A1	2.319	2.319
Area Available in Nozzle Wall	A2	2.070	2.070
Area Available in Inward Nozzle	A3	0.000	0.000
Area Available in Welds	A4	1.000	1.577
Area Available in Pad	A5	0.000	19.040
Area Available in Hub	A6	0.000	0.000
TOTAL AREA AVAILABLE	Atot	5.389	25.006

The area available without a pad is Insufficient.
The area available with the given pad is Sufficient.

Note: The Nozzle does not fall within the scope of the diameter requirements of App. 1-7(b). Therefore, the Membrane and Bending stress checks are not required.

Weld Size Calculations, Description: M2 (24in)

Intermediate Calc. for nozzle/shell Welds	Tmin	7.0000	mm.
Intermediate Calc. for pad/shell Welds	TminPad	7.0000	mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 283 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.9000 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o \text{ mm.}$
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$5.6560 = 0.7 * W_p \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) * S_v) \\
 &= \max(0, (18.527 - 3.1491 + 2 * 7.0 * 1.0 * (1.0 * 7.0 - 6.2213)) * 138) \\
 &= 213.55 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v \\
 &= (2.0696 + 19.04 + 1.5775 - 0.0 * 1.0) * 138 \\
 &= 312.83 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v \\
 &= (2.0696 + 0.0 + 1. + (0.98)) * 138 \\
 &= 55.84 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S \\
 &= (2.0696 + 0.0 + 1.5775 + 19.04 + (0.98)) * 138 \\
 &= 326.34 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.1416 / 2.0) * 609.6 * 10.0 * 0.49 * 138 \\
 &= 647. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi / 2) * D_P * W_P * 0.49 * S_{EW} \\
 &= (3.1416 / 2.0) * 800.0 * 8.0 * 0.49 * 138 \\
 &= 679. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n \\
 &= (3.1416 * 301.3) * (10.0 - 3.0) * 0.7 * 138 \\
 &= 640. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi / 2) * D_{lo} * W_{gpn} * 0.74 * S_{eg} \\
 &= (3.1416 / 2) * 609.6 * 10.0 * 0.74 * 138 \\
 &= 977. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi / 2) * D_{lo} * (W_{gnvi} - C_{as}) * 0.74 * S_{ng}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 284 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= (3.1416/2.0) * 609.6 * (10.0 - 3.0) * 0.74 * 138$$

$$= 684. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (679 + 640) = 1319 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (647 + 977 + 684 + 0) = 2308 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (679 + 684 + 0) = 1363 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 1318 kN , must exceed W = 213 kN or W1 = 312 kN
 Path 2-2 = 2307 kN , must exceed W = 213 kN or W2 = 55 kN
 Path 3-3 = 1363 kN , must exceed W = 213 kN or W3 = 326 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 11 bars

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 83.1858 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 243.1858 mm.

Percent Elongation Calculations:

% Elongation per Table UG-79-1 (50*tnom/Rf*(1-Rf/Ro)) 1.668 %

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 285 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Input, Nozzle Desc: K8 (2in)

From: 30

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	3699.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		1747.40	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 286 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: K8 (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3862 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000	mm.
Parallel to Vessel Wall, opening length	d	56.8000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 287 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.776	NA
Area in Shell	A1	2.941	0.440	NA
Area in Nozzle Wall	A2	4.680	4.576	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.610	6.005	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(56.8 * 6.2213 * 1 + 2 * 13.6 * 6.2213 * 1(1-0.99))$$

$$= 1.776 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 56.8(1.0 * 7.0 - 1.0 * 6.221) - 2 * 13.6$$

$$(1.0 * 7.0 - 1.0 * 6.2213) * (1 - 0.989)$$

$$= 0.440 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 17.5) (13.6 - 0.39) 0.9894$$

$$= 4.576 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3862 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 288 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 7.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:
 $= \min[tb3, \max(tb1, tb2)]$
 $= \min[7.8, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 $= \max(ta, tb)$
 $= \max(3.3862, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = $78 \text{ }^\circ\text{C}$

Min Metal Temp. w/o impact per UCS-66, Curve A $-8 \text{ }^\circ\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^\circ\text{C}$
Min Metal Temp. w/o impact per UG-20(f) $-29 \text{ }^\circ\text{C}$

Gov. MDMT of the nozzle to shell joint welded assembly : $-104 \text{ }^\circ\text{C}$

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) $-18 \text{ }^\circ\text{C}$
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) $-104 \text{ }^\circ\text{C}$

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
Design Pressure/Ambient Rating = $4.10/51.10 = 0.080$

Weld Size Calculations, Description: K8 (2in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld $4.9000 = 0.7 * t_{min}$ $7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:
 $= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (1.7758 - 0.4401 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 6.2213))138)$
 $= 21.31 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 289 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (4.5757 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.74 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.5757 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.71 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.5757 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.71 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (pi/2) * D_{lo} * (W_{gvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (88 + 144) = 232 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (88 + 0 + 94 + 0) = 182 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (88 + 94 + 0) = 182 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 231 kN , must exceed W = 21 kN or W1 = 76 kN

Path 2-2 = 182 kN , must exceed W = 21 kN or W2 = 102 kN

Path 3-3 = 182 kN , must exceed W = 21 kN or W3 = 102 kN

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 290 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 1.4718 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 211.4718 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 291 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input, Nozzle Desc: N04 (6in)

From: 40

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		4550.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-106	B
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		90.00	deg
Diameter		6.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	8.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	300.0000	mm.
Thickness of Pad	te	10.0000	mm.


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 292 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Weld leg size between Pad and Shell Wp 6.0000 mm.
Groove weld depth between Pad and Nozzle Wgpn 10.0000 mm.
Reinforcing Pad Width 65.8625 mm.

Flange Class 150
Flange Grade GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: N04 (6in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 5.869 in.
Actual Thickness Used in Calculation 0.378 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 77.54) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.2702 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.5131 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 310.1452 mm.
Parallel to Vessel Wall, opening length d 155.0726 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 293 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p/S_v)$$

$$= \min(1, 137.9/137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.855, 1.0)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	2.820	4.234	NA
Area in Shell	A1	7.970	2.460	NA
Area in Nozzle Wall	A2	1.895	1.822	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.896	0.896	NA
Area in Element	A5	13.173	13.173	NA
TOTAL AREA AVAILABLE	Atot	23.934	18.351	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

The area available with the given pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * t_n * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(155.0726 * 5.3937 * 1 + 2 * 6.6012 * 5.3937 * 1(1-0.86))$$

$$= 4.234 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * t_n(E1 * t - F * tr) * (1 - fr1)$$

$$= 155.073(1.0 * 7.0 - 1.0 * 5.394) - 2 * 6.601$$

$$(1.0 * 7.0 - 1.0 * 5.3937) * (1 - 0.855)$$

$$= 2.460 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 294 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= (2 * T_{lwp}) * (t_n - t_{rn}) * fr_2$$

$$= (2 * 17.5) * (6.6 - 0.51) * 0.855$$

$$= 1.822 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= (W_o^2 - A_r \text{ Lost}) * Fr_3 + ((W_i - c_{an}/0.707)^2 - A_r \text{ Lost}) * fr_2 + Trapfr_4$$

$$= (0.6375) * 0.86 + (0.0) * 0.86 + 35.1399^2 * 1.0$$

$$= 0.896 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(D_p, D_L) - (\text{Nozzle OD})) * (\min(t_p, T_{lwp}, t_e)) * fr_4$$

$$= (300.0 - 168.275) * 10.0 * 1.0$$

$$= 13.173 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures $t_a = 3.5131 \text{ mm.}$

Wall Thickness per UG16(b), $tr_{16b} = 4.5000 \text{ mm.}$

Wall Thickness, shell/head, internal pressure $tr_{b1} = 4.7961 \text{ mm.}$

Wall Thickness $tb_1 = \max(tr_{b1}, tr_{16b}) = 4.7961 \text{ mm.}$

Wall Thickness, shell/head, external pressure $tr_{b2} = 3.4524 \text{ mm.}$

Wall Thickness $tb_2 = \max(tr_{b2}, tr_{16b}) = 4.5000 \text{ mm.}$

Wall Thickness per table UG-45 $tb_3 = 9.2200 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb_3, \max(tb_1, tb_2)]$$

$$= \min[9.22, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(t_a, t_b)$$

$$= \max(3.5131, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 9.6012 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, Curve: B

Govern. thk, $t_g = 9.601$, $t_r = 0.27$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $t_r * (E^*) / (t_g - c) = 0.041$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B $-29 \text{ }^\circ\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^\circ\text{C}$

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govern. thk, $t_g = 9.601$, $t_r = 0.27$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $t_r * (E^*) / (t_g - c) = 0.041$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B $-29 \text{ }^\circ\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^\circ\text{C}$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 295 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, tg = 9.601, tr = 0.27, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.041$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 9.601, tr = 0.27, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.041$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
Flange MDMT with Temp reduction per UCS-66 (b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 19.60 = 0.209$

Weld Size Calculations, Description: N04 (6in)

Intermediate Calc. for nozzle/shell Welds Tmin 6.6012 mm.
Intermediate Calc. for pad/shell Welds TminPad 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.6208 = 0.7 * t_{min}$	$5.6560 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$4.2420 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

= $\max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v)$
= $\max(0, (4.2337 - 2.4602 + 2 * 6.6012 * 0.855 * (1.0 * 7.0 - 5.3937)) 138)$
= 26.96 kN

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 296 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (1.8218 + 13.1725 + 0.8965 - 0.0 * 0.86) * 138$$

$$= 219.12 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (1.8218 + 0.0 + 0.5472 + (0.7902)) * 138$$

$$= 43.56 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (1.8218 + 0.0 + 0.8965 + 13.1725 + (0.7902)) * 138$$

$$= 230.01 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 168.275 * 8.0 * 0.49 * 118$$

$$= 122. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416/2.0) * 300.0 * 6.0 * 0.49 * 138$$

$$= 191. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 80.8369) * (9.6012 - 3.0) * 0.7 * 118$$

$$= 138. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416/2) * 168.275 * 10.0 * 0.74 * 138$$

$$= 270. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 168.275 * (10.0 - 3.0) * 0.74 * 138$$

$$= 189. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (191 + 138) = 329 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (122 + 270 + 189 + 0) = 581 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (191 + 189 + 0) = 380 \text{ kN}$$

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 297 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Summary of Failure Path Calculations:

Path 1-1 = 329 kN , must exceed W = 26 kN or W1 = 219 kN
 Path 2-2 = 580 kN , must exceed W = 26 kN or W2 = 43 kN
 Path 3-3 = 379 kN , must exceed W = 26 kN or W3 = 230 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 5.9286 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 165.9286 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 298 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K1B (2in)

From: 40

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		5400.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		90.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 299 از 411	
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری		پروژه
	V00	0009	CN	ME	120	MF	GCS		BK

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: K1B (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000 mm.
Parallel to Vessel Wall, opening length	d	56.8000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 300 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.540	NA
Area in Shell	A1	2.941	0.908	NA
Area in Nozzle Wall	A2	4.680	4.591	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.610	6.488	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(56.8 * 5.3937 * 1 + 2 * 13.6 * 5.3937 * 1(1-0.99))$$

$$= 1.540 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 56.8(1.0 * 7.0 - 1.0 * 5.394) - 2 * 13.6$$

$$(1.0 * 7.0 - 1.0 * 5.3937) * (1 - 0.989)$$

$$= 0.908 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 17.5) (13.6 - 0.34) 0.9894$$

$$= 4.591 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3430 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 301 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 7.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:
 $= \min[tb3, \max(tb1, tb2)]$
 $= \min[7.8, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 $= \max(ta, tb)$
 $= \max(3.343, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = $78 \text{ }^\circ\text{C}$

Min Metal Temp. w/o impact per UCS-66, Curve A $-8 \text{ }^\circ\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^\circ\text{C}$
Min Metal Temp. w/o impact per UG-20(f) $-29 \text{ }^\circ\text{C}$

Gov. MDMT of the nozzle to shell joint welded assembly : $-104 \text{ }^\circ\text{C}$

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) $-18 \text{ }^\circ\text{C}$
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) $-104 \text{ }^\circ\text{C}$

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
Design Pressure/Ambient Rating = $4.10/51.10 = 0.080$

Weld Size Calculations, Description: K1B (2in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld $4.9000 = 0.7 * t_{min}$ $7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:
 $= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (1.5396 - 0.9077 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 5.3937)) 138)$
 $= 14.67 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 302 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (4.5906 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.94 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.5906 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.5906 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.92 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (88 + 144) = 232 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (88 + 0 + 94 + 0) = 182 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (88 + 94 + 0) = 182 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 231 kN , must exceed W = 14 kN or W1 = 76 kN

Path 2-2 = 182 kN , must exceed W = 14 kN or W2 = 102 kN

Path 3-3 = 182 kN , must exceed W = 14 kN or W3 = 102 kN

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 303 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 1.4718 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 161.4718 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 304 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: N07A (2in)

From: 40

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		4550.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		270.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	15.8500	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 305 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: N07A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.624 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3393 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000 mm.
Parallel to Vessel Wall, opening length	d	56.8000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 306 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادرکننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.025	1.539	NA
Area in Shell	A1	2.942	0.908	NA
Area in Nozzle Wall	A2	4.420	4.332	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	8.351	6.230	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(56.8 \cdot 5.3937 \cdot 1 + 2 \cdot 12.85 \cdot 5.3937 \cdot 1(1 - 0.99))$$

$$= 1.539 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 \cdot t - F \cdot tr) - 2 \cdot tn(E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 56.8(1.0 \cdot 7.0 - 1.0 \cdot 5.394) - 2 \cdot 12.85$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 5.3937) \cdot (1 - 0.989)$$

$$= 0.908 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot tlnp)(tn - trn)fr2$$

$$= (2 \cdot 17.5)(12.85 - 0.34) \cdot 0.9894$$

$$= 4.332 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 \cdot fr2 + (Wi - can/0.707)^2 \cdot fr2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3393 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 307 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 7.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:

$= \min[tb3, \max(tb1, tb2)]$
 $= \min[7.8, \max(4.7961, 4.5)]$
 $= 4.7961 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$= \max(ta, tb)$
 $= \max(3.3393, 4.7961)$
 $= 4.7961 \text{ mm.}$

Available Nozzle Neck Thickness = 15.8500 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $tg = 10.0$, $tr = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio $= tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A $-8 \text{ }^{\circ}\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^{\circ}\text{C}$
Min Metal Temp. w/o impact per UG-20(f) $-29 \text{ }^{\circ}\text{C}$

Gov. MDMT of the nozzle to shell joint welded assembly : $-104 \text{ }^{\circ}\text{C}$

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) $-18 \text{ }^{\circ}\text{C}$
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) $-104 \text{ }^{\circ}\text{C}$

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10/19.60 = 0.209$

Weld Size Calculations, Description: N07A (2in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld $4.9000 = 0.7 * t_{min}$ $7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (1.5392 - 0.908 + 2 * 12.85 * 0.9894 * (1.0 * 7.0 - 5.3937))138)$
 $= 14.34 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 308 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (4.3322 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 73.38 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.3322 + 0.0 + 0.9894 + (1.7799)) * 138$$

$$= 97.92 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.3322 + 0.0 + 0.9894 + 0.0 + (1.7799)) * 138$$

$$= 97.92 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 82.5 * 10.0 * 0.49 * 136$$

$$= 87. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 34.825) * (15.85 - 3.0) * 0.7 * 136$$

$$= 134. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 82.5 * (10.0 - 3.0) * 0.74 * 138$$

$$= 93. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (87 + 134) = 221 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (87 + 0 + 93 + 0) = 179 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (87 + 93 + 0) = 179 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 220 kN , must exceed W = 14 kN or W1 = 73 kN

Path 2-2 = 179 kN , must exceed W = 14 kN or W2 = 97 kN

Path 3-3 = 179 kN , must exceed W = 14 kN or W3 = 97 kN

	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 309 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	
	BK	GCS	MF	120	ME	CN	0009	V00	

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 1.4197 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 161.4197 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 310 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: N09A (1.5in)

From: 40

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	200.0000	mm.
Distance from Bottom/Left Tangent		3750.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		289.14	deg
Diameter		1.5000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	14.4500	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 311 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: N09A (1.5in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	1.500 in.
Actual Thickness Used in Calculation	0.569 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per App. 1 of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)} \\
 &= 22.05 \left(\exp \left(\frac{4.1}{136.43 \cdot 1.0} \right) - 1 \right) \\
 &= 0.0664 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3000 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	93.4727 mm.
Parallel to Vessel Wall, opening length	d	46.7364 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 312 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar		0.422		1.267		NA
Area in Shell	A1		2.837		0.747		NA
Area in Nozzle Wall	A2		4.134		4.050		NA
Area in Inward Nozzle	A3		0.000		0.000		NA
Area in Welds A41+A42+A43			0.989		0.989		NA
Area in Element	A5		0.000		0.000		NA
TOTAL AREA AVAILABLE	Atot		7.961		5.786		NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 70.66 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(46.7364 * 5.3937 * 1 + 2 * 11.45 * 5.3937 * 1(1 - 0.99))$$

$$= 1.267 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 46.736(1.0 * 7.0 - 1.0 * 5.394) - 2 * 11.45$$

$$(1.0 * 7.0 - 1.0 * 5.3937) * (1 - 0.989)$$

$$= 0.747 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 * 17.5) (11.45 - 0.3) 0.9894 / \sin(72.4)$$

$$= 4.050 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 313 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/19.60 = 0.209

Weld Size Calculations, Description: N09A (1.5in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

Required Thickness Actual Thickness
 Nozzle Weld 4.9000 = 0.7 * tmin. 7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (1.267 - 0.7468 + 2 * 11.45 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 5.3937)) 138) \\
 &= 12.19 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (4.0495 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 69.48 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (4.0495 + 0.0 + 0.9894 + (1.586)) * 138 \\
 &= 91.35 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (4.0495 + 0.0 + 0.9894 + 0.0 + (1.586)) * 138 \\
 &= 91.35 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 71.0054 * 10.0 * 0.49 * 136 \\
 &= 75. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 29.4354) * (14.45 - 3.0) * 0.7 * 136 \\
 &= 101. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 314 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 71.0054 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 80. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (75 + 101) = 176 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (75 + 0 + 80 + 0) = 154 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (75 + 80 + 0) = 154 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 175 \text{ kN}, \text{ must exceed } W = 12 \text{ kN} \text{ or } W1 = 69 \text{ kN} \\
 \text{Path 2-2} &= 154 \text{ kN}, \text{ must exceed } W = 12 \text{ kN} \text{ or } W2 = 91 \text{ kN} \\
 \text{Path 3-3} &= 154 \text{ kN}, \text{ must exceed } W = 12 \text{ kN} \text{ or } W3 = 91 \text{ kN}
 \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

$$\text{Converged Max. Allow. Pressure in Operating case} = 16 \text{ bars}$$

Note: The MAWP of this junction was limited by the parent Shell/Head.

$$\text{Nozzle is O.K. for the External Pressure} = 1 \text{ bars}$$

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: N09A (1.5in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

$$\begin{aligned}
 \text{Actual Inside Diameter Used in Calculation} &= 1.500 \text{ in.} \\
 \text{Actual Thickness Used in Calculation} &= 0.569 \text{ in.}
 \end{aligned}$$

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per App. 1 of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)} \\
 &= 22.05 \left(\exp \left(\frac{4.1}{136.43 \cdot 1.0} \right) - 1 \right) \\
 &= 0.0664 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3000 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

$$\begin{aligned}
 \text{Parallel to Vessel Wall (Diameter Limit)} &D1 = 88.2000 \text{ mm.} \\
 \text{Parallel to Vessel Wall, opening length} &d = 44.1000 \text{ mm.} \\
 \text{Normal to Vessel Wall (Thickness Limit), no pad} &T_{lnp} = 17.5000 \text{ mm.}
 \end{aligned}$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 315 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

AREA AVAILABLE, A1 to A5	Design	External	Mapnc
Area Required	Ar	0.796	1.196
Area in Shell	A1	2.282	0.704
Area in Nozzle Wall	A2	3.942	3.861
Area in Inward Nozzle	A3	0.000	0.000
Area in Welds A41+A42+A43		0.989	0.989
Area in Element	A5	0.000	0.000
TOTAL AREA AVAILABLE	Atot	7.214	5.555

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F (1 - fr_1)) \text{ per UG-37(d)}$$

$$= 0.5 (44.1 \cdot 5.3937 \cdot 1 + 2 \cdot 11.45 \cdot 5.3937 \cdot 1 (1 - 0.99))$$

$$= 1.196 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 44.1 (1.0 \cdot 7.0 - 1.0 \cdot 5.394) - 2 \cdot 11.45$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 5.3937) \cdot (1 - 0.989)$$

$$= 0.704 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp}) (t_n - tr_n) fr_2$$

$$= (2 \cdot 17.5) (11.45 - 0.3) 0.9894$$

$$= 3.861 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr_2 + (W_i - can / 0.707)^2 \cdot fr_2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3000 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.5200 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.52, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 316 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= \max(3.3, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 14.4500 mm. --> OK

Weld Size Calculations, Description: N09A (1.5in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.9000 = 0.7 * t_{min.}$	$7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (1.1959 - 0.7045 + 2 * 11.45 * 0.9894 * (1.0 * 7.0 - 5.3937)) 138)$$

$$= 11.79 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (3.861 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 66.88 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (3.861 + 0.0 + 0.9894 + (1.586)) * 138$$

$$= 88.75 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (3.861 + 0.0 + 0.9894 + 0.0 + (1.586)) * 138$$

$$= 88.75 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 67.0 * 10.0 * 0.49 * 136$$

$$= 70. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo})/4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 27.775) * (14.45 - 3.0) * 0.7 * 136$$

$$= 95. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 67.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 75. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 317 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SONW} + \text{SNW}) = (70 + 95) = 166 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (70 + 0 + 75 + 0) = 146 \text{ kN} \\ \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\ &= (70 + 75 + 0) = 146 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned} \text{Path 1-1} &= 165 \text{ kN} , \text{ must exceed } W = 11 \text{ kN} \quad \text{or } W1 = 66 \text{ kN} \\ \text{Path 2-2} &= 145 \text{ kN} , \text{ must exceed } W = 11 \text{ kN} \quad \text{or } W2 = 88 \text{ kN} \\ \text{Path 3-3} &= 145 \text{ kN} , \text{ must exceed } W = 11 \text{ kN} \quad \text{or } W3 = 88 \text{ kN} \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 12.9850 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 173.5808 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 318 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Input, Nozzle Desc: N09B (1.5in)

From: 40

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	200.0000	mm.
Distance from Bottom/Left Tangent		3750.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		250.86	deg
Diameter		1.5000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	14.4500	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		150	
Flange Grade		GR 1.1	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 319 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: N09B (1.5in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	1.500 in.
Actual Thickness Used in Calculation	0.569 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per App. 1 of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)} \\
 &= 22.05 \left(\exp \left(\frac{4.1}{136.43 \cdot 1.0} \right) - 1 \right) \\
 &= 0.0664 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3000 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	93.4727 mm.
Parallel to Vessel Wall, opening length	d	46.7364 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc
--------------------------	--------	----------	-------

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 320 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar		0.422		1.267		NA
Area in Shell	A1		2.837		0.747		NA
Area in Nozzle Wall	A2		4.134		4.050		NA
Area in Inward Nozzle	A3		0.000		0.000		NA
Area in Welds A41+A42+A43			0.989		0.989		NA
Area in Element	A5		0.000		0.000		NA
TOTAL AREA AVAILABLE	Atot		7.961		5.786		NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 70.66 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(46.7364 * 5.3937 * 1 + 2 * 11.45 * 5.3937 * 1(1 - 0.99))$$

$$= 1.267 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 46.736(1.0 * 7.0 - 1.0 * 5.394) - 2 * 11.45$$

$$(1.0 * 7.0 - 1.0 * 5.3937) * (1 - 0.989)$$

$$= 0.747 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 * 17.5) (11.45 - 0.3) 0.9894 / \sin(72.4)$$

$$= 4.050 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 321 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/19.60 = 0.209

Weld Size Calculations, Description: N09B (1.5in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

Required Thickness Actual Thickness
 Nozzle Weld 4.9000 = 0.7 * tmin. 7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (1.267 - 0.7468 + 2 * 11.45 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 5.3937)) 138) \\
 &= 12.19 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (4.0495 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 69.48 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (4.0495 + 0.0 + 0.9894 + (1.586)) * 138 \\
 &= 91.35 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (4.0495 + 0.0 + 0.9894 + 0.0 + (1.586)) * 138 \\
 &= 91.35 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 71.0054 * 10.0 * 0.49 * 136 \\
 &= 75. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 29.4354) * (14.45 - 3.0) * 0.7 * 136 \\
 &= 101. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 322 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 71.0054 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 80. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (75 + 101) = 176 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (75 + 0 + 80 + 0) = 154 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (75 + 80 + 0) = 154 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 175 \text{ kN}, \text{ must exceed } W = 12 \text{ kN} \text{ or } W1 = 69 \text{ kN} \\
 \text{Path 2-2} &= 154 \text{ kN}, \text{ must exceed } W = 12 \text{ kN} \text{ or } W2 = 91 \text{ kN} \\
 \text{Path 3-3} &= 154 \text{ kN}, \text{ must exceed } W = 12 \text{ kN} \text{ or } W3 = 91 \text{ kN}
 \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

$$\text{Converged Max. Allow. Pressure in Operating case} = 16 \text{ bars}$$

Note: The MAWP of this junction was limited by the parent Shell/Head.

$$\text{Nozzle is O.K. for the External Pressure} = 1 \text{ bars}$$

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: N09B (1.5in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

$$\begin{aligned}
 \text{Actual Inside Diameter Used in Calculation} &= 1.500 \text{ in.} \\
 \text{Actual Thickness Used in Calculation} &= 0.569 \text{ in.}
 \end{aligned}$$

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per App. 1 of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)} \\
 &= 22.05 \left(\exp \left(\frac{4.1}{136.43 \cdot 1.0} \right) - 1 \right) \\
 &= 0.0664 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3000 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	88.2000	mm.
Parallel to Vessel Wall, opening length	d	44.1000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 - 073 - 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 323 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	0.796	1.196	NA
Area in Shell	A1	2.282	0.704	NA
Area in Nozzle Wall	A2	3.942	3.861	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	7.214	5.555	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F (1 - fr_1)) \text{ per UG-37(d)}$$

$$= 0.5 (44.1 \cdot 5.3937 \cdot 1 + 2 \cdot 11.45 \cdot 5.3937 \cdot 1 (1 - 0.99))$$

$$= 1.196 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 44.1 (1.0 \cdot 7.0 - 1.0 \cdot 5.394) - 2 \cdot 11.45$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 5.3937) \cdot (1 - 0.989)$$

$$= 0.704 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp}) (t_n - tr_n) fr_2$$

$$= (2 \cdot 17.5) (11.45 - 0.3) 0.9894$$

$$= 3.861 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr_2 + (W_i - can / 0.707)^2 \cdot fr_2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3000 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.5200 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.52, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 324 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= \max(3.3, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 14.4500 mm. --> OK

Weld Size Calculations, Description: N09B (1.5in)

Intermediate Calc. for nozzle/shell Welds $t_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$4.9000 = 0.7 * t_{min.}$	$7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A1 + 2 * t_n * f_{r1} * (E1 * t - t_r)) S_v)$$

$$= \max(0, (1.1959 - 0.7045 + 2 * 11.45 * 0.9894 * (1.0 * 7.0 - 5.3937)) * 138)$$

$$= 11.79 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2 + A5 + A4 - (W_i - Can / .707)^2 * f_{r2}) * S_v$$

$$= (3.861 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 66.88 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (3.861 + 0.0 + 0.9894 + (1.586)) * 138$$

$$= 88.75 \text{ kN}$$

Weld Load [W3]:

$$= (A2 + A3 + A4 + A5 + (2 * t_n * t * f_{r1})) * S$$

$$= (3.861 + 0.0 + 0.9894 + 0.0 + (1.586)) * 138$$

$$= 88.75 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 67.0 * 10.0 * 0.49 * 136$$

$$= 70. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 27.775) * (14.45 - 3.0) * 0.7 * 136$$

$$= 95. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi} - Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 67.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 75. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 325 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SONW} + \text{SNW}) = (70 + 95) = 166 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (70 + 0 + 75 + 0) = 146 \text{ kN} \\ \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\ &= (70 + 75 + 0) = 146 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned} \text{Path 1-1} &= 165 \text{ kN} , \text{ must exceed } W = 11 \text{ kN} \quad \text{or } W1 = 66 \text{ kN} \\ \text{Path 2-2} &= 145 \text{ kN} , \text{ must exceed } W = 11 \text{ kN} \quad \text{or } W2 = 88 \text{ kN} \\ \text{Path 3-3} &= 145 \text{ kN} , \text{ must exceed } W = 11 \text{ kN} \quad \text{or } W3 = 88 \text{ kN} \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 12.9850 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 173.5808 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 326 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K4A (2in)

From: 40

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	400.0000	mm.
Distance from Bottom/Left Tangent		4650.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		40.98	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 327 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K4A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3862 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	151.6108	mm.
Parallel to Vessel Wall, opening length	d	75.8054	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 328 از 411	
	پروژه	بسته کاری	صادرکننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar	0.683	2.052	NA
Area in Shell	A1	4.608	1.213	NA
Area in Nozzle Wall	A2	5.959	5.826	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	11.556	8.028	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 48.53 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5 (75.8054 \cdot 5.3937 \cdot 1 + 2 \cdot 13.6 \cdot 5.3937 \cdot 1 (1 - 0.99))$$

$$= 2.052 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 \cdot t - F \cdot tr) - 2 \cdot tn (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 75.805 (1.0 \cdot 7.0 - 1.0 \cdot 5.394) - 2 \cdot 13.6$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 5.3937) \cdot (1 - 0.989)$$

$$= 1.213 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 \cdot 17.5) (13.6 - 0.39) 0.9894 / \sin(51.8)$$

$$= 5.826 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 \cdot fr2 + (Wi - can / 0.707)^2 \cdot fr2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 329 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/51.10 = 0.080

Weld Size Calculations, Description: K4A (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

Required Thickness Actual Thickness
 Nozzle Weld 4.9000 = 0.7 * tmin. 7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (2.0522 - 1.213 + 2 * 13.6 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 5.3937)) 138) \\
 &= 17.53 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (5.8261 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 93.98 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (5.8261 + 0.0 + 0.9894 + (1.8838)) * 138 \\
 &= 119.95 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (5.8261 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138 \\
 &= 119.95 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 112.1066 * 10.0 * 0.49 * 136 \\
 &= 118. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 46.978) * (16.6 - 3.0) * 0.7 * 136 \\
 &= 192. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 330 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 112.1066 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 126. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (118 + 192) = 309 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (118 + 0 + 126 + 0) = 243 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (118 + 126 + 0) = 243 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 309 \text{ kN}, \text{ must exceed } W = 17 \text{ kN} \text{ or } W1 = 93 \text{ kN} \\
 \text{Path 2-2} &= 243 \text{ kN}, \text{ must exceed } W = 17 \text{ kN} \text{ or } W2 = 119 \text{ kN} \\
 \text{Path 3-3} &= 243 \text{ kN}, \text{ must exceed } W = 17 \text{ kN} \text{ or } W3 = 119 \text{ kN}
 \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K4A (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3862 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	113.6000	mm.
Parallel to Vessel Wall, opening length	d	56.8000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 331 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

AREA AVAILABLE, A1 to A5	Design	External	Mapnc
Area Required Ar	1.025	1.540	NA
Area in Shell A1	2.941	0.908	NA
Area in Nozzle Wall A2	4.680	4.576	NA
Area in Inward Nozzle A3	0.000	0.000	NA
Area in Welds A41+A42+A43	0.989	0.989	NA
Area in Element A5	0.000	0.000	NA
TOTAL AREA AVAILABLE Atot	8.610	6.473	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F (1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5 (56.8 \cdot 5.3937 \cdot 1 + 2 \cdot 13.6 \cdot 5.3937 \cdot 1 (1 - 0.99))$$

$$= 1.540 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 \cdot t - F \cdot tr) - 2 \cdot t_n (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 56.8 (1.0 \cdot 7.0 - 1.0 \cdot 5.394) - 2 \cdot 13.6 (1.0 \cdot 7.0 - 1.0 \cdot 5.3937) \cdot (1 - 0.989)$$

$$= 0.908 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp}) (t_n - t_{rn}) fr2$$

$$= (2 \cdot 17.5) (13.6 - 0.39) 0.9894$$

$$= 4.576 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr2 + (W_i - can / 0.707)^2 \cdot fr2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3862 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 332 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= \max(3.3862, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Weld Size Calculations, Description: K4A (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (1.5396 - 0.9077 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 5.3937)) 138)$$

$$= 14.67 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (4.5757 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.74 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.5757 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.71 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.5757 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.71 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 333 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SONW} + \text{SNW}) = (88 + 144) = 232 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 0 + 94 + 0) = 182 \text{ kN} \\ \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 94 + 0) = 182 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned} \text{Path 1-1} &= 231 \text{ kN} , \text{ must exceed } W = 14 \text{ kN} \quad \text{or } W1 = 76 \text{ kN} \\ \text{Path 2-2} &= 182 \text{ kN} , \text{ must exceed } W = 14 \text{ kN} \quad \text{or } W2 = 102 \text{ kN} \\ \text{Path 3-3} &= 182 \text{ kN} , \text{ must exceed } W = 14 \text{ kN} \quad \text{or } W3 = 102 \text{ kN} \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 41.4600 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 254.7896 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 334 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input, Nozzle Desc: K6 (2in)

From: 40

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		5000.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		90.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	6.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 335 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: K6 (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 31.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0945 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3430 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	125.6000 mm.
Parallel to Vessel Wall, opening length	d	62.8000 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9) \\
 &= 0.989
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 136.4 / 137.9)
 \end{aligned}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 336 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= 0.989$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.989, 1.0)$$

$$= 0.989$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	1.132	1.700	NA
Area in Shell	A1	3.256	1.005	NA
Area in Nozzle Wall	A2	3.638	3.552	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.989	0.989	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	7.883	5.546	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * tn * tr * F(1-fr1)) \text{ per UG-37(d)}$$

$$= 0.5(62.8 * 5.3937 * 1 + 2 * 10.6 * 5.3937 * 1(1-0.99))$$

$$= 1.700 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 62.8(1.0 * 7.0 - 1.0 * 5.394) - 2 * 10.6$$

$$(1.0 * 7.0 - 1.0 * 5.3937) * (1 - 0.989)$$

$$= 1.005 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 17.5) (10.6 - 0.34) 0.9894$$

$$= 3.552 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10.0^2 * 0.9894 + (0.0)^2 * 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 6.3430 mm.
Wall Thickness per UG16(b),	tr16b = 7.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tbl = max(trb1, tr16b) = 7.5000 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 337 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Wall Thickness $tb2 = \max(trb2, tr16b) = 7.5000 \text{ mm.}$
Wall Thickness per table UG-45 $tb3 = 10.8000 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:
 $= \min[tb3, \max(tb1, tb2)]$
 $= \min[10.8, \max(7.5, 7.5)]$
 $= 7.5000 \text{ mm.}$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 $= \max(ta, tb)$
 $= \max(6.343, 7.5)$
 $= 7.5000 \text{ mm.}$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, $t_g = 10.0$, $t_r = 1.796$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $t_r * (E^*) / (t_g - c) = 0.257$, Temp. Reduction = $78 \text{ }^\circ\text{C}$

Min Metal Temp. w/o impact per UCS-66, Curve A $-8 \text{ }^\circ\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1) $-104 \text{ }^\circ\text{C}$
Min Metal Temp. w/o impact per UG-20(f) $-29 \text{ }^\circ\text{C}$

Gov. MDMT of the nozzle to shell joint welded assembly : $-104 \text{ }^\circ\text{C}$

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) $-18 \text{ }^\circ\text{C}$
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) $-104 \text{ }^\circ\text{C}$

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
Design Pressure/Ambient Rating = $4.10/51.10 = 0.080$

Weld Size Calculations, Description: K6 (2in)

Intermediate Calc. for nozzle/shell Welds $T_{min} = 7.0000 \text{ mm.}$

Results Per UW-16.1:

Required Thickness Actual Thickness
Nozzle Weld $4.9000 = 0.7 * t_{min}$ $7.0700 = 0.7 * W_o \text{ mm.}$

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:
 $= \max(0, (A-A1+2*t_n*f_{r1}*(E1*t-t_r))S_v)$
 $= \max(0, (1.6997 - 1.0051 + 2 * 10.6 * 0.9894 * (1.0 * 7.0 - 5.3937))138)$
 $= 14.22 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 338 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Load [W1]:

$$= (A2+A5+A4-(W_i-Can/.707)^2*fr2)*Sv$$

$$= (3.5518 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 62.62 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (3.5518 + 0.0 + 0.9894 + (1.4682)) * 138$$

$$= 82.86 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (3.5518 + 0.0 + 0.9894 + 0.0 + (1.4682)) * 138$$

$$= 82.86 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 36.7) * (16.6 - 6.0) * 0.7 * 136$$

$$= 117. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SONW + SNW) = (88 + 117) = 205 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (88 + 0 + 94 + 0) = 182 \text{ kN}$$

$$PATH33 = (Sonw + Tngw + Sinw)$$

$$= (88 + 94 + 0) = 182 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 204 kN , must exceed W = 14 kN or W1 = 62 kN

Path 2-2 = 182 kN , must exceed W = 14 kN or W2 = 82 kN

Path 3-3 = 182 kN , must exceed W = 14 kN or W3 = 82 kN

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 339 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادرکننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 1.4718 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 161.4718 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 340 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Input, Nozzle Desc: K1 (2in)

From: 40

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Cylinder/Cone Centerline	L1	400.0000	mm.
Distance from Bottom/Left Tangent		5200.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C


Type of Element Connected to the Shell : Nozzle

Material		SA-105	
Material UNS Number		K03504	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	136.43	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		40.98	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material		SA-105	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Flange Class		300	
Flange Grade		GR 1.1	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 341 از 411	
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری		پروژه
	V00	0009	CN	ME	120	MF	GCS		BK

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Note : Checking Nozzle 90 degrees to the Longitudinal axis.

Reinforcement CALCULATION, Description: K1 (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	2.000 in.
Actual Thickness Used in Calculation	0.654 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3862 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	151.6108 mm.
Parallel to Vessel Wall, opening length	d	75.8054 mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000 mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5	Design	External	Mapnc

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 342 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Area Required	Ar		0.683		2.052		NA
Area in Shell	A1		4.608		1.213		NA
Area in Nozzle Wall	A2		5.959		5.826		NA
Area in Inward Nozzle	A3		0.000		0.000		NA
Area in Welds A41+A42+A43			0.989		0.989		NA
Area in Element	A5		0.000		0.000		NA
TOTAL AREA AVAILABLE	Atot		11.556		8.028		NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 48.53 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F (1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5 (75.8054 \cdot 5.3937 \cdot 1 + 2 \cdot 13.6 \cdot 5.3937 \cdot 1 (1 - 0.99))$$

$$= 2.052 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 \cdot t - F \cdot tr) - 2 \cdot tn (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 75.805 (1.0 \cdot 7.0 - 1.0 \cdot 5.394) - 2 \cdot 13.6$$

$$(1.0 \cdot 7.0 - 1.0 \cdot 5.3937) \cdot (1 - 0.989)$$

$$= 1.213 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot tlnp) (tn - trn) fr2 / \sin(\alpha3)$$

$$= (2 \cdot 17.5) (13.6 - 0.39) 0.9894 / \sin(51.8)$$

$$= 5.826 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 \cdot fr2 + (Wi - can / 0.707)^2 \cdot fr2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:A, Curve:B)

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.257, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	-8 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 343 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
 Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :
 Design Pressure/Ambient Rating = 4.10/51.10 = 0.080

Weld Size Calculations, Description: K1 (2in)

Intermediate Calc. for nozzle/shell Welds Tmin 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (2.0522 - 1.213 + 2 * 13.6 * 0.9894 * \\
 &\quad (1.0 * 7.0 - 5.3937)) 138) \\
 &= 17.53 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (5.8261 + 0.0 + 0.9894 - 0.0 * 0.99) * 138 \\
 &= 93.98 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (5.8261 + 0.0 + 0.9894 + (1.8838)) * 138 \\
 &= 119.95 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (5.8261 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138 \\
 &= 119.95 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 112.1066 * 10.0 * 0.49 * 136 \\
 &= 118. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 46.978) * (16.6 - 3.0) * 0.7 * 136 \\
 &= 192. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								شماره صفحه : 344 از 411
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	
	V00	0009	CN	ME	120	MF	GCS	BK	

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * (W_{gvi-Cas}) * 0.74 * S_{ng} \\
 &= (3.1416/2.0) * 112.1066 * (10.0 - 3.0) * 0.74 * 138 \\
 &= 126. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SONW} + \text{SNW}) = (118 + 192) = 309 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (118 + 0 + 126 + 0) = 243 \text{ kN} \\
 \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\
 &= (118 + 126 + 0) = 243 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned}
 \text{Path 1-1} &= 309 \text{ kN}, \text{ must exceed } W = 17 \text{ kN} \text{ or } W1 = 93 \text{ kN} \\
 \text{Path 2-2} &= 243 \text{ kN}, \text{ must exceed } W = 17 \text{ kN} \text{ or } W2 = 119 \text{ kN} \\
 \text{Path 3-3} &= 243 \text{ kN}, \text{ must exceed } W = 17 \text{ kN} \text{ or } W3 = 119 \text{ kN}
 \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

Note : Checking Nozzle in plane parallel to the vessel axis.

Reinforcement CALCULATION, Description: K1 (2in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 1.7961 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 28.4) / (136 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.0855 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3862 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	113.6000	mm.
Parallel to Vessel Wall, opening length	d	56.8000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	17.5000	mm.

Results of Nozzle Reinforcement Area Calculations: (cm²)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 345 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

AREA AVAILABLE, A1 to A5	Design	External	Mapnc
Area Required Ar	1.025	1.540	NA
Area in Shell A1	2.941	0.908	NA
Area in Nozzle Wall A2	4.680	4.576	NA
Area in Inward Nozzle A3	0.000	0.000	NA
Area in Welds A41+A42+A43	0.989	0.989	NA
Area in Element A5	0.000	0.000	NA
TOTAL AREA AVAILABLE Atot	8.610	6.473	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= 0.5 (d \cdot tr \cdot F + 2 \cdot t_n \cdot tr \cdot F (1 - fr_1)) \text{ per UG-37(d)}$$

$$= 0.5 (56.8 \cdot 5.3937 \cdot 1 + 2 \cdot 13.6 \cdot 5.3937 \cdot 1 (1 - 0.99))$$

$$= 1.540 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E_1 \cdot t - F \cdot tr) - 2 \cdot t_n (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 56.8 (1.0 \cdot 7.0 - 1.0 \cdot 5.394) - 2 \cdot 13.6 (1.0 \cdot 7.0 - 1.0 \cdot 5.3937) \cdot (1 - 0.989)$$

$$= 0.908 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 \cdot t_{lnp}) (t_n - tr_n) fr_2$$

$$= (2 \cdot 17.5) (13.6 - 0.39) 0.9894$$

$$= 4.576 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= W_o^2 \cdot fr_2 + (W_i - can / 0.707)^2 \cdot fr_2$$

$$= 10.0^2 \cdot 0.9894 + (0.0)^2 \cdot 0.9894$$

$$= 0.989 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3862 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb_3, \max(tb_1, tb_2)]$$

$$= \min[7.8, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 346 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$= \max(3.3862, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Weld Size Calculations, Description: K1 (2in)

Intermediate Calc. for nozzle/shell Welds T_{min} 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.9000 = 0.7 * t _{min} .	7.0700 = 0.7 * W _o mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (1.5396 - 0.9077 + 2 * 13.6 * 0.9894 * (1.0 * 7.0 - 5.3937)) 138)$$

$$= 14.67 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (4.5757 + 0.0 + 0.9894 - 0.0 * 0.99) * 138$$

$$= 76.74 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (4.5757 + 0.0 + 0.9894 + (1.8838)) * 138$$

$$= 102.71 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (4.5757 + 0.0 + 0.9894 + 0.0 + (1.8838)) * 138$$

$$= 102.71 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 84.0 * 10.0 * 0.49 * 136$$

$$= 88. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.1416 * 35.2) * (16.6 - 3.0) * 0.7 * 136$$

$$= 144. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi}-Cas) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 84.0 * (10.0 - 3.0) * 0.74 * 138$$

$$= 94. \text{ kN}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 347 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SONW} + \text{SNW}) = (88 + 144) = 232 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 0 + 94 + 0) = 182 \text{ kN} \\ \text{PATH33} &= (\text{Sonw} + \text{Tngw} + \text{Sinw}) \\ &= (88 + 94 + 0) = 182 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

$$\begin{aligned} \text{Path 1-1} &= 231 \text{ kN} , \text{ must exceed } W = 14 \text{ kN} \quad \text{or } W1 = 76 \text{ kN} \\ \text{Path 2-2} &= 182 \text{ kN} , \text{ must exceed } W = 14 \text{ kN} \quad \text{or } W2 = 102 \text{ kN} \\ \text{Path 3-3} &= 182 \text{ kN} , \text{ must exceed } W = 14 \text{ kN} \quad \text{or } W3 = 102 \text{ kN} \end{aligned}$$

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 16 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 41.4600 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 254.7896 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 348 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input, Nozzle Desc: N01 (10in)

From: 50

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-516	70
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1200.00	mm.
Design Length of Section	L	2649.9998	mm.
Shell Finished (Minimum) Thickness	t	10.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		5900.00	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle

Material		SA-106	B
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		90.00	deg
Diameter		10.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	40	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	10.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material		SA-516	70
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	450.0000	mm.
Thickness of Pad	te	10.0000	mm.


 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 349 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

Weld leg size between Pad and Shell Wp 10.0000 mm.
Groove weld depth between Pad and Nozzle Wgpn 10.0000 mm.
Reinforcing Pad Width 88.4750 mm.

Flange Class 150
Flange Grade GR 1.1

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: N01 (10in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 10.111 in.
Actual Thickness Used in Calculation 0.319 in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 603.0) / (138 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 1.7961 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (4.1 \cdot 131.41) / (118 \cdot 1.0 - 0.6 \cdot 4.1)$$

$$= 0.4580 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.6850 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 525.6515 mm.
Parallel to Vessel Wall, opening length d 262.8257 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp 17.5000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 350 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p/S_v)$$

$$= \min(1, 137.9/137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.855, 1.0)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	4.747	7.128	NA
Area in Shell	A1	13.600	4.198	NA
Area in Nozzle Wall	A2	1.393	1.325	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		1.802	1.802	NA
Area in Element	A5	17.695	17.695	NA
TOTAL AREA AVAILABLE	Atot	34.489	25.019	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	273.0500	10.0000 mm.
Based on given Pad Diameter:	450.0000	0.0000 mm.
Based on Shell or Nozzle Thickness:	273.0500	8.1121 mm.

Area Required [A]:

$$= 0.5(d * tr * F + 2 * t_n * tr * F(1 - fr1)) \text{ per UG-37(d)}$$

$$= 0.5(262.8257 * 5.3937 * 1 + 2 * 5.1121 * 5.3937 * 1(1 - 0.86))$$

$$= 7.128 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * t_n(E1 * t - F * tr) * (1 - fr1)$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 351 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

$$= 262.826 (1.0 * 7.0 - 1.0 * 5.394) - 2 * 5.112$$

$$(1.0 * 7.0 - 1.0 * 5.3937) * (1 - 0.855)$$

$$= 4.198 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 17.5) * (5.11 - 0.69) * 0.855$$

$$= 1.325 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= (Wo^2 - Ar \text{ Lost}) * Fr3 + ((Wi - can / 0.707)^2 - Ar \text{ Lost}) * fr2 + Wp^2 * fr4$$

$$= (0.9375) * 0.86 + (0.0) * 0.86 + 254.0^2 * 1.0$$

$$= 1.802 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (Nozzle \text{ OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (450.0 - 273.05) * 10.0 * 1.0$$

$$= 17.695 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.6850 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 4.7961 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 4.7961 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 11.1026 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[11.103, \max(4.7961, 4.5)]$$

$$= 4.7961 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.685, 4.7961)$$

$$= 4.7961 \text{ mm.}$$

Available Nozzle Neck Thickness = 8.1121 mm. --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained	: 53.0,	Allowable	: 117.9 N./mm ²	Passed
Expansion	: 0.0,	Allowable	: 241.8 N./mm ²	Passed
Occasional	: 5.2,	Allowable	: 156.8 N./mm ²	Passed
Shear	: 8.3,	Allowable	: 82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 352 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, Curve: B

Govrn. thk, tg = 8.112, tr = 0.458, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.09$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, tg = 8.112, tr = 0.458, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.09$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, tg = 8.112, tr = 0.458, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.09$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Shell to Pad Weld Junction at Pad OD, Curve: B

Govrn. thk, tg = 10.0, tr = 1.796, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.257$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: B

Govrn. thk, tg = 8.112, tr = 0.458, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.09$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -29 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 19.60 = 0.209$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 353 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Size Calculations, Description: N01 (10in)

Intermediate Calc. for nozzle/shell Welds T_{min} 5.1121 mm.
Intermediate Calc. for pad/shell Welds T_{minPad} 7.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$3.5785 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$3.5000 = 0.5 * T_{minPad}$	$7.0700 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A - A_1 + 2 * t_n * f_{r1} * (E_1 * t - t_r)) S_v)$$

$$= \max(0, (7.128 - 4.1979 + 2 * 5.1121 * 0.855 * (1.0 * 7.0 - 5.3937)) 138)$$

$$= 42.34 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A_2 + A_5 + A_4 - (W_i - C_{an} / .707)^2 * f_{r2}) * S_v$$

$$= (1.3248 + 17.695 + 1.8016 - 0.0 * 0.86) * 138$$

$$= 287.10 \text{ kN}$$

Weld Load [W2]:

$$= (A_2 + A_3 + A_4 + (2 * t_n * t * f_{r1})) * S_v$$

$$= (1.3248 + 0.0 + 0.855 + (0.6119)) * 138$$

$$= 38.49 \text{ kN}$$

Weld Load [W3]:

$$= (A_2 + A_3 + A_4 + A_5 + (2 * t_n * t * f_{r1})) * S$$

$$= (1.3248 + 0.0 + 1.8016 + 17.695 + (0.6119)) * 138$$

$$= 295.54 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.1416/2.0) * 273.05 * 10.0 * 0.49 * 118$$

$$= 248. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.1416/2.0) * 450.0 * 10.0 * 0.49 * 138$$

$$= 478. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - C_{an}) * 0.7 * S_n$$

$$= (3.1416 * 133.9689) * (8.1121 - 3.0) * 0.7 * 118$$

$$= 178. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 354 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= (3.1416/2) * 273.05 * 10.0 * 0.74 * 138$$

$$= 438. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gvi} - C_{as}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 273.05 * (10.0 - 3.0) * 0.74 * 138$$

$$= 306. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (478 + 178) = 655 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (248 + 438 + 306 + 0) = 992 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (478 + 306 + 0) = 784 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 655 kN , must exceed W = 42 kN or W1 = 287 kN

Path 2-2 = 991 kN , must exceed W = 42 kN or W2 = 38 kN

Path 3-3 = 783 kN , must exceed W = 42 kN or W3 = 295 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 12 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1 bars

The Drop for this Nozzle is : 15.7390 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 175.7390 mm.

Input Echo, WRC107/537 Item 1, Description: N01 (10in) :

Diameter Basis for Vessel	Vbasis	ID
Cylindrical or Spherical Vessel	Cylsph	Cylindrical
Internal Corrosion Allowance	Cas	3.0000 mm.
Vessel Diameter	Dv	1200.000 mm.
Vessel Thickness	Tv	10.000 mm.
Design Temperature	T1	234.0 °C
Vessel Material		SA-516 70
Vessel UNS Number		K02700
Vessel Cold S.I. Allowable	Smc	137.90 N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90 N./mm ²

Note:

Using 2 * Yield for Discontinuity Stress Allowable (Div 2, 4.1.6.3), Sps.

Make sure that material properties at this temperature are not time-dependent for Material: SA-516 70

Attachment Type	Type	Round
Diameter Basis for Nozzle	Nbasis	ID

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 355 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	256.826	mm.
Nozzle Thickness	Tn	8.112	mm.
Nozzle Material		SA-106 B	
Nozzle UNS Number		K03006	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	10.000	mm.
Diameter of Reinforcing Pad	Dpad	450.000	mm.
Design Internal Pressure	Dp	4.100	bars
Include Pressure Thrust	No		

External Forces and Moments in WRC 107/537 Convention:


Radial Load	(SUS)	P	14.0	kN
Longitudinal Shear	(SUS)	Vl	14.0	kN
Circumferential Shear	(SUS)	Vc	-10.5	kN
Circumferential Moment	(SUS)	Mc	-7000.0	N-m
Longitudinal Moment	(SUS)	Ml	-10500.0	N-m
Torsional Moment	(SUS)	Mt	-9100.0	N-m

Use Interactive Control No
WRC107 Version Version March 1979

Include Pressure Stress Indices per Div. 2 No
Compute Pressure Stress per WRC-368 No
Local Loads applied at end of Nozzle/Attachment No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".



Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$\begin{aligned}
 &= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(\text{t} - \text{ca})) \\
 &= 273.05 + 2 * 1.65 * \text{sqrt}(606.5 (10.0 - 3.0)) \\
 &= 488.070 \text{ mm.}
 \end{aligned}$$

WRC 107 Stress Calculation for SUSstained loads:

Radial Load	P	14.0	kN
Circumferential Shear	VC	-10.5	kN
Longitudinal Shear	VL	14.0	kN
Circumferential Moment	MC	-7000.0	N-m
Longitudinal Moment	ML	-10500.0	N-m

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 356 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Torsional Moment MT -9100.0 N-m

Dimensionless Parameters used : Gamma = 35.97

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N (PHI) / (P/Rm)	0.195	4C	5.137	(A,B)
N (PHI) / (P/Rm)	0.195	3C	3.416	(C,D)
M (PHI) / (P)	0.195	2C1	0.039	(A,B)
M (PHI) / (P)	0.195	1C !	0.070	(C,D)
N (PHI) / (MC/ (Rm**2 * Beta))	0.195	3A	1.457	(A,B,C,D)
M (PHI) / (MC/ (Rm * Beta))	0.195	1A	0.080	(A,B,C,D)
N (PHI) / (ML/ (Rm**2 * Beta))	0.195	3B	3.709	(A,B,C,D)
M (PHI) / (ML/ (Rm * Beta))	0.195	1B	0.027	(A,B,C,D)
N (x) / (P/Rm)	0.195	3C	3.416	(A,B)
N (x) / (P/Rm)	0.195	4C	5.137	(C,D)
M (x) / (P)	0.195	1C1	0.072	(A,B)
M (x) / (P)	0.195	2C !	0.039	(C,D)
N (x) / (MC/ (Rm**2 * Beta))	0.195	4A	2.685	(A,B,C,D)
M (x) / (MC/ (Rm * Beta))	0.195	2A	0.039	(A,B,C,D)
N (x) / (ML/ (Rm**2 * Beta))	0.195	4B	1.461	(A,B,C,D)
M (x) / (ML/ (Rm * Beta))	0.195	2B	0.042	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Type of Stress Load		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-6.9	-6.9	-6.9	-6.9	-4.6	-4.6	-4.6	-4.6
Circ. Bend. P		-11.3	11.3	-11.3	11.3	-20.2	20.2	-20.2	20.2
Circ. Memb. MC		0.0	0.0	0.0	0.0	8.2	8.2	-8.2	-8.2
Circ. Memb. MC		0.0	0.0	0.0	0.0	97.0	-97.0	-97.0	97.0
Circ. Memb. ML		31.4	31.4	-31.4	-31.4	0.0	0.0	0.0	0.0
Circ. Bend. ML		50.1	-50.1	-50.1	50.1	0.0	0.0	0.0	0.0
Tot. Circ. Str.		63.3	-14.4	-99.7	23.1	80.4	-73.2	-130.1	104.4
Long. Memb. P		-4.6	-4.6	-4.6	-4.6	-6.9	-6.9	-6.9	-6.9
Long. Bend. P		-20.9	20.9	-20.9	20.9	-11.2	11.2	-11.2	11.2
Long. Memb. MC		0.0	0.0	0.0	0.0	15.1	15.1	-15.1	-15.1
Long. Bend. MC		0.0	0.0	0.0	0.0	46.9	-46.9	-46.9	46.9
Long. Memb. ML		12.3	12.3	-12.3	-12.3	0.0	0.0	0.0	0.0
Long. Bend. ML		77.0	-77.0	-77.0	77.0	0.0	0.0	0.0	0.0

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 357 از 411	
	پروژه	بسته کاری	صادرکننده	تسهيلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Tot. Long. Str.	63.9	-48.4	-114.9	81.0	43.9	-27.4	-80.2	36.1
Shear VC	-1.4	-1.4	1.4	1.4	0.0	0.0	0.0	0.0
Shear VL	0.0	0.0	0.0	0.0	-1.9	-1.9	1.9	1.9
Shear MT	-4.6	-4.6	-4.6	-4.6	-4.6	-4.6	-4.6	-4.6
Tot. Shear	-6.0	-6.0	-3.1	-3.1	-6.5	-6.5	-2.6	-2.6
Str. Int.	69.6	49.4	115.5	81.1	81.6	74.1	130.2	104.5

Dimensionless Parameters used : Gamma = 86.64

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.325	4C	6.644	(A,B)
N(PHI) / (P/Rm)	0.325	3C	2.278	(C,D)
M(PHI) / (P)	0.325	2C1	0.007	(A,B)
M(PHI) / (P)	0.325	1C !	0.067	(C,D)
N(PHI) / (MC/ (Rm**2 * Beta))	0.325	3A	1.925	(A,B,C,D)
M(PHI) / (MC/ (Rm * Beta))	0.325	1A	0.055	(A,B,C,D)
N(PHI) / (ML/ (Rm**2 * Beta))	0.325	3B	3.838	(A,B,C,D)
M(PHI) / (ML/ (Rm * Beta))	0.325	1B	0.005	(A,B,C,D)
N(x) / (P/Rm)	0.325	3C	2.278	(A,B)
N(x) / (P/Rm)	0.325	4C	6.644	(C,D)
M(x) / (P)	0.325	1C1	0.020	(A,B)
M(x) / (P)	0.325	2C !	0.036	(C,D)
N(x) / (MC/ (Rm**2 * Beta))	0.325	4A	7.630	(A,B,C,D)
M(x) / (MC/ (Rm * Beta))	0.325	2A	0.021	(A,B,C,D)
N(x) / (ML/ (Rm**2 * Beta))	0.325	4B	2.131	(A,B,C,D)
M(x) / (ML/ (Rm * Beta))	0.325	2B	0.007	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-21.9	-21.9	-21.9	-21.9	-7.5	-7.5	-7.5	-7.5
Circ. Bend. P		-11.7	11.7	-11.7	11.7	-115.4	115.4	-115.4	115.4
Circ. Memb. MC		0.0	0.0	0.0	0.0	16.1	16.1	-16.1	-16.1
Circ. Memb. MC		0.0	0.0	0.0	0.0	238.1	-238.1	-238.1	238.1
Circ. Memb. ML		48.2	48.2	-48.2	-48.2	0.0	0.0	0.0	0.0
Circ. Bend. ML		34.2	-34.2	-34.2	34.2	0.0	0.0	0.0	0.0
Tot. Circ. Str.		48.7	3.8	-116.0	-24.2	131.3	-114.1	-377.1	329.8

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053-073-9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 358 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Long. Memb. P	-7.5	-7.5	-7.5	-7.5	-21.9	-21.9	-21.9	-21.9
Long. Bend. P	-33.5	33.5	-33.5	33.5	-61.7	61.7	-61.7	61.7
Long. Memb. MC	0.0	0.0	0.0	0.0	63.9	63.9	-63.9	-63.9
Long. Bend. MC	0.0	0.0	0.0	0.0	91.6	-91.6	-91.6	91.6
Long. Memb. ML	26.8	26.8	-26.8	-26.8	0.0	0.0	0.0	0.0
Long. Bend. ML	48.3	-48.3	-48.3	48.3	0.0	0.0	0.0	0.0
Tot. Long. Str.	34.1	4.4	-116.0	47.5	71.9	12.1	-239.1	67.5
Shear VC	-2.1	-2.1	2.1	2.1	0.0	0.0	0.0	0.0
Shear VL	0.0	0.0	0.0	0.0	-2.8	-2.8	2.8	2.8
Shear MT	-4.1	-4.1	-4.1	-4.1	-4.1	-4.1	-4.1	-4.1
Tot. Shear	-6.2	-6.2	-2.0	-2.0	-6.9	-6.9	-1.3	-1.3
Str. Int.	51.0	12.4	118.0	71.8	132.1	126.9	377.1	329.8

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		14.3	14.8	14.3	14.8	14.3	14.8	14.3	14.8
Circ. Pl (SUS)		24.4	24.4	-38.3	-38.3	3.6	3.6	-12.8	-12.8
Circ. Q (SUS)		38.8	-38.8	-61.4	61.4	76.8	-76.8	-117.3	117.3
Long. Pm (SUS)		7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2
Long. Pl (SUS)		7.7	7.7	-16.9	-16.9	8.2	8.2	-22.0	-22.0
Long. Q (SUS)		56.2	-56.2	-97.9	97.9	35.7	-35.7	-58.1	58.1
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		-1.4	-1.4	1.4	1.4	-1.9	-1.9	1.9	1.9
Shear Q (SUS)		-4.6	-4.6	-4.6	-4.6	-4.6	-4.6	-4.6	-4.6
Pm (SUS)		14.3	14.8	14.3	14.8	14.3	14.8	14.3	14.8
Pm+Pl (SUS)		38.9	39.3	24.1	23.7	19.0	19.3	16.8	17.2
Pm+Pl+Q (Total)		81.2	43.3	108.1	88.3	95.7	59.5	115.9	119.3

Vessel Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	14.75	137.90	Passed
Pm+Pl (SUS)	39.27	206.85	Passed
Pm+Pl+Q (TOTAL)	119.29	413.70	Passed

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 359 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress Load		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		35.1	35.5	35.1	35.5	35.1	35.5	35.1	35.5
Circ. Pl (SUS)		26.3	26.3	-70.1	-70.1	8.6	8.6	-23.6	-23.6
Circ. Q (SUS)		22.4	-22.4	-45.9	45.9	122.7	-122.7	-353.4	353.4
Long. Pm (SUS)		17.6	17.6	17.6	17.6	17.6	17.6	17.6	17.6
Long. Pl (SUS)		19.2	19.2	-34.3	-34.3	42.0	42.0	-85.8	-85.8
Long. Q (SUS)		14.8	-14.8	-81.8	81.8	29.9	-29.9	-153.3	153.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		-2.1	-2.1	2.1	2.1	-2.8	-2.8	2.8	2.8
Shear Q (SUS)		-4.1	-4.1	-4.1	-4.1	-4.1	-4.1	-4.1	-4.1
Pm (SUS)		35.1	35.5	35.1	35.5	35.1	35.5	35.1	35.5
Pm+Pl (SUS)		61.6	62.0	35.2	34.8	60.0	60.0	79.9	80.3
Pm+Pl+Q (Total)		85.0	41.4	98.7	65.1	167.0	109.1	342.0	365.3

Vessel Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	35.53	137.90	Passed
Pm+Pl (SUS)	80.33	206.85	Passed
Pm+Pl+Q (TOTAL)	365.34	413.70	Passed

Because only sustained loads were specified, the Pm+Pl+Q allowable was 3 * Smh.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 360 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input, Nozzle Desc: N03 (10in)

From: 70

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-105	
Shell Allowable Stress at Temperature	Sv	136.40	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Outside Diameter of Bolted Blind Flange	D	1420.00	mm.
Head Finished (Minimum) Thickness	t	60.0000	mm.
Head Internal Corrosion Allowance	c	3.0000	mm.
Head External Corrosion Allowance	co	0.0000	mm.

Note : User defined Limit(s) of Reinforcement specified below:

Physical Maximum for Diameter Limit	Dmax	450.0000	mm.
Distance from Head Centerline	L1	320.0000	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle


Material		SA-106 B	
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		320.00	deg
Diameter		10.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	20.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	26.0000	mm.
Inside Projection	h	4000.0000	mm.
Weld leg size, Inside Element to Shell	Wi	20.0000	mm.
Pad Material		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 361 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	450.0000	mm.
Thickness of Pad	te	15.0000	mm.
Weld leg size between Pad and Shell	Wp	12.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	15.0000	mm.
Reinforcing Pad Width		88.4750	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, with Inside projection

Reinforcement CALCULATION, Description: N03 (10in)

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	9.710	in.
Actual Thickness Used in Calculation	0.520	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 126.32) / (118 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.4402 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.7666 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	450.0000	mm.
Parallel to Vessel Wall, opening length	d	225.0000	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		40.5041	mm.
Normal to Vessel Wall, Inward		18.0041	mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 362 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/136.4)$$

$$= 0.864$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/136.4)$$

$$= 0.864$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p/S_v)$$

$$= \min(1, 137.9/136.4)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.864, 1.0)$$

$$= 0.864$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	59.858	59.876	NA
Area in Shell	A1	19.709	19.681	NA
Area in Nozzle Wall	A2	6.835	6.607	NA
Area in Inward Nozzle	A3	2.242	2.242	NA
Area in Welds A41+A42+A43		5.604	5.604	NA
Area in Element	A5	26.542	26.542	NA
TOTAL AREA AVAILABLE	Atot	60.932	60.676	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degr.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	444.6669	15.0000 mm.
Based on given Pad Diameter:	450.0000	14.5479 mm.
Based on the Estimated Diameter Limit:	448.4125	14.6796 mm.

Area Required [A]:

$$= 0.5 * d * t + t * t_n(1-fr1) \text{ per UG-39(a) (1)}$$

$$= 0.5 * 252.6467 * 46.8856 + 46.8856 * 10.2016(1-0.86)$$

$$= 59.876 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1*t - F*tr) - 2 * t_n(E1*t - F*tr) * (1 - fr1)$$

$$= 197.353(1.0 * 57.0 - 1.0 * 46.886) - 2 * 10.202$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 363 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$(1.0 * 57.0 - 1.0 * 46.8856) * (1 - 0.864) = 19.681 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$\begin{aligned} &= (2 * Tlwp) * (tn - trn) * fr2 \\ &= (2 * 40.5) * (10.2 - 0.77) * 0.8644 \\ &= 6.607 \text{ cm}^2 \end{aligned}$$

Area Available in Inward Nozzle [A3]:

$$\begin{aligned} &= 2 * ti * \min(h, Tl, 2.5 * ti) * fr2 \\ &= 2 * 7.2016 * (18.0041) * 0.8644 \\ &= 2.242 \text{ cm}^2 \end{aligned}$$

Area Available in Welds [A41 + A42 + A43]:

$$\begin{aligned} &= Wo^2 * fr3 + (Wi - can/0.707)^2 * fr2 + Wp^2 * fr4 \\ &= 20.0^2 * 0.86 + (15.7573)^2 * 0.86 + 0.0^2 * 1.0 \\ &= 5.604 \text{ cm}^2 \end{aligned}$$

Area Available in Element [A5]:

$$\begin{aligned} &= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4 \\ &= (450.0 - 273.05) * 15.0 * 1.0 \\ &= 26.542 \text{ cm}^2 \end{aligned}$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.7666 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 49.8715 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 49.8715 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.4524 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 11.1026 mm.

Determine Nozzle Thickness candidate [tb]:

$$\begin{aligned} &= \min[tb3, \max(tb1, tb2)] \\ &= \min[11.103, \max(49.8715, 4.5)] \\ &= 11.1026 \text{ mm.} \end{aligned}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$\begin{aligned} &= \max(ta, tb) \\ &= \max(3.7666, 11.1026) \\ &= 11.1026 \text{ mm.} \end{aligned}$$

Available Nozzle Neck Thickness = 13.2016 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, Curve: B

Govrn. thk, tg = 13.202, tr = 0.44, c = 3.0 mm., E* = 1.0
Thickness Ratio = tr * (E*)/(tg - c) = 0.043, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-20 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 364 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, tg = 13.202, tr = 0.44, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.043$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -20 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
Min Metal Temp. w/o impact per UG-20(f) -29 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, tg = 13.202, tr = 0.44, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.043$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B -20 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
Min Metal Temp. w/o impact per UG-20(f) -29 °C

Shell to Pad Weld Junction at Pad OD, min(Curve:B, Curve:A)

Govrn. thk, tg = 15.0, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.037$, Temp. Reduction = 78 °C
Pad governing, Conservatively assuming Pad stress = Shell stress(Div. 1 L-9.3).

Min Metal Temp. w/o impact per UCS-66, Curve A 4 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:B, Curve:A)

Govrn. thk, tg = 13.202, tr = 0.44, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.043$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A 0 °C
Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
Gov. MDMT of the Nozzle : -104 °C
Gov. MDMT of the Reinforcement Pad : -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -18 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b) -104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = 4.10/19.60 = 0.209

Weld Size Calculations, Description: N03 (10in)

Intermediate Calc. for nozzle/shell Welds Tmin 10.2016 mm.
Intermediate Calc. for pad/shell Welds TminPad 15.0000 mm.
Intermediate Calc. for Inward Weld TminIns 10.2016 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 365 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	6.0000 = Min per Code	14.1400 = 0.7 * Wo mm.
Pad Weld	7.5000 = 0.5*TminPad	8.4840 = 0.7 * Wp mm.
Inward Weld	6.0000 = Min per Code	11.1400 = 0.7 * Wi-Can mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (59.876 - 19.6813 + 2 * 10.2016 * 0.8644 * (1.0 * 57.0 - 46.8856))136) \\
 &= 572.54 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (6.6068 + 26.5425 + 5.6039 - 9.7753 * 0.86) * 136 \\
 &= 499.28 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (6.6068 + 2.2416 + 5.6039 + (10.0529)) * 136 \\
 &= 334.22 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (6.6068 + 2.2416 + 5.6039 + 26.5425 + (10.0529)) * 136 \\
 &= 696.23 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 273.05 * 20.0 * 0.49 * 118 \\
 &= 496. \text{ kN}
 \end{aligned}$$

Shear, Inward Nozzle Weld [Sinw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.1416/2.0) * 273.05 * 15.7573 * 0.49 * 118 \\
 &= 390. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.1416/2.0) * 450.0 * 12.0 * 0.49 * 136 \\
 &= 567. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.1416 * 131.4242) * (13.2016 - 3.0) * 0.7 * 118 \\
 &= 348. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 366 از 411
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.1416/2) * 273.05 * 15.0 * 0.74 * 138$$

$$= 656. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi-Cas}) * 0.74 * S_{ng}$$

$$= (3.1416/2.0) * 273.05 * (26.0 - 3.0) * 0.74 * 136$$

$$= 996. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (567 + 348) = 914 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (496 + 656 + 996 + 390) = 2538 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (567 + 996 + 390) = 1953 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 914 kN , must exceed W = 572 kN or W1 = 499 kN
 Path 2-2 = 2538 kN , must exceed W = 572 kN or W2 = 334 kN
 Path 3-3 = 1952 kN , must exceed W = 572 kN or W3 = 696 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 5 bars

Nozzle is O.K. for the External Pressure 1 bars

The Cut Length for this Nozzle is, Drop + Ho + H + T : 4260.0000 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 367 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Input, Nozzle Desc: Chimney Nozzle

From: 70

Pressure for Reinforcement Calculations	P	4.100	bars
Temperature for Internal Pressure	Temp	234	°C
Design External Pressure	Pext	1.03	bars
Temperature for External Pressure	Tempex	100	°C
Shell Material		SA-105	
Shell Allowable Stress at Temperature	Sv	136.40	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Outside Diameter of Bolted Blind Flange	D	1420.00	mm.
Head Finished (Minimum) Thickness	t	60.0000	mm.
Head Internal Corrosion Allowance	c	3.0000	mm.
Head External Corrosion Allowance	co	0.0000	mm.

Note : User defined Limit(s) of Reinforcement specified below:

Physical Maximum for Diameter Limit	Dmax	450.0000	mm.
Distance from Head Centerline	L1	320.0000	mm.
User Entered Minimum Design Metal Temperature		5.00	°C

Type of Element Connected to the Shell : Nozzle


Material		SA-106 B	
Material UNS Number		K03006	
Material Specification/Type		Smls. pipe	
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		220.00	deg
Diameter		10.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-105	
Flange Type		None	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	20.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	26.0000	mm.
Inside Projection	h	4000.0000	mm.
Weld leg size, Inside Element to Shell	Wi	20.0000	mm.
Pad Material		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 368 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	450.0000	mm.
Thickness of Pad	te	15.0000	mm.
Weld leg size between Pad and Shell	Wp	12.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	15.0000	mm.
Reinforcing Pad Width		88.4750	mm.
Flange Class		150	
Flange Grade		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, with Inside projection

Reinforcement CALCULATION, Description: Chimney Nozzle

ASME Code, Section VIII, Div. 1, 2019, UG-37 to UG-45

Actual Inside Diameter Used in Calculation	9.710	in.
Actual Thickness Used in Calculation	0.520	in.

Note:

Post Weld Heat Treatment is required for this nozzle and it was specified as being heat treated.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_n \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (4.1 \cdot 126.32) / (118 \cdot 1.0 - 0.6 \cdot 4.1) \\
 &= 0.4402 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.7666 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	450.0000	mm.
Parallel to Vessel Wall, opening length	d	225.0000	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		40.5041	mm.
Normal to Vessel Wall, Inward		18.0041	mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 369 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/136.4)$$

$$= 0.864$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n/S_v)$$

$$= \min(1, 117.9/136.4)$$

$$= 0.864$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p/S_v)$$

$$= \min(1, 137.9/136.4)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.864, 1.0)$$

$$= 0.864$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	59.858	59.876	NA
Area in Shell	A1	19.709	19.681	NA
Area in Nozzle Wall	A2	6.835	6.607	NA
Area in Inward Nozzle	A3	2.242	2.242	NA
Area in Welds A41+A42+A43		5.604	5.604	NA
Area in Element	A5	26.542	26.542	NA
TOTAL AREA AVAILABLE	Atot	60.932	60.676	NA

The External Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degr.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	444.6669	15.0000 mm.
Based on given Pad Diameter:	450.0000	14.5479 mm.
Based on the Estimated Diameter Limit:	448.4125	14.6796 mm.

Area Required [A]:

$$= 0.5 * d * t + t * t_n(1-fr1) \text{ per UG-39(a) (1)}$$

$$= 0.5 * 252.6467 * 46.8856 + 46.8856 * 10.2016(1-0.86)$$

$$= 59.876 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1*t - F*tr) - 2 * t_n(E1*t - F*tr) * (1 - fr1)$$

$$= 197.353(1.0 * 57.0 - 1.0 * 46.886) - 2 * 10.202$$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 370 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$$(1.0 * 57.0 - 1.0 * 46.8856) * (1 - 0.864) = 19.681 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * T_{lwp}) * (t_n - t_{rn}) * f_{r2}$$

$$= (2 * 40.5) * (10.2 - 0.77) * 0.8644$$

$$= 6.607 \text{ cm}^2$$

Area Available in Inward Nozzle [A3]:

$$= 2 * t_i * \min(h, T_l, 2.5 * t_i) * f_{r2}$$

$$= 2 * 7.2016 * (18.0041) * 0.8644$$

$$= 2.242 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= W_o^2 * f_{r3} + (W_i - c_{an}/0.707)^2 * f_{r2} + W_p^2 * f_{r4}$$

$$= 20.0^2 * 0.86 + (15.7573)^2 * 0.86 + 0.0^2 * 1.0$$

$$= 5.604 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(D_p, D_L) - (\text{Nozzle OD})) * (\min(t_p, T_{lwp}, t_e)) * f_{r4}$$

$$= (450.0 - 273.05) * 15.0 * 1.0$$

$$= 26.542 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	$t_a = 3.7666 \text{ mm.}$
Wall Thickness per UG16(b),	$t_{r16b} = 4.5000 \text{ mm.}$
Wall Thickness, shell/head, internal pressure	$t_{rb1} = 49.8715 \text{ mm.}$
Wall Thickness	$t_{b1} = \max(t_{rb1}, t_{r16b}) = 49.8715 \text{ mm.}$
Wall Thickness, shell/head, external pressure	$t_{rb2} = 3.4524 \text{ mm.}$
Wall Thickness	$t_{b2} = \max(t_{rb2}, t_{r16b}) = 4.5000 \text{ mm.}$
Wall Thickness per table UG-45	$t_{b3} = 11.1026 \text{ mm.}$

Determine Nozzle Thickness candidate [tb]:

$$= \min[t_{b3}, \max(t_{b1}, t_{b2})]$$

$$= \min[11.103, \max(49.8715, 4.5)]$$

$$= 11.1026 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(t_a, t_b)$$

$$= \max(3.7666, 11.1026)$$

$$= 11.1026 \text{ mm.}$$

Available Nozzle Neck Thickness = 13.2016 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Pad Weld for the Nozzle, Curve: B

Govrn. thk, $t_g = 13.202$, $t_r = 0.44$, $c = 3.0 \text{ mm.}$, $E^* = 1.0$
Thickness Ratio = $t_r * (E^*) / (t_g - c) = 0.043$, Temp. Reduction = $78 \text{ }^\circ\text{C}$

Min Metal Temp. w/o impact per UCS-66, Curve B	$-20 \text{ }^\circ\text{C}$
Min Metal Temp. at Required thickness (UCS 66.1)	$-104 \text{ }^\circ\text{C}$
Min Metal Temp. w/o impact per UG-20(f)	$-29 \text{ }^\circ\text{C}$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 371 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: B

Govrn. thk, tg = 13.202, tr = 0.44, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.043$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve B	-20 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Min Metal Temp. w/o impact per UG-20(f)	-29 °C

Shell to Pad Weld Junction at Pad OD, min(Curve:B, Curve:A)

Govrn. thk, tg = 15.0, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.037$, Temp. Reduction = 78 °C
Pad governing, Conservatively assuming Pad stress = Shell stress(Div. 1 L-9.3).

Min Metal Temp. w/o impact per UCS-66, Curve A	4 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), min(Curve:B, Curve:A)

Govrn. thk, tg = 13.202, tr = 0.44, c = 3.0 mm., E* = 1.0
Thickness Ratio = $tr * (E^*) / (tg - c) = 0.043$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve A	0 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Gov. MDMT of the Nozzle	: -104 °C
Gov. MDMT of the Reinforcement Pad	: -104 °C
Gov. MDMT of the nozzle to shell joint welded assembly	: -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c)	-18 °C
Flange MDMT with Temp reduction per UCS-66(b) (1) (-b)	-104 °C

Where the Stress Reduction Ratio per UCS-66(b)(1)(-b) is :

Design Pressure/Ambient Rating = $4.10 / 19.60 = 0.209$

Weld Size Calculations, Description: Chimney Nozzle

Intermediate Calc. for nozzle/shell Welds	Tmin	10.2016	mm.
Intermediate Calc. for pad/shell Welds	TminPad	15.0000	mm.
Intermediate Calc. for Inward Weld	TminIns	10.2016	mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$6.0000 = \text{Min per Code}$	$14.1400 = 0.7 * W_o$ mm.
Pad Weld	$7.5000 = 0.5 * T_{minPad}$	$8.4840 = 0.7 * W_p$ mm.
Inward Weld	$6.0000 = \text{Min per Code}$	$11.1400 = 0.7 * W_i$ -Can mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 372 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (59.876 - 19.6813 + 2 * 10.2016 * 0.8644 * (1.0 * 57.0 - 46.8856)) 136)$
 $= 572.54 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$
 $= (6.6068 + 26.5425 + 5.6039 - 9.7753 * 0.86) * 136$
 $= 499.28 \text{ kN}$

Weld Load [W2]:

$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$
 $= (6.6068 + 2.2416 + 5.6039 + (10.0529)) * 136$
 $= 334.22 \text{ kN}$

Weld Load [W3]:

$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$
 $= (6.6068 + 2.2416 + 5.6039 + 26.5425 + (10.0529)) * 136$
 $= 696.23 \text{ kN}$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$= (\pi/2) * Dlo * Wo * 0.49 * Snw$
 $= (3.1416/2.0) * 273.05 * 20.0 * 0.49 * 118$
 $= 496. \text{ kN}$

Shear, Inward Nozzle Weld [Sinw]:

$= (\pi/2) * Dlo * Wo * 0.49 * Snw$
 $= (3.1416/2.0) * 273.05 * 15.7573 * 0.49 * 118$
 $= 390. \text{ kN}$

Shear, Pad Element Weld [Spew]:

$= (\pi/2) * DP * WP * 0.49 * SEW$
 $= (3.1416/2.0) * 450.0 * 12.0 * 0.49 * 136$
 $= 567. \text{ kN}$

Shear, Nozzle Wall [Snw]:

$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$
 $= (3.1416 * 131.4242) * (13.2016 - 3.0) * 0.7 * 118$
 $= 348. \text{ kN}$

Tension, Pad Groove Weld [Tpgw]:

$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$
 $= (3.1416/2) * 273.05 * 15.0 * 0.74 * 138$
 $= 656. \text{ kN}$

Tension, Shell Groove Weld [Tngw]:

$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$
 $= (3.1416/2.0) * 273.05 * (26.0 - 3.0) * 0.74 * 136$
 $= 996. \text{ kN}$

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 373 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (567 + 348) = 914 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (496 + 656 + 996 + 390) = 2538 \text{ kN} \\ \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\ &= (567 + 996 + 390) = 1953 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 914 kN , must exceed W = 572 kN or W1 = 499 kN
 Path 2-2 = 2538 kN , must exceed W = 572 kN or W2 = 334 kN
 Path 3-3 = 1952 kN , must exceed W = 572 kN or W3 = 696 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 5 bars

Nozzle is O.K. for the External Pressure 1 bars

The Cut Length for this Nozzle is, Drop + Ho + H + T : 4260.0000 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2020

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 374 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

FEA N03 10INCH

Results were generated with the finite element program FE/Pipe®. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Tue Dec 24 18:16:42 2024.

- [Model Notes](#)
- [Load Case Report](#)
- [Solution Data](#)
- [ASME Code Stress Output Plots](#)
- [Stress Results - Notes](#)
- [ASME Overstressed Areas](#)
- [Highest Primary Stress Ratios](#)
- [Highest Secondary Stress Ratios](#)
- [Highest Fatigue Stress Ratios](#)
- [Highest Stress Ratios Per Region](#)
- [Stress Intensification Factors](#)
- [Allowable Loads](#)
- [Compressive Stress Summary](#)
- [Flexibilities](#)
- [Graphical Results](#)

Model Notes
Model Notes

Input Echo:

Model Type : Flat Head

Parent Geometry

Parent Outside Diam. : 1420.000 mm.
Thickness : 57.000 mm.
Attached Shell Length : 426.000 mm.
Attached Shell Thick : 0.000 mm.

Parent Properties:

Cold Allowable : 137.9 MPa
Hot Allowable : 136.5 MPa
Material DB # 1015022.
Ultimate Tensile (Amb) : 482.6 MPa
Yield Strength (Amb) : 248.2 MPa
Yield Strength (Hot) : 206.8 MPa
Elastic Modulus (Amb) : 201341.0 MPa
Poissons Ratio : 0.300
Expansion Coefficient : 0.1297E-04 mm./mm./deg.
Weight Density : 0.0000E+00 N /cu.mm. (NOT USED)

Nozzle Geometry

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 375 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Nozzle Outside Diam. : 273.000 mm.
 Thickness : 10.200 mm.
 Length : 300.000 mm.
 RePad Width : 88.400 mm.
 RePad Thickness : 15.000 mm.
 Location perpendicular to the head centerline : 300.000 mm.
 Nozzle Tilt Angle : 0.000 deg.

Nozzle Properties
 Cold Allowable : 117.9 MPa
 Hot Allowable : 117.9 MPa
 Material DB # 1009922.
 Ultimate Tensile (Amb) : 413.7 MPa
 Yield Strength (Amb) : 241.3 MPa
 Yield Strength (Hot) : 201.3 MPa
 Elastic Modulus (Amb) : 202720.0 MPa
 Poissons Ratio : 0.300
 Expansion Coefficient : 0.1297E-04 mm./mm./deg.
 Weight Density : 0.0000E+00 N /cu.mm. (NOT USED)

Design Operating Cycles : 7000.
 Ambient Temperature (Deg.) : 21.10

Uniform thermal expansion produces no stress in this geometry.
 Any thermal loads will come through operating forces and moments applied through the nozzle.

Nozzle Inside Temperature : 234.00 deg.
 Nozzle Outside Temperature : 234.00 deg.
 Vessel Inside Temperature : 234.00 deg.
 Vessel Outside Temperature : 234.00 deg.

Nozzle Pressure : 0.410 MPa
 Vessel Pressure : 0.410 MPa

User Defined Load Input Echo for the ATTACHMENT:
 Loads are given at the End of Nozzle
 Loads are defined in Global Coordinates

Forces(N) Moments (N-m)

Load Case	FX	FY	FZ	MX	MY	MZ
WEIGHT:	14000.0	14000.0	10500.0	0.0	0.0	0.0

FEA Model Loads:
 These are the actual Attachment loads applied to the FEA model.
 These are the User Defined Loads translated to the end of the nozzle and reported in global coordinates.

Forces(N) Moments (N-m)

Load Case	FX	FY	FZ	MX	MY	MZ
WEIGHT:	14000.0	14000.0	10500.0	0.0	0.0	0.0

Stresses ARE nodally AVERAGED.

No weld dimensions have been given for the nozzle connection to the shell. This will produce conservative results for external loads and may tend to produce more realistic inside surface pressure stresses.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 376 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

No pad weld dimensions have been given for the pad connection to the shell. Few correlations have been performed to investigate the sensitivity of peak stresses to this value. Reasonable lengths have been assumed.

Vessel Centerline Vector: 0.000 1.000 0.000
Nozzle Centerline Vector: 0.000 1.000 0.000
Zero Degree Orientation Vector: 1.000 0.000 0.000

Nozzle Orientation Angle :320.000

[Table of Contents](#)

Load Case Report
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
6:16pm DEC 24,2024

\$P

Load Case Report

\$X

Inner and outer element temperatures are the same throughout the model. No thermal ratcheting calculations will be performed.

THE 9 LOAD CASES ANALYZED ARE:

1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range between the installed and the operating states.

/----- Loads in Case 1
Loads due to Weight

2 SUSTAINED (Wgt+Pr)

Sustained case run to satisfy local primary membrane and bending stress limits.

/----- Loads in Case 2
Loads due to Weight
Pressure Case 1

3 OPERATING

Case run to compute the operating stresses used in secondary, peak and range calculations as needed.

/----- Loads in Case 3
Pressure Case 1
Loads from (Operating)

4 RANGE (Fatigue Calc Performed)

Case run to get the RANGE of stresses. as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case 4
Plus Stress Results from CASE 3
Minus Stress Results from CASE 1

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 377 از 411
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											

```

5 Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case 5
Loads from (Axial)

6 Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case 6
Loads from (Inplane)

7 Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case 7
Loads from (Outplane)

8 Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case 8
Loads from (Torsion)

9 Program Generated -- Force Only

Case run to compute sif's and flexibilities.
/----- Loads in Case 9
Pressure Case 1

```

Table of Contents

Solution Data
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 6:16pm DEC 24, 2024

Solution Data

Maximum Solution Row Size = 948
 Number of Nodes = 2560
 Number of Elements = 855
 Number of Solution Cases = 8

Summation of Loads per Case

Case #	FX	FY	FZ
1	14000.	14000.	10500.
2	14000.	612222.	10500.
3	0.	598222.	0.
4	0.	1161253.	0.
5	0.	0.	0.
6	0.	0.	0.
7	0.	0.	0.
8	0.	598222.	0.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)							
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 378 از 411
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	
	BK	GCS	MF	120	ME	CN	0009	
							V00	

[Table of Contents](#)

ASME Code Stress Output Plots
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: NOZZLE
 6:16pm DEC 24,2024

\$P

ASME Code Stress Output Plots

\$X

- 1) Pl < SPL (SUS,Membrane) Case 2
- 2) Qb < SPS (SUS,Bending) Case 2
- 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
- 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
- 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
- 6) Pl+Pb+Q < SPS (OPE,Inside) Case 3
- 7) Pl+Pb+Q < SPS (OPE,Outside) Case 3
- 8) Membrane < User (OPE,Membrane) Case 3
- 9) Bending < User (OPE,Bending) Case 3
- 10) Pl+Pb+Q+F < 2Sa (SIF,Outside) Case 5
- 11) Pl+Pb+Q+F < 2Sa (SIF,Outside) Case 6
- 12) Pl+Pb+Q+F < 2Sa (SIF,Outside) Case 7
- 13) Pl+Pb+Q+F < 2Sa (SIF,Outside) Case 8
- 14) Pl+Pb+Q+F < 2Sa (SIF,Outside) Case 9
- 15) Pl+Pb+Q < SPS (EXP,Inside) Case 4
- 16) Pl+Pb+Q < SPS (EXP,Outside) Case 4
- 17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
- 18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

[Table of Contents](#)

Stress Results - Notes
 FEPipe Version 15.0
 Released Jan. 2021

Jobname: NOZZLE
 6:16pm DEC 24,2024

\$P

Stress Results - Notes

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 379 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

- Results in this analysis were generated using the finite element solution method.
- Using 2019 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Ratio between Operating and Design Pressure = 1.000000
Range cases use operating pressure. Primary cases use design pressure.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary loads.
- Primary bending stresses at discontinuities are treated like secondary stresses. (Pb=0)
- Use Equivalent Stress (Von Mises).
- TRIAXIAL Stress Guidelines:
S1+S2+S3 evaluation omitted from operating stress.
Include S1+S2+S3 evaluation in primary case evaluation.
Bending stress NOT included for all S1+S2+S3 calculations.
- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

ASME Overstressed Areas
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
6:16pm DEC 24,2024

\$P

ASME Overstressed Areas

\$X

*** NO OVERSTRESSED NODES IN THIS MODEL ***

[Table of Contents](#)

Highest Primary Stress Ratios
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
6:16pm DEC 24,2024

\$P

Highest Primary Stress Ratios

\$X

Pad Next to Nozzle 1

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
49	455	Min Prin. Stress = -11. (89% Neg, 0% NegHi)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 380 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

MPa MPa Plot Reference:
4) P1+Pb+Q < SPS (SUS,Outside) Case 2
10%

Nozzle 1 Next to Shell

P1 SPL Primary Membrane Load Case 2
51 201 Min Prin. Stress = -34. (79% Neg, 63% NegHi)
MPa MPa Plot Reference:
1) P1 < SPL (SUS,Membrane) Case 2
25%

Shell Next to Nozzle 1 Pad

P1+Pb+Q SPS Primary+Secondary (Outer) Load Case 2
43 455 Min Prin. Stress = -14. (99% Neg, 81% NegHi)
MPa MPa Plot Reference:
4) P1+Pb+Q < SPS (SUS,Outside) Case 2
9%

Nozzle 1

P1 SPL Primary Membrane Load Case 2
18 201 Min Prin. Stress = -10. (67% Neg, 61% NegHi)
MPa MPa Plot Reference:
1) P1 < SPL (SUS,Membrane) Case 2
8%

[Table of Contents](#)

Highest Secondary Stress Ratios
FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 6:16pm DEC 24,2024

Highest Secondary Stress Ratios \$X

In combination case 4 the max range stress divided by the max component stress is 1.91. The case tensor components are in some directions additive and so the combination case will have HIGHER stresses than the largest of any of the individual cases by more than 50%.

Load Case	Combined/Max (Inside)	Combined/Max (Outside)
4	1.619	1.914

Pad Next to Nozzle 1

P1+Pb+Q SPS Primary+Secondary (Outer) Load Case 2
49 455 Min Prin. Stress = -11. (89% Neg, 0% NegHi)
MPa MPa Plot Reference:
4) P1+Pb+Q < SPS (SUS,Outside) Case 2
10%

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 381 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

Nozzle 1 Next to Shell

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
113	443	Min Prin. Stress = -34. (79% Neg, 63% NegHi)
MPa	MPa	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
25%		

Shell Next to Nozzle 1 Pad

Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 2
43	455	Min Prin. Stress = -14. (99% Neg, 81% NegHi)
MPa	MPa	Plot Reference:
		4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
9%		

Nozzle 1

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 2
22	443	Min Prin. Stress = -10. (67% Neg, 61% NegHi)
MPa	MPa	Plot Reference:
		3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
4%		

[Table of Contents](#)

Highest Fatigue Stress Ratios

FEPipe Version 15.0 Jobname: NOZZLE \$P
Released Jan. 2021 6:16pm DEC 24,2024

Highest Fatigue Stress Ratios

\$X

Pad Next to Nozzle 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
37	0.000 Life	Stress Concentration Factor = 1.350
MPa	0.064 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 1.0000E11
Allowable		"B31" Fatigue Stress Allowable = 686.0
574.2		Markl Fatigue Stress Allowable = 575.0
MPa		WRC 474 Mean Cycles to Failure = 98,740,944.
		WRC 474 99% Probability Cycles = 22,938,418.
6%		WRC 474 95% Probability Cycles = 31,847,108.
		BS5500 Allowed Cycles(Curve F) = 18,274,966.
		Membrane-to-Bending Ratio = 0.189
		Bending-to-PL+PB+Q Ratio = 0.841
		Plot Reference:
		18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

Nozzle 1 Next to Shell

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
73	0.000 Life	Stress Concentration Factor = 1.350
MPa	0.126 Stress	Strain Concentration Factor = 1.000

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 382 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادرکننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

Allowable 579.9 MPa
 12%
 Cycles Allowed for this Stress = 1.0000E11
 "B31" Fatigue Stress Allowable = 589.5
 Markl Fatigue Stress Allowable = 575.0
 WRC 474 Mean Cycles to Failure = 43,591,768.
 WRC 474 99% Probability Cycles = 10,126,763.
 WRC 474 95% Probability Cycles = 14,059,737.
 BS5500 Allowed Cycles(Curve F) = 4,364,570.
 Membrane-to-Bending Ratio = 0.721
 Bending-to-PL+PB+Q Ratio = 0.581
 Plot Reference:
 17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4

Shell Next to Nozzle 1 Pad

Pl+Pb+Q+F 40 MPa
 Damage Ratio 0.070
 Life Stress
 Allowable 574.2 MPa
 7%
 Primary+Secondary+Peak (Outer) Load Case 4
 Stress Concentration Factor = 1.350
 Strain Concentration Factor = 1.000
 Cycles Allowed for this Stress = 1.0000E11
 "B31" Fatigue Stress Allowable = 686.0
 Markl Fatigue Stress Allowable = 575.0
 WRC 474 Mean Cycles to Failure = 92,355,320.
 WRC 474 99% Probability Cycles = 21,454,980.
 WRC 474 95% Probability Cycles = 29,787,538.
 BS5500 Allowed Cycles(Curve F) = 16,084,873.
 Membrane-to-Bending Ratio = 0.125
 Bending-to-PL+PB+Q Ratio = 0.889
 Plot Reference:
 18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

Nozzle 1

Pl+Pb+Q+F 20 MPa
 Damage Ratio 0.034
 Life Stress
 Allowable 579.9 MPa
 3%
 Primary+Secondary+Peak (Outer) Load Case 4
 Stress Concentration Factor = 1.000
 Strain Concentration Factor = 1.000
 Cycles Allowed for this Stress = 1.0000E11
 "B31" Fatigue Stress Allowable = 589.5
 Markl Fatigue Stress Allowable = 575.0
 WRC 474 Mean Cycles to Failure = 9.4231E8
 WRC 474 99% Probability Cycles = 2.1891E8
 WRC 474 95% Probability Cycles = 3.0392E8
 BS5500 Allowed Cycles(Curve F) = 4.0373E8
 Membrane-to-Bending Ratio = 4.676
 Bending-to-PL+PB+Q Ratio = 0.176
 Plot Reference:
 18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4

[Table of Contents](#)

Highest Stress Ratios Per Region

FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 6:16pm DEC 24,2024

Highest Stress Ratios Per Region

\$X

Pad Next to Nozzle 1

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 383 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

P1 16 MPa	SPL 207 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -11. (89% Neg, 0% NegHi) Plot Reference: 1) P1 < SPL (SUS,Membrane) Case 2
7%		
Qb 46 MPa	SPS 455 MPa	Primary Bending Load Case 2 Min Prin. Stress = -11. (89% Neg, 0% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
10%		
P1+Pb+Q 43 MPa	SPS 455 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -11. (89% Neg, 0% NegHi) Plot Reference: 3) P1+Pb+Q < SPS (SUS,Inside) Case 2
9%		
P1+Pb+Q 49 MPa	SPS 455 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -11. (89% Neg, 0% NegHi) Plot Reference: 4) P1+Pb+Q < SPS (SUS,Outside) Case 2
10%		
S1+S2+S3 9 MPa	4S 546 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -11. (89% Neg, 0% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
1%		
P1+Pb+Q 32 MPa	SPS 455 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -9. (93% Neg, 0% NegHi) Plot Reference: 6) P1+Pb+Q < SPS (OPE,Inside) Case 3
6%		
P1+Pb+Q 38 MPa	SPS 455 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -9. (93% Neg, 0% NegHi) Plot Reference: 7) P1+Pb+Q < SPS (OPE,Outside) Case 3
8%		
Membrane 11 MPa	User 455 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -9. (93% Neg, 0% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
2%		
Bending 35 MPa	User 455 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -9. (93% Neg, 0% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
7%		
P1+Pb+Q 21 MPa	SPS 455 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -6. (78% Neg, 0% NegHi) Plot Reference: 15) P1+Pb+Q < SPS (EXP,Inside) Case 4
4%		
P1+Pb+Q 27 MPa	SPS 455 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -6. (78% Neg, 0% NegHi) Plot Reference: 16) P1+Pb+Q < SPS (EXP,Outside) Case 4
6%		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادرکننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 384 از 411
پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											

Pl+Pb+Q+F 28 MPa	Damage Ratio 0.000 Life 0.049 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 686.0 Markl Fatigue Stress Allowable = 575.0 WRC 474 Mean Cycles to Failure = 3.0274E8 WRC 474 99% Probability Cycles = 70,329,584. WRC 474 95% Probability Cycles = 97,643,768. BS5500 Allowed Cycles(Curve F) = 75,109,856. Membrane-to-Bending Ratio = 0.189 Bending-to-PL+PB+Q Ratio = 0.841 Plot Reference: 17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
------------------------	--	--

Pl+Pb+Q+F 37 MPa	Damage Ratio 0.000 Life 0.064 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 686.0 Markl Fatigue Stress Allowable = 575.0 WRC 474 Mean Cycles to Failure = 98,740,944. WRC 474 99% Probability Cycles = 22,938,418. WRC 474 95% Probability Cycles = 31,847,108. BS5500 Allowed Cycles(Curve F) = 18,274,966. Membrane-to-Bending Ratio = 0.189 Bending-to-PL+PB+Q Ratio = 0.841 Plot Reference: 18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
------------------------	--	--

Nozzle 1 Next to Shell

Pl 51 MPa	SPL 201 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -34. (79% Neg, 63% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
25%		
Qb 94 MPa	SPS 443 MPa	Primary Bending Load Case 2 Min Prin. Stress = -34. (79% Neg, 63% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
21%		
Pl+Pb+Q 113 MPa	SPS 443 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -34. (79% Neg, 63% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
25%		
Pl+Pb+Q 102 MPa	SPS 443 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -34. (79% Neg, 63% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
22%		
S1+S2+S3 56 MPa	4S 472 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -34. (79% Neg, 63% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
11%		
Pl+Pb+Q 83 MPa	SPS 443 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -30. (82% Neg, 65% NegHi) Plot Reference:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 385 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3	
18%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3	
65	443	Min Prin. Stress = -30. (82% Neg, 65% NegHi)	
MPa	MPa	Plot Reference:	
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3	
14%			
Membrane	User	Component Evaluation Load Case 3	
39	443	Min Prin. Stress = -30. (82% Neg, 65% NegHi)	
MPa	MPa	Plot Reference:	
		8) Membrane < User (OPE,Membrane) Case 3	
8%			
Bending	User	Component Evaluation Load Case 3	
62	443	Min Prin. Stress = -30. (82% Neg, 65% NegHi)	
MPa	MPa	Plot Reference:	
		9) Bending < User (OPE,Bending) Case 3	
14%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
54	443	Min Prin. Stress = -25. (83% Neg, 65% NegHi)	
MPa	MPa	Plot Reference:	
		15) Pl+Pb+Q < SPS (EXP,Inside) Case 4	
12%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4	
49	443	Min Prin. Stress = -25. (83% Neg, 65% NegHi)	
MPa	MPa	Plot Reference:	
		16) Pl+Pb+Q < SPS (EXP,Outside) Case 4	
11%			
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4	
73	0.000 Life	Stress Concentration Factor = 1.350	
MPa	0.126 Stress	Strain Concentration Factor = 1.000	
		Cycles Allowed for this Stress = 1.0000E11	
Allowable		"B31" Fatigue Stress Allowable = 589.5	
579.9		Mark1 Fatigue Stress Allowable = 575.0	
MPa		WRC 474 Mean Cycles to Failure = 43,591,768.	
		WRC 474 99% Probability Cycles = 10,126,763.	
12%		WRC 474 95% Probability Cycles = 14,059,737.	
		BS5500 Allowed Cycles(Curve F) = 4,364,570.	
		Membrane-to-Bending Ratio = 0.721	
		Bending-to-PL+PB+Q Ratio = 0.581	
		Plot Reference:	
		17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4	
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4	
67	0.000 Life	Stress Concentration Factor = 1.350	
MPa	0.115 Stress	Strain Concentration Factor = 1.000	
		Cycles Allowed for this Stress = 1.0000E11	
Allowable		"B31" Fatigue Stress Allowable = 589.5	
579.9		Mark1 Fatigue Stress Allowable = 575.0	
MPa		WRC 474 Mean Cycles to Failure = 63,116,128.	
		WRC 474 99% Probability Cycles = 14,662,449.	
11%		WRC 474 95% Probability Cycles = 20,356,966.	
		BS5500 Allowed Cycles(Curve F) = 5,776,221.	
		Membrane-to-Bending Ratio = 0.578	
		Bending-to-PL+PB+Q Ratio = 0.634	
		Plot Reference:	
		18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4	

Shell Next to Nozzle 1 Pad

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 386 از 411	
	پروژه	بسته کاری	صادر کننده	تسهيلات	رشته	نوع مدرک	سريال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

P1 10 MPa	SPL 207 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -14. (99% Neg, 81% NegHi) Plot Reference: 1) P1 < SPL (SUS,Membrane) Case 2
4%		
Qb 40 MPa	SPS 455 MPa	Primary Bending Load Case 2 Min Prin. Stress = -14. (99% Neg, 81% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
8%		
P1+Pb+Q 37 MPa	SPS 455 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -14. (99% Neg, 81% NegHi) Plot Reference: 3) P1+Pb+Q < SPS (SUS,Inside) Case 2
8%		
P1+Pb+Q 43 MPa	SPS 455 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -14. (99% Neg, 81% NegHi) Plot Reference: 4) P1+Pb+Q < SPS (SUS,Outside) Case 2
9%		
S1+S2+S3 6 MPa	4S 546 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -14. (99% Neg, 81% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
1%		
P1+Pb+Q 31 MPa	SPS 455 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -11. (99% Neg, 78% NegHi) Plot Reference: 6) P1+Pb+Q < SPS (OPE,Inside) Case 3
6%		
P1+Pb+Q 36 MPa	SPS 455 MPa	Primary+Secondary (Outer) Load Case 3 Min Prin. Stress = -11. (99% Neg, 78% NegHi) Plot Reference: 7) P1+Pb+Q < SPS (OPE,Outside) Case 3
7%		
Membrane 8 MPa	User 455 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -11. (99% Neg, 78% NegHi) Plot Reference: 8) Membrane < User (OPE,Membrane) Case 3
1%		
Bending 34 MPa	User 455 MPa	Component Evaluation Load Case 3 Min Prin. Stress = -11. (99% Neg, 78% NegHi) Plot Reference: 9) Bending < User (OPE,Bending) Case 3
7%		
P1+Pb+Q 26 MPa	SPS 455 MPa	Primary+Secondary (Inner) Load Case 4 Min Prin. Stress = -8. (99% Neg, 74% NegHi) Plot Reference: 15) P1+Pb+Q < SPS (EXP,Inside) Case 4
5%		
P1+Pb+Q 30 MPa	SPS 455 MPa	Primary+Secondary (Outer) Load Case 4 Min Prin. Stress = -8. (99% Neg, 74% NegHi) Plot Reference: 16) P1+Pb+Q < SPS (EXP,Outside) Case 4
6%		

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان:	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 387 از 411
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											
053 – 073 – 9184																		

Pl+Pb+Q+F 35 MPa	Damage Ratio 0.000 Life 0.060 Stress	Primary+Secondary+Peak (Inner) Load Case 4 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 686.0 Mark1 Fatigue Stress Allowable = 575.0 WRC 474 Mean Cycles to Failure = 1.6676E8 WRC 474 99% Probability Cycles = 38,740,632. WRC 474 95% Probability Cycles = 53,786,488. BS5500 Allowed Cycles(Curve F) = 34,175,576. Membrane-to-Bending Ratio = 0.125 Bending-to-PL+PB+Q Ratio = 0.889 Plot Reference: 17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4
Pl+Pb+Q+F 40 MPa	Damage Ratio 0.000 Life 0.070 Stress	Primary+Secondary+Peak (Outer) Load Case 4 Stress Concentration Factor = 1.350 Strain Concentration Factor = 1.000 Cycles Allowed for this Stress = 1.0000E11 "B31" Fatigue Stress Allowable = 686.0 Mark1 Fatigue Stress Allowable = 575.0 WRC 474 Mean Cycles to Failure = 92,355,320. WRC 474 99% Probability Cycles = 21,454,980. WRC 474 95% Probability Cycles = 29,787,538. BS5500 Allowed Cycles(Curve F) = 16,084,873. Membrane-to-Bending Ratio = 0.125 Bending-to-PL+PB+Q Ratio = 0.889 Plot Reference: 18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4
Nozzle 1		
Pl 18 MPa	SPL 201 MPa	Primary Membrane Load Case 2 Min Prin. Stress = -10. (67% Neg, 61% NegHi) Plot Reference: 1) Pl < SPL (SUS,Membrane) Case 2
8%		
Qb 14 MPa	SPS 443 MPa	Primary Bending Load Case 2 Min Prin. Stress = -10. (67% Neg, 61% NegHi) Plot Reference: 2) Qb < SPS (SUS,Bending) Case 2
3%		
Pl+Pb+Q 22 MPa	SPS 443 MPa	Primary+Secondary (Inner) Load Case 2 Min Prin. Stress = -10. (67% Neg, 61% NegHi) Plot Reference: 3) Pl+Pb+Q < SPS (SUS,Inside) Case 2
4%		
Pl+Pb+Q 17 MPa	SPS 443 MPa	Primary+Secondary (Outer) Load Case 2 Min Prin. Stress = -10. (67% Neg, 61% NegHi) Plot Reference: 4) Pl+Pb+Q < SPS (SUS,Outside) Case 2
3%		
S1+S2+S3 28 MPa	4S 472 MPa	Part 5 (5.3.2) Load Case 2 Min Prin. Stress = -10. (67% Neg, 61% NegHi) Plot Reference: 5) S1+S2+S3 < 4S (SUS,S1+S2+S3) Case 2
6%		
Pl+Pb+Q 17 MPa	SPS 443 MPa	Primary+Secondary (Inner) Load Case 3 Min Prin. Stress = -5. (60% Neg, 57% NegHi) Plot Reference:

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 388 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

		6) Pl+Pb+Q < SPS (OPE,Inside) Case 3	
3%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 3	
17	443	Min Prin. Stress = -5. (60% Neg, 57% NegHi)	
MPa	MPa	Plot Reference:	
		7) Pl+Pb+Q < SPS (OPE,Outside) Case 3	
3%			
Membrane	User	Component Evaluation Load Case 3	
16	443	Min Prin. Stress = -5. (60% Neg, 57% NegHi)	
MPa	MPa	Plot Reference:	
		8) Membrane < User (OPE,Membrane) Case 3	
3%			
Bending	User	Component Evaluation Load Case 3	
10	443	Min Prin. Stress = -5. (60% Neg, 57% NegHi)	
MPa	MPa	Plot Reference:	
		9) Bending < User (OPE,Bending) Case 3	
2%			
Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4	
17	443	Min Prin. Stress = -12. (80% Neg, 76% NegHi)	
MPa	MPa	Plot Reference:	
		15) Pl+Pb+Q < SPS (EXP,Inside) Case 4	
3%			
Pl+Pb+Q	SPS	Primary+Secondary (Outer) Load Case 4	
20	443	Min Prin. Stress = -12. (80% Neg, 76% NegHi)	
MPa	MPa	Plot Reference:	
		16) Pl+Pb+Q < SPS (EXP,Outside) Case 4	
4%			
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4	
17	0.000 Life	Stress Concentration Factor = 1.000	
MPa	0.029 Stress	Strain Concentration Factor = 1.000	
		Cycles Allowed for this Stress = 1.0000E11	
Allowable		"B31" Fatigue Stress Allowable = 589.5	
579.9		Mark1 Fatigue Stress Allowable = 575.0	
MPa		WRC 474 Mean Cycles to Failure = 1.5884E9	
		WRC 474 99% Probability Cycles = 3.6901E8	
		WRC 474 95% Probability Cycles = 5.1232E8	
		BS5500 Allowed Cycles(Curve F) = 9.2658E8	
		Membrane-to-Bending Ratio = 4.676	
		Bending-to-PL+PB+Q Ratio = 0.176	
		Plot Reference:	
		17) Pl+Pb+Q+F < 2Sa (EXP,Inside) Case 4	
Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4	
20	0.000 Life	Stress Concentration Factor = 1.000	
MPa	0.034 Stress	Strain Concentration Factor = 1.000	
		Cycles Allowed for this Stress = 1.0000E11	
Allowable		"B31" Fatigue Stress Allowable = 589.5	
579.9		Mark1 Fatigue Stress Allowable = 575.0	
MPa		WRC 474 Mean Cycles to Failure = 9.4231E8	
		WRC 474 99% Probability Cycles = 2.1891E8	
		WRC 474 95% Probability Cycles = 3.0392E8	
		BS5500 Allowed Cycles(Curve F) = 4.0373E8	
		Membrane-to-Bending Ratio = 4.676	
		Bending-to-PL+PB+Q Ratio = 0.176	
		Plot Reference:	
		18) Pl+Pb+Q+F < 2Sa (EXP,Outside) Case 4	

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 389 از 411	
	پروژه	بسته کاری	صادرکننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

Stress Intensification Factors
 FEPipe Version 15.0 Jobname: NOZZLE \$P
 Released Jan. 2021 6:16pm DEC 24, 2024

Stress Intensification Factors \$X

Branch/Nozzle Sif Summary

	Peak	Primary	Secondary	SSI
Axial :	3.593	2.661	5.322	1.342
Inplane :	1.891	1.401	2.802	1.236
Outplane:	1.852	1.372	2.743	1.152
Torsion :	0.595	0.837	0.882	0.771
Pressure:	10.970	8.126	16.252	1.735

The above stress intensification factors are to be used in a beam-type analysis of the piping system. Inplane, Outplane and Torsional sif's should be used with the matching branch pipe whose diameter and thickness is given below. The axial sif should be used to intensify the axial stress in the branch pipe calculated by F/A. The pressure sif should be used to intensify the nominal pressure stress in the PARENT or HEADER, calculated from $PD_o/2T$. B31 calculations use mean diameters and Section VIII calculations use outside diameters. SSIs are based on peak stress factors and correlated test results.

Pipe OD : 273.000 mm.
 Pipe Thk: 10.200 mm.
 Z approx: 553274.125 cu.mm.
 Z exact : 533404.750 cu.mm.

(SSI = SIF^x)	Axial	Inpl	Outpl	Tors	Pres
SIF/SSI Exponents:	0.765	0.529	0.513	0.343	0.875

SIF/SSI exponent based on relationship between primary and peak stress factors from the finite element analysis.

B31.3 Branch Pressure i-factor = 21.214
 Header Pressure i-factor = 22.858

The B31.3 pressure i-factors should be used with with F/A, where F is the axial force due to pressure, and A is the area of the pipe wall. This is equivalent to finding the pressure stress from (ip) $(PD/4T)$.

B31.3 (Branch)
 Peak Stress Sif 0.000 Axial
 1.000 Inplane
 1.000 Outplane
 1.000 Torsional

B31.1 (Branch)
 Peak Stress Sif 0.000 Axial
 1.000 Inplane
 1.000 Outplane
 1.000 Torsional

WRC 330 (Branch)
 Peak Stress Sif 0.000 Axial
 3.830 Inplane

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 – 073 – 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادرکننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 390 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

1.000 Outplane
3.830 Torsional

[Table of Contents](#)

Allowable Loads
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
6:16pm DEC 24, 2024

\$P

Allowable Loads

\$X

SECONDARY		Maximum	Conservative	Realistic
Load Type (Range):		Individual	Simultaneous	Simultaneous
		Occuring	Occuring	Occuring
Axial Force	(N)	679738.	192080.	288120.
Inplane Moment	(mm. N)	81778656.	16340499.	34663432.
Outplane Moment	(mm. N)	83528856.	16690214.	35405288.
Torsional Moment	(mm. N)	259920672.	73448200.	110172304.
Pressure	(MPa)	2.12	0.41	0.41

PRIMARY		Maximum	Conservative	Realistic
Load Type:		Individual	Simultaneous	Simultaneous
		Occuring	Occuring	Occuring
Axial Force	(N)	637020.	168564.	252847.
Inplane Moment	(mm. N)	76639336.	14340007.	30419748.
Outplane Moment	(mm. N)	78279536.	14646906.	31070778.
Torsional Moment	(mm. N)	128279912.	33944644.	50916968.
Pressure	(MPa)	1.99	0.41	0.41

NOTES:

- 1) Maximum Individual Occuring Loads are the maximum allowed values of the respective loads if all other load components are zero, i.e. the listed axial force may be applied if the inplane, outplane and torsional moments, and the pressure are zero.
- 2) The Conservative Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A conservative stress combination equation is used that typically produces stresses within 50-70% of the allowable stress.
- 3) The Realistic Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A more realistic stress combination equation is used based on experience at Paulin Research. Stresses are typically produced within 80-105% of the allowable.
- 4) Secondary allowable loads are limits for expansion and operating piping loads.
- 5) Primary allowable loads are limits for weight, primary and sustained type piping loads.
- 6) High D/T low pressure systems may be subject to instability and should be checked when compressive

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																									
شماره پیمان: 053 - 073 - 9184	<table><tr><th colspan="8">THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)</th></tr><tr><th>نسخه</th><th>سریال</th><th>نوع مدرک</th><th>رشته</th><th>تسهیلات</th><th>صادر کننده</th><th>بسته کاری</th><th>پروژه</th></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)								نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 391 از 411
THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)																										
نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه																			
V00	0009	CN	ME	120	MF	GCS	BK																			

stresses are present.

[Table of Contents](#)

Compressive Stress Summary
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
6:16pm DEC 24,2024

\$P

Compressive Stress Summary (MPa)

\$X

Nomenclature:

Min Stress - Compressive Membrane and Bending Stress
Pts in Region - No. of nodes in the model region
>5% Compression - 5% or more of Compressive Stress Limit
>50% Compression - 50% or more of Compressive Stress Limit

Compressive Stress Limit = $-0.55 \text{ Min}(S_y, kE_t/R)$, Section
slenderness ratio (elastic buckling) not considered.

#	Load Type	Case	Min Stress	Pts in Region	>5% Compression and Bending	>50% Compression and Bending	Region
1	SUSTAINED	2	-34.	352	79%	63%	Nozzle 1 Next to Shell
2	OPERATING	3	-30.	352	82%	65%	Nozzle 1 Next to Shell
3	EXPANSION	4	-25.	352	83%	65%	Nozzle 1 Next to Shell
4	SUSTAINED	2	-10.	928	67%	61%	Nozzle 1
5	OPERATING	3	-5.	928	60%	57%	Nozzle 1
6	EXPANSION	4	-12.	928	80%	76%	Nozzle 1
7	SUSTAINED	2	-11.	1024	89%	0%	Pad Next to Nozzle 1
8	OPERATING	3	-9.	1024	93%	0%	Pad Next to Nozzle 1
9	EXPANSION	4	-6.	1024	78%	0%	Pad Next to Nozzle 1
10	SUSTAINED	2	-14.	96	99%	81%	Shell Next to Nozzle 1 Pad
11	OPERATING	3	-11.	96	99%	78%	Shell Next to Nozzle 1 Pad
12	EXPANSION	4	-8.	96	99%	74%	Shell Next to Nozzle 1 Pad

[Table of Contents](#)

Flexibilities
FEPipe Version 15.0
Released Jan. 2021

Jobname: NOZZLE
6:16pm DEC 24,2024

\$P

Flexibilities

\$X

The following stiffnesses should be used in a piping,
"beam-type" analysis of the intersection. The stiff-
nesses should be inserted at the surface of the
branch/header or nozzle/vessel junction. The general
characteristics used for the branch pipe should be:

Outside Diameter = 273.000 mm.

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 392 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

Wall Thickness = 10.200 mm.

Axial Translational Stiffness = 607636. N /mm.
Inplane Rotational Stiffness = 616889344. mm. N /deg
Outplane Rotational Stiffness = 711035840. mm. N /deg

The following stiffness(es) were not generated because of errors in input or because the finite element model is stiffer than the piping model.

Torsional Rotational Stiffness

Estimated Radial Shell Displacement due to Allowable Loads

SECONDARY:

Axial (mm.) = 1.119 In-Plane (mm.) = 0.304 Out-Plane (mm.) = 0.269

PRIMARY

Axial (mm.) = 1.048 In-Plane (mm.) = 0.285 Out-Plane (mm.) = 0.252

Secondary Conservative Displacement = 0.431 mm.

Secondary Realistic Displacement = 0.717 mm.

Primary Conservative Displacement = 0.378 mm.

Primary Realistic Displacement = 0.629 mm.

Intersection Flexibility Factors for Branch/Nozzle

:

Find axial stiffness: $K = 3EI/(kd)^3$ N /mm.

Find bending and torsional stiffnesses: $K = EI/(kd)$ mm. N per radian.

The EI product is 0.14635E+14 N mm.²

The value of (d) to use is: 262.800 mm..

The resulting bending stiffness is in units of force x length per radian.

Axial Flexibility Factor (k) = 1.585

Inplane Flexibility Factor (k) = 1.576

Outplane Flexibility Factor (k) = 1.367

[Table of Contents](#)

Finite Element Model

- [Finite Element Model](#)

Area of Discontinuity at Nozzle

- [1\) Pl < SPL \(SUS Membrane\) Case 2](#)
- [2\) Qb < SPS \(SUS Bending\) Case 2](#)
- [3\) Pl+Pb+Q < SPS \(SUS Inside\) Case 2](#)
- [4\) Pl+Pb+Q < SPS \(SUS Outside\) Case 2](#)
- [5\) S1+S2+S3 < 4S \(SUS S1+S2+S3\) Case 2](#)
- [6\) Pl+Pb+Q < SPS \(OPE Inside\) Case 3](#)
- [7\) Pl+Pb+Q < SPS \(OPE Outside\) Case 3](#)
- [8\) Membrane < User \(OPE Membrane\) Case 3](#)
- [9\) Bending < User \(OPE Bending\) Case 3](#)
- [15\) Pl+Pb+Q < SPS \(EXP Inside\) Case 4](#)



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:

053 - 073 - 9184


THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

شماره صفحه : 393 از 411

- [16\) Pl+Pb+Q < SPS \(EXP Outside\) Case 4](#)
- [17\) Pl+Pb+Q+F < 2Sa \(EXP Inside\) Case 4](#)
- [18\) Pl+Pb+Q+F < 2Sa \(EXP Outside\) Case 4](#)
- [10\) Pl+Pb+Q+F < 2Sa \(SIF Outside\) Case 5](#)
- [11\) Pl+Pb+Q+F < 2Sa \(SIF Outside\) Case 6](#)
- [12\) Pl+Pb+Q+F < 2Sa \(SIF Outside\) Case 7](#)
- [13\) Pl+Pb+Q+F < 2Sa \(SIF Outside\) Case 8](#)
- [14\) Pl+Pb+Q+F < 2Sa \(SIF Outside\) Case 9](#)

Finite Element Model



3d



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 394 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

1) P1 < SPL (SUS Membrane) Case 2



3d

3d(Deformed)



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 395 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

2) Qb < SPS (SUS Bending) Case 2



3d

3d(Deformed)



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 396 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

3) P1+Pb+Q < SPS (SUS Inside) Case 2






3d

3d(Deformed)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 397 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادرکننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

4) P1+Pb+Q < SPS (SUS Outside) Case 2



3d

3d(Deformed)

-
-



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 398 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

5) $S1+S2+S3 < 4S$ (SUS $S1+S2+S3$) Case 2



3d

3d(Deformed)



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 399 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

6) P1+Pb+Q < SPS (OPE Inside) Case 3



3d

3d(Deformed)



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 400 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

7) P1+Pb+Q < SPS (OPE Outside) Case 3






3d

3d(Deformed)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 401 از 411																
	<table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادر کننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>		نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK
	نسخه		سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه									
V00	0009	CN	ME	120	MF	GCS	BK											

8) Membrane < User (OPE Membrane) Case 3






3d 3d(Deformed)

-
-

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00	شماره صفحه : 402 از 411
پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه											
BK	GCS	MF	120	ME	CN	0009	V00											

9) Bending < User (OPE Bending) Case 3



3d

3d(Deformed)



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

شماره صفحه : 403 از 411

15) P1+Pb+Q < SPS (EXP Inside) Case 4



3d

-
-



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 404 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

16) P1+Pb+Q < SPS (EXP Outside) Case 4



3d

•
•



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

شماره صفحه : 405 از 411

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

17) $P_l + P_b + Q + F < 2S_a$ (EXP Inside) Case 4



3d

•

•



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:




053 - 073 - 9184

THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)

نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

شماره صفحه : 406 از 411

18) $P_l + P_b + Q + F < 2S_a$ (EXP Outside) Case 4



3d

•
•



نگهداشت و افزایش تولید میدان نفتی بینک
سطح الارض و ابنیه تحت الارض

خرید بسته نیم زدای گاز ایستگاه تقویت فشار گاز بینک
(قرارداد BK-HD-GCS-CO-0010_08)



شماره پیمان:



053 - 073 - 9184

**THERMAL/MECHANICAL CALCULATION BOOK FOR
REBOILER (R-100)**

شماره صفحه : 407 از 411

نسخه	سویال	نوع مدرک	رشته	تسهیلات	صادر کننده	بسته کاری	پروژه
V00	0009	CN	ME	120	MF	GCS	BK

10) $P_l + P_b + Q + F < 2S_a$ (SIF Outside) Case 5





3d

3d(Deformed)

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 408 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

11) P1+Pb+Q+F < 2Sa (SIF Outside) Case 6





3d 3d(Deformed)

-
-

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)								
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)							شماره صفحه : 409 از 411	
	پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال		نسخه
	BK	GCS	MF	120	ME	CN	0009		V00

12) P1+Pb+Q+F < 2Sa (SIF Outside) Case 7





3d

3d(Deformed)

-
-

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان : 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100) <table><tr><td>نسخه</td><td>سریال</td><td>نوع مدرک</td><td>رشته</td><td>تسهیلات</td><td>صادرکننده</td><td>بسته کاری</td><td>پروژه</td></tr><tr><td>V00</td><td>0009</td><td>CN</td><td>ME</td><td>120</td><td>MF</td><td>GCS</td><td>BK</td></tr></table>	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه	V00	0009	CN	ME	120	MF	GCS	BK	شماره صفحه : 410 از 411
	نسخه	سریال	نوع مدرک	رشته	تسهیلات	صادرکننده	بسته کاری	پروژه										
	V00	0009	CN	ME	120	MF	GCS	BK										

13) $P_l + P_b + Q + F < 2S_a$ (SIF Outside) Case 8





3d

3d(Deformed)

-
-

 NISOC	نگهداشت و افزایش تولید میدان نفتی بینک سطح الارض و ابنیه تحت الارض خرید بسته نم زدای گاز ایستگاه تقویت فشار گاز بینک (قرارداد BK-HD-GCS-CO-0010_08)																	
شماره پیمان: 053 – 073 – 9184	THERMAL/MECHANICAL CALCULATION BOOK FOR REBOILER (R-100)	شماره صفحه : 411 از 411																
	<table><tr><td>پروژه</td><td>بسته کاری</td><td>صادر کننده</td><td>تسهیلات</td><td>رشته</td><td>نوع مدرک</td><td>سریال</td><td>نسخه</td></tr><tr><td>BK</td><td>GCS</td><td>MF</td><td>120</td><td>ME</td><td>CN</td><td>0009</td><td>V00</td></tr></table>		پروژه	بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه	BK	GCS	MF	120	ME	CN	0009	V00
	پروژه		بسته کاری	صادر کننده	تسهیلات	رشته	نوع مدرک	سریال	نسخه									
BK	GCS	MF	120	ME	CN	0009	V00											

14) P1+Pb+Q+F < 2Sa (SIF Outside) Case 9



3d

3d(Deformed)